

AASZ

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8301260249 DOC. DATE: 83/01/20 NOTARIZED: YES DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME AUTHOR AFFILIATION
 EURY, L.W. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Application for amend to License DPR-23, revising oversight
 in previous 821001 request re auxiliary feedwater sys
 operability.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 243
 TITLE: OR Submittal: General Distribution

NOTES: *w/ check : 1200.00*

	RECIPIENT			COPIES				RECIPIENT			COPIES		
	ID	CODE	NAME	L	T	E		ID	CODE	NAME	L	T	E
	NRR	ORB1	BC 01	7		7							
INTERNAL:	ELD/HDS1			1		0		NRR/DL	DIR	1		1	
	NRR/DL			1		0		NRR/DSI	RAB	1		1	
	<u>REG. FILE</u>		04	1		1		RGN2		1		1	
EXTERNAL:	ACRS		09	6		6		LPDR	03	1		1	
	NRC PDR		02	1		1		NSIC	05	1		1	
	NTIS			1		1							



Carolina Power & Light Company

JAN 20 1983

Director of Nuclear Reactor Regulation
Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
United States Nuclear Regulatory Commission
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
REQUEST FOR LICENSE AMENDMENT
AUXILIARY FEEDWATER SYSTEM OPERABILITY

Dear Mr. Varga:

Summary:

In accordance with the Code of Federal Regulations, Title 10, Part 59.90 and Part 2.101, Carolina Power and Light Company (CP&L) hereby requests revisions to the Technical Specifications (TS) for the H. B. Robinson Steam Electric Plant, Unit No. 2 (HBR2). These revisions correct an oversight made in a previous request dated October 1, 1982, regarding Auxiliary Feedwater System (AFW) operability that was issued as Amendment No. 74 to the HBR2 operating license.

Discussion

Technical Specification 3.4.1.b requires three (3) AFW pumps to be operable and TS 3.4.1.d requires the essential features including system piping and valves directly associated with the above components to be operable. The changes requested by CP&L and approved with Amendment No. 74 were intended to provide 72 hours to make operable an inoperable AFW pump and/or its essential features. As TS 3.4.3 was revised, only 24 hours was provided for repair of an AFW pump's essential features, since only TS 3.4.1.b was excepted from the 24 hour repair time allowed. In order to correct this oversight, TS 3.4.1.d should be excepted from TS 3.4.3 and references to essential features should be added to TS 3.4.4 as indicated in the attachment.

These revisions represent a single Class II amendment as defined by 10CFR170.22 for which a fee of \$1,200 is required. Please find a check in that amount enclosed.

*A001
w/check: 1200.00*

8301260249 830120
PDR ADCK 05000261
P PDR

teville Street • P. O. Box 1551 • Raleigh, N. C. 27602

Mr. Steven A. Varga

-2-

The TS pages affected by these changes are attached for your use. The subject changes are denoted by vertical bars in the right margin. If you have any questions regarding this request, please contact a member of our Nuclear Licensing Staff.


Yours very truly,



L. W. Eury
Senior Vice President
Power Supply

DCS/kjr (6040C8T4)
Attachments

L. W. Eury, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.


Notary (Seal)

My commission expires: OCT 04 1986

cc: Mr. J. P. O'Reilly (NRC-RII)
Mr. G. Requa (NRC)
Mr. Steve Weise (NRC-HBR)

