

ENCLOSURE 3

Marked-Up and Retyped Technical Specification Pages

(1405RNP)

9112050164 911127
PDR ADOCK 05000261
PDR

ENCLOSURE 3

Marked-Up and Retyped Technical Specification Pages

- i. Power operation with less than three loops in service is prohibited.

3.3.1.2 During power operation, the requirements of 3.3.1.1 may be modified to allow any one of the following components to be inoperable. If the system is not restored to meet the requirements of 3.3.1.1 within the time period specified, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the requirements of 3.3.1.1 are not satisfied within an additional 48 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.

- a. One accumulator may be isolated for a period not to exceed four hours. *or otherwise inoperable relative to the requirements of 3.3.1.1.b*
- b. If one safety injection pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours, provided the remaining safety injection pump is demonstrated to be operable prior to initiating repairs.
- c. If one residual heat removal pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours, provided the other residual heat removal pump is demonstrated to be operable prior to initiating repairs.

3.3.1.3 When the reactor is in the hot shutdown condition, the requirements of 3.3.1.1 and 3.3.1.2 shall be met. Except that the accumulators may be isolated, ~~and~~ In addition, any one component as defined in 3.3.1.2 may be inoperable for a period equal to the time period specified in the subparagraphs of 3.3.1.2 plus 48 hours, after which the plant shall be placed in the cold shutdown condition utilizing normal operating procedures. The safety injection pump power supply breakers must be racked out when the reactor coolant system temperature is below 350°F and the system is not vented to containment atmosphere.

or otherwise inoperable relative to the requirements of 3.3.1.1.b

3.3.1.4 When the reactor is in the cold shutdown condition (except refueling operation when Specification 3.8.1.e applies), both residual heat removal loops must be operable. Except that either the normal or emergency power source to both residual heat removal loops may be inoperable.

- a. If one residual heat removal loop becomes inoperable during cold shutdown operation, within 24 hours verify the existence of a method to add make-up water to the reactor coolant system such as charging pumps, safety injection pumps (under adequate operator control to prevent system overpressurization), or primary water (if the reactor coolant system is open for maintenance) as back-up decay heat removal method. Restore the inoperable RHR loop to operable status within 14 days or prepare and submit a Special Report to the Commission within the next 30 days outlining the action taken, the cause of the inoperability, and the plans and schedule for restoring the loop to operable status.
- b. If both residual heat removal loops become inoperable during cold shutdown operation, close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere prior to the reactor coolant average temperature exceeding 200°F, restore at least one residual

- i. Power operation with less than three loops in service is prohibited.

3.3.1.2 During power operation, the requirements of 3.3.1.1 may be modified to allow any one of the following components to be inoperable. If the system is not restored to meet the requirements of 3.3.1.1 within the time period specified, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the requirements of 3.3.1.1 are not satisfied within an additional 48 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.

- a. One accumulator may be isolated or otherwise inoperable relative to the requirements of 3.3.1.1.b for a period not to exceed four hours.
- b. If one safety injection pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours, provided the remaining safety injection pump is demonstrated to be operable prior to initiating repairs.
- c. If one residual heat removal pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours, provided the other residual heat removal pump is demonstrated to be operable prior to initiating repairs.

3.3.1.3 When the reactor is in the hot shutdown condition, the requirements of 3.3.1.1 and 3.3.1.2 shall be met. Except that the accumulators may be isolated or otherwise inoperable relative to the requirements of 3.3.1.1.b. In addition, any one component as defined in 3.3.1.2 may be inoperable for a period equal to the time period specified in the subparagraphs of 3.3.1.2 plus 48 hours, after which the plant shall be placed in the cold shutdown condition utilizing normal operating procedures. The safety injection pump power supply breakers must be racked out when the reactor coolant system temperature is below 350°F and the system is not vented to containment atmosphere.

3.3.1.4 When the reactor is in the cold shutdown condition (except refueling operation when Specification 3.8.1.e applies), both residual heat removal loops must be operable. Except that either the normal or emergency power source to both residual heat removal loops may be inoperable.

- a. If one residual heat removal loop becomes inoperable during cold shutdown operation, within 24 hours verify the existence of a method to add make-up water to the reactor coolant system such as charging pumps, safety injection pumps (under adequate operator control to prevent system overpressurization), or primary water (if the reactor coolant system is open for maintenance) as back-up decay heat removal method. Restore the inoperable RHR loop to operable status within 14 days or prepare and submit a Special Report to the Commission within the next 30 days outlining the action taken, the cause of the inoperability, and the plans and schedule for restoring the loop to operable status.
- b. If both residual heat removal loops become inoperable during cold shutdown operation, close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere prior to the reactor coolant average temperature exceeding 200°F, restore at least one residual