
SEP 3 0 1981

Docket No. 50-261

Mr. J. A. Jones Senior Vice President Carolina Power and Light Company 336 Fayetteville Street Raleigh, North Carolina 27602

NRC PDR Local PDR NSIC **TERA** D. Eisenhut ORB 1 File J. Heltemes S. Varga C. Parrish W. Ross **OELD** G. Vissing ACRS (10)

DISTRIBUTION



Dear Mr. Jones:

By letter dated January 7, 1980, signed by Darrell G. Eisenhut, we requested that you review your Quality Assurance Program for Robinson Unit 2 to assure that diesel generators (DG) fuel oil is included. Your letter of May 14, 1980 did not respond directly to our request. As the result of subsequent discussions between the staff and CP&L representatives our current understanding of your position on this matter is as follows:

- Diesel generators fuel oil is not included in the Quality Assurance Program for Robinson Unit 2.
- 2. You do not completely subscribe to the Regulatory Position in Regulatory Guide 1.137 (Revision 1) dated October 1979.

The staff'soposition remains as stated in Mr. Eisenhut's letter, i.e., consumable items shall be classified as safety related and subject to applicable provisions of Appendix B to 10 CFR Part 50 when the quality of the item is necessary for functional performance of safety related components. If you do not intend to include the DG fuel oil within your Quality Assurance Program, we consider that your current Technical Specifications regarding DG fuel oil should be revised to include the following requirements:

- 1. At least once per 92 days a sample of diesel fuel From each Emergency Diesel Generator Fuel Oil Storage Tanks be obtained in accordance with ASTM D270-65 and be within the acceptable limits specified in Table ! of ASTM D975-74 when checked for viscosity, water, and sediment.
- Immediately prior to transfer of the diesel fuel oil to an Emergency Diesel Generator Fuel Oil Storage Tank, a sample of fuel being transferred by obtained in accordance with ASTM D270-65 and be within the acceptable limits specified in Table 1 of ASTM D975-74 when checked for viscosity, water, and sediment.

OFFICE SURNAME			••••••••				
B1101 PDR A	50047 81093 DOCK 050002	0 61 DR	*************	OFFICIAL	RECORD C	ОРҮ	 USGPO: 1981—335-960

You are requested to comply with our position in our January 7, 1980 letter or, in the alternative, propose a Technical Specification change to reflect the requirements stated above. You are requested to reply within 45 days of receipt of this letter.

Sincerely,

Original Signed By:

Steven A. Varga, Chief Operating Reactors Branch No. 1 Division of Licensing

cc: See next page

OFFICE	ORB 1	ORB 4	ORB 1	·	
SURNAME	WRoss/rs/	GX///Sing	Star ga	 	
DATE	9/ 3c /81	9/30/81	92.9/81	***************************************	***************************************
v				L	

Mr. J. A. Jones Carolina Power and Light Company

cc: G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Hartsville Memorial Library Home and Fifth Avenues Hartsville, South Carolina 29550

U. S. Nuclear Regulatory Commission Resident Inspector's Office H. B. Robinson Steam Electric Plant Route 5, Box 266-1A Hartsville, South Carolina 29550

Michael C. Farrar, Chairman Atomic Safety and Licensing Appeal Board Panel U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Richard S. Salzman Atomic Safety and Licensing Appeal Board Panel U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. W. Reed Johnson Atomic Safety and Licensing Appeal Board Panel U. S. Nuclear Regulatory Commission Washington, D. C. 20555