

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8407190296 DOC. DATE: 84/07/05 NOTARIZED: NO DOCKET #  
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261  
 AUTH. NAME: AUTHOR AFFILIATION  
 ZIMMERMAN, S.R. Carolina Power & Light Co.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Submits two revs to "Request for Approval of Transfer of Contaminated Sediment to HB Robinson Ash Pond - Safety Analysis." Refs to radiation & pH monitors should be deleted & ash slurry pump rate changed to gallons per minute.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES: OL: 07/31/70. 05000261

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB1 BC	01	7				
INTERNAL:	ELD/HDS1		1		NRR/DE/MTEB		1
	NRR/DL DIR		1		NRR/DL/ORAB		1
	NRR/DSI/METB		1		NRR/DSI/RAB		1
	REG FILE	04	1		RGN2		1
EXTERNAL:	ACRS	09	6		LPDR	03	1
	NRC PDR	02	1		NSIC	05	1
	NTIS		1				



Carolina Power & Light Company

SERIAL: NLS-84-256

JUL 05 1984

Director of Nuclear Reactor Regulation  
Attention: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing  
United States Nuclear Regulatory Commission  
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23  
REVISIONS TO SUBMITTAL  
DISPOSAL OF LICENSED MATERIAL

Dear Mr. Varga:

The intent of this letter is to provide two revisions to the report entitled, "Request for Approval of Transfer of Contaminated Sediment to the H. B. Robinson Ash Pond-Safety Analysis". This report was transmitted on January 17, 1983 and again on March 9, 1984 in conjunction with Carolina Power & Light Company's (CP&L) request for approval to dispose of slightly contaminated sediment from the Unit 2 settling pond to the Unit 1 ash pond. The revisions are as follows:

1. Section 5.1.1 entitled "Settling Ponds," contains the following statement: "Each pond discharge is equipped with an automatic compositing water sampler, pH and radiation monitors, and an oil skimmer." The radiation and pH monitors have been difficult to maintain and are not required, and CP&L intends to take no credit for their presence at this time. Therefore, in order to better represent the described system, all references to the radiation and pH monitors should be deleted.
2. In Section 5.1.2 entitled "Ash Pond," the proper dimensions of the ash slurry pump rate should be gallons per minute (gpm), not gallons per day (gpd).

CP&L believes that these revisions do not affect the reported results for our Safety Analysis, and that they will not cause your staff any inconveniences in the review of our disposal request. If you have any questions regarding this matter, please contact Mr. David Stadler at (919) 836-6739.

Yours very truly,

S. R. Zimmerman  
Manager

Nuclear Licensing Section

CGL/pgp (220CGL)

cc: Mr. J. P. O'Reilly (NRC-RII)  
Mr. G. Requa (NRC)  
Mr. Steve Weise (NRC-HBR)

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

8407190296 840705  
PDR ADOCK 05000261  
P PDR

Acc/10