

Charles R. Pierce
Regulatory Affairs Director

Southern Nuclear
Operating Company, Inc.
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, AL 35242

Tel 205.992.7872
Fax 205.992.7601



July 11, 2014

Docket Nos.: 50-424

NL-14-1081

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Vogtle Electric Generating Plant Unit 1
1R18 Inservice Inspection Report Summary

Ladies and Gentlemen:

Southern Nuclear Operating Company (SNC) submits herewith the Vogtle Electric Generating Plant Unit 1, Interval 3, Period 2, Outage 3 Inservice Inspection Summary Report (Enclosure). This report describes and summarizes the inservice inspection activities performed during the Spring 2014 maintenance / refueling outage. Paragraph IWA-6240 of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, 2001 Edition with addenda through 2003 requires submittal of the enclosed report.

The supporting inservice inspection documentation, e.g., examination plans and schedules, examination results and reports, examination methods and procedures, evaluation results, and corrective action and repairs, is available for review upon request at Vogtle Electric Generating Plant.

This letter contains no NRC commitments. If you have any questions, please contact Ken McElroy at (205) 992-7369.

Respectfully submitted,

A handwritten signature in black ink that reads "C. R. Pierce".

C. R. Pierce
Regulatory Affairs Director

CRP/RMJ/lac

U. S. Nuclear Regulatory Commission

NL-14-1081

Page 2

cc: Southern Nuclear Operating Company

Mr. S. E. Kuczynski, Chairman, President & CEO

Mr. D. G. Bost, Executive Vice President & Chief Nuclear Officer

Mr. T. E. Tynan, Vice President – Vogtle 1 & 2

Mr. B. L. Ivey, Vice President – Regulatory Affairs

Mr. D. R. Madison, Vice President – Fleet Operations

Mr. B. J. Adams, Vice President – Engineering

Mr. S. C. Waldrup, Regulatory Affairs Manager - Vogtle

RType: CVC7000

U. S. Nuclear Regulatory Commission

Mr. V. M. McCree, Regional Administrator

Mr. R. E. Martin, NRR Senior Project Manager – Vogtle 1 & 2

Mr. L. M. Cain, Senior Resident Inspector – Vogtle 1 & 2

**Vogtle Electric Generating Plant – Unit 1
1R18 Inservice Inspection Report Summary**

Enclosure

**Vogtle Electric Generating Plant – Unit 1
Inservice Inspection Report
Refueling Outage (1R18), Interval 3, Period 2, Outage 3, Tabs A - F**

INSERVICE INSPECTION REPORT

REFUELING 18

**INTERVAL 3
PERIOD 2
OUTAGE 3**

**Vogtle Electric Generating Plant
Unit 1**

(7821 River Road, Waynesboro, Georgia 30830)

**Southern Nuclear Operating Company
40 Inverness Parkway
Birmingham, Alabama 35242**

COMMERCIAL OPERATION DATE: May 31, 1987

DOCUMENT COMPLETION DATE: July 2014

FINAL REPORT TABLE OF CONTENTS

<u>SECTION</u>	<u>TAB</u>
VOLUME 1 (OWNER'S REPORT)	
• INTRODUCTION AND ABBREVIATIONS	A
• ASME FORM NIS-1 AND ABSTRACT	B
• INSERVICE INSPECTION EXAMINATION (OWNER'S REPORT) SUMMARY	
CLASS 1 AND 2 WELDS AND SUPPORT EXAMINATIONS	C
SYSTEM PRESSURE TESTS	D
REPORTABLE INDICATION SUMMARY	E
• OWNER'S REPORT FOR REPAIR AND REPLACEMENTS (ASME FORM NIS-2)	F
VOLUME 2 (ISI EXAMINATION DATA)	
• EXAMINATION PROGRAM PLAN (TOTAL SCOPE SUMMARY)	G
• ISI EXAMINATION DATA	H
VOLUME 3 (CERTIFICATIONS)	
• PERSONNEL CERTIFICATIONS	I
• EXAMINATION PROCEDURES (LISTING)	J
• EQUIPMENT CERTIFICATIONS & CALIBRATION BLOCKS (LISTING)	K
VOLUME 4 (FLOW ACCELERATED CORROSION - FAC)	
• FAC EXAMINATION SUMMARY	L
• FAC EXAMINATION DATA	M

VOLUME 1

CONTAINS THE INFORMATION TO MEET THE REQUIREMENTS OF ASME CODE 2001 EDITION w 2003
ADDENDA, SECTION XI, SUBSECTION IWA-6240 FOR SUBMITTAL OF A SUMMARY REPORT TO THE
NRC FOLLOWING EACH REFUELING OUTAGE.

VOLUMES 2 AND 3

CONTAIN THE SUPPORTING DOCUMENTATION FOR THE EXAMINATIONS PERFORMED (RETAINED
ON SITE BY VEGP)

VOLUME 4

CONTAINS DOCUMENTATION OF THE FLOW ACCELERATED CORROSION (FAC) INSPECTIONS
PERFORMED (RETAINED ON SITE BY VEGP)


**SOUTHERN NUCLEAR
OPERATING COMPANY**

**ENGINEERING PROGRAMS
DEPARTMENT**

INSERVICE INSPECTIONS

PLANT VOGTLE UNIT 1

REFUELING OUTAGE 18



Spring 2014

**Volume 1
Owner's Report**

TAB A

INTRODUCTION AND ABBREVIATIONS

INTRODUCTION

This report documents the examinations and tests performed at Vogtle Electric Generating Plant, Unit 1 (VEGP-1) between October 18, 2012 {end of the seventeenth (17th) maintenance/refueling outage, 1R17} and April 12, 2014 {end of the eighteenth (18th) maintenance/refueling outage, 1R18} to meet the requirements of Article IWA-6000 of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, 2001 Edition with 2003 Addenda (Code).

This report also addresses Code-applicable repairs and/or replacements, which were documented since the last maintenance/refueling outage at VEGP-1 through the completion of the eighteenth maintenance/refueling outage on April 12, 2014 done per the 2001 Edition with 2003 Addenda. The Owner's Reports for Repairs and Replacements (Form NIS-2) are included herein.

LIST OF ABBREVIATIONS

ACC	Acceptable
AD	Anchor/Darling
AFW	Auxiliary Feedwater System
AI	GPC Action Item (followed by unique no. denoting Action Item number)
ANII	Authorized Nuclear Inservice Inspector
ASME	American Society of Mechanical Engineers
ASNT	American Society for Nondestructive Testing
ASTM	American Society for Testing and Materials
BC	Branch Connection
CCSS	Centrifugally Cast Stainless Steel
CCW	Component Cooling Water
CE	Combustion Engineering
CH	Closure Head
CR	Condition Report
CS	Containment Spray
CVCS	Chemical and Volume Control System
DS	Downstream
ET	Eddy Current Examination
EVAL	Evaluation
FAC	Flow-Accelerated Corrosion (may also be referred to as "erosion/corrosion")
FB	Flange Bolting
FNF	FAC Notification Report
FW	Feedwater System
FSAR	VEGP Final Safety Analysis Report (includes updates thereto)
GEO	Geometric Indications
GPC	Georgia Power Company
HHSI	High Head Safety Injection
HL	Hanger Lug
HX	Heat Exchanger
HYD	Hydraulic Snubber
IEN	NRC Information Notice (may also be shown as "IN" followed by unique no. denoting notice number)
IND	Indication
INF	Indication Notification Form
ISI	Inservice Inspection
IST	Inservice Testing
ITS	VEGP Improved Technical Specification
ID	Inside Diameter
IR	Inside Radius
LB	Large Bore
LD	Longitudinal Seam Weld Extending Downstream
LD-I	Longitudinal Seam Weld Downstream Inside Radius of Elbow
LD-O	Longitudinal Seam Weld Downstream Outside Radius of Elbow
LMT	Lambert, MacGill and Thomas
LU	Longitudinal Seam Weld Extending Upstream
LU-I	Longitudinal Seam Weld Upstream Inside Radius of Elbow
LU-O	Longitudinal Seam Weld Upstream Outside Radius of Elbow
MECH	Mechanical Snubber
MS	Main Steam System
MT	Magnetic Particle Examination
NCI	Nonconformance Item
NDE	Nondestructive Examination

LIST OF ABBREVIATIONS - (continued)

NI	No Indication
NRC	United States Nuclear Regulatory Commission
NRC-B	NRC Bulletin (followed by unique no. denoting Bulletin number)
NRI	No Recordable Indication
NSCW	Nuclear Service Cooling Water System
OR	Outside Radius
PL	Pipe Lug
PM	Paul-Munroe ENERTECH
PR	Pipe Restraint
PROF	Profile
PS	Pipe Support
PSA	Pacific Scientific
PSI	Preservice Inspection
PT	Liquid Penetrant Examination
RCS	Reactor Coolant System
RCP	Reactor Coolant Pump
RHR	Residual Heat Removal System
RI	Recordable Indication
RLW	Refracted Longitudinal Wave
RL	Restraint Lug
RPV	Reactor Pressure Vessel
RR	Relief Request (followed by unique no. denoting relief request number)
RWST	Refueling Water Storage Tank
SAT	Satisfactory Examination Results
SB	Small Bore
SCS	Southern Company Services
SI	Safety Injection System
SNC	Southern Nuclear Operating Company
SUP	Supplemental Data
T&C	Thickness and Contour
TDAFW	Turbine Driven Auxiliary Feedwater (Pump)
UNSAT	Unsatisfactory Examination Results
US	Upstream
UT	Ultrasonic Examination
VEGP	Vogtle Electric Generating Plant (common unless followed by "-1" or "-2" to designate a specific plant unit)
VT	Visual Examination
<u>W</u>	Westinghouse

TAB B

ASME FORM NIS-1 AND ABSTRACT

- **Form NIS-1**
- **Abstract**

FORM NIS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS
As required by the Provisions of the ASME Code Rules

1. Owner: Southern Nuclear Operating Company (as agent for Georgia Power Company),
40 Inverness Center Parkway, Birmingham, AL 35242
2. Plant: Vogtle Electric Generating Plant
7821 River Road, Waynesboro, Georgia 30830
3. Plant Unit: One
4. Owner Certification of Authorization: N/A
5. Commercial Service Date: 05/31/87
6. National Board Number for Unit: N/A
7. Components Inspected:

Component or Appurtenance	Manufacturer or Installer and Address	Manufacturer or Installer Serial Number	State or Province Number	National Board Number
Reactor Pressure Vessel	Combustion Eng. Inc., Chattanooga, TN	8971	N/A	21668
Steam Generators 1, 2, 3, & 4	Westinghouse Elec., Tampa, FL	GAGT 1881, GAGT 1882, GAGT 1883, GAGT 1884,	N/A	NA
Reactor Coolant Pumps 2, 3, & 4	Westinghouse Elec., Cheswick, PA	F1089, F1090, F1091	N/A	N/A
Boron Injection Tank	Southwest Fabricating and Welding Co., Houston, TX	0070	N/A	434
Pressurizer Safety Valves A & C	Crosby Valve & Gage Co. Wrentham, MASS	N5694-00-0035 N5694-00-0043	NA	NA
Selected Piping, Components, and Supports	Pullman Power Products, Williamsport, PA	System Numbers 1201, 1204, 1205, 1206, 1208, 1301, 1302, & 1305	N/A	N/A

FORM NIS-1 (Back)

8. Examination Dates: October 18, 2012 to April 12, 2014
9. Inspection Period Identification: Second Inspection Period
10. Inspection Interval Identification: Third Inspection Interval
11. Applicable Edition of Section XI 2001 Addenda 2003
12. Date/Revision of Inspection Plan: Volume 1 (12/12/2012, Version 7.0); Volume 2 (12/16/2013, Version 6.0); Volume 3 (12/8/2011, Version 2.0); Volume 5 (2/18/2014, Version 5.0)
13. Abstract of Examinations and Tests. Include a list of examinations and tests and a statement concerning status of work required for the Inspection Plan. (See Abstract and Examination Summary Listings)
14. Abstract of Results of Examinations and Tests. (See Abstract)
15. Abstract of Corrective Measures. (See Abstract)

We certify that a) the statements made in this report are correct, b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI, and c) corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N/A

Expiration Date N/A

Date: 7-10-14

Signed: Southern Nuclear
Operating Company, Inc.
Owner

By: James C. Robinson

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Georgia and employed by The Hartford Steam Boiler Inspection and Insurance Company of Connecticut of Hartford, CT have inspected the components described in this Owner's Report during the period October 18, 2012 to April 12, 2014, and state that to the best of my knowledge and belief, the Owner has performed examinations and tests and taken corrective measures described in this Owner's Report in accordance with the Inspection Plan and as required of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commission: GA938
National Board, State, Province, and Endorsements

Date: 07-10-14

ABSTRACT – ASME CLASS 1 AND 2

Introduction/Status

The ASME Boiler and Pressure Vessel Code, Section XI, 2001 Edition (Code), with the 2003 Addenda, is the applicable code for conducting inservice inspection activities during the third ten-year inspection interval at VEGP-1. Examinations and tests required by the Code are scheduled in accordance with "Inspection Program B" as defined in Code paragraphs IWB-2412 and IWC-2412. This "Owner's Report for Inservice Inspection" is for those second inspection period examinations and tests which were performed between October 18, 2012 (end of the 1R17 maintenance/refueling outage) and April 12, 2014 (end of the 1R18 maintenance/refueling outage).

VEGP has implemented ASME Section XI, Appendix VIII, "Performance Demonstration for Ultrasonic Examination Systems," as required by 10 CFR 50.55a, amended by the *Federal Register* Notices 64 FR 51370 dated September 22, 1999, as later modified by 69 FR58804, dated October 1, 2004. The initial Rule specified the 1995 Edition with Addenda through 1996 as the applicable edition of ASME Section XI, Appendix VIII. The 2004 Rule incorporated the 2001 Edition with NRC caveats. VEGP has, except where requests for relief, technical alternatives or exemptions have been approved, complied with the requirements for expedited implementation of the applicable Appendix VIII supplements using the EPRI Performance Demonstration Initiative (PDI).

In addition to the summary of inservice inspection activities, this report addresses Code-applicable repairs and replacements documented at VEGP-1 since 1R17 through the end of 1R18. The Owner's Reports for Repairs or Replacements (Form NIS-2) are provided herein.

It should be noted that Authorized Nuclear Inservice Inspector (ANII) inspection services were provided for those examinations and tests required by the Code. ASME Section XI examinations and tests are itemized in the applicable sections by reference to Examination Category. Examinations which do not meet the Code-required coverage either reference request(s) for relief or indicate that additional relief is required.

Class 1 Examinations

Selected Class 1 components were examined utilizing ultrasonic testing (UT), magnetic particle testing (MT), liquid penetrant (PT), and visual testing (VT) methods, as applicable. Specific components and examination areas are itemized in the applicable portions of this document.

- During the scope of examinations conducted, no Class 1 components were observed to have reportable indications.

Two (2) Class 1 piping and/or equipment welds had limited coverage during examinations because of physical limitations due to the geometric configuration of the welded areas. More than ninety percent (90%) of the required volume must be examined as addressed in ASME Section XI Code Case N-460 for adequate ASME Section XI Code-required examination coverage to be attained. As noted herein, the subject code case has been approved by the NRC for use as documented in NRC Regulatory Guide 1.147. It is impractical to achieve the ASME Section XI Code-required coverage due to the geometric configuration of the welded areas. These limited examinations will be submitted to the NRC through the relief request process as allowed by 10 CFR 50.55a.

Class 1 System Pressure Tests

Table IWB-2500-1, Examination Category B-P of the 2001 Edition with Addenda through 2003 of ASME Section XI requires the performance of a system leakage test (IWB-5221) each refueling outage. This system leakage test was performed prior to plant startup following the refueling outage. These visual examinations revealed minor leakage and boron residue at mechanical connections. These leakage conditions were either corrected or evaluated and determined acceptable for continued system operation.

Class 2 Examinations

Selected Class 2 components were examined utilizing ultrasonic testing (UT), magnetic particle testing (MT), liquid penetrant (PT), and visual testing (VT) methods, as applicable. Specific components and examination areas are itemized in the applicable portions of this document.

- During the scope of examinations conducted, no Class 2 components were observed to have reportable indications.

Three (3) Class 2 piping and/or equipment welds had limited coverage during examinations because of physical limitations due to the geometric configuration of the welded areas. As with the Class 1 examinations, it is impractical to achieve the ASME Section XI Code-required coverage due to the geometric configuration of the welded areas. These limited examinations will be submitted to the NRC through the relief request process as allowed by 10 CFR 50.55a.

Class 2 System Pressure Tests

Table IWC-2500-1, Examination Category C-H of the 2001 Edition with Addenda through 2003 of ASME Section XI requires system leakage tests. The specific system leakage tests performed are itemized in the "System Pressure Tests" portion of this report document. The visual examinations performed during these system leakage tests found only minor leakage or residue at mechanical joints such as valve stem packing and at flanged connections. These leakage conditions were either corrected or evaluated and determined acceptable for continued system operation.

Class 1 and 2 Component Supports

Selected Class 1 and 2 component supports were examined utilizing the visual testing (VT) method. Specific components and examination areas are itemized in the applicable portions of this document.

- During the scope of examinations conducted, no component supports were observed to have reportable indications.

Class MC Containment Examinations (IWE)

General Visual, VT-3 and VT-1 examinations were performed on Class MC Pressure Retaining components with their integral attachments. These examinations were performed in accordance with ASME Section XI, Subsection IWE of the 2001 Edition through the 2003 Addenda and were performed using NMP-ES-024-207 "General Visual Examination (IWE)". Per procedure NMP-ES-024-207, the pressure retaining bolting and the containment pressure boundary was examined for defects that could violate its leak-tightness or structural integrity.

Personnel performing the examinations were qualified in accordance with Fleet procedure NMP-ES-024-100 "Procedure (Written Practice) for Qualification and Certification of Nondestructive Examination Personnel". Optical aids such as flashlights, mirrors and binoculars were used when performing the examinations that included both direct and remote visual examination methods.

Category E-A, Containment Surfaces

A General Inspection of 100% of the exterior accessible surface areas of the containment pressure boundary was performed and documented under Surveillance 84303-101-SNC479537. All anomalies consisted of surface rust, debris, scratches, discolorations, arc strikes, etc. and were evaluated as not affecting the structural integrity or leak tightness of the containment pressure boundary.

The following containment pressure boundary bolted connections were examined while the connections were disassembled for work activities. VT-1 or VT-3 examinations were performed to fulfill the requirements. No anomalies of the examined components were identified. Examinations were performed under work orders SNC409198, SNC409199, and SNC428064. Results of examinations are documented under Surveillance 84303-101-SNC479537.

Personnel Air Lock Emergency Air Cover	12101R2014
Escape Air Lock Emergency Air Cover	12101R2015
Dedicated Outage Penetrations	55-M

Class CC Containment Examinations (IWL)

No Class CC Containment Examinations (IWL) were performed.

Status of Examinations Required for the current Interval

This was the 3rd refueling outage in the 2nd Inspection Period of the 3rd Interval. The results from this outage, combined with the "completed" examinations from the previous 2nd Period refueling outages (1R16 and 1R17) represents 100% of the total Class 1 and 2 scope for the 2nd Inspection Period in the 3rd Interval. VEGP Unit 1 is within ASME Code compliance, pending NRC approval of the volumetric and/or surface examination limitations. Requests for relief will be submitted within the required time frame specified by 10 CFR 50.55a.

In addition, selected examinations performed during the refueling outage are planned to be credited to the 3rd Inspection Period of the 3rd Interval. The "Remarks" in the Examination Summaries located in Tab C of this report reflect these examinations. As allowed by ASME Section XI, paragraph IWA-2430(d)(3) "the inspection period to be reduced or extended by as much as one year to enable an inspection to coincide with a plant outage." As such, selected components examined during the 1R18 are planned to be credited to the 3rd Inspection period.

Applicable Code Cases

The applicable Code Cases are identified in Enclosure 4, Volume 1 of the VEGP Units 1 and 2 Inservice Inspection Plan, Third Inspection Intervals. The Code Cases and limitations of use are derived from Revision 14, 15, and 16 of NRC Regulatory Guide 1.147.

TAB C

INSERVICE INSPECTION EXAMINATION (OWNER'S REPORT) SUMMARY

- **CLASS 1 AND 2 WELD EXAMINATIONS**
- **CLASS 1 AND 2 SUPPORT EXAMINATIONS**

Vogle 1R18 – Examination Summary (Total Piping)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
R-A R1.11H	11201-031-3-RB 2" ELBOW TO PIPE	NMP-ES-024-501	S14V1U008	NRI	Examined weld and base material per MRP-146.
R-A R1.11H	11201-042-3-RB 2" ELBOW TO PIPE	NMP-ES-024-501	S14V1U009	NRI	Examined weld and base material per MRP-146.
R-A R1.11H	11201-046-3-RB 2" ELBOW TO PIPE	NMP-ES-024-501	S14V1U010	NRI	Examined weld and base material per MRP-146.
R-A R1.11H	11201-051-3-RB 2" ELBOW TO PIPE	NMP-ES-024-501	S14V1U011	NRI	Examined weld and base material per MRP-146.
R-A R1.20	11204-021-19-RB 6" ELBOW TO PIPE	NMP-ES-024-501	S14V1U026	NRI	Exam credited to third inspection period.
R-A R1.20	11204-023-17-RB 6" PIPE TO ELBOW (AI 87-0131)	NMP-ES-024-501	S14V1U043	NRI	NA
R-A R1.16	11204-024-13-RB 6" PIPE TO VALVE	NMP-ES-024-501	S14V1U051	NRI	50% Code Coverage. Relief Request required. Exam credited to third inspection period.
R-A R1.20	11204-024-15-RB 6" PIPE TO ELBOW	NMP-ES-024-501	S14V1U020	NRI	Exam credited to third inspection period.
R-A R1.20	11204-024-16-RB 6" ELBOW TO PIPE	NMP-ES-024-501	S14V1U050	NRI	Exam credited to third inspection period.
R-A R1.20	11204-024-17-RB 6" PIPE TO ELBOW	NMP-ES-024-501	S14V1U019	NRI	Exam credited to third inspection period.
R-A R1.20	11204-024-18-RB 6" ELBOW TO PIPE	NMP-ES-024-501	S14V1U017	NRI	Exam credited to third inspection period.
R-A R1.20	11204-024-19-RB 6" PIPE TO BRANCH CONNECTION	NMP-ES-024-501	S14V1U018	NRI	Exam credited to third inspection period.
R-A R1.16	11204-126-14-RB 10" ELBOW TO PIPE (AI 87-0131)	NMP-ES-024-501	S14V1U027	NRI	NA
R-A R1.16	11204-126-15-RB 10" PIPE TO VALVE (AI 87-0131)	NMP-ES-024-501	S14V1U028	NRI	50% Code Coverage. Relief Request required.
R-A R1.11	11204-243-30-RB 1.5" VALVE TO PIPE	NMP-ES-024-501	S14V1U044	NRI	Examined weld and base material per MRP-146.
R-A R1.11H	11204-243-31-RB 1.5" PIPE TO ELBOW	NMP-ES-024-501	S14V1U045	NRI	Examined weld and base material per MRP-146.

Vogle 1R18 – Examination Summary (Total Piping)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
R-A R1.11	11204-244-24-RB 1.5" VALVE TO PIPE	NMP-ES-024-501	S14V1U038	NRI	Examined base material only per MRP-146.
R-A R1.11H	11204-244-25-RB 1.5" PIPE TO ELBOW	NMP-ES-024-501	S14V1U039	NRI	Examined weld and base material per MRP-146.
R-A R1.11	11204-245-29-RB 1.5" VALVE TO PIPE	NMP-ES-024-501	S14V1U046	NRI	Examined base material only per MRP-146.
R-A R1.11H	11204-245-30-RB 1.5" PIPE TO ELBOW	NMP-ES-024-501	S14V1U047	NRI	Examined weld and base material per MRP-146.
R-A R1.11	11204-246-32-RB 1.5" VALVE TO PIPE	NMP-ES-024-501	S14V1U040	NRI	Examined base material only per MRP-146.
R-A R1.11H	11204-246-33-RB 1.5" PIPE TO ELBOW	NMP-ES-024-501	S14V1U041	NRI	Examined weld and base material per MRP-146.
R-A R1.20	11208-043-3 C-RB 1.5" PIPE TO PIPE	NMP-ES-024-501	S14V1U021	NRI	Exam credited to third inspection period.
R-A R1.20	11208-043-4 A-RB 1.5" PIPE TO TEE	NMP-ES-024-501	S14V1U022	NRI	Exam credited to third inspection period.
R-A R1.20	11208-043-4-RB 1.5" PIPE TO PIPE	NMP-ES-024-501	S14V1U023	NRI	Exam credited to third inspection period.
R-A R1.11	11302-108-13-RB 6" TEE TO PIPE	NMP-ES-024-502	S14V1U001	RI	Counterbore previously recorded with no change. Acceptable as is. Exam credited to third inspection period.
R-A R1.11	11302-108-15-RB PENETRATION TO 6" PIPE	NMP-ES-024-502	S14V1U029	NRI	Exam credited to third inspection period.
R-A R1.11	11302-108-16-RB 6" PIPE TO VALVE	NMP-ES-024-502	S14V1U030	NRI	Exam credited to third inspection period.
R-A R1.11	11302-108-17-RB 6" VALVE TO PIPE	NMP-ES-024-502	S14V1U031	NRI	Exam credited to third inspection period.
R-A R1.11	11302-108-18-RB 6" PIPE TO ELBOW	NMP-ES-024-502	S14V1U032	NRI	Exam credited to third inspection period.
R-A R1.11	11302-110-15-RB PENETRATION TO 6" PIPE	NMP-ES-024-502	S14V1U033	NRI	Exam credited to third inspection period.
R-A R1.11	11302-110-16-RB 6" PIPE TO VALVE	NMP-ES-024-502	S14V1U034	NRI	Exam credited to third inspection period.

Vogtle 1R18 – Examination Summary (Total Piping)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
R-A R1.11	11302-110-17-RB 6" VALVE TO PIPE	NMP-ES-024-502	S14V1U035	NRI	Exam credited to third inspection period.
R-A R1.11	11302-110-18-RB 6" PIPE TO ELBOW	NMP-ES-024-502	S14V1U036	NRI	Exam credited to third inspection period.
R-A R1.11	11302-110-20-RB 6" PIPE TO ELBOW	NMP-ES-024-502	S14V1U037	NRI	Exam credited to third inspection period.
R-A R1.20BER	11305-058-1-RB FORGING TO 16" PIPE (TS 5.5.16)	NMP-ES-024-502	S14V1U002	NRI	NA
C-C C3.20	11305-058-3 SUPPORT H001	NMP-ES-024-401 NMP-ES-024-301	S14V1M001 S14V1P001	NRI	Indication determined to be NRI per supplemental PT exam.
R-A R1.20BER	11305-058-4-RB 16" PIPE TO VALVE (TS 5.5.16)	NMP-ES-024-502	S14V1U003	NRI	NA
R-A R1.20BER	11305-058-5-RB 16" VALVE TO PIPE (TS 5.5.16)	NMP-ES-024-502	S14V1U004	NRI	NA
R-A R1.20BER	11305-058-6-RB 16" PIPE TO VALVE (TS 5.5.16)	NMP-ES-024-502	S14V1U005	NRI	NA
R-A R1.20BER	11305-058-7-RB 16" VALVE TO PIPE (TS 5.5.16)	NMP-ES-024-502	S14V1U006	NRI	NA
R-A R1.20BER	11305-058-8-RB 16" PIPE TO PENETRATION (TS 5.5.16)	NMP-ES-024-502	S14V1U007	NRI	NA
C-C C3.20	11305-058-11 SUPPORT H007	NMP-ES-024-401	S14V1M002	NRI	NA

Vogtle 1R18 – Examination Summary (Total Equipment)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
N-722 B15.120	11201-B6-001-I10-VT CHANNEL HEAD DRAIN TUBE (WCAP 12907)	NMP-ES-024-202	S14V1V011	Accept	NA
N-722 B15.120	11201-B6-002-I10-VT CHANNEL HEAD DRAIN TUBE (WCAP 12907)	NMP-ES-024-202	S14V1V012	Accept	NA
N-722 B15.120	11201-B6-003-I10-VT CHANNEL HEAD DRAIN TUBE (WCAP 12907)	NMP-ES-024-202	S14V1V013	Accept	NA
N-722 B15.120	11201-B6-004-I10-VT CHANNEL HEAD DRAIN TUBE (WCAP 12907)	NMP-ES-024-202	S14V1V014	Accept	NA
B-N-1 B13.10	11201-V6-001-I01 VESSEL INTERIOR	NMP-ES-024-203	S14V1V042	Accept	NA
B-N-1 B13.CH	11201-V6-001-I02 VESSEL CLOSURE HEAD INTERIOR (FSAR 5.3.3.7)	NMP-ES-024-203	S14V1V041	Accept	NA
N-770-1 / A-2 R-A / R1.15D	11201-V6-001-W33-RB OUTLET NOZZLE N1 TO SAFE END WELD at 22 DEGREES	VENDOR	VENDOR	NRI	Pre-stress improvement exam performed on unmitigated butt weld of Hot Leg Nozzle prior to Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.
N-770-1 / D R-A / R1.20	11201-V6-001-W33-RB OUTLET NOZZLE N1 TO SAFE END WELD at 22 DEGREES	VENDOR	VENDOR	NRI	Post-stress improvement exam performed on butt weld of Hot Leg Nozzle after mitigation by Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.
N-770-1 / A-2 R-A / R1.15D	11201-V6-001-W36-RB Outlet Nozzle N4 to Safe End Weld at 158 Degrees	VENDOR	VENDOR	NRI	Pre-stress improvement exam performed on unmitigated butt weld of Hot Leg Nozzle prior to Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.

Vogtle 1R18 – Examination Summary (Total Equipment)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
N-770-1 / D R-A / R1.20	11201-V6-001-W36-RB Outlet Nozzle N4 to Safe End Weld at 158 Degrees	VENDOR	VENDOR	NRI	Post-stress improvement exam performed on butt weld of Hot Leg Nozzle after mitigation by Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.
N-770-1 / A-2 R-A / R1.15D	11201-V6-001-W37-RB Outlet Nozzle N5 to Safe End Weld at 202 Degrees	VENDOR	VENDOR)	NRI	Pre-stress improvement exam performed on unmitigated butt weld of Hot Leg Nozzle prior to Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.
N-770-1 / D R-A / R1.20	11201-V6-001-W37-RB Outlet Nozzle N5 to Safe End Weld at 202 Degrees	VENDOR	VENDOR	NRI	Post-stress improvement exam performed on butt weld of Hot Leg Nozzle after mitigation by Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.
N-770-1 / A-2 R-A / R1.15D	11201-V6-001-W40-RB Outlet Nozzle N8 to Safe End Weld at 338 Degrees	VENDOR	VENDOR	NRI	Pre-stress improvement exam performed on unmitigated butt weld of Hot Leg Nozzle prior to Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.

Vogtle 1R18 – Examination Summary (Total Equipment)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
N-770-1 / D R-A / R1.20	11201-V6-001-W40-RB Outlet Nozzle N8 to Safe End Weld at 338 Degrees	VENDOR	VENDOR	NRI	Post-stress improvement exam performed on butt weld of Hot Leg Nozzle after mitigation by Mechanical Stress Improvement Process (MSIP™) as required by N-770-1 Note 12. No cracking detected by exam.
N-729 B4.10 VT2	11201-V6-CRDM (VT-2) Vessel Closure Head Exterior	NMP-ES-024-208	S14V1V023	Accept	NA
C-B C2.21	11201-B6-001-W18 32" STEAM OUTLET NOZZLE WELD TO UPPER HEAD WELD	NMP-ES-024-401 NMP-ES-024-516	S14V1M003 S14V1U049	NRI	50% Code Coverage. Relief Request required. Exam credited to third inspection period.
C-A C1.10	11201-B6-002-W04 TRANSITION CONE TO LOWER CONE END STUB BARREL WELD	NMP-ES-024-516	S14V1U042	NRI	Exam credited to third inspection period.
C-A C1.10	11201-B6-002-W05 LOWER CONE END STUB BARREL TO LOWER SHELL BARREL	NMP-ES-024-516	S14V1U048	NRI	Exam credited to third inspection period.
C-C C3.10	11201-B6-002-W25 TRUNNION TO SHELL WELD	NMP-ES-024-301	S14V1P005	NRI	Trunnion supports 11201-B6-002-S10. Exam credited to third inspection period.
B-D B3.140	11201-B6-003-IR-01 INLET NOZZLE INNER RADIUS	NMP-ES-024-513	S14V1U013	NRI	Exam credited to third inspection period.
B-D B3.140	11201-B6-003-IR-02 *OUTLET NOZZLE INNER RADIUS	NMP-ES-024-513	S14V1U014	NRI	Exam credited to third inspection period.
B-D B3.140	11201-B6-004-IR-01 INLET NOZZLE INNER RADIUS	NMP-ES-024-513	S14V1U015	NRI	Exam credited to third inspection period.
B-D B3.140	11201-B6-004-IR-02 OUTLET NOZZLE INNER RADIUS	NMP-ES-024-513	S14V1U016	NRI	Exam credited to third inspection period.
B-G-1 B6.180	11201-P6-002-B01 THRU B24 MAIN FLANGE BOLTS	NMP-ES-024-504	S14V1U012	NRI	Exam credited to third inspection period.
B-G-2 B7.60	11201-P6-002-B25 THRU B32 1.5" DIA. SEALWATER HOUSING CAP SCREWS	NMP-ES-024-201	MWO SNC520019	SAT	NA
B-G-2 B7.60	11201-P6-003-B25 THRU B32 1.5" DIA. SEALWATER HOUSING CAP SCREWS	NMP-ES-024-201	MWO SNC520020	SAT	NA

Vogle 1R18 – Examination Summary (Total Equipment)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s)	Results	Remarks
B-G-2 B7.60	11201-P6-004-B25 THRU B32 1.5" DIA. SEALWATER HOUSING CAP SCREWS	NMP-ES-024-201	MWO SNC520021	SAT	NA
B-O B14.10	11201-V6-001-W184 CRD HOUSING WELD	NMP-ES-024-301	S14V1P003	NRI	Exam credited to third inspection period.
B-O B14.10	11201-V6-001-W188 CRD HOUSING WELD	NMP-ES-024-301	S14V1P002	NRI	Exam credited to third inspection period.
B-M-2 B12.50	11201PSV8010A-IS VALVE INTERNAL SURFACES	VENDOR	VENDOR	SAT	NA
B-M-2 B12.50	11201PSV8010C-IS VALVE INTERNAL SURFACES	VENDOR	VENDOR	SAT	NA
C-B C2.21	11204-V6-001-W01 INLET NOZZLE TO VESSEL HEAD	NMP-ES-024-301 NMP-ES-024-516	S14V1P004 S14V1U024	NRI	50% Code Coverage. Relief Request required. Exam credited to third inspection period.
C-A C1.20	11204-V6-001-W02 VESSEL HEAD TO VESSEL SHELL	NMP-ES-024-516	S14V1U025	NRI	47% Code Coverage. Relief Request required. Exam credited to third inspection period.

Vogtle 1R18 – Examination Summary (Total Supports)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s).	Results	Remarks
F-A F1.40S	11201-B6-002-S06 HYDRAULIC SNUBBER	NMP-ES-024-203	S14V1V003	Accept	NA
F-A F1.40S	11201-B6-002-S08 HYDRAULIC SNUBBER	NMP-ES-024-203	S14V1V004	Accept	NA
F-A F1.40	11201-B6-002-S10 UPPER SUPPORT FRAME	NMP-ES-024-203	S14V1V032	SAT	NA
F-A F1.10S	11201-030-H026 MECH SNUBBER	NMP-ES-024-203	S14V1V022	Accept	Exam credited to third inspection period.
F-A F1.10S	11201-049-H002 MECH SNUBBER	NMP-ES-024-203	S14V1V007	Accept	Exam credited to third inspection period.
F-A F1.10S	11201-049-H010 MECH SNUBBER	NMP-ES-024-203	S14V1V008	Accept	Exam credited to third inspection period.
F-A F1.10S	11201-051-H001 MECH SNUBBER	NMP-ES-024-203	S14V1V005	Accept	Exam credited to third inspection period.
F-A F1.10S	11201-051-H008 MECH SNUBBER	NMP-ES-024-203	S14V1V006	Accept	Exam credited to third inspection period.
F-A F1.10S	11201-053-H006 MECH SNUBBER	NMP-ES-024-203	S14V1V010	Accept	Exam credited to third inspection period.
F-A F1.10S	11204-034-H002 MECH SNUBBER	NMP-ES-024-203	S14V1V009	Accept	Exam credited to third inspection period.
F-A F1.20D(1)	11205-008-H032 LIN RACK 2-D	NMP-ES-024-203	S14V1V039	SAT	NA
F-A F1.20C(1)	11205-008-H601 LIN RACK 1-D	NMP-ES-024-203	S14V1V030	SAT	NA
F-A F1.20S	11206-002-H013T LISEGA HYD SNUBBER	NMP-ES-024-203	S14V1V002	Accept	Exam credited to third inspection period.
F-A F1.10S	11208-001-H032 MECH SNUBBER	NMP-ES-024-203	S14V1V019	Accept	Exam credited to third inspection period.
F-A F1.10S	11208-047-H006 MECH SNUBBER	NMP-ES-024-203	S14V1V018	Accept	Exam credited to third inspection period.
F-A F1.20S	11301-015-H007 HYDRAULIC SNUBBER	NMP-ES-024-203	S14V1V001	Accept	Exam credited to third inspection period.
F-A F1.20S	11301-107-H002 MECH SNUBBER	NMP-ES-024-203	S14V1V016	Accept	Exam credited to third inspection period.

Vogtle 1R18 – Examination Summary (Total Supports)

ASME Section XI Cat / Item	Examination/Area	Examination Procedure(s)	Exam/Cal Sheet No(s).	Results	Remarks
F-A F1.20S	11302-109-H022 MECH SNUBBER	NMP-ES-024-203	S14V1V017	Accept	Exam credited to third inspection period.
F-A F1.20F(1)	11305-058-H001 LIN RESTRAINT	NMP-ES-024-203	S14V1V015	SAT	Exam credited to third inspection period.
F-A F1.20S	11305-058-H005 MECH SNUBBER	NMP-ES-024-203	S14V1V035	Accept	Exam credited to third inspection period.
F-A F1.20H(1)	11305-058-H007 VAR SPRING	NMP-ES-024-203	S14V1V021	SAT	Exam credited to third inspection period.
F-A F1.20H(1)	11305-062-H002 VAR SPRING	NMP-ES-024-203	S14V1V038	SAT	Exam credited to third inspection period.

TAB D

INSERVICE INSPECTION EXAMINATION (OWNER'S REPORT) SUMMARY

- **SYSTEM PRESSURE TESTS**

SYSTEM PRESSURE TESTS

The following system pressure tests on Class 1 and Class 2 components were performed during the reporting period. The system pressure tests indicated include system leakage tests for:

- Class 1 components (IWB-2500-1, Examination Category B-P),
- Class 2 components (IWC-2500-1, Examination category C-H) not required to operate during normal plant operation which are identified as 84003-107 through 84003-110, and,
- Class 2 components (IWC-2500-1, Examination category C-H) required to operate during normal plant operation which is identified as 84003-1DF.

Boundaries for the system pressure tests are described in the Pressure Test Plan (Inservice Inspection Plan-Volume 3). Examination results are discussed in the applicable sections of this report document. The examination data for these system pressure tests is available at the plant site for review upon request.

<u>Test Number</u>	<u>Exam Cat/ Item No.</u>	<u>Test Description</u>
14910-101	B-P / B15.10	Class 1 System Leakage Test
84003-107	C-H / C7.10	Penetration 31 (SI to Hot Legs 2 & 3) System Leakage Test
84003-109	C-H / C7.10	Penetration 56 (RHR Hot Leg Injection) System Leakage Test
84003-110	C-H / C7.10	Safety Injection (SI) Pump Suction System Leakage Test
84003-1DF	C-H / C7.10	Reactor Vessel Head Flange O-Ring Leakoff Lines System Leakage Test (See Note below)

Note: This system leakage test satisfied the requirements of ISI program Alternative VEGP-ISI-ALT-10 as approved by the USNRC by letter dated March 19, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14078A331).

TAB E

INSERVICE INSPECTION EXAMINATION (OWNER'S REPORT) SUMMARY

- **REPORTABLE INDICATION SUMMARY**

REPORTABLE INDICATION SUMMARY

No Indication Notifications Forms and/or Condition Reports were issued due to *reportable* indications or conditions being observed during the examination of either Class 1 or 2 components or Class 1 or 2 component supports during the reporting period. SNC defines "reportable" as that which exceeds prescribed "acceptance criteria" (i.e. ASME Tables, etc.) which require repair and/or replacement.

TAB F

OWNER'S REPORT FOR REPAIR AND REPLACEMENTS (ASME FORM NIS-2)

OWNER'S REPORTS FOR REPAIRS OR REPLACEMENTS (FORM NIS-2)

The following Owner's Reports for Repairs or Replacements (Form NIS-2) are provided for work activities documented during the reporting period. Reports are identified by their respective traveler number which is denoted on each of the NIS-2 reports. The originals of the NIS-2 reports are filed with their respective traveler packages at the plant site. Only those NIS-2 reports applicable to VEGP-1 are included in this report document. Any attachments, e.g., code data reports, etc., referenced in the NIS-2 reports will be made available for review upon request at the plant site.

12002	13101	13118	13137	14002	14058
12060	13102	13119	13138	14003	14059
13033	13103	13120	13139	14004**	14060
13034	13104	13121	13140	14005**	14061
13035	13105	13123	13141	14006**	14062**
13087	13106	13124	13142	14007**	14063
13090	13107	13125	13143	14017	14064
13091	13108	13127*	13144	14022	14065
13092	13109	13128**	13145*	14023	14070
13093	13110	13129	13146	14026	14071
13094	13111	13130	13147	14032	14072
13095	13112	13131	13149	14033	14073
13096	13113	13132	13150	14040	14074*
13097	13114	13133	13151	14041	14078
13098	13115	13134	13152	14051	14079
13099	13116	13135	14000	14052	14081
13100	13117	13136	14001	14057	

* - NIS-2 Form documents more than one NIS-2 Form.

** - NIS-2 Form is documented on another NIS-2 Form.

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 12002

1. Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address Waynesboro, GA 30830
2. Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address SNC121569
Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Maintenance Department
Name Plant Vogtle
Address 1208/Chemical and Volume Control
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A
4. Identification of System 1208/Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec III Edition, 1974 Addenda, Winter 1975 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s)

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
STUD	WESTINGHOUSE ELECTRICAL CORP	3001306	N/A	N/A	2009	INSTALLED	YES
NUTS	WESTINGHOUSE ELECTRICAL CORP	241436	N/A	N/A	2009	INSTALLED	YES

7. Description of Work Replacement of Studs and Nuts for 11208E6007

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure ☐ psi Test Temp. ☐ °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed For Mike Skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/09/13 to 06/29/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938
National Board, State, Province and Endorsements

Date 29 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 12060

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1208/Chemical and Volume Control
- (a) Applicable Construction Code ASME Sec III Edition, 1977 Addenda, Summer 1977 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s) N31

Date July 7, 2014
Sheet 1 of 1
Unit 1
SNC121075
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
DIAPHRAGM VALVE	HILLS - MC CANA	519-1280	N/A	11208U4482	1986	REMOVED	YES
DIAPHRAGM VALVE	ITT ENGINEERED VALVES	875717-001-001	N/A	11208U4482	2012	INSTALLED	YES

- Description of Work Replacement of the Hills Mc Cana valve with an ITT Engineered valve

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Mr. F. J. Skinner Superintendent Date 07/8/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/13/13 to 07/08/14 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
National Board, State, Province and Endorsements
Date 08 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13033

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1202/ Nuclear Service Cooling Water
5. (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 75
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date July 2, 2014
Sheet 1 of 1
Unit 1
SNC 434868
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	ANVIL INTERNATIONAL	41-107111	N/A	11202031H006	2013	INSTALLED	YES

7. Description of Work Installation of new pipe support per DCP SNC331604

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Superintendent Date 7/3/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 02/11/13 to 07/06/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938
National Board, State, Province and Endorsements

Date 06 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13034

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address

Date July 2, 2014
Sheet 1 of 1

2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address

Unit 1
SNC 434869
Repair/Replacement Organization P.O. No., Job No., etc.

3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

4. Identification of System 1202/ Nuclear Service Cooling Water

5. (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 75
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	ANVIL INTERNATIONAL	41-109277	N/A	11202023H008	2013	INSTALLED	YES

7. Description of Work Installation of new pipe support per DCP SNC331604

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Mikel Skinner Superintendent Date 7/3/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 06/10/13 to 07/03/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 03 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13035

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/ Nuclear Service Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 75
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	ANVIL INTERNATIONAL	41-109277	N/A	11202033H005	2013	INSTALLED	YES

7. Description of Work Installation of new pipe support per DCP SNC331604

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Michael Skinner Superintendent Date 7/3/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 06/10/13 to 07/05/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938

National Board, State, Province and Endorsements

Date 05 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13087

1. Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Date July 6, 14
Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
MWO # SNC 446335
Address Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance
Name Plant Vogtle
Address
4. Identification Of System 1201 / Reactor Coolant System
5. (a) Applicable Construction Code ASME SEC III 1977 Edition, Summer 1979 Addenda, Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PRESURIZER PORV	CROSBY VALVE AND GAGE CO.	P-126	N/A	1PV0456A	N/A	CORRECTED	YES

7. Description Of Work Pressurizer Porv was inspected and repaired as required with the installation of a new valve plug and a new valve seat.
8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A PSI Test Temp. N/A °F
9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Foy for Mike Skinner Superintendent Date 07/7/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
National Board, State, Province and Endorsements

Date 08 July 2014 *08/09/13

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13090

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W/1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481876
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	33516	N/A	11201031H005	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-1/4 S/N 33525 with PSA-1/4 S/N 33516

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] for Michael Skinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/19/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA-938
Inspector's Signature National Board, State, Province and Endorsements
Date 25 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13091

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date 06/23/14
Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC481881
Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
4. Identification Of System 1208 / Chemical and Volume Control System
5. (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	23342	N/A	1-1208-045-H002	1987	INSTALLED	YES

7. Description Of Work Snubber PSA-1/4, serial #33501 was replaced with PSA-1/4, serial # 23342 to support surveillance testing.
8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F
9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mark Skinner for Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut, of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/15/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements

Date 28 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13092

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/Nuclear Service Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481882
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	16099	N/A	11202088H026	1987	INSTALLED	YES

- Description of Work Replace Snubber PSA-10 S/N 16100 with PSA-10 S/N 16099
- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F
- Remarks See Item 7
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed B. E. Skinner Superintendent Date 06/30/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/27/13 to 06/30/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 30 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13093

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1204/Safety Injection
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481884
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	11501	N/A	11204126H601	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-35 S/N 11733 with PSA-35 S/N 11501

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 06/23/2014
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/22/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13094

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date 06/23/14
Sheet 1 Of 1
- Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC481897
Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
- Identification Of System 1305 /Condensate & Feedwater System
- (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, 1644-5 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A
- Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	31300875/004	N/A	1-1305-058-H005	1987	INSTALLED	YES

- Description Of Work Snubber PSA-100, serial #2159 was replaced with a Lisega 308256RF3, serial # 31300875/004 to support surveillance testing.
- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F
- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 06/24/14 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 06/24/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13095

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date 06/23/14
Sheet 1 Of 1
- Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC481901
Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
- Identification Of System 1305 /Condensate & Feedwater System
- (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, 1644-5 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A
- Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	30700367/002	N/A	1-1305-060-H005	1987	INSTALLED	YES

- Description Of Work Snubber PSA-100, serial #2225 was replaced with a Liseqa 308256RF3, serial # 30700367/002 to support surveillance testing.
- Test Conducted: Hydrostatic ☐ Other ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Pressure N/A PSI Test Temp. N/A °F
- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut, of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/23/13 to 06/26/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 26 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13096

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481903
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	417	N/A	11201046H005	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-73 S/N 252 with AD-73 S/N 417

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben K. for Mikkel Skinner Date 06/23/2014
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/19/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 23 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13097

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1208/Chemical and Volume Control
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481905
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	363	N/A	11208007H004	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-71 S/N 240 with AD-71 S/N 363

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] FOR MARKER GRINNY Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/19/13 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.
By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 27 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13098

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address

Date June 23, 2014

Sheet 1 of 1

2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address

Unit 1

SNC 481913

Repair/Replacement Organization P.O. No., Job No., etc.

3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System 1208/Chemical and Volume Control

5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977

(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.

(c) Applicable Section XI Code Case(s) N-249-1

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	624	N/A	11208449H021	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-41 S/N 1034 with AD-41 S/N 624

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Mark Skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 07/19/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions GA 938
National Board, State, Province and Endorsements

Date 25 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13099

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date 06/23/14
Sheet 1 Of 1
- Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC481916
Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
- Identification Of System 1301 /Main Steam System
- (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, N-249-1 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A
- Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	3110544/004	N/A	1-1301-128-H099	1987	INSTALLED	YES

- Description Of Work Snubber AD-151, serial #524 was replaced with a Liseqa 303856RF2, serial # 3110544/004 to support surveillance testing.
- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F
- Remarks See Item 7
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Mike Skinner Superintendent Date 6/24/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/31/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 25 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13100

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date 06/23/14
Sheet 1 Of 1
- Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC481918
Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
- Identification Of System 1301 /Main Steam System
- (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, N-249-1 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A
- Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	31300359/006	N/A	1-1301-137-H002	1987	INSTALLED	YES

- Description Of Work Snubber AD-153L, serial #596 was replaced with a Liseqa 303956RC7, serial # 31300359/006 to support surveillance testing.
- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F
- Remarks See Item 7
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed B. J. Formik SKINNER Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/31/13 to 06/28/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 28 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13101

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/Main Steam
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	708	N/A	11301137H004	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-151L S/N 709 with AD-151L S/N 708

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Mikel Skinner Date 06/23/2014
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/31/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 24 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13102

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/Nuclear Service Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 23, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc. SNC 481922
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	404	N/A	11202002H022	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-501 S/N 132 with AD-501-S/N 404

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Foy for Mikel Skinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 31 July 2013 to 24 June 2014, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938

National Board, State, Province and Endorsements

Date 24 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13103

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/Main Steam
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481925
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	408	N/A	11301178H003	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-501 S/N 414 with AD-501 S/N 408

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mike Kimmer Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/31/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938

National Board, State, Province and Endorsements

Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13104

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/Nuclear Safety Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 27, 2014
Sheet 1 of 1
Unit 1
SNC 481929
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	75	N/A	11202181H058	1987	INSTALLED	YES

- Description of Work Replace Snubber AD-1603 S/N 70 with AD-1603 S/N 75
- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F
- Remarks See Item 7
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Date 06/27/14
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/01/13 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 27 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13105

1. Owner Southern Nuclear Operating Company Date June 23, 2014
40 Inverness Center Parkway, Birmingham, AL Sheet 1 of 1
Address
 2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 SNC 481932
Address Repair/Replacement Organization P.O. No., Job No., etc.
 3. Work Performed by Maintenance Department Type Code Symbol Stamp N/A
Name Authorization No. N/A
Plant Vogtle Expiration Date N/A
Address
 4. Identification of System 1206/Containment Spray
 5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s) N-249-1

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	689	N/A	11206005H009	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-1603 S/N 644 with AD-1503 S/N 689

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Tommy Skinner Date 06/23/2014
 Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/31/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938

National Board, State, Province and Endorsements

Date 24 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13108

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1302/Auxiliary Feed Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481934
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	93	N/A	11302109H023	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-1603 S/N 677 with AD-1603 S/N 93

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for M. K. Skinner Superintendent Date 07/11/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/31/13 to 07/02/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 02 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13107

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1301/Main Steam
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481938
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	243	N/A	11301104H002	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-5503 S/N 326 with AD-5503 S/N 243

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Michael Skinner Date 06/25/2014
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 06/27/14 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 27 June 2014

* 08/01/13

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13108

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/Main Steam
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 24, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	227	N/A	11301105H004	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-5501 S/N 288 with AD-5501 S/N 227

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Mike Skinn Superintendent Date 06/25/2014
Owner of Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/01/13 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
Date 27 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13109

1. Owner Southern Nuclear Operating Company
40 Inverness Center Parkway, Birmingham, AL
 Name _____
 Address _____
2. Plant Vogtle Electric Generating Plant
Waynesboro, GA 30830
 Name _____
 Address _____
3. Work Performed by Maintenance Department
 Name _____
Plant Vogtle
 Address _____
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s) 1844-5

Date June 23, 2014
 Sheet 1 of 1
 Unit 1
 Repair/Replacement Organization P.O. No., Job No., etc. SNC 481974
 Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	600	N/A	11201030H042	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-1L S/N 640 with PSA-1L S/N 600

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
 Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Mike Superintendent Date 06/23/2014
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/01/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
 Inspector's Signature National Board, State, Province and Endorsements
 Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13110

1. Owner Southern Nuclear Operating Company
40 Inverness Center Parkway, Birmingham, AL
 Name
 Address
2. Plant Vogtle Electric Generating Plant
Waynesboro, GA 30830
 Name
 Address
3. Work Performed by Maintenance Department
Plant Vogtle
 Name
 Address
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s) 1644-5

Date June 27, 2014
 Sheet 1 of 1
 Unit 1
SNC 481975
 Repair/Replacement Organization P.O. No., Job No., etc.
 Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	28736	N/A	11201029H024	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-3 S/N 28765 with PSA-3 S/N 28736

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed for Mike Skinner Superintendent Date 06/30/14
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/01/13 to 06/30/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
 National Board, State, Province and Endorsements

Date 30 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13111

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1206/Containment Spray
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481978
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	97614260/34	N/A	11206005HQ10	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-3 S/N 27598 with Lisega 305253RF3 S/N 97614260/34

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for M. Keel Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/01/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 25 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13112

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1208/Chemical and Volume Control
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 481980
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	31200597/005	N/A	11208042H046	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-3 S/N 27256 with Liseaga 305253RF3 S/N 31200597/005

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Ben Fray for Mikel Skinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/01/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 25 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13113

- Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name Plant Vogtle
Address
- Identification of System 1302/ Auxiliary Feed Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1844-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc. SNC 481984
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

5. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	12089	N/A	11302109H009	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-10 S/N 15477 with PSA-10 S/N 12089

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for [Signature] Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 06/23/14 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature]

Commissions GA 938
National Board, State, Province and Endorsements

Date 24 June 2014

* 08/02/13

CSH
07/07/14

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13114

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1204/Seal Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 482215
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	11254	N/A	11204124H018	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-35 S/N 12260 with PSA-35 S/N 11254

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for m. ket 5/1/14 Superintendent Date 06/30/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/30/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 30 June 2014 National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13115

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 482216
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	33498	N/A	11208002H030	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-1/4 S/N 33467 with PSA-1/4 S/N 33498

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben F. Skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 27 June 2014

*CC# 06/27/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13116

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/Containment Spray
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	864	N/A	11208002H035	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-151 S/N 172 with AD-151 S/N 864

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Foy for Mike Skinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 24 JUNE 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13117

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1204/Safety Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1844-5

Date June 24, 2014
Sheet 1 of 1
Unit 1
SNC 482224
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	15471	N/A	11204024H038	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-10 S/N15976 with PSA-10 S/N 15471

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Don E. Skinner for M. K. Skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/26/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 26 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13118

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL

Date 06/23/14

Sheet 1 Of 1

2. Plant Vogtle Electric Generating Plant
Waynesboro, GA 30830
Address

Unit 1

MWO # SNC482229
Repair/Replacement Organization P.O. No., Job No., etc.

3. Work Performed by Nuclear Operations Maintenance
Name

Plant Vogtle
Address

4. Identification Of System 1204 / Safety Injection System

5. (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	15470	N/A	1-1204-021-H021	1987	INSTALLED	YES

7. Description Of Work Snubber PSA-10, serial #15449 was replaced with PSA-10, serial # 15470 to support surveillance testing.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed B. F. for Mikel Skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/26/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements

Date 26 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13119

1. Owner Southern Nuclear Operating Company Date 06/23/14
40 Inverness Center Parkway, Birmingham, AL Sheet 1 Of 1
 2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 MWO # SNC482230
Address Repair/Replacement Organization P.O. No., Job No., etc.
 3. Work Performed by Nuclear Operations Maintenance Plant Vogtle
Name Address
 4. Identification Of System 1204 / Safety Injection System
 5. (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 Ed., 2003 Add.
 (c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	15478	N/A	1-1204-042-H014	1987	INSTALLED	YES

7. Description Of Work Snubber PSA-10, serial #16514 was replaced with PSA-10, serial # 15478 to support surveillance testing.
 8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A PSI Test Temp. N/A °F
 9. Remarks See Item 7
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
 Certificate of Authorization No. N/A Expiration Date N/A
 Signed [Signature] for Mike Skinner Superintendent Date 06/25/2014
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/24/14 to 06/26/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
 Inspector's Signature National Board, State, Province and Endorsements
 Date 26 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13120

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1204/Safety Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 482231
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	12090	N/A	11204042H016	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-10 S/N 15975 with PSA-10 S/N 12090

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Mikel Skinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 23 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13121

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1201/Reactor Coolant
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	424	N/A	11201030H601	1987	INSTALLED	YES

- Description of Work Replace Snubber AD-151 S/N 133 with AD-151 S/N 424

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Fyfe for Mikel Skinner Superintendent Date 06/27/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/27/13 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 27 June 2014 National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13123

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/ Nuclear Service Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 76
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PUMP	BINGHAM WILLAMET	1A062	N/A	11202P4003	1983	CORRECTED	YES

- Description of Work Reinstallation of reworked pump

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE	
I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.	
Type Code Symbol Stamp	N/A
Certificate of Authorization No.	N/A
Expiration Date	N/A
Signed <u>Bm Tzy for Mike Skiff</u>	Date <u>06/30/14</u>
Owner or Owner's Designee, Title	

CERTIFICATE OF INSERVICE INSPECTION	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of <u>Georgia</u> and employed by <u>Hartford Steam Boiler Inspection and Insurance Co. of Connecticut</u> of <u>Hartford, Connecticut</u> have inspected the components described in this Owner's Report during the period <u>08-09-13</u> to <u>07/01/14</u> , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.	
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.	
Inspector's Signature <u>[Signature]</u>	Commissions <u>GA 938</u>
Date <u>07/01/2014</u>	National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13124

1. Owner Southern Nuclear Operating Company Date July 7, 14
40 Inverness Center Parkway, Birmingham, AL Sheet 1 Of 1
 Name
2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 MWO # SNC 128045
 Address Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance Plant Vogtle
 Name Address
4. Identification Of System 1202 / Nuclear Service Coolant Water
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Winter 1975 Addenda, _____ Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
 (c) Applicable Section XI Code Case(s) N/A
6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
CONTROL VALVE	FISHERCONTROLS COMPANY	7971547	N/A	1HV1669B	1983	CORRECTED	YES

7. Description Of Work Rework the Valve, said work to include the replacement of Studs and Nuts
8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
 Other ☐ Pressure N/A PSI Test Temp. N/A °F
9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 07/17/14
 Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
 Date 08 July 2014 National Board, State, Province and Endorsements
*08/02/13

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13125

1. Owner Southern Nuclear Operating Company
 Name 40 Inverness Center Parkway, Birmingham, AL
 Address Waynesboro, GA 30830
 Address Waynesboro, GA 30830
2. Plant Vogtle Electric Generating Plant
 Name Waynesboro, GA 30830
 Address Waynesboro, GA 30830
3. Work Performed by Maintenance Department
 Name Plant Vogtle
 Address Plant Vogtle
4. Identification of System 1302 / Auxiliary Feed Water
5. (a) Applicable Construction Code ASME Section III 1974 Edition, Summer 1975 Addenda, N1781 Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed, 2003 add.
 (c) Applicable Section XI Code Case(s)
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
MDAFW B	FISHER CONTROL	7964057	N/A	1HV5118	1980	CORRECTED	YES

7. Description of Work Replacement of Studs and Nuts
8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
 Other ☐ Pressure _____ psi Test Temp. _____ °F
9. Remarks N/A

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
 Certificate of Authorization No. N/A Expiration Date N/A
 Signed [Signature] Superintendent Date 6/17/2014
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 08/02/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Inspector's Signature Commissions GA 938
 Date 23 June 2014 National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13127*

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1204/ Safety Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 1974
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 29, 2014
Sheet 1 of 1
Unit 1
SNC 126584
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
CHECK VALVE	ROCKWELL	BG420	N/A	11204U4145	1983	REMOVED	YES
CHECK VALVE	FLOWERVE	59BWT	N/A	11204U4145	2014	INSTALLED	YES
COUPLING	CAMCO	EIO	N/A	N/A	1980	INSTALLED	YES
RAD	BERGEN POWER	S74168	N/A	N/A	2008	INSTALLED	YES

7. Description of Work Replacement of check valve 1-1204-U4-145

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks This also addresses Traveler 13128

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Bruce Foy for M. Skinner Superintendent Date 07/9/14
Owner of Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/12/13 to 07/09/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 09 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13129

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/ Chemical and Volume Control System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, Summer 77
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed, 2003 add.
(c) Applicable Section XI Code Case(s) N31

Date June 18, 2014
Sheet 1 of 1
Unit 1
SNC 517062
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ITT ENGINEERED VALVES	892647-001-001	N/A	11208Y4296	2014	INSTALLED	YES

7. Description of Work Replaced valve

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 6/18/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/09/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13130

- Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name Plant Vogtle
Address
- Identification of System 1204/Safety Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 27, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc. SNC 499283
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	369	N/A	11204023H002	1987	INSTALLED	YES

7. Description of Work Replace Snubber AD-1601 S/N 531 with AD-1603 S/N 369

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Ben Fug for Mikel Skinner Superintendent Date 06/30/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/09/13 to 06/30/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 30 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13131

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1204/Safety Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5
- Identification Of Components

Date June 30, 2014
Sheet 1 of 1
Unit 1
SNC 499319
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	11506	N/A	11204126H020	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-35 S/N 12256 with PSA-35 S/N 11506

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE	
I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.	
Type Code Symbol Stamp	<u>N/A</u>
Certificate of Authorization No.	<u>N/A</u>
Expiration Date	<u>N/A</u>
Signed <u>[Signature]</u> Owner or Owner's Designee, Title	Date <u>06/30/14</u>

CERTIFICATE OF INSERVICE INSPECTION	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of <u>Georgia</u> and employed by <u>Hartford Steam Boiler Inspection and Insurance Co. of Connecticut</u> of <u>Hartford, Connecticut</u> have inspected the components described in this Owner's Report during the period <u>09/09/13</u> to <u>06/30/14</u> , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.	
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.	
Inspector's Signature <u>[Signature]</u>	Commissions <u>GA 938</u> National Board, State, Province and Endorsements
Date <u>30 June 2014</u>	

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13132

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/ Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, Winter 1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 24, 2014
Sheet 1 of 1
Unit 1
SNC 502685
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPING	PULLMAN POWER	N/A	N/A	1-1208-055-1	1987	CORRECTED	YES

7. Description of Work Removal and reinstallation of elbow to support MSIP

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] for mikel skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/12/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 25 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13133

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/Nuclear Safety Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, W1975
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
RELIEF VALVE	CROSBY VALVE & GAGE CO.	N67936-00-0006	N/A	1PSV11766	1984	REMOVED	YES
RELIEF VALVE	CROSBY VALVE & GAGE CO.	N67936-00-0004	N/A	1PSV11766	1984	INSTALLED	YES

- Description of Work Replaced Relief Valve 1PSV11766 S/N# N67936-00-0006 with S/N# 67936-00-0004 which is a rotating spare
- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F
- Remarks See Item 7
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE			
I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.			
Type Code Symbol Stamp	<u>N/A</u>		
Certificate of Authorization No.	<u>N/A</u>	Expiration Date	<u>N/A</u>
Signed	<u>for mikel Slinger</u> Superintendent	Date	<u>06/30/2014</u>
Owner or Owner's Designee, Title			

CERTIFICATE OF INSERVICE INSPECTION	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of <u>Georgia</u> and employed by <u>Hartford Steam Boiler Inspection and Insurance Co. of Connecticut</u> of <u>Hartford, Connecticut</u> have inspected the components described in this Owner's Report during the period <u>09/09/13</u> to <u>06/30/14</u> , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.	
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.	
Inspector's Signature	Commissions <u>GA 938</u> National Board, State, Province and Endorsements
Date <u>30 June 2014</u>	

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13134

1. Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name Plant Vogtle
Address
4. Identification of System 1202/Nuclear Safety Cooling Water
5. (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, W1975
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 30, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc. SNC 509842
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
RELIEF VALVE	CROSBY VALVE & GAGE CO.	N67951-00-0002	N/A	1PSV11744	1984	REMOVED	YES
RELIEF VALVE	CROSBY VALVE & GAGE CO.	N67951-00-0005	N/A	1PSV11744	1984	INSTALLED	YES

7. Description of Work Replaced Relief Valve 1PSV11744 S/N# N67951-00-002 with S/N# N67951-00-0005 which is a rotating spare

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Ferguson for Mike Skinner Superintendent Date 06/30/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/11/13 to 06/30/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
National Board, State, Province and Endorsements

Date 30 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13135

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1301/ Main Steam System
- (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, W 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 27, 2014
Sheet 1 of 1
Unit 1
SNC 376153
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	CROSBY	N56904-00-0017	N/A	1PSV8708B	1975	INSTALLED	YES
VALVE	CROSBY	N56904900037	N/A	1PSV8708B	1975	REMOVED	YES

7. Description of Work Removed N56904-00-0037 and replaced with N56904-00-0017

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed for m. kel skinner Superintendent Date 06/27/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/11/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938
National Board, State, Province and Endorsements

Date 28 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13136

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1202/Nuclear Safety Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, W1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-249-1

Date June 27, 2014
Sheet 1 of 1
Unit 1
SNC 376135
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
RELIEF VALVE	CROSBY VALVE & GAGE CO.	N56900-00-0025	N/A	1PSV8121	1977	REMOVED	YES
RELIEF VALVE	CROSBY VALVE & GAGE CO.	N56900-00-0049	N/A	1PSV8121	1977	INSTALLED	YES

7. Description of Work Replaced Relief Valve 1PSV8121 S/N# N56900-00-025 with S/N# 56900-00-0049 which is a rotating spare

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Ben Fay for Mike Skinner Superintendent Date 06/27/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/11/13 to 06/28/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions GA 938
National Board, State, Province and Endorsements

Date 28 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13137

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/ Main Steam System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June, 2014
Sheet 1 of 1
Unit 1
SNC 449470
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSNZ-96	N/A	1HV3006A	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Michael Thomas Superintendent Date 6/11/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/17/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13138

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/ Main Steam System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 17, 2014
Sheet 1 of 1
Unit 1
SNC 449477
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSOA-69	N/A	1HV3006B	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 6/19/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/17/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Inspector's Signature Commissions GA 938
National Board, State, Province and Endorsements
Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13139

1. Owner Southern Nuclear Operating Company Date June 19, 2014
40 Inverness Center Parkway, Birmingham, AL
 Address 1 of 1
2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830
 Address SNC 449473
 Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Maintenance Department Type Code Symbol Stamp N/A
Plant Vogtle Authorization No. N/A
 Address Expiration Date N/A
4. Identification of System 1301/ Main Steam System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s)

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSOA-26	N/A	1HV3016A	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mikel Skinner Superintendent Date 06/23/2014
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/17/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
 Inspector's Signature National Board, State, Province and Endorsements
 Date 23 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13140

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/ Main Steam System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 19, 2014
Sheet 1 of 1
Unit 1
SNC 449478
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PS0A-64	N/A	1HV3016B	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed for MIKE SKINNER Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 06/17/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 25 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13141

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1301/ Main Steam System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 18, 2014
Sheet 1 of 1
Unit 1
SNC 449474
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PS0A-100	N/A	1HV3026A	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Superintendent Date 6/18/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/17/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13142

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL

Date June 27, 2014

2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address

Sheet 1 of 1

Unit 1

SNC 449479

Repair/Replacement Organization P.O. No., Job No., etc.

3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address

Type Code Symbol Stamp N/A

Authorization No. N/A

Expiration Date N/A

4. Identification of System 1301/ Main Steam System

5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A

(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.

(c) Applicable Section XI Code Case(s)

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSOB-12	N/A	1HV3026B	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed for Mike Superintendent Date 06/30/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/17/13 to 07/01/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 01 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13143

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1301/ Main Steam System
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June, 2014
Sheet 1 of 1
Unit 1
SNC 449476
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSOB-46	N/A	1HV3036A	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Superintendent Date 6/18/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 09/17/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements

Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13144

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1301/ Main Steam System
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 19, 2014
Sheet 1 of 1
Unit 1
SNC 449481
Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSOC-18	N/A	1HV3036B	1979	CORRECTED	YES

7. Description of Work Replace valve gates

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed for Mikel Skinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 06/17/13 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 25 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13145 + 14062

1. Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name Plant Vogtle
Address
4. Identification of System 1201/ Reactor Coolant System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, Winter 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 30, 2014
Sheet 1 of 1
Unit 1
SNC 439152
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	CROSBY	N569464-00-0035	N/A	1PSV8010A	1977	CORRECTED	YES

7. Description of Work VT-3 of valve by Wyle Labs to ensure valve condition and rebuild requirements, rebuild included installation of Disc Insert and Nozzle.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks This also addresses Traveler 14062

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Emily F. Skinner Superintendent Date 06/30/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 01/24/14 to 07/01/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 01 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13146

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/ Reactor Coolant System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, Winter 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 30, 2014
Sheet 1 of 1
Unit 1
SNC 439152
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	CROSBY	N569464-00-0037	N/A	1PSV8010B	1977	CORRECTED	YES

7. Description of Work VT-3 of valve by Wyle Labs to ensure valve condition and rebuild requirements, no rebuild required.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Benjamin Skinner Superintendent Date 07/11/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 01/24/14 to 07/01/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 01 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13147

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1201/ Reactor Coolant System
- (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, Winter 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 30, 2014
Sheet 1 of 1
Unit 1
SNC 439152
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	CROSBY	N569464-00-0043	N/A	1PSV8010C	1977	CORRECTED	YES

7. Description of Work VT-3 of valve by Wyle Labs to ensure valve condition and rebuild requirements, no rebuild required.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 07/1/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 01/24/14 to 07/01/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions CA 938
Date 01 July 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13149

1. Owner Southern Nuclear Operating Company
 Name
40 Inverness Center Parkway, Birmingham, AL
 Address
 Sheet 1 of 1
2. Plant Vogtle Electric Generating Plant
 Name
Waynesboro, GA 30830
 Address
 Unit 1
SNC520021
 Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Maintenance Department
 Name
Plant Vogtle
 Address
 Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System 1201/ Reactor Coolant
5. (a) Applicable Construction Code ASME Sec III Edition, 1971 Addenda, Winter 1972 Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
 (c) Applicable Section XI Code Case(s)
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PUMP	WESTINGHOUSE ELECTRICAL CORP	10-9744D35G02	N/A	11201P6004	1987	CORRECTED	YES

7. Description of Work Replacement of the Number 2 Seal housing

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
 Other ☐ Pressure _____ psi Test Temp. _____ °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE	
I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.	
Type Code Symbol Stamp	<u>N/A</u>
Certificate of Authorization No.	<u>N/A</u>
Expiration Date	<u>N/A</u>
Signed <u>[Signature]</u> for <u>Michael Skinner</u> Superintendent	Date <u>06/25/2014</u>
Owner or Owner's Designee, Title	

CERTIFICATE OF INSERVICE INSPECTION	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of <u>Georgia</u> and employed by <u>Hartford Steam Boiler Inspection and Insurance Co. of Connecticut</u> of <u>Hartford, Connecticut</u> have inspected the components described in this Owner's Report during the period <u>12/02/13</u> to <u>06/26/14</u> , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.	
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.	
Inspector's Signature <u>[Signature]</u>	Commissions <u>GA 938</u>
Date <u>26 June 2014</u>	National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13150

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1201/ Reactor Coolant
- (a) Applicable Construction Code ASME Sec III Edition, 1971 Addenda, Winter 1972 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s)
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PUMP	WESTINGHOUSE ELECTRICAL CORP	3-9744D35G01	N/A	11201P6003	1987	CORRECTED	YES

- Description of Work Replacement of the Number 2 Seal housing

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed M. B. O'Sullivan Superintendent Date 6/17/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 12/04/13 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13151

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1201/ Reactor Coolant
- (a) Applicable Construction Code ASME Sec III Edition, 1971 Addenda, Winter 1972 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s)
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PUMP	WESTINGHOUSE ELECTRICAL CORP	2-9744D35G01	N/A	11201P6002	1987	CORRECTED	YES

- Description of Work Replacement of the Number 2 Seal housing

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mikel Skinner Superintendent Date 7/2/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 12/04/13 to 07/02/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 02 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 13152

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1201/ Reactor Coolant
- (a) Applicable Construction Code ASME Sec III Edition, 1971 Addenda, Winter 1972 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s)
- Identification Of Components

Date 4/14/2014
Sheet 1 of 1
Unit 1
SNC520018
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PUMP	WESTINGHOUSE ELECTRICAL CORP	1-9744D35G01	N/A	11201P6001	1987	CORRECTED	YES

7. Description of Work Replacement of the Number 2 Seal housing

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Superintendent Date 6/17/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 12/02/13 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14000

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1208/Chemical and Volume Control
- (a) Applicable Construction Code ASME Sec III Edition, 1974 Addenda, Winter 1975 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s)
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
CHECK VALVE	WESTINGHOUSE ELECTRICAL CORP	030081CS88000 00000S74-0017	N/A	11208U6035	1978	CORRECTED	YES

- Description of Work Replacement of the Valve Bonnet, Connection Studs and Nuts

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 07/08/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 02/07/14 to 07/08/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions GA938
National Board, State, Province and Endorsements

Date 08 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14001

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1208/Chemical and Volume Control
- (a) Applicable Construction Code ASME Sec III Edition, 1974 Addenda, Summer 1974 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s) 1553-1, 1649
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
CHECK VALVE	WESTINGHOUSE ELECTRICAL CORP	030081CS88000 00000S74-0018	N/A	11208U6036	1978	CORRECTED	YES

- Description of Work Replacement of the Valve Bonnet, Connection Studs and Nuts

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 07/17/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 02/07/14 to 07/09/14 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
Date 09 July 2014 National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14002

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1208/Chemical and Volume Control
- (a) Applicable Construction Code ASME Sec III Edition, 1974 Addenda, Summer 1974 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s) 1553-1, 1649
- Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
CHECK VALVE	WESTINGHOUSE ELECTRICAL CORP	030081CS88000 00000S74-0019	N/A	11208U6037	1978	CORRECTED	YES

- Description of Work Replacement of the Valve Bonnet, Connection Studs and Nuts

- Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

- Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Superintendent Date 07/17/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 02/07/14 to 07/09/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 09 July 2014 National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14003

1. Owner Southern Nuclear Operating Company Date June 24, 2014
Name 40 Inverness Center Parkway, Birmingham, AL Sheet 1 of 1
Address Waynesboro, GA 30830
2. Plant Vogtle Electric Generating Plant Unit 1
Name Waynesboro, GA 30830 SNC535950
Address Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Maintenance Department Type Code Symbol Stamp N/A
Name Plant Vogtle Authorization No. N/A
Address Expiration Date N/A
4. Identification of System 1208/Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec III Edition, 1974 Addenda, Summer 1974 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s) 1553-1, 1649

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
CHECK VALVE	WESTINGHOUSE ELECTRICAL CORP	030081CS88000 00000S74-0020	N/A	11208U6038	1978	CORRECTED	YES

7. Description of Work
- Replacement of the Valve Bonnet, Connection Studs and Nuts

8. Test Conducted: Hydrostatic
- ☐
- Pneumatic
- ☐
- Nominal Operating Pressure
- ☒
- Exempt
- ☐
-
- Other
- ☐
- Pressure _____ psi Test Temp. _____ °F

9. Remarks
- See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/ACertificate of Authorization No. N/A Expiration Date N/ASigned Ben Fy for Mr. R. Skinner Superintendent Date 06/24/2014
Owner or Owner's Designee, Title**CERTIFICATE OF INSERVICE INSPECTION**

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 02-07-14 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938
National Board, State, Province and EndorsementsDate 25 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14017

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1204/ Safety Injection
- (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 1975
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) N-30-1, 1539-1

Date July 2, 2014
Sheet 1 of 1
Unit 1
SNC 517437
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
CHECK VALVE	ROCKWELL	BG421	N/A	11204U4143	1983	REMOVED	YES
CHECK VALVE	ROCKWELL	88ABV	N/A	11204U4143	1989	INSTALLED	YES

7. Description of Work Replacement of check valve 1-1204-U4-143

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks This also addresses Traveler 13128

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mike S. [Signature] Superintendent Date 7/2/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/13/14 to 07/06/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions

GA 938
National Board, State, Province and Endorsements

Date 06 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14022

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date July 7, 14
Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
MWO # SNC 525873
Address
Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
4. Identification Of System 1204 / Safety Injection
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Winter 1975 Addenda, Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed, 2003 Add.
(c) Applicable Section XI Code Case(s) N/A
6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
CHECK VALVE	ROCKWELL INTERNATIONAL	BG422	N/A	1-1204-U4-146	1983	REMOVED	YES
CHECK VALVE	FLOWSERVE CORPORATION	76BKH	N/A	1-1204-U4-146	2008	INSTALLED	YES

7. Description Of Work Removed the Rockwell design valve and replaced with the Flowserve design reference ED C071759901

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mike Skinner Superintendent Date 07/7/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
National Board, State, Province and Endorsements
Date 08 July 2014 # 03/06/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14023

1. Owner Southern Nuclear Operating Company Date July 7, 14
40 Inverness Center Parkway, Birmingham, AL Sheet 1 Of 1
 Name
2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 MWO # SNC 517440
 Address Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance Plant Vogtle
 Name Address
4. Identification Of System 1204 / Safety Injection
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Winter 1975 Addenda, Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 Ed., 2003 Add.
 (c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
CHECK VALVE	ROCKWELL INTERNATIONAL	BG424	N/A	1-1204-U4-144	1983	REMOVED	YES
CHECK VALVE	FLOWERVE CORPORATION	75BKH	N/A	1-1204-U4-144	2008	INSTALLED	YES

7. Description Of Work Removed the Rockwell design valve and replaced with the Flowserve design reference ED C071759901

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
 Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben J. for Michael S. Skinner Superintendent Date 07/7/14
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
 National Board, State, Province and Endorsements

Date 08 July 2014 * 03/06/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14028

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec III Edition, 1974 Addenda, Winter 1975 Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001, 2003 Add
(c) Applicable Section XI Code Case(s)

Date June 25, 2014
Sheet 1 of 1
Unit 1
SNC555148
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	KREOTEST MANUFACTURING	ABR1-2	N/A	11208U4A11	1983	INSTALLED	YES

7. Description of Work Removed ABR1-4 and replaced with ABR1-2

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed [Signature] Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/03/14 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
Date 25 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14032

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date 06/23/14
Sheet 1 Of 1
- Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC551542
Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
- Identification Of System 1204 / Safety Injection System
- (a) Applicable Construction Code ASME SEC III 1977 Edition, Winter 1977 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A
- Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	18893	N/A	1-1204-031-H015	1987	INSTALLED	YES

7. Description Of Work Snubber PSA-1/2, serial #19923 was replaced with PSA-1/2, serial # 18893 to support surveillance testing.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Foy for Mike Skinner Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/10/14 to 06/27/14 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements

Date 27 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14033

1. Owner Southern Nuclear Operating Company
40 Inverness Center Parkway, Birmingham, AL
 Name _____
 Address _____
2. Plant Vogtle Electric Generating Plant
Waynesboro, GA 30830
 Name _____
 Address _____
3. Work Performed by Maintenance Department
 Name _____
Plant Vogtle
 Address _____
4. Identification of System 1201/ Reactor Coolant System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W 1977
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s) _____

Date June 23, 2014
 Sheet 1 of 1
 Unit 1
SNC 482235
 Repair/Replacement Organization P.O. No., Job No., etc.
 Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	958-GAE-RCESHS-01	N/A	N11201B6002R06	1987	CORRECTED	YES

7. Description of Work Replaced Compression Control Valve, Tension Control Valve and Test in Place Assemblies

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Em Fry for Mike Skinner Superintendent Date 06/23/2014
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/11/14 to 06/25/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
 Date 25 June 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14040

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date July 3, 14
Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC 376175
Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
4. Identification Of System 1301 / Main Steam
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Winter 1975 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
VALVE	ANCHOR/DARLING	E9001-7-2	N/A	1-1301-U4-008	1980	CORRECTED	YES

7. Description Of Work Replacement of studs and nuts for the 1-1301-U4-008 valve.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Mikel Skinner Superintendent Date 7/3/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/19/14 to 07/03/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements

Date 03 July 2014

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14041

Sheet 1 of 1

Repair/Replacement Organization P.O. No., Job No., etc.

Address

1208 / Chemical and Volume Control System

(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.

(c) Applicable Section XI Code Case(s) N/A

(c) Applicable Section XI Code Case(s) N/A

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	00614770/024	N/A	1-1208-011-H045	1987	INSTALLED	YES

Snubber Liseqa 301856RF2, serial #03615870/096 was replaced with a Liseqa 301856RF2, serial # 00614770/024 to support surveillance testing.

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A PSI Test Temp. N/A °F

Applicable Manufacturer's Data Reports to be attached

Signed *[Signature]* Superintendent Date 06/30/19
Owner or Owner's Designee, Title

Inspector's Signature _____ Commissions CA938
National Board, State, Province and Endorsements
Date 30 June 2014

~~ORIGINAL~~

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14051

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/ Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, Winter 1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
HEAT EXCHANGER	JOSEPH OAT CORPORATION	2322-4A	1055	1-1208-E6-003	2005	CORRECTED	YES

7. Description of Work Replacement of Studs and Nuts

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Fay for Mike Skinner Superintendent Date 07/9/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/23/14 to 07/09/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
Date 09 July 2014 National Board, State, Province and Endorsements

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14052

1. Owner Southern Nuclear Operating Company
40 Inverness Center Parkway, Birmingham, AL
 Name
 Address
2. Plant Vogtle Electric Generating Plant
Waynesboro, GA 30830
 Name
 Address
3. Work Performed by Maintenance Department
Plant Vogtle
 Name
 Address
4. Identification of System 1201/ Reactor Coolant System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 1975
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s) 1516-2, 1567

Date June 18, 2014
 Sheet 1 of 1
 Unit 1
SNC 481911
 Repair/Replacement Organization P.O. No., Job No., etc.

Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ANCHOR/DARLING	E9001-59-1	N/A	1HV5106	1982	CORRECTED	YES

7. Description of Work Replaced disk

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
 Certificate of Authorization No. N/A Expiration Date N/A
 Signed Michael Skomer Superintendent Date 06/18/2014
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/23/14 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
 National Board, State, Province and Endorsements

Date 23 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14057

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 562718
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	26762	N/A	11201029H027	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-3 S/N 28741 with PSA-3 S/N 26762

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed 3m for Mike Skinner Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/24/14 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements
Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14058

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 562719
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	25370	N/A	11201030H020	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-3 S/N 26939 with PSA-3 S/N 25370

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Superintendent Date 06/23/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/24/14 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Inspector's Signature Commissions GA 938
National Board, State, Province and Endorsements
Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14059

- Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name
Plant Vogtle
Address
- Identification of System 1201/Reactor Coolant
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 562720
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	24103	N/A	11201042H003	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-1 S/N 23206 with PSA-1 S/N 24103

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed For Mike SKinner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/24/14 to 06/23/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 23 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14060

- Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address Waynesboro, GA 30830
- Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address Waynesboro, GA 30830
- Work Performed by Maintenance Department
Name Plant Vogtle
Address Waynesboro, GA 30830
- Identification of System 1301/ Main Steam System
- (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, N/A
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 27, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc. SNC 449479
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
VALVE	ROCKWELL	PSOB-12	N/A	1HV3026B	1979	CORRECTED	YES

7. Description of Work Replace valve bonnet

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Ben Foy for M. S. L. Skinner Superintendent Date 06/30/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/25/14 to 07/01/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions GA 938
National Board, State, Province and Endorsements

Date 01 July 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14061

1. Owner Southern Nuclear Operating Company
 Name 40 Inverness Center Parkway, Birmingham, AL
 Address
 Date June 30, 2014
 Sheet 1 of 1
2. Plant Vogtle Electric Generating Plant
 Name Waynesboro, GA 30830
 Address
 Unit 1
 SNC 563018
 Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Maintenance Department
 Name
 Plant Vogtle
 Address
 Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A
4. Identification of System 1201/Reactor Coolant
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
 (c) Applicable Section XI Code Case(s) 1644-5

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	33481	N/A	11201051H001	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-1/4 S/N 35178 with PSA-1/4 S/N 33481
8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
 Other ☐ Pressure N/A psi Test Temp. N/A °F
9. Remarks See Item 7
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
 Certificate of Authorization No. N/A Expiration Date N/A
 Signed Bun Fey for m. k. Skinner Superintendent Date 06/30/14
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/25/14 to 06/30/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA938
 Inspector's Signature National Board, State, Province and Endorsements
 Date 30 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14063

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, W1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s) 1644-5

Date June 23, 2014
Sheet 1 of 1
Unit 1
SNC 563451
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PULLMAN POWER PRODUCTS	14072	N/A	11208042H046	1987	INSTALLED	YES

7. Description of Work Replace Snubber PSA-1/4 S/N 14077 with PSA-1/45 S/N 14072

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A

Signed Mr. Fy Brinkner Superintendent Date 06/23/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/27/14 to 06/24/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA938
National Board, State, Province and Endorsements
Date 24 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14064

- Owner Southern Nuclear Operating Company Date July 2, 2014
Name 40 Inverness Center Parkway, Birmingham, AL
Address Sheet 1 of 1
- Plant Vogtle Electric Generating Plant Unit 1
Name Waynesboro, GA 30830
Address SNC127040
Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Maintenance Department Type Code Symbol Stamp N/A
Name Plant Vogtle Authorization No. N/A
Address Expiration Date N/A
- Identification of System 1217/ Auxillary Component Cooling Water
- (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 1974
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
BUTTERFLY VALVE	FISHER CONTROLS	797330	N/A	1HV1974	1981	CORRECTED	YES

7. Description of Work Replacement of Studs and Nuts for Valve Body/Flange

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure _____ psi Test Temp. _____ °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Mike Siano Superintendent Date 7/3/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/27/14 to 07/06/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 06 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14065

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/ Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec. III Edition, 1974 Addenda, Summer 1975
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed, 2003 add.
(c) Applicable Section XI Code Case(s)

Date June 24, 2014
Sheet 1 of 1
Unit 1
SNC 555148
Repair/Replacement Organization P.O. No., Job No., etc.
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
STUD/ HEAVY HEX HEAD SCREW	MACKSON INCORPORATED	20209040	N/A	N/A	2014	INSTALLED	YES
NUT, HEAVY HEX	MACKSON INCORPORATED	C36068	N/A	N/A	2014	INSTALLED	YES

7. Description of Work Replace Studs and Nuts for Pipe Clamp 11208012H010

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Bonny for Mike Superintendent Date 06/25/2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 04/01/14 to 06/26/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 26 June 2014

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14070

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Date July 7, 14
Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant
Unit 1
Waynesboro, GA 30830
Address
MWO # SNC 523885
Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance
Name
Plant Vogtle
Address
4. Identification Of System 1201 / Reactor Coolant
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Summer 1974 Addenda, _____ Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 Ed., 2003 Add.
(c) Applicable Section XI Code Case(a) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
SHIM ON LOOP 1 LOWER LATERAL SUPPORT	WESTINGHOUSE	N/A	N/A	11201B6001R11	1986	CORRECTED	YES

7. Description Of Work Removed, machined and reinstalled shim plate due to MSIP

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A Expiration Date _____ N/A

Signed [Signature] for Mike Skinner Superintendent Date 07/08/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA 938
Inspector's Signature National Board, State, Province and Endorsements

Date 08 July 2014 * 03/28/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14071

- Owner Southern Nuclear Operating Company Date July 7, 14
Name
40 Inverness Center Parkway, Birmingham, AL Sheet 1 Of 1
- Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 MWO # SNC 523885
Address Repair/Replacement Organization P.O. No., Job No., etc.
- Work Performed by Nuclear Operations Maintenance Plant Vogtle
Name Address
- Identification Of System 1201 / Reactor Coolant
- (a) Applicable Construction Code ASME SEC III 1974 Edition, Summer 1974 Addenda, Code Case
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
(c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
SHIM ON LOOP 2 LOWER LATERAL SUPPORT	WESTINGHOUSE	N/A	N/A	11201B6002R11	1986	CORRECTED	YES

7. Description Of Work Removed, machined and reinstalled shim plate due to MSIP

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 07/08/14
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements

Date 08 July 2014

* 03/28/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14072

1. Owner Southern Nuclear Operating Company Date July 7, 14
40 Inverness Center Parkway, Birmingham, AL Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 MWO # SNC 523885
Address Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance Plant Vogtle
Name Address
4. Identification Of System 1201 / Reactor Coolant
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Summer 1974 Addenda, Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001Ed., 2003 Add.
 (c) Applicable Section XI Code Case(s) N/A
6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
SHIM ON LOOP 3 LOWER LATERAL SUPPORT	WESTINGHOUSE	N/A	N/A	11201B6003R11	1986	CORRECTED	YES

7. Description Of Work Removed, machined and reinstalled shim plate due to MSIP

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
 Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed for M. R. S. Superintendent Date 07/07/14
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/07/14 to 07/08/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
08 July 2014 National Board, State, Province and Endorsements
* 03/28/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14073

1. Owner Southern Nuclear Operating Company Date July 7, 14
40 Inverness Center Parkway, Birmingham, AL Sheet 1 Of 1
2. Plant Vogtle Electric Generating Plant Unit 1
Waynesboro, GA 30830 MWO # SNC 523885
Address Repair/Replacement Organization P.O. No., Job No., etc.
3. Work Performed by Nuclear Operations Maintenance Plant Vogtle
Name Address
4. Identification Of System 1201 / Reactor Coolant
5. (a) Applicable Construction Code ASME SEC III 1974 Edition, Summer 1974 Addenda, Code Case
 (b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 Ed., 2003 Add.
 (c) Applicable Section XI Code Case(s) N/A

6. Identification Of Components

NAME OF COMPONENT	NAME OF MANUFACTURER	MANUFACTURER SERIAL NO.	NATIONAL BOARD NO.	OTHER IDENTIFICATION	YEAR BUILT	CORRECTED, REMOVED, OR INSTALLED	ASME CODE STAMPED (YES OR NO)
SHIM ON LOOP 4 LOWER LATERAL SUPPORT	WESTINGHOUSE	N/A	N/A	11201B6004R11	1986	CORRECTED	YES

7. Description Of Work Removed, machined and reinstalled shim plate due to MSIP

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒ Exempt ☐
 Other ☐ Pressure N/A PSI Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] for Mike Kennedy Date 07/08/14
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the national Board of boiler and Pressure vessel inspectors and the State or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 07/08/14 to 07/08/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions GA938
Inspector's Signature National Board, State, Province and Endorsements
 Date 08 July 2014 * 03/28/14

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14074*

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1208/ Chemical and Volume Control
5. (a) Applicable Construction Code ASME Sec. III Edition, 1977 Addenda, Winter 1977
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
FILTER VESSEL	VACCO	N-2529	N/A	1-1208-F4-004	1983	REMOVED	YES
FILTER VESSEL	ENERGY STEEL & SUPPLY CO	NFAB40415-4	N/A	1-1208-F4-004	2014	INSTALLED	YES
HEX NUT	DUBOSE NATIONAL ENERGY	9PJ1	N/A	N/A	2014	INSTALLED	YES
STUD	ENERGY STEEL & SUPPLY CO	153384	N/A	N/A	2014	INSTALLED	YES
3" ELBOW	CONSOLIDATED POWER	NNDI-1	N/A	N/A	2014	INSTALLED	YES
3" PIPE	CONSOLIDATED POWER	E42640	N/A	N/A	2013	INSTALLED	YES
2" ELBOW	TAYLOR FORGE STAINLESS	NMOZ-1	N/A	N/A	2013	INSTALLED	YES
2" PIPE	CONSOLIDATED POWER	96340	N/A	N/A	2013	INSTALLED	YES

7. Description of Work Replace Back washable filter vessel with replaceable filter assembly per DCP SNC517148

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks This NIS-2 also covers Travelers 14004, 14005, 14006 and 14007 which cover the fabrication and installation welding
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed for MRS. J. K. Skinner Superintendent
Owner or Owner's Designee, Title

Date 07/1/2014

ORIGINAL

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 02/27/14 to 07/06/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


Inspector's Signature

Commissions GA938
National Board, State, Province and Endorsements

Date 06 July 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14078

- Owner Southern Nuclear Operating Company
Name 40 Inverness Center Parkway, Birmingham, AL
Address
- Plant Vogtle Electric Generating Plant
Name Waynesboro, GA 30830
Address
- Work Performed by Maintenance Department
Name Plant Vogtle
Address
- Identification of System 1201/ Reactor Coolant System
- (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, Summer 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)

Date April 14, 2014
Sheet 1 of 1
Unit 1
Repair/Replacement Organization P.O. No., Job No., etc. SNC 471528
Type Code Symbol Stamp N/A
Authorization No. N/A
Expiration Date N/A

6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
STUD	ENERGY STEEL & SUPPLY CO.	NF11201806	N/A	N/A	2013	INSTALLED	YES

7. Description of Work Replace Man-Way Stud 2H12 on Steam Generator #2

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] WIKEL SKINNER Date 06/27/14
Owner or Owner's Designee, Title Superintendent

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/31/14 to 06/27/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA-938
Date 27 June 2014 National Board, State, Province and Endorsements

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14079

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/ Reactor Coolant System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, Summer 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
STUD	ENERGY STEEL & SUPPLY CO.	NF11201805	N/A	N/A	2013	INSTALLED	YES

7. Description of Work Replace Man-Way Stud 4C5 on Steam Generator #4

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp N/A
Certificate of Authorization No. N/A Expiration Date N/A
Signed Michael Skinner Superintendent Date 6-17-2014
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of Georgia and employed by Hartford Steam Boiler Inspection and Insurance Co. of Connecticut of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 03/31/14 to 06/26/14, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions GA 938
National Board, State, Province and Endorsements
Date 26 June 2014

ORIGINAL

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required By The Provisions Of The ASME Code Section XI

Traveler # 14081

1. Owner Southern Nuclear Operating Company
Name
40 Inverness Center Parkway, Birmingham, AL
Address
2. Plant Vogtle Electric Generating Plant
Name
Waynesboro, GA 30830
Address
3. Work Performed by Maintenance Department
Name
Plant Vogtle
Address
4. Identification of System 1201/ Reactor Coolant System
5. (a) Applicable Construction Code ASME Sec. III Edition, 1971 Addenda, Summer 1972
(b) Applicable Edition of Section XI Used for Repair/Replacement Activity 2001 ed. 2003 add.
(c) Applicable Section XI Code Case(s)
6. Identification Of Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Corrected, Removed, or Installed	ASME Code Stamped (Yes or No)
STEAM GENERATOR	WESTINGHOUSE ELECTRIC CORP.	GAGT 1884	N/A	1-1201-B6-004	1981	CORRECTED	YES

7. Description of Work Installed 10 Mechanical Tube Plugs on Steam Generator #4

8. Test Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐ Exempt ☒
Other ☐ Pressure N/A psi Test Temp. N/A °F

9. Remarks See Item 7

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE			
I certify that the statements made in the report are correct and that this conforms to the requirements of the ASME Code, Section XI.			
Type Code Symbol Stamp	<u>N/A</u>		
Certificate of Authorization No.	<u>N/A</u>	Expiration Date	<u>N/A</u>
Signed <u>Michael J. Shiner</u>	Superintendent	Date	<u>7/1/14</u>
Owner or Owner's Designee, R/R			

CERTIFICATE OF INSERVICE INSPECTION	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or Province of <u>Georgia</u> and employed by <u>Hartford Steam Boiler Inspection and Insurance Co. of Connecticut</u> of <u>Hartford, Connecticut</u> have inspected the components described in this Owner's Report during the period <u>04/01/14</u> to <u>07/06/14</u> , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.	
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.	
Inspector's Signature <u>[Signature]</u>	Commissions <u>GA938</u> National Board, State, Province and Endorsements
Date <u>06 July 2014</u>	