	Exelon Nuclear				
Jo	Job Performance Measure				
	Letdown Orifice Operation				
	JPM Number: <u>CRa (N-63)</u>				
	Revision Number: <u>10</u>				
	Date: <u>1/24/2013</u>				
Revised By:	Robert Peterson	<u>3/18/2014</u> Date			
Validated By:	Pat Comerford Operations Dept.	<u>4/7/2014</u> Date			
Approved By:	Brian Lewin Operations Representative	<u>4/7/2014</u> Date			

-

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE:</u> All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See 1. Task description and number, JPM description and number are identified. 2. Knowledge and Abilities (K/A) references are included. File Copy 3. Performance location specified. (in-plant, control room, simulator, or other) 4. Initial setup conditions are identified. 5. Initiating cue (and terminating cue if required) are properly identified. 6. Task standards identified and verified by SME review. 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). Verify the procedure(s) referenced by this JPM reflects the current revision: 8. Procedure BOP CV-9 Rev: 08 Procedure Rev: Verify cues both verbal and visual are free of conflict. 9. 10. Verify performance time is accurate 11. If the JPM cannot be performed as written with proper responses, then revise the JPM. 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below: Bill Hochstetter (Signature on file) 1/24/13 SME / Instructor Date Robert F. Peterson 3/18/2014 SME / Instructor Date

Revision Record (Summary)

Revision 10

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 03/03/13 by Bill Hochstetter and Rob Lawlor.
- Created from JPM No. N-63

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.
- 2. Line up letdown via BOP CV-9 so that 75 gpm is established. (In IC-100)
- 3. Turn on a set of Pzr BU heaters. (In IC-100)
- 4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 5. This completes the setup for this JPM.

- 1. You are the Unit 1 NSO.
- 2. Letdown flow is currently 75 gpm

INITIATING CUE

- 1. You have been directed to raise letdown flow to 120 gallons per minute and then restore systems to automatic in accordance with BOP CV-9, "Letdown Orifice Isolation", step 2.
- 2. Inform the US when complete.
- 3. Another NSO will respond to ALL other Control Room annunciators and conditions.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

Task Standard: PERFORM lineups of the CVCS

UNSAT requires written comments on respective step.

* Denotes critical steps: 3, 5 & 6

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME:

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. Refer to BOP CV-9, Letdown Orifice Operation	o OPEN BOP CV-9, step F.2			
Cue: All prerequisites are met	NOTE			
	NOTE			
Provide the examine	ee with a copy of the BOP CV-9			
The evaluator may judge the candidate candidates' competency b • 1-9-B1 LF • 1-9-A1 REC • 1-9-E • 1-9-D3 • 1-7-B2 RCF	e by correctly performing the critica by NOT receiving the following alar P LTDWN REL TEMP HIGH GEN HX LTDWN TEMP HIGH 22 LTDWN TEMP HIGH CHG LINE FLOW HI LOW P SEAL WTR INJ FLOW LOW	al steps ms:	, and t	he
2. Adjust 1CV121 in MANUAL to compensate for additional letdown flow	 At 1PM05J: 1) Place 1CV121 in Manual 2) Raise charging flow to about 132 gpm using the raise pushbutton as indicated on 1FI-121A 			
*3. Place 1PCV-CV131 to manual and lower letdown pressure to ~180 psig.	At 1PM05J: • PLACE 1CV131 in MANUAL AND • LOWER letdown pressure to ~180 psig by raising output on 1PK-131			
	NOTE			
The examinee may decide tha	t step 4 is NOT required and go	to step	5.	

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
4. If required, ADJUST 1CC130A/B, as necessary	At 1PM05J: • Place 1TK-130 in MANUAL AND • RAISE Output			
 *5. Raise letdown flow from 75 gpm to 120 gpm letdown <i>NOTE to Evaluator:</i> Evaluate the alarms that annunciate to determine competency of manual operations of controls in previous 3 steps 	 At 1PM05J: SIMULTANEOUSLY OPEN 1CV8149A AND SIMULTANEOUSLY ADJUST PCV-1CV131 to maintain pressure ~370 psig 			
*6. Restore 1PCV-CV131 to AUTO	At 1PM05J:PLACE 1CV131 in AUTO			
If examinee manipulated 1CC130A/B ir step 7. If the valve was not manipula	<u>NOTE</u> n manual to control letdown tem ated and temperature is normal, bypassed.	peratu step 7	ire per ' may l	form De
 Ensure 1CC130A/B is maintaining normal letdown temperature of about120 °F. 	 At 1PM05J: Check letdown temp. normal on 1TI-130 Place 1TK-130 in AUTO 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 Adjust 1CV121, in manual to match charging and letdown flow while establishing PZR at program level. Cue: This JPM is completed. 	 At 1PM05J: Adjust 1CV121 in Manual Verify charging flow is about 12 gpm greater than letdown flow and PZR level is trending to program. Place 1FK-121 in AUTO Informs US that 120 gpm letdown flow is in service (and system is restored to automatic). 			

RECORD STOP TIME:

JPM SUMM	ARY		
Operator's Name:	Job Title:	□ RC	□SRO
JPM Title: <u>Letdown Orifice Operation</u> JPM Number: <u>CRa (N-63)</u> Revision Task Number and Title: <u>4C.CV-01 PERFORM II</u> K/A Number and Importance: <u>004A4.06 3.6/3.</u> <i>Ability to manually operator and/or monitor in the co control valves</i> Suggested Testing Environment: <u>Simulator</u> Alternate Path: □Yes ⊠No SRO Only: □Yes	n Number: <u>00</u> ineups of the C\ <u>1</u> ontrol room: Let	<u>/CS</u> down isola ne Critical:	tion and flow □Yes ⊠No
BOP CV-9 Rev. 8 Letdown Orifice Operation			
Actual Testing Environment:	Control Room	🗆 In-Pla	int 🗆 Other
Testing Method: □ Simulate ⊠ Perform			
Estimated Time to Complete: 15 minutes	Actual Time U	sed:	minutes
EVALUATION SUMMARY: Were all the Critical Elements performed satisfacto	rily? □Ye	es	_ No
The operator's performance was evaluated against contained within this JPM and has been determined	standards d to be: □Sa	atisfactory	Unsatisfactory
Comments:			
Evaluator's Name:	(I	Print)	
Evaluator's Signature:	Da	ite:	

- 1. You are the Unit 1 NSO.
- 2. Letdown flow is currently 75 gpm.

INITIATING CUE

- 1. You have been directed to raise letdown flow to 120 gallons per minute and then restore systems to automatic in accordance with BOP CV-9, "Letdown Orifice Isolation", step 2.
- 2. Inform the US when complete.
- 3. Another NSO will respond to ALL other Control Room annunciators and conditions.

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

S	1.	Task description and number, JPM description and number are iden	tified.
ee e	2.	Knowledge and Abilities (K/A) references are included.	
Ē	3.	Performance location specified. (in-plant, control room, simulator, or	other)
e O	4.	Initial setup conditions are identified.	
òp	5.	Initiating cue (and terminating cue if required) are properly identified	
Ś	6.	Task standards identified and verified by SME review.	
	7.	Critical steps meet the criteria for critical steps and are identified with asterisk (*).	h an
	8.	Verify the procedure(s) referenced by this JPM reflects the current reflected by this JPM reflects the current reflected to the current reflected	evision:
	9.	Verify cues both verbal and visual are free of conflict.	
	10.	 Verify performance time is accurate 	
	11.	. If the JPM cannot be performed as written with proper responses, th revise the JPM.	ien
	12.	 When JPM is initially validated, sign and date JPM cover page. Sub validations, sign and date below: 	osequent
	Lynn	In Sanders / Brian Clark 9/24/09	
	-	SME / Instructor Date	
	<u>Robe</u>	bert F. Peterson 3/18/2014	
		SME / Instructor Date	

SME / Instructor

Date

Revision Record (Summary)

Revision 3

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Changed Non Licensed Operator to Equipment Operator

SIMULATOR SETUP INSTRUCTIONS

1) Reset to IC-101 (from IC-11) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2) Lower 1B SI Accumulator pressure to 600 psig. (In IC-101)

(NOTE: if using a caep, the quotation marks must be straight (plain text) quotes, not "curly quotes" like Word uses.)

- a) trgset 3 "ZLO1SI8875B(2).gt.0"
- b) trg 3 "ior ZDI1SI8875B open"
- c) irf nt78 on
- 3) Put TR 57 on screen 2.
- 4) During performance of this JPM, standby to MRF NT78 OFF at Evaluator's direction if required.
- 5) When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
- 6) This completes the setup for this JPM.

- 1. You are the unit NSO.
- 2. The unit is in Mode 1 steady state power.
- 3. An improper valve lineup resulted in reducing the 1B SI Accumulator pressure to 600 psig.
- 4. The improper valve lineup has been corrected.
- 5. 1BOL 5.1, Accumulators LCOAR, has been initiated.
- 6. Annunciator 1-5-B2, ACCUM 1B PRESS HIGH LOW, is LIT.

INITIATING CUE

The Unit Supervisor directs you to restore the 1B SI Accumulator pressure to within the Technical Specification limits.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

Task Standard: ADJUST SI accumulator pressure.

UNSAT requires written comments on respective step.

* Denotes critical steps: 2, 4, 6 & 9

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME:

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 Refer to BOP SI-8, Increasing SI Accumulator Pressure 	 LOCATE and OPEN BOP SI-8 			
Cue: All prerequisites have been met				
Cue: (if asked) There are no personnel in CNMT				
*2. Align nitrogen tube trailer	DIRECT EO to OPEN:			
<i>Cue: EO reports the Nitrogen Tube Trailer Manifold Discharge Valve is OPEN</i>	 Nitrogen Tube Trailer Manifold Discharge Valve 			
Cue: EO reports 0NT078 is OPEN	• 0NT078			
Ev The following s	valuator's Note: steps are located at 1PM06J.			
 VERIFY/CLOSE 1SI943, Accumulator vent control valve 	° VERIFY/CLOSE 1SI943			
Cue: 1SI943 POT is set at 0.0				
*4. OPEN 1SI8880, Nitrogen supply isolation valve	• OPEN 1SI8880			
5. Initiate 1BOL 5.1	° INITIATE 1BOL 5.1			
Cue: 1BOL 5.1 has been initiated				
*6. OPEN 1SI8875B, 1B Accumulator Vent valve	Start raising accumulator pressure: • OPEN 1SI8875B			
7. Monitor pressure increase	 Monitor pressure using 1PI-962 & 963 			
Ev Alternate path is	valuator's Note: initiated in the following step.			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 8. CLOSE 1SI8875B, 1B Accumulator Vent valve when accumulator pressure is between 602 and 647 psig. Cue: Unit Supervisor acknowledges that 1SI8875B has failed to close 	 Stop raising accumulator pressure Attempt to CLOSE 1SI8875B when accumulator pressure is between 602 and 647 psig Inform US of 1SI8875B failure to close 			
1BOL 5.1 is not exi IF the candidate instructs the E (ie, befor direct the Booth	ted because 1CV8875B is open. O to close 0NT078 to stop the p they close 1SI8880), Operator to: MRF NT78 OFF.	ressur	e rise	
 *9. CLOSE a nitrogen supply isolation valve Evaluator Note: Closing <u>either</u> of these valves satisfies the critical task. It is expected the operator will close both. 	 Close valve(s) to stop pressure rise 1SI8880 on 1PM06J 0NT078 at tube trailer by EO 			
 10. Isolate nitrogen tube trailer (<i>if not already done</i>) Cue: EO reports 0NT078 is CLOSED Cue: EO reports the Nitrogen Tube Trailer Manifold Discharge Valve is CLOSED 	 DIRECT EO to CLOSE: 0NT078 Nitrogen Tube Trailer Manifold Discharge Valve 			
Ev IF Alarm 1-5-B2 reflashes due to hig asks The Unit Supervisor directs you to r	valuator's Note: gh accumulator pressure (>647 # for direction, CUE: maintain accumulator pressure v limits.	‡), and within	candio Tech S	date Spec

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Contingency step ONLY if Alarm 1- 5-B2 is present and 1B Accumulator pressure is >647#, otherwise N/A.				
11. OPEN 1SI943, Accumulator vent control valve until Alarm 1-5-B5 clears, then reclose 1SI943.	• Alarm 1-5-B5 is NOT LIT.			
Cue: This JPM is completed				

RECORD STOP TIME:

JPM SUMMARY

Operator's Name:	Job Title: □ EO □ RO □ SRO □ FS
JPM Title: <u>Raise SI Accumulator Pressure (1SI88758</u> JPM Number: <u>CRb (N-3a)</u> Revision Task Number and Title: 4C.SI-04 ADJUST SI accum	<u>B fails to close)</u> Number: <u>3</u> nulator pressure.
K/A Number and Importance: <u>006A4.02 4.0/3.8</u> <i>Ability to manually operate and/or monitor in the con</i> Suggested Testing Environment: <u>Simulator</u> Alternate Path: ⊠Yes □No SRO Only: □Yes Reference(s): BOP SI-8, Increasing SI Accumulator Pressure (Rev BAR 1-5-B2, ACCUM 1B PRESS HIGH LOW (Rev. Tech Spec 3.5.1	ntrol room: valves. ⊠No Time Critical: ⊡Yes ⊠No v. 15) 1)
CRITICAL STEPS (*) 2, 4, 6 & 9	Control Doom In Plant In Other
Testing Method: □ Simulate ⊠ Perform	
Estimated Time to Complete: 8 minutes	Actual Time Used: minutes
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactori	ly? □Yes □No
The operator's performance was evaluated against s contained within this JPM and has been determined	standards to be: □ Satisfactory □ Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature	Date:

- 1. You are the unit NSO.
- 2. The unit is in Mode 1 steady state power.
- 3. An improper valve lineup resulted in reducing the 1B SI Accumulator pressure to 600 psig.
- 4. The improper valve lineup has been corrected.
- 5. 1BOL 5.1, Accumulators LCOAR, has been initiated.
- 6. Annunciator 1-5-B2, ACCUM 1B PRESS HIGH LOW, is LIT.

INITIATING CUE

The Unit Supervisor directs you to restore the 1B SI Accumulator pressure to within the Technical Specification limits.

Exelon Nuclear				
Job Performance Measure				
Synchronize DG to Bus (Will Not Load)				
JPM Number: <u>CRc (N-19a)</u>				
Revision Number: 00				
Date: <u>1/24/2013</u>				
Revised By: <u>Bill Hochstetter</u> <u>1/24/13</u>				
Validated By: <u>Pat Comerford</u> <u>4/7/2014</u>				
Operations Dept. Date				
Approved By: Brian Lewin 4/7/2014				

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- 1. Task description and number, JPM description and number are identified.
- 2. Knowledge and Abilities (K/A) references are included.
- File Copy 3. Performance location specified. (in-plant, control room, simulator, or other)
 - Initial setup conditions are identified. 4.
 - 5. Initiating cue (and terminating cue if required) are properly identified.
 - 6. Task standards identified and verified by SME review.
 - Critical steps meet the criteria for critical steps and are identified with an 7. asterisk (*).
 - 8. Verify the procedure(s) referenced by this JPM reflects the current revision: Rev: <u>25</u> Procedure BOP DG-11 Procedure Rev:
 - Verify cues both verbal and visual are free of conflict. 9.
 - 10. Verify performance time is accurate
 - 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson	<u>3/18/2014</u>
SME / Instructor	Date

SME / Instructor

Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.
- 2. Override DG governor speed adjuster by: (In IC-100)
 - trgset 3 "zlo1hsdg026(3)>0"
 - Set trg 3 to neutral position (between Raise and Lower) of dialog box for "zdi1hsdg019"
- 3. Start 1A DG for loading per BOP DG-11, step F.1. (In IC-100)
 - Clear the local trouble alarm by MRF EG06 RESET.
- 4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
- 5. This completes the setup for this JPM

- 1. You are an extra NSO.
- 2. The unit's ESF busses are being supplied by the SATs.
- 3. The 1A Diesel Generator has been running unloaded for approximately fifteen minutes after a manual start.
- 4. Jacket water and lube oil temperatures are acceptable for loading the diesel generator.
- 5. BOP DG-11 steps F.1 through F.4 have been completed as indicated.

INITIATING CUE:

The Unit Supervisor directs you to parallel and load the 1A Diesel Generator to 5400 KW per step F.5 of BOP DG-11, "Diesel Generator Startup".

Fill in the JPM Start Time when the student acknowledges the Initiating Cue. Information For Evaluator's Use:

Task Standard: Load The Diesel Generator

UNSAT requires written comments on respective step.

- * Denotes critical steps: 6, 7, 8, 9, & 11
- Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.
- Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 Refer to BOP DG-11, Diesel Generator Startup 	LOCATE and OPEN BOP DG-11, step F.5			
Cue: All prerequisites have been met				
Cue: (If asked) The 1A DG was started per step F.1				
Cue: (If asked) The 1A DG was started fifteen minutes ago				
Note: Provide the examinee a copy of BOP DG-11 and BOP DG- 11T1.				
 Notify Electric Operations of pending diesel generator parallel operation, estimated run time, and loading 				
Cue: Electric Operations has been informed	Notify Electric Operations			
 Auto Re-close Circuit Arm Selector Switch 	At 1PM01J: • PLACE Auto Re-close Circuit Arm Selector Switch to SURV TEST			
4. Verify DG operating properly	At 1PM01J, CHECK: DG frequency DG voltage			
5. Verify the same voltage across each phase.	At 1PM01J, CHECK: • DG phase voltages			

ELEMENT	STANDARD	SAT	UNSAT	Comment Number
*6. Turn on the 1A DG Feed to 141 Sync Selector switch.	 At 1PM01J: TURN Sync Selector switch for DG 1A Feed to 4KV Bus 141 to ON 			
*7. Adjust the incoming voltage.	 At 1PM01J: ADJUST incoming voltage SLIGHTLY HIGHER than running voltage using DG 1A Volt Adj control 			
*8. Adjust 1A DG speed.	 At 1PM01J: Adjust speed so synchroscope rotates SLOWLY in FAST DIRECTION using DG 1A Gov Adj control 			
*9. Synchronize the DG <i>Cue: (If requested) NLO is locally</i> <i>monitoring temperatures per</i> <i>notes in BOP</i>	 At 1PM01J: PLACE control switch for ACB 1413 to CLOSE when synchroscope is slightly before 12 o'clock 			
10. Verify the synchroscope is locked in.	At 1PM01J: • VERIFY synchroscope "locks in" at 12 o'clock			
 *11. Immediately load the 1A DG to 1000 KW. Note: The governor adjust switch is failed such that the diesel generator will NOT load. 	 At 1PM01J: IMMEDIATELY load DG to 1000 KW by going to RAISE on Gov Adj Control OPEN output breaker (Based on NOTE prior to step that closes 1413) 			

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 12. Notify the US of the unsuccessful loading of the diesel <i>Cue: The Unit Supervisor</i> acknowledges the failure and will initiate an WR for maintenance to investigate. 	 NOTIFY Unit Supervisor of the unsuccessful loading of the diesel 			
Cue: This JPM is completed.				

RECORD STOP TIME:

JPM SUMMARY
Operator's Name: Job Title:
JPM Title: <u>Synchronize D/G to Bus (Will Not load)</u>
JPM Number: <u>CR-c (N-63)</u> Revision Number: <u>00</u>
Task Number and Title: 4C.DG-02 Load The Diesel Generator
K/A Number and Importance: 064A2.09 3.1/3.3
Ability to (a) predict the impacts of the following malfunctions or operations on the ED/G system; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Synchronization of the ED/G with other electric power supplies.
Suggested Testing Environment: <u>Simulator</u>
Alternate Path: ⊠Yes □No SRO Only: □Yes ⊠No Time Critical: □Yes ⊠No
Reference(s): BOP DG-11 Rev. 25
CRITICAL STEPS (*) 6, 7, 8, 9, & 11
Actual Testing Environment: Simulator Control Room In-Plant Other
Testing Method: 🗌 Simulate 🛛 Perform
Estimated Time to Complete: <u>15</u> minutes Actual Time Used: minutes
EVALUATION SUMMARY:
Were all the Critical Elements performed satisfactorily? Yes No
The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory
Comments:
Evaluator's Name: (Print)
Evaluator's Signature: Date:

- 1. You are an extra NSO.
- 2. The unit's ESF busses are being supplied by the SATs.
- 3. The 1A Diesel Generator has been running unloaded for approximately fifteen minutes after a manual start.
- 4. Jacket water and lube oil temperatures are acceptable for loading the diesel generator.
- 5. BOP DG-11 steps F.1 through F.4 have been completed as indicated.

INITIATING CUE:

The Unit Supervisor directs you to parallel and load the 1A Diesel Generator to 5400 KW per step F.5 of BOP DG-1111, "Diesel Generator Startup".



JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- File Copy 1. Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
 - 3. Performance location specified. (in-plant, control room, simulator, or other)
 - 4. Initial setup conditions are identified.
 - 5. Initiating cue (and terminating cue if required) are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure(s) referenced by this JPM reflects the current revision: 8. Procedure BOP FW-1 Rev: 18 Procedure Rev:
 - 9. Verify cues both verbal and visual are free of conflict.
 - 10. Verify performance time is accurate
 - 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

3/18/2014

SME / Instructor

Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

- 2. Ensure MW OUT is selected.
- 3. Start the 4th CD/CB pump and 1A MFP. Take 1C MFP off line and reset trip when it has stopped. Open 1FW0012C recirc valve. (In IC-100)
- 4. Set up triggers for alarms and action as shown: (In IC-100)

TRGSET 7 "zao1sifwtsc.gt.0.22" (TRUE when speed is greater than 1430 RPM) TRGSET 8 "zao1sifwtsc.gt.0.22" TRGSET 9 "zao1sifwtsc.gt.0.22" TRGSET 10 "zao1sifwtsc.gt.0.22" TRG 7: IMF PN1164 ON (1C TDFP High Vibration alarm) TRG 8: SET YCY2903_1O=1 (Allows PPC parameter to be set) TRG 9: SET YCY2903_1V=8 (PPC shows 8 MILS vibration on 1C TDFP Brg 2) TRG 10: IMF FW02B 300 (Trips the 1C TDFP after 5 minutes)

- 5. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 6. This completes the setup for this JPM.

- 1. You are the Unit NSO.
- 2. The unit is at 75% power.
- 3. 1A and 1B FW pumps are online.
- 4. The 4th CD/CD pump was started in preparation for this pumps swap.
- 5. The 1C FW pump is NOT running.

INITIATING CUES

- 1. The US directs you to place the 1C FW pump on line and take 1A FW pump off line.
- 2. BOP FW-1, "STARTUP AND SWAPPING OF TURBINE DRIVEN FW PUMPS", has been completed through step 3.e, inclusive, of the main body. The trip test and reset of steps 3.d and 3.e were completed successfully.

Information For Evaluator's Use:

Task Standard: <u>Startup/shutdown a Main Feedwater Pump at Power</u>

UNSAT requires written comments on respective step.

- * Denotes critical steps: 2, 3, 5 & 7
- Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.
- Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
		NOTE				
The examinee may want to trend bearing temperatures on the computer per the limitations and actions section of the procedure. TR-34 is snapped into NSO screen 1 on the desk, facing 1PM07J.						
1.	Refer to BOP FW-1, Startup and Swapping of a Turbine Driven Main Feedwater Pump	OPEN BOP FW-1, step F.3.f.				
Provide copy of BOP FW-1 placekept through step F.3.e.						
Cue:	All Prerequisites have been met					
*2.	Open LP stop valve	At 1PM04J:				
		 DEPRESS and HOLD LP stop valve open pushbutton until backlit 				
*3.	Open HP stop valve	At 1PM04J:				
		 DEPRESS and HOLD HP stop valve open pushbutton until backlit 				
4.	Ensure manual speed control	At 1PM04J:				
		ENSURE speed setter control indicating light is lit				
	ELEMENT STANDARD			UNSAT	Comment Number	
---	---	--	-------------------	-----------	-------------------	--
 *5. Increase speed and maintain for at least 15 minutes. At 1PM04J: DEPRESS increase speed pushbutton to bring turbine to between 1500 and 2000 RPM. HOLD speed for at least 15 minutes for warmup. NOTE: This begins the Alternate Path. 						
En TR TR TR TR	Allows RG 7: IMF PN1164 ON (1C TDFP H RG 8: SET YCY2903_1O=1 (Allows RG 9: SET YCY2903_1V=8 (PPC s RG 10: IMF FW02B 300 (Trips 1C	in order listed. (Triggers are in High Vibration) s next parameter to be set) hows 8 MILS vibration on 1C TD IDFP after 5 minutes)	IC-100)FP Brç) g 2)		
6. Cue: Cue:	Respond to alarm FW PUMP TURB VIB (1-16-A4) <i>Unit 2 Assist NSO reports</i> <i>1VT-FW040 on 1PM12J: 1C</i> <i>TDFP #2 bearing vibration</i> <i>reads 8 MILs</i> <i>EO reports 1C TDFP is</i> <i>vibrating badly</i>	 At 1PM12J, CHECK: BAR 1-16-A4 FW pump 1C vibration (1VT-FW040 is not modeled on the simulator) Contact EO at 1C TDFP for vibration report 				

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
*7. Trip 1C TDFP	 Limitation E.2: Immediately trip FW pump 1C if excessive vibration of 5 MILS is detected. At 1PM04J: PRESS Turbine Trip Pushbutton Verify Turbine Trip Alarm and backlight ILLUMINATE. 				
Evaluator Note: If Candidate does NOT trip the 1C TDFP within 5 minutes of receiving the report of high vibration, MF FW02B will automatically insert to trip the 1C TDFP. In the event the TDFP automatically trips because the candidate failed to take action, Critical Step #7 was not met. Cue: EO reports he tripped the 1C TDFP locally because of high vibration.					
Cue: <u>This JPM is completed</u>					

RECORD STOP TIME:

JPM SUMMARY

Operator's Name:	Job Title:		∃SRO
JPM Title: Swap a Turbine Driven Feedwater Pump	(High Vibratior	<u>ı)</u>	
JPM Number: CRd (N-80a) Revision	Number: 00		
Task Number and Title: 4C.FW-06 Startup/shutdow	n a Main Feedv	water Pump a	at Power
K/A Number and Importance: 059A2.07 3.0/3.3		-	
Ability to (a) predict the impacts of the following mality (b) based on those predictions, use procedures to consequences of those malfunctions or operations: Suggested Testing Environment: <u>Simulator</u> Alternate Path: I Yes INO SRO Only: Yes	functions or op orrect, control, Tripping of MF ⊠No Tim	erations on th or mitigate th W pump turb e Critical: 🗌	ne MFW; and ne ine Yes ⊠No
Reference(s): 1BOP FW-1, Rev 18; BAR 1-16-A4			
CRITICAL STEPS ([^]) 2, 3, 5 & 7 Actual Tosting Environment: ⊠ Simulator □ 0	Control Poom	□ In Plant	□ Other
Testing Method: □ Simulate ⊠ Perform			
Estimated Time to Complete: 10 minutes	Actual Time U	sed: r	ninutes
EVALUATION SUMMARY:			
Were all the Critical Elements performed satisfactor	ilγ? □Ye	es 🗆	No
The operator's performance was evaluated against contained within this JPM and has been determined	standards to be: □ Sa	atisfactory □	Unsatisfactory
Comments:			
Evaluator's Name:	(F	Print)	
Evaluator's Signature:	Da	te:	

- 1. You are the Unit NSO.
- 2. The unit is at 75% power.
- 3. 1A and 1B FW pumps are online.
- 4. The 4th CD/CD pump was started in preparation for this pumps swap.
- 5. The 1C FW pump is NOT running.

INITIATING CUES

- 1. The US directs you to place the 1C FW pump on line and take 1A FW pump off line.
- 2. BOP FW-1, "STARTUP AND SWAPPING OF TURBINE DRIVEN FW PUMPS", has been completed through step 3.e, inclusive, of the main body. The trip test and reset of steps 3.d and 3.e were completed successfully.

	Exelon Nuclear				
Job Performance Measure					
Transfer Pre	Transfer Pressurizer Pressure Control to Automatic				
	JPM Number: <u>CRe</u>				
	Revision Number: <u>00</u>				
	Date: <u>5/1/2014</u>				
Revised By:	Robert Peterson	<u>5/1/2014</u> Date			
Validated By:	Brian Lewin Operations Dept.	<u>5/4/2014</u> Date			
Approved By:	Brian Lewin Operations Representative	<u>5/4/2014</u> Date			

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- File Copy 1. Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
 - 3. Performance location specified. (in-plant, control room, simulator, or other)
 - 4. Initial setup conditions are identified.
 - 5. Initiating cue (and terminating cue if required) are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure(s) referenced by this JPM reflects the current revision: 8. Procedure 1BGP 100-1 Rev: <u>56</u> Procedure Rev:
 - 9. Verify cues both verbal and visual are free of conflict.
 - 10. Verify performance time is accurate
 - 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

5/1/2014

SME / Instructor

Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset to IC-101 (from IC-11) (password nrc14)
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.
- 2. Verify/place all Pzr Backup Heaters are in AUTO and Variable Heater control switch is in AFTER CLOSE.
- 3. When RCS pressure is stable, place 1PK-455A, B & C in MANUAL.
- 4. Turn the pot for 1PK-455A to 3.5 (actual number not important, just significantly lower than 6.688).
- 5. Turn the pots for 1PK-455B & C to 4.5 (actual number not important, just significantly higher than 0).
- 6. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 7. This completes the setup for this JPM.

- 1. You are the Unit 1 Assist NSO.
- 2. Unit 1 is in 1BGP 100-1, Plant Heatup following a refueling outage.
- 3. RCS pressure is stable with pressure control in MANUAL.

INITIATING CUES

The Unit Supervisor has directed you to perform 1BGP 100-1, Step 67, Place Pressurizer Pressure Control in Automatic.

Information For Evaluator's Use:

Task Standard: CONTROL Pressurizer Pressure in Master Manual Mode (and switch to automatic control)

UNSAT requires written comments on respective step.

- * Denotes critical steps: 3, 4 & 6
- Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.
- Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1.	Refer to 1BGP 100-1, Step 67.	OPENS 1BGP 100-1, Step 67.			
No	te: Provide the examinee a copy of 1BGP 100-1, Step 67.				
2.	Refer to 1BGP 100-1A1 for 1PK- 455A potentiometer setting.	Refers to 1BGP 100-1A1 for pot setting of 6.688.			
*3.	Adjust 1PK-455A potentiometer to 6.688.	Adjusts 1PK-455A pot to 6.688 (acceptable range: 6.6-6.8).			
*4.	Place 1PK-455A in AUTO.	Places controller 1PK-455A in AUTO.			
5.	Set 1PK-455B and 1PK-455C potentiometers to 0.	Sets both1PK-455B and 1PK- 455C pots to 0.			
*6.	Place 1PK-455B and 455C in AUTO.	Places controllers 1PK-455B and 455C in AUTO.			
7.	Place at least 2 Backup Heaters to ON.	Turns on at least 2 Backup heaters.			
8.	Verify/place the Variable Heater Control Switch to AFTER CLOSE position.	Verifies the Variable Heater Control Switch is in AFTER CLOSE.			
9.	Adjusts 1PK-455A potentiometer with controller in AUTO or MANUAL to maintain 2235 PSIG.	Monitors RCS or Pzr Pressure and verifies spray valves respond and pressure is trending to 2235 PSIG.			

Cue (when pressure is trending towards being stabilized): This JPM is completed.

RECORD STOP TIME:

JPM SUMMARY

Operator's Name:	Job Title:	🗆 RO	□SRO
JPM Title: Transfer Pressurizer Pressure Control to	Automatic		
JPM Number: <u>CRe</u> Revision	Number: (00	
Task Number and Title: 4D.RY-02 CONTROL Press	surizer Pres	ssure in Master	<u>Manual Mode</u>
(Pressure Controller in manual)			
K/A Number and Importance: 010A3.02 3.6/3.5			
Ability to monitor automatic operation of the PZR PC	CS, includir	ng: PZR pressu	re.
Suggested Testing Environment: Simulator			
Alternate Path: □Yes ⊠No SRO Only: □Yes	⊠No	Time Critical:	_Yes ⊠No
Reference(s): 1BGP 100-1, Rev 56			
CRITICAL STEPS (*) 3, 4 & 6			
Actual Testing Environment: Simulator	Control Roo	om 🗌 In-Pla	nt 🗌 Other
Testing Method: Simulate Perform			
Estimated Time to Complete: <u>10</u> minutes	Actual Tim	ne Used:	minutes
EVALUATION SUMMARY:			
Were all the Critical Elements performed satisfactor	ily? [] Yes	□ No
The operator's performance was evaluated against	standards		
contained within this JPM and has been determined	to be: [Satisfactory	Unsatisfactory
Comments:			
Evaluator's Name:		(Print)	
Evaluator's Signature:		Date:	

- 1. You are the Unit 1 Assist NSO.
- 2. Unit 1 is in 1BGP 100-1, Plant Heatup following a refueling outage.
- 3. RCS pressure is stable with pressure control in MANUAL.

INITIATING CUES

The Unit Supervisor has directed you to perform 1BGP 100-1, Step 67, Place Pressurizer Pressure Control in Automatic.

	Exelon Nuclear				
Jc	Job Performance Measure				
SX Flo	SX Flooding Requiring RCFC Isolation (Running Train Leak)				
	JPM Number: <u>CRf</u>				
	Revision Number: <u>0</u>				
	Date: <u>3/18/2014</u>				
Revised By:	Robert Peterson	<u>3/18/2014</u> Date			
Validated By:	Pat Comerford Operations Dept.	<u>4/7/2014</u> Date			
Approved By:	Brian Lewin Operations Representative	<u>4/7/2014</u> Date			

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- File Copy 1. Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
 - 3. Performance location specified. (in-plant, control room, simulator, or other)
 - 4. Initial setup conditions are identified.
 - 5. Initiating cue (and terminating cue if required) are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure(s) referenced by this JPM reflects the current revision: 8. Procedure 1BOA PRI-7 Rev: <u>106</u> Procedure Rev:
 - 9. Verify cues both verbal and visual are free of conflict.
 - 10. Verify performance time is accurate
 - 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

SME / Instructor

3/18/2014 Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.
- 2. Insert MF SW02A at 10 GPM. (In IC-100)
- 3. Acknowledge CNMT DRAIN LEAK DETECT FLOW HIGH alarm (1-1-A2). (In IC-100)
- 4. IMF PN1423 OFF and PN1427 OFF to prevent nuisance alarms from the effects of this realignment on the 1A CNMT chiller.
- 5. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 6. This completes the setup for this JPM.

- 1. You are the Unit 1 Assist NSO.
- 2. Unit 1 is experiencing a loss of Essential Service Water.
- 3. Cnmt Floor Drain Sump (1FT-RF008) indicates ~1.2 GPM flow.

INITIATING CUES

1. The Unit Supervisor has directed you to perform the actions necessary to isolate the leak per 1BOA PRI-7, Essential Service Water Malfunction, step 5.d.

Information For Evaluator's Use:

Task Standard: RESPOND to Essential Service Water malfunction

UNSAT requires written comments on respective step.

- * Denotes critical steps: 6, 7 & 8
- Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.
- Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. No	Refer to 1BOA PRI-7, step 5.d, Essential Service Water Malfunction te: Provide the examinee a copy	LOCATE and OPEN 1BOA PRI-7, step 5.d			
	of 1BOA PRI-7.				
2.	Shutdown the NON-running SX pump's train RCFCs. Close the associated RCFC train isolation valves.	Train 1B: • Stop 1B RCFC o Stop 1D RCFC Train 1B: • Close 1SX016B			
		Close 1SX027B			
4.	Check if the leak has stopped.	Leak has not stopped - CNMT sump recorders are still trending up.			
5.	Open the associated RCFC train isolation valves.	Train 1B • Open 1SX016B • Open 1SX027B			

EVALUATOR:

The operator MAY start the NON-running SX pump's train RCFCs 1B and 1D in High Speed.

BOOTH OPERATOR:

Candidate may elect to have the EO start the Aux Lube Oil Pump(s) for either or both SX pumps. The RFs are:

- MRF SW03 ON for 1A SX pump
- MRF SW04 ON for 1B SX pump

ELEMENT	<u>STANDARD</u>		UNSAT	Comment Number
*6. Start the NON-running SX Pump and stop the running SX Pump.	Start 1B SX PumpStop 1A SX Pump			
EVALUATOR: The next realignment will cause the 1A CNMT chiller to trip on high condenser pressure after few minutes. The alarms are overridden OFF to prevent a distraction. If the candidate addresses the need to realign the CNMT chiller or goes to check on the chiller status, provid the cue. CUE: An extra NSO will be assigned to realign the CNMT Chiller. Continue the assigned task.				after a te rovide s igned
*7. Shutdown the NON-running SX pump's train RCFCs.	Train 1A: • Stop 1A RCFC • Stop 1C RCFC			
*8. Close the associated RCFC train isolation valves.	Train 1A: Close 1SX016A Close 1SX027A			
9. Check if the leak has stopped.	Leak has stopped - CNMT sump recorders stop trending up.			
10. Inform the US that leak is isolated.	Inform US that SX leak has stopped and one train of RCFC has been isolated.			
Cue: This JPM is completed.				
RECORD STOP TIME:				

JPM SUMMARY

Operator's Name:	Job Title:	□ RO □SRO
JPM Title: SX Flooding Requiring RCFC Isolation (F	Running Tra	ain Leak)
JPM Number: <u>CRf</u> Revision	Number: 0	00
Task Number and Title: 4D.OA-69 RESPOND to Es	sential Ser	vice Water malfunction
K/A Number and Importance: 022A2.05 3.1/3.5		
Ability to (a) predict the impacts of the following mal (b) based on those predictions, use procedures to c consequences of those malfunctions or operations: Suggested Testing Environment: Simulator	functions o orrect, con Major leak	r operations on the CCS; and trol, or mitigate the in CCS.
Alternate Path: \Box Yes \boxtimes No SRO Only: \Box Yes	⊠No	Time Critical:
Reference(s): 1BOA PRI-7 Rev 106		
CRITICAL STEPS (*) 6 7 & 8		
Actual Testing Environment:	Control Roc	om
Testing Method: □ Simulate ⊠ Perform		
Estimated Time to Complete: 15 minutes	Actual Tim	e Used: minutes
EVALUATION SUMMARY:		
Were all the Critical Elements performed satisfactor	ily? []Yes □No
The operator's performance was evaluated against contained within this JPM and has been determined	standards to be: [□ Satisfactory □ Unsatisfactory
Comments:		
Evaluator's Name:		(Print)
Evaluator's Signature:		Date:

- 1. You are the Unit 1 Assist NSO.
- 2. Unit 1 is experiencing a loss of Essential Service Water.
- 3. Cnmt Floor Drain Sump (1FT-RF008) indicates ~1.2 GPM flow.

INITIATING CUES

1. The Unit Supervisor has directed you to perform the actions necessary to isolate the leak per 1BOA PRI-7, Essential Service Water Malfunction, step 5.d.

	Exelon Nuclear	
Jo	b Performance Measure	
	Containment Release (With Rad Alarm)	
	JPM Number: <u>CRg</u>	
	Revision Number: 02	
	Date: <u>3/18/2014</u>	
Revised By:	Robert Peterson	<u>3/18/2014</u> Date
Validated By:	Pat Comerford Operations Dept.	<u>4/7/2014</u> Date
Approved By:	Brian Lewin Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- File Copy 1. Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
 - 3. Performance location specified. (in-plant, control room, simulator, or other)
 - 4. Initial setup conditions are identified.
 - 5. Initiating cue (and terminating cue if required) are properly identified.
 - 6. Task standards identified and verified by SME review.
 - Critical steps meet the criteria for critical steps and are identified with an 7. asterisk (*).
 - 8. Verify the procedure(s) referenced by this JPM reflects the current revision: Procedure BOP VQ-6 Rev: 7 Procedure BCP 400 TCNMT/ROUTINE Rev: 23 Procedure BAR RM11-4-1AR12J Rev: 10
 - 9. Verify cues both verbal and visual are free of conflict.
 - 10. Verify performance time is accurate
 - 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

3/18/2014

SME / Instructor

Date

Revision Record (Summary)

Revision 2 Converted to current format and verified procedure steps. 3/18/2014 RFP

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-101 (from IC-11) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

- 2. Insert overrides and MF so CNMT pressure indicates 0.9 PSIG (in IC-101) SMDG CH6
 - IMF PN1259 ON (CNMT Internal press HIGH alarm ON)
 - IOR ZAO1PDIVP231 0.9 (CNMT pressure indicated at 0.9#)
 - IOR ZAO1PDIVP236 0.9
 - IOR ZAO1PIPC004 0.9
 - IOR ZAO1PIPC005 0.9
 - imf ch08a 0.9
 - imf ch08b 0.9
 - imf ch08c 0.9
 - imf ch08d 0.9
- 3. IMF RM05O to prevent automatic CNMT Vent Isolation actuation. (in IC-101)
- 4. Trgset 12 "zlo1vq05c(2).gt.0" to set trigger for rad monitor alarm when 1VQ05C is opened.
- 5. IMF RM01AP (12 10) 1.8 to cause 1AR12J to alarm 10 seconds after 1VQ05C is opened.
- 6. Place the "UNIT 1 CNMT GASEOUS RELEASE" placard on 0PM02J above the VQ valves.
- 7. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 8. This completes the setup for this JPM.

- 1. You are the Unit 1 Assist NSO.
- 2. A Unit 1 Containment Vent Release Package is approved for release.

INITIATING CUES

The Unit Supervisor has directed you to perform a normal release without a purge fan, using BOP VQ-6, Containment Mini-Purge System Operation to vent Unit 1 Containment in accordance with step 6 of BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form, Routine Containment Release. All containment release paperwork has been verified acceptable up to step 6.

Information For Evaluator's Use:

Task Standard: PERFORM Containment Vent

UNSAT requires written comments on respective step.

- * Denotes critical steps: 5 & 8
- Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.
- Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME_____

ELEMENT	<u>STANDARD</u>		UNSAT	Comment Number		
<u>NOTE</u> Provide the candidate with a copy of BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form, Routine Containment Release completed up to step 6 with approval for release.						
 Refer to BOP VQ-6, Containment Mini-Purge System Operation. Cue: Provide copy of BOP VQ-6 when candidate locates procedure book. 	 LOCATE and OPEN BOP VQ-6 					
 Review BOP VQ-6, steps prior to main body. Cue: All prerequisites are met. 	 Review Prerequisites, Precautions, and Limitations and Actions 					
Steps 3 and 4 n	<u>NOTE:</u> Steps 3 and 4 may be performed in any order.					
3. Enter data into release form	 Record on release form: Unit 1 Actual time 0.9 PSIG 					
4. Verify aux building ventilation	 0B VA Exhaust Fan is in operation. 					

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
*5. Open CNMT Mini-Flow Purge Exhaust Isolation valves.	At 0PM02J: • 1VQ005A OPEN light is LIT • 1VQ005B OPEN light is LIT • 1VQ005C OPEN light is LIT				
EVALUATOR NOTE Ten seconds after the release is started, 1AR12J, Unit 1 CNMT Fuel Handling Incident Rad monitor, will HIGH ALARM at 63.1 mRem/hour. This <u>normally</u> would result in a CNMT Vent Isolation Signal that <u>normally</u> would close the B train valve 1VQ005B, but the isolation signal is not generated and the valve fails to automatically close.					
 Record the time the valves were opened and release began on the Gaseous Effluent Release Form. 	 Record the start time of the release on the Gaseous Effluent Release Form. Log in unit log 				
NOTE: The alternate path starts here when a containment vent isolation signal from 1AR12J fails to close 1VQ005B.					

ELEMENT			<u>STANDARD</u>		UNSAT	Comment Number
7. Re NOTE	espond to RM-11 alarm. : If the candidate does not respond to RM-11 alarm then:	•	Respond to RM-11 alarm			
Cue:	<i>The Unit Supervisor directs you to respond to the RM-11 alarm.</i>	•	Determine alarming rad monitor			
Cue:	Grid 4, monitor 1AR12J is flashing red	0	Refer to BAR RM11-4- 1AR12J and BOP AR/PR-11			
Provic Cue: VENT LIT.	le BAR RM11-4-1AR12J if candidate indicates they desire to check the alarm response. (If asked) Annunciator CNMT ISOLATION (1-5-C7) is NOT	•	subsequent operator actions. Recognize monitor is in interlock state and B train VQ valve should have closed automatically, but did not.			
Note: Applicant can use BAR RM11-2-1PR01J, RM11-4-1AR12J, or BOP VQ-6 Limitations and Actions E.2 as guidance to secure the Cnmt Release.						
*8. St or	op release as directed per BAR BOP.	4 • 10	At 0PM02J Close at least NE of the following: o 1VQ005A o 1VQ005B o 1VQ005C			
Cue:	(if asked) CNMT pressure is now .75 psi	0	Record data on Release Form			

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
9.	Inform Supervisor of Rad monitor 1AR12J status, failure of auto Cnmt Vent Isolation, and that release was manually terminated.	Notify Unit Supervisor of release termination.			
Cue: Cue:	The Unit Supervisor / Shift Manager acknowledges condition of 1AR12J, failure of CNMT Vent Isolation auto actuation, manual termination. This JPM is completed.				

RECORD STOP TIME_____

JPM SUMMARY

Operator's Name: Job Title: ROSRO
JPM Title: Containment Release (With Rad Alarm)
JPM Number: CRg Revision Number: 02
Task Number and Title: 4C.VQ-01 PERFORM Containment Vent
K/A Number and Importance: 072A3.01 Imp Factor: 2.9/3.1
Ability to monitor automatic operation of the ARM system, including: Changes in ventilation alignment.
Suggested Testing Environment: <u>Simulator</u>
Alternate Path: ⊠Yes □No SRO Only: □Yes ⊠No Time Critical: □Yes ⊠No
Reference(s): BOP VQ-6 Rev 7 & BCP 400-TCNMT/ROUTINE Rev 23 & BAR RM11-4- 1AR12J, Containment Fuel Handling ICDT Rev 10
CRITICAL STEPS (*) 5 & 8
Actual Testing Environment: 🛛 Simulator 🛛 Control Room 🔲 In-Plant 🗌 Other
Testing Method: <
Estimated Time to Complete: 10 minutes Actual Time Used: minutes
EVALUATION SUMMARY:
Were all the Critical Elements performed satisfactorily?
The operator's performance was evaluated against standards contained within this JPM and has been determined to be:
Comments:
Evaluator's Name: (Drint)
Evaluator's Signature: Date:

- 1. You are the Unit 1 Assist NSO.
- 2. A Unit 1 Containment Vent Release Package is approved for release.

INITIATING CUES

The Unit Supervisor has directed you to perform a normal release without a purge fan, using BOP VQ-6, Containment Mini-Purge System Operation to vent Unit 1 Containment in accordance with step 6 of BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form, Routine Containment Release. All containment release paperwork has been verified acceptable up to step 6.

Exelon Nuclear					
Job Performance Measure					
Start Hydrogen Monitoring System					
JPM Number: <u>CRh</u>					
Revision Number: <u>01</u>					
Date: <u>3/24/2014</u>					
Revised By:	Robert Peterson	<u>3/24/2014</u> Date			
Validated By:	Pat Comerford Operations Dept.	<u>4/7/2014</u> Date			
Approved By:	Brian Lewin Operations Representative	<u>4/7/2014</u> Date			

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

- See 1. Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
- File Copy 3. Performance location specified. (in-plant, control room, simulator, or other)
 - Initial setup conditions are identified. 4.
 - 5. Initiating cue (and terminating cue if required) are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - 8. Verify the procedure(s) referenced by this JPM reflects the current revision: Procedure BOP PS-9 Rev: 4 Procedure <u>1BEP-1</u> Rev: 202
 - Verify cues both verbal and visual are free of conflict. 9.
 - 10. Verify performance time is accurate
 - 11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

SME / Instructor

3/24/2014 Date

Revision Record (Summary)

Revision 1 Converted to current format and verified procedure steps. 3/24/2014 RFP

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset to IC-101 (from IC-11) (password nrc14)
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.
- 2. VERIFY/CLOSE 1PS228A, 1PS228B, 1PS229A, 1PS229B (In IC-101)
- 3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 4. This completes the setup for this JPM.
INITIAL CONDITIONS

- 1. You are an extra NSO in the control room during a LOCA event.
- 2. The crew has performed the actions contained in 1BEP-0, Reactor Trip or Safety Injection and is currently in 1BEP-1, Loss of Reactor or Secondary Coolant.
- 3. Containment Isolation Phase A has just been reset.

INITIATING CUE

Place the Hydrogen Monitors in service per BOP PS-9, Post LOCA Containment Hydrogen Monitoring System Operation.

Information For Evaluator's Use:

Task Standard: Operate the Hydrogen Analyzer

UNSAT requires written comments on respective step.

- * Denotes critical steps: 2, 3 & 6
- Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.
- Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 Refer to BOP PS-9, Post-LOCA Containment Hydrogen Monitoring System Operation 	Locate and OPEN BOP PS-9, Post LOCA Cnmt Hydrogen Monitoring System Operation			
Note: Step 1 may be performed at any time				
Cue: All prerequisites are met				
*2. Open the following valves on 1PM11J.				
 1PS228A Pri Cnmt Isol to H₂ Monitor 	OPEN 1PS228A on 1PM11J			
 1PS230A Return Cnmt Isol from H₂ Monitor 	OPEN 1PS230A on 1PM11J			
 1PS228B Pri Cnmt Isol to H₂ Monitor 	OPEN 1PS228B on 1PM11J			
 1PS229A Sec Cnmt Isol to H₂ Monitor 	OPEN 1PS229A on 1PM11J			
 1PS229B Sec Cnmt Isol to H₂ Monitor 	OPEN 1PS229B on 1PM11J			
 1PS230B Return Cnmt Isol from H₂ Monitor 	OPEN 1PS230B on 1PM11J			
*3. Direct EO to locally open the following valves at 1PS47J & 1PS48J				
 1PS232A Manual Inlet Isol to H₂ Monitor 	1PS232A locally OPENED			
 1PS233A Manual Outlet Isol from H₂ Monitor 	1PS233A locally OPENED			
 1PS232B Manual Inlet Isol to H₂ Monitor 	1PS232B locally OPENED			
 1PS233B Manual Outlet from H₂ Monitor 	1PS233B locally OPENED			
<i>Cue: EO reports that valves have been locally Opened</i>				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
 Direct EO to locally verify the ALARM SET / NORMAL switch is set to NORMAL on 1PS43J & 1PS44J Cue: EO reports that switch is in NORMAL 	ALARM SET / NORMAL switch is set to NORMAL			
 *6. Place the ON-OFF switch on 1HSU-PS345 & 1HSU-PS346 on 1PM12J to the ON position. Cue: Four minutes have elapsed. 	ON-OFF switch on 1HSU- PS345 & 346 on 1PM12J are ON.			
 Verify the H₂ & System Status Alarm lights on 1HSU-PS345 & 1HSU- PS346 are NOT ON. 	H ₂ & System Status Alarm lights are NOT ON.			
 Verify on 1PM06J 1EL-PS343 & 1EL-PS344 LO RANGE lights are ON. 	LO RANGE lights are ON.			
Cue: This JPM is completed.		 	 	

RECORD STOP TIME_____

JPM SUMMARY
Operator's Name: Job Title:
JPM Title: <u>Start Hydrogen Monitoring System</u>
JPM Number: <u>CRh</u> Revision Number: <u>01</u>
Task Number and Title: <u>4C.PS-01 Operate the Hydrogen Analyzer</u>
K/A Number and Importance: 029A2.04 2.5/3.2
Ability to (a) predict the impacts of the following malfunctions or operations on the Containment Purge System; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: Health physics sampling of containment atmosphere.
Suggested Testing Environment: Simulator
Alternate Path: □ Yes ⊠No SRO Only: □ Yes ⊠No Time Critical: □ Yes ⊠No
Reference(s): BOP PS-9, Post LOCA Containment Hydrogen Monitoring System Operation
1BEP-1, Loss of Reactor of Secondary Coolant
CRITICAL STEPS (*) 2, 3 & 6
Actual Testing Environment: 🛛 Simulator 🛛 Control Room 🗌 In-Plant 🗌 Other
Testing Method: Simulate Perform
Estimated Time to Complete: <u>15</u> minutes Actual Time Used: minutes
EVALUATION SUMMARY:
Were all the Critical Elements performed satisfactorily?
The operator's performance was evaluated against standards contained within this JPM and has been determined to be:
Comments:
Evaluator's Name: (Print)
Evaluator's Signature: Date:

INITIAL CONDITIONS

- 1. You are an extra NSO in the control room during a LOCA event.
- 2. The crew has performed the actions contained in 1BEP-0, Reactor Trip or Safety Injection and is currently in 1BEP-1, Loss of Reactor or Secondary Coolant.
- 3. Containment Isolation Phase A has just been reset.

INITIATING CUE

Place the Hydrogen Monitors in service per BOP PS-9, Post LOCA Containment Hydrogen Monitoring System Operation.