



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
REGION III  
2443 WARRENVILLE RD. SUITE 210  
LISLE, IL 60532-4352

July 24, 2014

Mr. Michael J. Pacilio  
Senior VP, Exelon Generation Co., LLC  
President and CNO, Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

**SUBJECT: CLINTON POWER STATION – NOTIFICATION OF AN NRC TRIENNIAL HEAT  
SINK PERFORMANCE INSPECTION AND REQUEST FOR INFORMATION  
INSPECTION REPORT 05000461/2014004**

Dear Mr. Pacilio:

On September 8, 2014, the U.S. Nuclear Regulatory Commission (NRC) will begin the on-site portion of the Triennial Heat Sink Performance Inspection at your Clinton Power Station. This inspection will be performed in accordance with NRC Baseline Inspection Procedure (IP) 71111.07T.

In order to minimize the impact that the inspection has on the site and to ensure a productive inspection, we have enclosed a request for documents needed for the inspection. The documents have been divided into three groups.

- The first group lists information necessary for our initial inspection scoping activities. This information should be available to the lead inspector no later than August 6, 2014. By August 13, 2014, the inspector will communicate the initial selected set of approximately 2-3 risk significant heat exchangers.
- The second group is to support our in-office preparation activities. This set of documents, including the calculations associated with the selected heat exchangers, should be available at the Regional Office no later than August 25, 2014. This information should be separated for each selected component, especially if provided electronically (e.g., folder with component name that includes calculations, condition reports, maintenance history, etc). During the in-office preparation activities, the inspector may identify additional information needed to support the inspection.
- The last group includes the additional information above as well as plant specific reference material. This information should be available onsite to the inspector on September 8, 2014. It is also requested that corrective action documents and/or questions developed during the inspection be provided to the inspector as the documents are generated.

All requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection. If no activities were accomplished in that time period, then the request applies to the last applicable document in the previous time period. It is important that these documents be as complete as possible, in order to minimize the number of documents requested during the preparation week or during the on-site inspection.

The lead inspector for this inspection is Gerard O'Dwyer. If there are questions about the material requested, or the inspection, please call Gerard O'Dwyer at (630) 829-9624. Please send the information to the following e-mail address Gerard.ODwyer@nrc.gov. A hard-copy with the required information is also an acceptable option.

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget, Control Number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget Control Number.

In accordance with Title 10, *Code of Federal Regulations* (CFR), Section 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records System (PARS) component of NRC's Agencywide Documents Access and Management System (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA Stuart Sheldon Acting For/

Ann Marie Stone, Chief  
Engineering Branch 2  
Division of Reactor Safety

Docket No. 50-461  
License No. NPF-62

Enclosure:  
TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST

cc w/encl: Distribution via LISTSERV®

# TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST

**Inspection Report:** 05000461/2014003

**Inspection Dates:** September 8 – 12, 2014

**Inspection Procedure:** Inspection Procedure 71111.07, "Heat Sink Performance"

**Lead Inspector:** G. O'Dwyer  
(630) 829-9624  
[Gerard.ODwyer@nrc.gov](mailto:Gerard.ODwyer@nrc.gov)

## ***I. Information Requested By August 6, 2014***

1. List of the Generic Letter (GL) 89-13, "Service Water System Problems Affecting Safety-Related Equipment," heat exchangers in order of risk significance.
2. Copy of heat exchanger performance trending data tracked for each GL 89-13 heat exchanger.
3. List of corrective action program documents (with a short description) associated with GL 89-13 heat exchangers, heat sinks, silting, corrosion, fouling, or heat exchanger testing, for the previous three years or since the last corrective action program document list was sent to the NRC for the previous Triennial heat sink performance inspection. The list should include all corrective action program documents not on the last corrective action program document list.
4. Copy of any self-assessment done on any of GL 89-13 heat exchangers.
5. Last two System Health Report(s) and maintenance rule system notebooks for all the GL 89-13 heat exchangers and the UHS and the Shutdown Service Water (SSW) System.
6. List of engineering-related operator workarounds (with a short description) associated with GL 89-13 heat exchangers and the UHS and Shutdown Service Water (SSW) System. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
7. List of permanent and temporary modifications (with a short description) associated with GL 89-13 heat exchangers. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
8. Copy of the Updated Final Safety Analysis Report (UFSAR) supplement applicable to License Renewal.

## TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST

### ***II. Information Requested By August 25, 2014***

1. Copies of the GL 89-13 responses.
2. Copy of the Updated Final Safety Analysis Report (UFSAR) section applicable to the GL 89-13 Heat Exchanger Program.
3. Copies of procedures developed to implement the recommendations of GL 89-13 (e.g., the GL 89-13 Heat Exchanger Program description).
4. Copies of the selected corrective action program documents.
5. For the specific heat exchangers selected:
  - a. Copies of the UFSAR sections applicable for each heat exchanger.
  - b. Copy of system description and design basis document for the heat exchangers (as applicable).
  - c. Provide a list of calculations (with a short description) which currently apply to each heat exchanger.
    - i. establish the limiting design basis heat load required to be removed by each of these heat exchangers;
    - ii. demonstrate the heat exchangers capacity to remove the limiting heat load;
    - iii. correlate surveillance testing and/or inspection results from these heat exchangers with design basis heat removal capability (e.g., basis for surveillance test and/or inspection acceptance criteria);
    - iv. evaluate the potential for water hammer in each heat exchanger or associated piping; and
    - v. evaluate excessive tube vibration in each heat exchanger.
  - d. Copy of any operability determinations or other documentation of degradation associated with the heat exchangers or the systems that support the operation for the selected heat exchangers.
  - e. Copy of the construction code, Design Specification, heat exchanger data sheets, and vendor documents including component drawings applicable for the heat exchangers.
  - f. Copies of normal, abnormal, and emergency operating procedures associated with the selected heat exchangers.
6. For the ultimate heat sink (UHS):
  - g. Copies of the applicable Updated Final Safety Analysis Report (UFSAR) sections.

## **TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST**

- h. Copy of system description and design basis document (as applicable).
  - i. Copy of any operability determinations or other documentation of degradation associated with the UHS or Shutdown Service Water (SSW) System.
  - j. Copy of the document (e.g. UFSAR or Technical Requirements Manual) that states the maximum cooling water system inlet temperature limit that still allows full licensed power operation of the nuclear reactor.
  - k. Copy of system description and design basis document (as applicable).
  - l. If available, provide an electronic copy of piping and instrumentation diagrams (P&IDs) for the service water system, including the intake structure.
7. A schedule of all inspections, cleanings, maintenance, or testing of any safety-related plant heat exchanger to be performed during the on-site portion of the inspection.

### ***III. Information Requested to be Available on First Day of Inspection, September 8, 2014***

- 1. For the specific heat exchangers selected.
  - a. Copy of the calculation which correlates surveillance testing results from these heat exchangers with design basis heat removal capability (e.g. basis for surveillance test acceptance criteria).
  - b. Copies of the two most recent completed tests and evaluation data confirming thermal performance for those heat exchangers which are performance tested.
  - c. Documentation and procedures that identify the types, accuracy, and location of any special instrumentation used for the two most recently completed thermal performance tests for the heat exchangers (e.g., high accuracy ultrasonic flow instruments or temperature instruments). Include calibration records for the instruments used during these tests.
  - d. Information regarding any alarms which monitor on-line performance.
  - e. Copy of the document describing the inspection results of each heat exchanger. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
  - f. The cleaning and inspection maintenance schedule for each heat exchanger for the next 5 years.
  - g. Copy of the design specification and heat exchanger data sheets for each heat exchanger.
  - h. Copy of the vendor manuals including component drawings for each heat exchanger.

## TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST

- i. Copy of the calculation which establishes the limiting (maximum) design basis heat load which is required to be removed by each of these heat exchangers.
  - j. Copy of the operating procedure that ensures that the maximum cooling water system inlet temperature limit is not exceeded.
  - k. Copy of the calculations or documents which evaluate the potential for water hammer in each heat exchanger or associated piping.
  - l. Copy of the calculations that evaluate excessive tube vibration in each heat exchanger and the documents that describe the controls that prevent heat exchanger degradation due to excessive flow induced vibration during operation.
  - m. Copy of the periodic flow testing at or near maximum design flow and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
  - n. Copy of the document which identifies the current number of tubes in service for each heat exchanger and the supporting calculation which establishes the maximum number of tubes which can be plugged in each heat exchanger.
  - o. Copy of the document establishing the repair criteria (plugging limit) for degraded tubes which are identified in each heat exchanger.
  - p. Copies of the documents that verify the structural integrity of the heat exchanger (e.g. eddy current summary sheets, ultrasonic testing results, and visual inspection results).
  - q. Copies of those documents that describe the methods taken to control water chemistry in the heat exchangers.
2. For the review associated with the system walkdown of the service water intake structure:
- a. Copies of corrective maintenance for the last 6 years associated with service water strainers and backwash function, traveling screens and trash racks.
  - b. Copies of the last two inspections and/or surveillances associated with service water strainers and backwash function, traveling screens and trash racks.
  - c. List of preventive maintenance, including frequency, associated with service water strainers and backwash function, traveling screens and trash racks.
  - d. Copies of abnormal procedures for the traveling screens and service water strainers including backwash function.
  - e. Copies of the last two inspections and/or surveillances documenting that component mounts have not excessively degraded (i.e., due to corrosion). For example, inspections for the mounts for the, Service water pumps, service water strainers, traveling screens and trash racks.
  - f. Copies of the documents associated with the monitoring, trending, and

## TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST

remediation of silt accumulation in the SSWS pump intake bay.

- g. Copies of surveillance procedures and testing results performed on the SSWS pump intake bay water level instruments. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
  - h. Copies of procedures associated with operating during adverse weather conditions (e.g. icing, high temperatures, grass intrusion or low level).
  - i. Copy of the evaluation for the potential effects of low flow/level on underwater weir walls intended to limit silt or sand intake, applicable to the SSWS pump intake bay.
- 3. For the review of the performance testing of the safety-related service water system (or equivalent) and the UHS
  - a. Copies of the last two performance tests, such as the ASME in-service test, for the pumps, traveling screens, strainers and valves in the safety-related service water system. If the components are not performance tested, please provide documentation verifying performance by the methods actually used.
  - b. Copies of the documents that demonstrate that Service Water flow balance testing was performed during the last three years. If the last flow test was performed longer than three years, then provide the last flow test.
  - c. Copies of the documents that demonstrate that flow balance testing will continue to be periodically done in the future.
  - d. Copies of procedures used to monitor interface valves between the safety related section of the service water system and the non-safety related section and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
  - e. Copies of the procedures that verify the performance of risk significant non-safety functions and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.

If the information requested above will not be available, please contact the Lead Inspectors Gerard O'Dwyer at (630) 829-9624, or by email [gerard.odwyer@nrc.gov](mailto:gerard.odwyer@nrc.gov), or Andrew Dunlop at (630) 829-9726, by email [Andrew.Dunlop@nrc.gov](mailto:Andrew.Dunlop@nrc.gov).

All requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection. If no activities were accomplished in that time period, then the request applies to the last applicable document in the previous time period. It is important that these documents be as complete as possible, in order to minimize the number of documents requested during the preparation week or during the on-site inspection.

The lead inspector for this inspection is Gerard O'Dwyer. If there are questions about the material requested, or the inspection, please call Gerard O'Dwyer at (630) 829-9624. Please send the information to the following e-mail address Gerard.ODwyer@nrc.gov. A hard-copy with the required information is also an acceptable option.

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget, Control Number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget Control Number.

In accordance with Title 10, *Code of Federal Regulations* (CFR), Section 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records System (PARS) component of NRC's Agencywide Documents Access and Management System (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA Stuart Sheldon Acting For/

Ann Marie Stone, Chief  
Engineering Branch 2  
Division of Reactor Safety

Docket No. 50-461  
License No. NPF-62

Enclosure:  
TRIENNIAL HEAT SINK PERFORMANCE INSPECTION DOCUMENT REQUEST

cc w/encl: Distribution via LISTSERV®

**DISTRIBUTION:**

See next page

DOCUMENT NAME: G:\DRSIII\DRS\Work in Progress\Ltr 072414 CLIN HS RFI GFO.doc

☐ Publicly Available      ☐ Non-Publicly Available      ☐ Sensitive      ☐ Non-Sensitive

To receive a copy of this document, indicate in the concurrence box "C" = Copy without attach/encl; "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII		RIII				
NAME	GO'Dwyer:ls		SSheldon for AMStone				
DATE	07/24/14		07/24/14				

**OFFICIAL RECORD COPY**



Letter to Michael J. Pacilio from Ann Marie Stone dated July 24, 2014.

SUBJECT: CLINTON POWER STATION – NOTIFICATION OF AN NRC TRIENNIAL HEAT  
SINK PERFORMANCE INSPECTION AND REQUEST FOR INFORMATION  
INSPECTION REPORT 05000461/2014004

DISTRIBUTION:

Anthony Bowers  
RidsNrrDorLpl3-2 Resource  
RidsNrrPMClinton Resource  
RidsNrrDirslrib Resource  
Cynthia Pederson  
Darrell Roberts  
Steven Orth  
Allan Barker  
Carole Ariano  
Linda Linn  
DRSIII  
DRPIII  
Patricia Buckley  
Carmen Olteanu