

Table 8.3-13—Division 1 Class 1E Uninterruptible Power Supply Nominal Loads

	Load Requirement (kW)				
	Momentary (1)		Random ⁽²⁾	Continuous	
Load Description	0-1 Min	119-120 Min	0-1 Min Duration	0-120 Min	
Inverter Load (MCC 31BRA)					
Containment Isolation Valves	39	0	0	0	
Solenoid Valves	0	0	0	2.3	
Valves and Dampers	98.6	0	165.9	0	
AC/DC Converters	0	0	0	31.4	
I&C Systems	0	0	0	10.2	
31BRA Control Power	0	0	1.6	0.3	
Main Steam Relief Control Valve	0	0	0	2.8	
Total Inverter Loads	137.6	0	167.5	47	
250 Vdc Loads (switchgear 31BUC)					
Control Power	17.7	0	0	1.2	
DC/DC Converters (3)	0	0	0	0	
• Inverter Load ⁽⁴⁾	158.2	0	192.5	54	
EDG Auxiliaries	1.4	1.4	0	0.8	
Total Division 1 EUPS Nominal Loads	177.3	1.4	192.5	56	

- 1. Maximum load occurring during the one minute momentary load duration is assumed for the entire one minute duration as described in IEEE Std 485-1997.
- 2. Random load assumed to occur at the most critical time of the duty cycle. Maximum load occurring during the one minute random load duration is assumed for the entire one minute duration.
- 3. AC/DC and DC/DC converters operate in parallel. Total load contribution from converters is shown as inverter load to include efficiency factor.
- 4. EUPS Battery load includes inverter efficiency factor of 87 percent.

Tier 2 Revision 7 Page 8.3-119



Table 8.3-14—Division 2 Class 1E Uninterruptible Power Supply Nominal Loads

	Load Requirement (kW)			
	Momentary (1)		Random ⁽²⁾	Continuous
Load Description	0-1 Min	119-120 Min	0-1 Min Duration	0-120 Min
Inverter Load (MCC 32BRA)				
Containment Isolation Valves	17.9	0	0	0
Solenoid Valves	0	0	0	2.7
Valves and Dampers	120.9	0	103.1	0
Special Emergency Lighting	0	0	0	4
AC/DC Converters	0	0	0	27.5
I&C Systems	0	0	0	6.6
32BRA Control Power	0	0	0.8	0.2
Main Steam Relief Control Valve	0	0	0	2.8
Communications	0	0	0	0.3
Total Inverter Loads	138.8	0	103.9	44.1
250 Vdc Loads (switchgear 32BUC)				
Control Power	15	1.2	0	1
DC/DC Converters (3)	0	0	0	0
• Inverter Load ⁽⁴⁾	159.5	0	119.4	50.7
EDG Auxiliaries	1.4	1.4	0	0.8
Total Division 2 EUPS Nominal Loads	175.9	2.6	119.4	52.5

- 1. Maximum load occurring during the one minute momentary load duration is assumed for the entire one minute duration as described in IEEE Std 485-1997.
- 2. Random load assumed to occur at the most critical time of the duty cycle. Maximum load occurring during the one minute random load duration is assumed for the entire one minute duration.
- 3. AC/DC and DC/DC converters operate in parallel. Total load contribution from converters is shown as inverter load to include efficiency factor.
- 4. EUPS Battery load includes inverter efficiency factor of 87 percent.

Tier 2 Revision 7 Page 8.3-120



Table 8.3-15—Division 3 Class 1E Uninterruptible Power Supply Nominal Loads

	Load Requirement (kW)			
	Momentary (1)		Random ⁽²⁾	Continuous
Load Description	0-1 Min	119-120 Min	0-1 Min Duration	0-120 Min
Inverter Load (MCC 33BRA)				
Containment Isolation Valves	17.9	0	0	0
Solenoid Valves	0	0	0	2.7
Valves and Dampers	120.9	0	103.1	0
Special Emergency Lighting	0	0	0	4
AC/DC Converters	0	0	0	27.5
I&C Systems	0	0	0	6.6
33BRA Control Power	0	0	0.8	0.2
Main Steam Relief Control Valve	0	0	0	2.8
Communications	0	0	0	0.3
Total Inverter Loads	138.8	0	103.9	44.1
250 Vdc Loads (switchgear 33BUC)				
Control Power	15	1.2	0	1
DC/DC Converters (3)	0	0	0	0
• Inverter Load ⁽⁴⁾	159.5	0	119.4	50.7
EDG Auxiliaries	1.4	1.4	0	0.8
Total Division 3 EUPS Nominal Loads	175.9	2.6	119.4	52.5

- 1. Maximum load occurring during the one minute momentary load duration is assumed for the entire one minute duration as described in IEEE Std 485-1997.
- 2. Random load assumed to occur at the most critical time of the duty cycle. Maximum load occurring during the one minute random load duration is assumed for the entire one minute duration.
- 3. AC/DC and DC/DC converters operate in parallel. Total load contribution from converters is shown as inverter load to include efficiency factor.
- 4. EUPS Battery load includes inverter efficiency factor of 87 percent.

Tier 2 Revision 7 Page 8.3-121



Table 8.3-16—Division 4 Class 1E Uninterruptible Power Supply Nominal Loads

	Load Requirement (kW)			
	Momentary (1)		Random ⁽²⁾	Continuous
Load Description	0-1 Min	119-120 Min	0-1 Min Duration	0-120 Min
Inverter Load (MCC 34BRA)				
Containment Isolation Valves	32.1	0	0	0
Solenoid Valves	0	0	0	1.4
Valves and Dampers	98.6	0	166	0
AC/DC Converters	0	0	0	32.5
I&C Systems	0	0	0	12.6
34BRA Control Power	0	0	1.6	0.3
Main Steam Relief Control Valve	0	0	0	2.8
Total Inverter Loads	130.7	0	167.6	49.6
250 Vdc Loads (switchgear 34BUC)				
Control Power	17.7	0	0	1.3
DC/DC Converters (3)	0	0	0	0
• Inverter Load ⁽⁴⁾	150.2	0	192.6	57
EDG Auxiliaries	1.4	1.4	0	0.8
Total Division 4 EUPS Nominal Loads	169.3	1.4	192.6	59.1

- 1. Maximum load occurring during the one minute momentary load duration is assumed for the entire one minute duration as described in IEEE Std 485-1997.
- 2. Random load assumed to occur at the most critical time of the duty cycle. Maximum load occurring during the one minute random load duration is assumed for the entire one minute duration.
- 3. AC/DC and DC/DC converters operate in parallel. Total load contribution from converters is shown as inverter load to include efficiency factor.
- 4. EUPS Battery load includes inverter efficiency factor of 87 percent.

Next File