

August 4, 2014

Mr. Mike Mennone, VP and General Manager
RSCC Wire & Cable LLC
20 Bradley Park Road
East Granby, CT 06026

SUBJECT: RSCC's RESPONSE TO THE U.S. NUCLEAR REGULATORY COMMISSION
INSPECTION REPORT NO. 99901443/2014-201 AND NOTICE OF
NONCONFORMANCE

Dear Mr. Mennone:

Thank you for your July 21, 2014, letters in response to the Notice of Nonconformance that were discussed in the subject U.S. Nuclear Regulatory Commission (NRC) inspection report (IR).

We have reviewed your letters and found that they are not fully responsive to both of the Notice of Nonconformances (NON) discussed in IR 99901443/2014-201. Specifically, your response to NON 99901443/2014-201-01 stated that the corrective step to avoid noncompliance will be to create a purchasing specification for the L4 oil and establish receipt inspection criteria for the oil to ensure consistency. This fails to examine: all cases where L4 oil is used; the original composition of L4 oil used during qualification; if there were any variations of the L4 oil composition between qualification and today; if any variations would affect the original qualification; if any applicable licensees/customers were notified of this deviation; and if a 10 CFR 21 evaluation was completed. Additionally, your response to NON 99901443/2014-201-02 stated that the corrective step taken was Drawing TD-005418 was revised to correct the diameter, bend radius, and pulling tension values. This fails to examine: if there was a review of other affected drawings or calculations; if applicable licensees/customers were notified of this deviation as the values in the drawings are used during installation of cables and other engineering and design-related activities; and if a 10 CFR 21 evaluation was completed.

Please clarify your response to address these concerns.

In accordance with 10 CFR 2.390 "Public Inspections, Exemptions, Requests for Withholding," of the NRC's "Rules of Practice," a copy of this letter, its enclosure(s), and your response will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's Agencywide Documents Access and Management System, accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html>. To the extent possible, your response should not include any personal privacy, proprietary, or safeguards information so that it can be made available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request that such material is withheld from public disclosure, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim (e.g., explain why the disclosure of

M. Mennone

- 2 -

information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21 "Protection of Safeguards Information: Performance Requirements."

Please contact Mr. Eugene Huang at 301-415-4140 or via electronic mail at Eugene.Huang@nrc.gov, if you have any questions or need assistance regarding this matter.

Sincerely,

/RA/

Richard A. Rasmussen, Chief
Electrical Vendor Inspection Branch
Division of Construction Inspection
and Operational Programs
Office of New Reactors

Docket No.: 99901443

information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21 "Protection of Safeguards Information: Performance Requirements."

Please contact Mr. Eugene Huang at 301-415-4140 or via electronic mail at Eugene.Huang@nrc.gov, if you have any questions or need assistance regarding this matter.

Sincerely,

/RA/

Richard A. Rasmussen, Chief
Electrical Vendor Inspection Branch
Division of Construction Inspection
and Operational Programs
Office of New Reactors

Docket No.: 99901443

DISTRIBUTION:

- ASakadales
- ERoach
- KKavanagh
- JJimenez
- ARamirez
- LMicewski
- TKendzia
- DTerry-Ward
- Mike.Mennone@r-scc.com

ADAMS ACCESSION No.: ML14213A364 NRO-002

OFFICE	NRO/DCIP/EVIB	NRO/DCIP/EVIB
NAME	EHuang	RRasmussen
DATE	08/04/2014	08/04/2014

OFFICIAL RECORD COPY