

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL**  
(TEMPORARY FORM)

CONTROL NO: 2857

<b>FROM:</b> Carolina Power & Light Company Raleigh, N. C. 27062 N. Bessac		<b>DATE OF DOC:</b> 4-26-73	<b>DATE REC'D</b> 5-1-73	<b>LTR</b> X	<b>FILE</b> MEMO   RPT   OTHER		
<b>TO:</b> Mr. O'Leary		<b>ORIG</b> 3 signed	<b>CC</b>	<b>OTHER</b>	<b>SENT AEC PDR</b> X <b>SENT LOCAL PDR</b> X		
<b>CLASS:</b> (U) PROP INFO		<b>INPUT</b>	<b>NO CYS REC'D</b> 40		<b>DOCKET NO:</b> 50-261		
<b>DESCRIPTION:</b> Ltr reporting an violation of plant administrative procedures on 3-27-73, in which an individual received 303 mrem more than the authorized quarterly limit of 2000 mrem.....				<b>ENCLOSURES:</b>			
<b>PLANT NAMES:</b> H. B. Robinson Unit No. 2				<b>Do Not Remove ACKNOWLEDGED</b>			

FOR ACTION/INFORMATION 5-2-73 AB

BUTLER(L) W/ Copies	SCHWENCER(L) W/ Copies	ZIEMANN(L) W/ Copies	YOUNGBLOOD(E) W/ Copies
CLARK(L) W/ Copies	STOLZ(L) W/ Copies	ROUSE(FM) W/ Copies	REGAN(E) W/ Copies
GOLLER(L) W/ Copies	VASSALLO(L) W/ Copies	DICKER(E) W/ Copies	W/ Copies
KNIEL(L) W/ Copies	← SCHEMEL(L) W/ 7 Copies	KNIGHTON(E) W/ Copies	W/ Copies
			W/ Copies

**INTERNAL DISTRIBUTION**

<b>REG FILE</b>	<b>TECH REVIEW</b>	DENTON	F & M	WADE	E
✓ AEC PDR	✓ HENDRIE	GRIMES	SMILEY	BROWN	E
✓ OGC, ROOM P-506A	✓ SCHROEDER	GAMMILL	NUSSBAUMER	G. WILLIAMS	E
✓ MUNTZING/STAFF	✓ MACCARY	KASTNER		SHEPPARD	E
✓ CASE	✓ KNIGHT	BALLARD	<b>LIC ASST.</b>		
GIAMBUSSO	✓ PAWLICKI	SPANGLER	<b>SERVICE</b>	L	<b>A/T IND</b>
BOYD	✓ SHAO		WILSON	L	BRAITMAN
V. MOORE-L(BWR)	✓ STELLO	<b>ENVIRO</b>	GOULBOURNE	L	SALTZMAN
DEYOUNG-L(PWR)	✓ HOUSTON	<b>MULLER</b>	SMITH	L	
✓ SKOVHOLT-L	✓ NOVAK	DICKER	GEARIN	L	PLANS
P. COLLINS	✓ ROSS	KNIGHTON	DIGGS	L	MCDONALD
	✓ IPPOLITO	YOUNGBLOOD	TEETS	L	DUBE
<b>REG OPR</b>	✓ TEDESCO	REGAN	LEE	L	
✓ <b>FILE &amp; REGION(2)</b>	✓ LONG	PROJ LEADER	MAIGRET	L	<b>INFO</b>
✓ MORRIS	✓ LAINAS		SHAFFER	F & M	C. MILES
✓ STEELE	✓ BENAROYA	<b>HARLESS</b>			
	✓ VOLLMER				

**EXTERNAL DISTRIBUTION**



✓ 1-LOCAL PDR Hartville, S. C.		1-PDR-SAN/LA/NY
✓ 1-DTIE(ABERNATHY)	(1)(2)(9)-NATIONAL LAB'S	1- GERALD LELLOUCHE
✓ 1-NSIC(BUCHANAN)	1-R. CARROLL-C, GT-B227	BROOKHAVEN NAT. LAB
1-ASLB-YORE/SAYRE	1- R. CATLIN,E-256-GT	1-AGMED(WALTER KOESTER,
WOODWARD/H ST.	1- CONSULTANT'S	RM C-427, GT)
✓ 16-CYS ACRS HOLDING SENT TO LIC ASST.	NEWMARK/BLUME/AGABIAN	1- RD...MULLER...F-309GT
S. TEETS ON 5-2-73	1- GERLAD ULRIKSON....ORNL	

**CP&L**

Carolina Power &amp; Light Company

April 26, 1973

50 - 261



Mr. John F. O'Leary  
 Directorate of Reactor Licensing  
 U. S. Atomic Energy Commission  
 Washington, D. C. 20545

Dear Mr. O'Leary:

H. B. ROBINSON UNIT NO. 2  
 LICENSE DPR-23  
VIOLATION OF PLANT ADMINISTRATIVE PROCEDURES

This letter reports a violation of Plant Administrative Procedures as required by Technical Specification 6.6.3.d. At 1030 on March 27, 1973, a man was instructed to check for leakage in the reactor sump area. A Radiation Control and Test Technician accompanied him due to the high radiation levels involved (about 20 R/hr.).

As a result of this inspection and prior work for the morning, the man received a total of 1282 mrem. When added to his prior quarterly exposure of 1021 mrem, a total quarterly exposure of 2303 mrem resulted. This was in excess of the 2000 mrem quarterly limit which the man had been authorized to receive.

A Plant Nuclear Safety Committee meeting was held at 1800 on March 27, 1973, to consider this situation. It was decided to control containment access during the remainder of the outage with Special Radiation Work Permits and to require that each man entering containment be informed and aware of his remaining dose. All RC&T technicians have been instructed on the importance of knowing the exposure limit and the exposure remaining of any individual working in their area.

Yours very truly,

*N. B. Bessac*  
 N. B. Bessac

Manager  
 Nuclear Generation

BJF:mp

cc: Mr. C. D. Barham  
 Mr. B. J. Furr  
 Mr. D. V. Menscer  
 Mr. E. E. Utley