

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 4095

FILE:

FROM: Carolina Power & Light Company Raleigh, North Carolina 27602 E. E. Utley			DATE OF DOC 6-14-73	DATE REC'D 6-25-73	LTR x	MEMO	RPT	OTHER
TO: D. J. Skovholt			ORIG 3 signed	CC 37	OTHER	SENT AEC PDR X SENT LOCAL PDR X		
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 40	DOCKET NO: 50-261			

DESCRIPTION:
Ltr re our 4-13-73 ltr...furnishing info regarding personnel radiation exposure...trans:

ENCLOSURES:
Table - Personnel Radiation Exposure

ACKNOWLEDGED DO NOT REMOVE

PLANT NAME: H. B. Robinson, Unit # 2

(40 cys rec'd)

FOR ACTION/INFORMATION 6-25-73 fod

BUTLER(L)	SCHWENCER(L)	ZIEMANN(L)	REGAN(E)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	✓KASTNER
W/ Copies	W/ Copies	W/ Copies	W/ 3 Copies
GOLLER(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL(L)	✓SCHEMEL(L)	YOUNGBLOOD(E)	
W/ Copies	W/2 Copies(INFO)	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

✓REG FILE	TECH REVIEW	DENTON	LIC ASST	A/T IND
✓AEC PDR	HENDRIE	GRIMES	BROWN (E)	BRAITMAN
OGC, ROOM P-506A	SCHROEDER	GAMMILL	DIGGS (L)	SALTZMAN
MUNTZING/STAFF	MACCARY	KASTNER	GEARIN (L)	
CASE	KNIGHT	BALLARD	GOULBOURNE (L)	PLANS
GIAMBUSSO	PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	SHAO		MAIGRET (L)	DUBE
MOORE (L)(BWR)	STELLO	ENVIRO	SERVICE (L)	
DEYOUNG(L)(PWR)	HOUSTON	MULLER	SHEPPARD (E)	INFO
SKOVHOLT (L)	NOVAK	DICKER	SMITH (L)	C. MILES
P. COLLINS	ROSS	KNIGHTON	✓TEETS (L)	
REG OPR	IPPOLITO	YOUNGBLOOD	WADE (E)	
✓FILE & REGION(3)	TEDESCO	REGAN	WILLIAMS (E)	
MORRIS	LONG	PROJECT LDR	WILSON (L)	
STEELE	LAINAS			
	BENAROYA			
	VOLLMER	HARLESS		

EXTERNAL DISTRIBUTION

✓1 - LOCAL PDR Hartville, S. C.	(1) (2) (9)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
1 - DTIE(ABERNATHY)	1-R. CARROLL-OC,GT-B227	1-GERALD LELLOUCHE
1 - NSIC(BUCHANAN)	1-R. CATLIN, E-256-GT	BROOKHAVEN NAT. LAB
1 - ASLB(YORE/SAYRE/ WOODARD/"H" ST.	1-CONSULTANT'S	1-AGMED(WALTER KOESTER
✓16 - CYS ACRS XXXXXX Sent 6-25-73 to	NEWMARK/BLUME/AGBABIAN	RM-C-427-GT
S. Teets for Dist.	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT



Carolina Power & Light Company

50 - 261

June 14, 1973

Regulatory

File Cy.

File: NG-5213

NG-73-105

Mr. Donald J. Skovholt
Assistant Director for Operating Reactors
Directorate of Licensing
U. S. Atomic Energy Commission
Washington, D.C. 20545


Dear Mr. Skovholt:

H. B. ROBINSON UNIT NO. 2
LICENSE NO. DPR-23
PERSONNEL RADIATION EXPOSURE



In response to your letter of April 13, 1973, an investigation of personnel radiation exposure records was conducted for the Robinson Plant. A listing of the desired information is enclosed. In some cases, existing records did not permit exact determination of duty function. For these cases, reasonable estimates were made.


Very truly yours,


E. E. Utley
Vice President
Bulk Power Supply

HSZ/DBW/jb

Enclosure

cc: Messrs. C. D. Barham
N. B. Bessac
B. J. Furr
D. V. Menscer
D. B. Waters



PERSONNEL RADIATION EXPOSURE

Plant Personnel

	<u>Duty</u>	<u>No. with $\geq$ 100 mrem</u>			<u>Total Man-rem</u>		
		<u>1970</u>	<u>1971</u>	<u>1972</u>	<u>1970</u>	<u>1971</u>	<u>1972</u>
1)	Routine Surveillance and Inspection	0	21	55	0	7	42
2)	Routine Maintenance	0	16	39	0	3	36
3)	Special Maintenance	0	0	0	0	0	0
4)	Routine Refueling Ops.	NA	NA	NA	NA	NA	NA
5)	Special Refueling Ops.	NA	NA	NA	NA	NA	NA
6)	Special Inspection	0	4	4	0	3	2

Contractor Personnel

	<u>Duty</u>	<u>No. with $\geq$ 100 mrem</u>			<u>Total Man-rem</u>		
		<u>1970</u>	<u>1971</u>	<u>1972</u>	<u>1970</u>	<u>1971</u>	<u>1972</u>
1)	Special Maintenance	0	235	142	0	342	132
2)	Inspection	0	7	5	0	9	5

NA = Not Applicable