



Exelon Generation®

Theresa Darling
Acting Regulatory Assurance Manager – Nine Mile Point

P.O. Box 63
Lycoming, NY 13093

315-349-2221 Office
www.exeloncorp.com

Theresa.darling@exeloncorp.com

August 22, 2014

U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

ATTN: Document Control Desk
Director, Division of Spent Fuel Storage and Transportation
Office of Nuclear Material Safety and Safeguards

Nine Mile Point Nuclear Station, Units 1 and 2
Renewed Facility Operating License Nos. DPR-63 and NPF-69
Docket Nos. 50-220 and 50-410

Nine Mile Point Nuclear Station Independent Spent Fuel Storage
Installation
General License
Docket No. 72-1036

SUBJECT: General License 30-day Cask Registration Notification and Thermal
Performance Assessment

Pursuant to the requirements of 10 CFR 72.212(b)(2), this letter provides the information to register the use of three approved spent fuel storage casks at the Nine Mile Point Nuclear Station (NMPNS) Independent Spent Fuel Storage Installation (ISFSI).

Licensee's Name:	Nine Mile Point Nuclear Station, LLC
Address:	PO Box 63 Lycoming, NY 13093
Reactor License Numbers:	DPR-63 and NPF-69
Docket Numbers:	50-220, 50-410 and 72-1036
Person Responsible for Providing additional information:	Ms. Theresa H. Darling 315-349-2221
Cask Certificate Number:	1004
Certificate Amendment Number:	10
Cask Model Number:	NUHOMS®-61BTH
Cask Identification Numbers:	NMP61BTH-1-A-2-017, loaded July 25, 2014 NMP61BTH-1-A-2-018, loaded July 31, 2014 NMP61BTH-1-A-2-019, loaded August 7, 2014

NM5526

The Technical Specifications (TS) for Certificate of Compliance (CoC) No. 1004, Amendment No. 10, §1.1.7 "Special Requirements for First System in Place", requires the results of the temperature measurements of the first Dry Shielded Canister (DSC) placed in service be submitted to the NRC for evaluation and assessment. Additionally, this section of TS requires subsequent users of the system to report heat loads higher than the first user. The first user of the NUHOMS® CoC No. 1004, Duke Energy, submitted the heat transfer characteristics for an 18.95 kilowatt (kW) Dry Shielded Canister (DSC) in a letter to the NRC, from Duke Energy, "Cask Certificate of Compliance, Docket No.: 72-1004, 30-day Report for Higher Canister Heat Loading per General Requirement Section 1.1.7," dated August 8, 2007 (ML072340622). The first DSC loaded at NMPNS had a heat load of 7.30 kW, as reported in our letter dated October 17, 2012.

A summary of the thermal performance of the 17th through 19th DSCs in place at the NMPNS ISFSI is submitted for your information.

Horizontal Storage Module (HSM) Model: NUHOMS® Model 102

HSM Identification Number: 7DFS-HSM003G
Cask: NMP61BTH-1-A-2-017
Calculated Heat Load: 7.408 kW
Calculated ΔT : 42 degrees F
Actual ΔT (Note 1): 25.05 degrees F


HSM Identification Number: 7DFS-HSM003H
Cask: NMP61BTH-1-A-2-018
Calculated Heat Load: 7.389 kW
Calculated ΔT : 42.5 degrees F
Actual ΔT (Note 1): 27.85 degrees F

HSM Identification Number: 7DFS-HSM003I
Cask: NMP61BTH-1-A-2-019
Calculated Heat Load: 7.340 kW
Calculated ΔT : 42 degrees F
Actual ΔT (Note 1): 37.3 degrees F

Note 1: The actual ΔT represents the measured ΔT obtained during equilibrium conditions. Equilibrium conditions were achieved when the daily temperature change observed was less than 6 degrees F over three consecutive days.

This letter contains no NRC commitments. Should you have any questions regarding the information in this submittal, please contact me at (315) 349-2221.

Sincerely,



Theresa H. Darling
Acting Regulatory Assurance Manager

Document Control Desk

August 22, 2014

Page 3

cc: NRC Regional Administrator, Region I
NRC Resident Inspector
NRR Project Manager