

30-261

## NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:

Mr. Robert W. Reid

FROM:

Carolina Power & Light Company  
Raleigh, North Carolina  
E. E. Utley

DATE OF DOCUMENT

5/10/77

DATE RECEIVED

5/16/77

☒ LETTER  
☒ ORIGINAL  
☐ COPY☒ NOTORIZED  
☒ NCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

3 SIGNED

## DESCRIPTION

Ltr. notorized 5/10/77.....trans the  
following:

ACKNOWLEDGED

(1-P)

PLANT NAME: DO NOT REMOVE  
H. B. Robinson Unit, No. 2

RJL

## ENCLOSURE

Amdt. to OL/change to tech specs...  
concerning Primary System Surveillance..

(1-P)

(40 cys rec'd)

## SAFETY

## FOR ACTION/INFORMATION

## ENVIRO

ASSIGNED AD:

BRANCH CHIEF:

PROJECT MANAGER:

LIC. ASST. :

Reid (S)  
Zwetzky  
Ingram

ASSIGNED AD:

BRANCH CHIEF:

PROJECT MANAGER:

LIC. ASST. :

## INTERNAL DISTRIBUTION

REG-FILE

NRC PDR

I &amp; E (2)

OELD

GOSSICK &amp; STAFF

MIPC

CASE

HANAUER

HARLESS

SYSTEMS SAFETY

HEINEMAN

SCHROEDER

ENGINEERING

MACARRY

BOSNAK

SIHWEIL

PAWLICKI

PLANT SYSTEMS

TEDESCO

BENAROYA

LAINAS

IPPOLITO

KIRKWOOD

OPERATING REACTORS

STELLO

SITE SAFETY &amp; ENV

ENVIRO ANALYSIS

DENTON &amp; MULLER

ENVIRO TECH.

ERNST

BALLARD

YOUNGBLOOD

SITE TECH.

GAMMILL

STEPP

HULMAN

SITE ANALYSIS

VOLLMER

BUNCH

J. COLLINS

KREGER

PROJECT MANAGEMENT

BOYD

P. COLLINS

HOUSTON

PETERSON

MELTZ

HEITEMES

SKOVHOLT

REACTOR SAFETY

ROSS

NOVAK

ROSZTOCZY

CHECK

AT &amp; I

SALTZMAN

RUTBERG

OPERATING TECH.

EISENHUT

SHAO

BAER

BUTLER

GRIMES

## EXTERNAL DISTRIBUTION

LPDR: Hartsville, SC

TIC:

NSIC:

ASLB:

ACRS/6 CYS -HOLDING/SENT

NAT, LAB:

REG V, IE

LA PDR

CONSULTANTS:

BROOKHAVEN NAT. LAB.

ULRIKSON (ORNL)

## CONTROL NUMBER

771360301

2  
60



Carolina Power & Light Company

May 10, 1977

FILE: NG-3514 (R)

SERIAL: NG-77-565

Office of Nuclear Reactor Regulation  
Attn: Mr. Robert W. Reid, Chief  
Operating Reactor Branch No. 4  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

**REGULATORY DOCKET FILE COPY**

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

DOCKET NO. 50-261

FACILITY OPERATING LICENSE NO. DPR-23

REQUEST FOR LICENSE AMENDMENT - REVISION OF TECHNICAL SPECIFICATIONS

Dear Mr. Reid:

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, Carolina Power & Light Company (CP&L) hereby requests a revision to the Technical Specifications for its H. B. Robinson Steam Electric Plant, Unit No. 2.


This revision has been prepared to preclude conflicts between the inservice inspection and testing requirements set forth in Section XI of the ASME, Boiler and Pressure Vessel Code, and Addenda and the current Technical Specifications. For H. B. Robinson Steam Electric Plant, Unit No. 2 the effective ASME code is determined to be the 1974 edition of Section XI through Summer 1975 Addenda. The next regular 40-month inspection interval commences November 7, 1977.

Accordingly, it is requested that the entire section 4.2 (pages 4.2-1 through 4.2-24) of the H. B. Robinson Steam Electric Plant, Unit No. 2 Technical Specifications be deleted and replaced with the attached replacement page. Appropriate changes are indicated by a vertical line in the margin.

In consonance with the commencement of the next regular 40-month inspection interval, it is requested that this Technical Specification change be issued with an effective date of November 7, 1977.

Yours very truly,

E. E. Utley  
Senior Vice President  
Power Supply



WH/gsm

Attachment

Sworn to and subscribed before me this 10th day of May, 1977.

Notary Public

My commission expires July 4, 1980.

171360301

## 4.2 Primary System Surveillance

### Applicability

Applies to in-service structural surveillance of the reactor vessel and primary system boundary.

### Objective

To assure the continued integrity of the primary system boundary.

### Specification

#### 4.2.1

- a. Inservice inspection of ASME Code Class 1, Class 2 and Class 3 components shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the NRC pursuant to 10 CFR 50, Section 50.55a(g) (6) (i).
- b. Inservice testing of ASME Code Class 1, Class 2 and Class 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the NRC pursuant to 10 CFR 50, Section 50.55a(g) (6) (i).