



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION II
245 PEACHTREE CENTER AVENUE NE, SUITE 1200
ATLANTA, GEORGIA 30303-1257

September 2, 2014

Mr. Benjamin C. Waldrep
Site Vice President
Duke Energy Progress, Inc.
Shearon Harris Nuclear Power Plant
P.O. Box 165, Mail Code: Zone 1
New Hill, NC 27562-0165

SUBJECT: MID-CYCLE ASSESSMENT LETTER FOR SHEARON HARRIS NUCLEAR
POWER PLANT – NRC INSPECTION REPORT 05000400/2014006

Dear Mr. Waldrep:

On August 13, 2014, the Nuclear Regulatory Commission (NRC) completed its mid-cycle performance review of Shearon Harris Nuclear Power Plant. The NRC reviewed the most recent quarterly performance indicators (PIs) in addition to inspection results and enforcement actions from July 1, 2013, through June 30, 2014. This letter informs you of the NRC's assessment of your facility during this period and its plans for future inspections at your facility.

The NRC determined that overall, Shearon Harris Nuclear Power Plant, operated in a manner that preserved public health and safety and met all cornerstone objectives. The NRC determined the performance at Shearon Harris Nuclear Power Plant, during the most recent quarter was within the Licensee Response Column of the NRC's Reactor Oversight Process (ROP) Action Matrix because all inspection findings had very low (i.e., green) safety significance, and all PIs indicated that your performance was within the nominal, expected range (i.e., green). Therefore, the NRC plans to conduct ROP baseline inspections at your facility.

As a result of the Safety Culture Common Language Initiative, the terminology and coding of cross-cutting aspects were revised. All cross-cutting aspects identified during inspections conducted in calendar year 2014 reflect this revision to Inspection Manual Chapter (IMC) 0310. Cross-cutting aspects identified in 2013 using the 2013 terminology were converted to the latest revision in accordance with the cross-reference in IMC 0310 during the mid-cycle assessment review and evaluated for cross-cutting themes and potential substantive cross-cutting issues in accordance with IMC 0305.

The enclosed inspection plan lists the inspections scheduled through December 31, 2015. Routine inspections performed by resident inspectors are not included in the inspection plan. The inspections listed during the last nine months of the inspection plan are tentative and may be revised at the end-of-cycle performance review. The NRC provides the inspection plan to allow for the resolution of any scheduling conflicts and personnel availability issues. The NRC will contact you as soon as possible to discuss changes to the inspection plan should circumstances warrant any changes. This inspection plan does not include security-related inspections, which will be sent via separate, non-publicly available correspondence. We also plan on conducting the following infrequently performed inspections and temporary

instructions: Operator Licensing Exams; and TI 2515/190, Near Term Task Force Recommendation 2.1, Flooding.

In response to the accident at Fukushima, the Commission issued Order EA-12-049, "Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events," which requires licensees to develop, implement, and maintain guidance and strategies to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities following a beyond-design-basis external event. Additionally, the Commission issued Order EA-12-051, "Order Modifying Licenses with Regard to Reliable Spent Fuel Pool Instrumentation," which requires licensees to have a reliable means of remotely monitoring wide-range Spent Fuel Pool levels to support effective prioritization of event mitigation and recovery actions in the event of a beyond-design-basis external event. The NRC is conducting audits of licensee efforts towards compliance with these Orders. This audit includes an onsite component in order for the NRC to evaluate licensee plans for complying with the Orders, as described in site-specific submittals, and to receive and review information relative to associated open items. This onsite activity will occur in the months prior to a declaration of compliance for the first unit at each site, and will aid staff in development of an ultimate Safety Evaluation for the site. The date for the onsite component at your site is scheduled for December 8, 2014. A site-specific audit plan for the visit will be provided in advance to allow sufficient time for preparations.

In accordance with Title 10 of the *Code of Federal Regulations* (10 CFR) 2.390 of the NRC's "Rules of Practice," a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's Agencywide Document Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Please contact me at 404-997-4645 with any questions you may have regarding this letter.

Sincerely,

/RA/

George T. Hopper, Chief
Reactor Projects Branch 4
Division of Reactor Projects

Docket Nos.: 50-400
License Nos.: NPF-63

Enclosure: Harris Inspection/Activity Plan
(09/01/2014 – 12/31/2015)

cc Distribution via ListServ

B. Waldrep

2

We also plan on conducting the following infrequently performed inspections and temporary instructions: Operator Licensing Exams; and TI 2515/190, Near Term Task Force Recommendation 2.1, Flooding.

In response to the accident at Fukushima, the Commission issued Order EA-12-049, "Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events," which requires licensees to develop, implement, and maintain guidance and strategies to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities following a beyond-design-basis external event. Additionally, the Commission issued Order EA-12-051, "Order Modifying Licenses with Regard to Reliable Spent Fuel Pool Instrumentation," which requires licensees to have a reliable means of remotely monitoring wide-range Spent Fuel Pool levels to support effective prioritization of event mitigation and recovery actions in the event of a beyond-design-basis external event. The NRC is conducting audits of licensee efforts towards compliance with these Orders. This audit includes an onsite component in order for the NRC to evaluate licensee plans for complying with the Orders, as described in site-specific submittals, and to receive and review information relative to associated open items. This onsite activity will occur in the months prior to a declaration of compliance for the first unit at each site, and will aid staff in development of an ultimate Safety Evaluation for the site. The date for the onsite component at your site is scheduled for December 8, 2014. A site-specific audit plan for the visit will be provided in advance to allow sufficient time for preparations.

In accordance with Title 10 of the *Code of Federal Regulations* (10 CFR) 2.390 of the NRC's "Rules of Practice," a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's Agencywide Document Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Please contact me at 404-997-4645 with any questions you may have regarding this letter.

Sincerely,

/RA/

George T. Hopper, Chief
Reactor Projects Branch 4
Division of Reactor Projects

Docket Nos.: 50-400
License Nos.: NPF-63

Enclosure: Harris Inspection/Activity Plan
(09/01/2014 – 12/31/2015)

cc Distribution via ListServ

☒ PUBLICLY AVAILABLE ☐ NON-PUBLICLY AVAILABLE ☐ SENSITIVE ☒ NON-SENSITIVE
ADAMS: ☒ Yes ACCESSION NUMBER: ☒ SUNSI REVIEW COMPLETE ☒ FORM 665 ATTACHED

OFFICE	DRP: RII	DRP: RII	DRP: RII		
SIGNATURE	DXW /RA/	JSD /RA/	GTH /RA/		
NAME	DJackson	JDodson	GHopper		
DATE	8/20/2014	8/27/2014	8/27/2014		
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: S:\DRP\PERIODIC ASSESSMENTS & REPORTS\EOC & MID-CYCLE\2014\MID-CYCLE\ADMIN WORKING FOLDER\LETTERS\HARRIS MID-CYCLE LTR 2014.DOCX

B. Waldrep

3

Letter to B. Waldrep from George T. Hopper dated September 2, 2014.

SUBJECT: MID-CYCLE ASSESSMENT LETTER FOR SHEARON HARRIS NUCLEAR
POWER PLANT – NRC INSPECTION REPORT 05000400/2014006

DISTRIBUTION

D. Gamberoni, RII

S. Price, RII

L. Douglas, RII

OE Mail

RIDSNNRRDIRS

PUBLIC

RidsNrrPMShearonHarris Resource

ROP Assessments

ROP Reports

Institute of Nuclear Power Operations (INPO)

Harris
Inspection / Activity Plan
09/01/2014 - 12/31/2015

Unit Number	Planned Dates Start End	Inspection Activity	Title	No. of Staff on Site
		OL EXAM - INITIAL LICENSE EXAM PREP		3
1	10/06/2014 10/10/2014	V23434	HARRIS/NOVEMBER 2014 INITIAL EXAM AT POWER FACILITIES	
		RP - TRANSPORTATION		1
1	10/27/2014 10/31/2014	IP 71124.08	Radioactive Solid Waste Processing and Radioactive Material Handling, Storage, and Transportation	
		OL EXAM - INITIAL LICENSE EXAM WEEK 1		3
1	11/03/2014 11/07/2014	V23434	HARRIS/NOVEMBER 2014 INITIAL EXAM AT POWER FACILITIES	
		OL EXAM - INITIAL LICENSE EXAM WEEK 2		3
1	11/10/2014 11/14/2014	V23434	HARRIS/NOVEMBER 2014 INITIAL EXAM AT POWER FACILITIES	
		ISI - UNIT 1 IN-SERVICE INSPECTION & RVH EXAM		2
1	04/06/2015 04/10/2015	IP 7111108P	Inservice Inspection Activities - PWR	
		RP - RP OCCUPATIONAL BASELINE WEEK 1		2
1	04/13/2015 04/17/2015	IP 71124.01	Radiological Hazard Assessment and Exposure Controls	
1	04/13/2015 04/17/2015	IP 71124.02	Occupational ALARA Planning and Controls	
1	04/13/2015 04/17/2015	IP 71124.03	In-Plant Airborne Radioactivity Control and Mitigation	
1	04/13/2015 04/17/2015	IP 71124.04	Occupational Dose Assessment	
1	04/13/2015 04/17/2015	IP 71124.05	Radiation Monitoring Instrumentation	
1	04/13/2015 04/17/2015	IP 71151	Performance Indicator Verification	
		SGISI - UNIT 1 SG IN-SERVICE INSPECTION		1
1	04/13/2015 04/17/2015	IP 7111108P	Inservice Inspection Activities - PWR	
		RP - RP OCCUPATIONAL BASELINE WEEK 2		3
1	04/27/2015 05/01/2015	IP 71124.01	Radiological Hazard Assessment and Exposure Controls	
1	04/27/2015 05/01/2015	IP 71124.02	Occupational ALARA Planning and Controls	
1	04/27/2015 05/01/2015	IP 71124.03	In-Plant Airborne Radioactivity Control and Mitigation	
1	04/27/2015 05/01/2015	IP 71124.04	Occupational Dose Assessment	
1	04/27/2015 05/01/2015	IP 71124.05	Radiation Monitoring Instrumentation	
1	04/27/2015 05/01/2015	IP 71151	Performance Indicator Verification	
		OL RQ - REQUAL INSP		2
1	08/03/2015 08/07/2015	IP 7111111B	Licensed Operator Requalification Program	
		PI&R - PROBLEM IDENTIFICATION AND RESOLUTION		4
1	09/14/2015 09/18/2015	IP 71152B	Problem Identification and Resolution	
1	09/28/2015 10/02/2015	IP 71152B	Problem Identification and Resolution	
		EP - EP EXERCISE		5
1	10/26/2015 10/30/2015	IP 7111404	Emergency Action Level and Emergency Plan Changes	
1	10/26/2015 10/30/2015	IP 7111407	Exercise Evaluation - Hostile Action (HA) Event	

This report does not include INPO and OUTAGE activities.
This report shows only on-site and announced inspection procedures.

Enclosure

Harris
Inspection / Activity Plan
09/01/2014 - 12/31/2015

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
			EP	- EP EXERCISE	5
1	10/26/2015	10/30/2015	IP 71151	Performance Indicator Verification	
			MODS	- PLANT MODIFICATIONS INSPECTION	6
1	11/16/2015	11/20/2015	IP 7111117T	Evaluations of Changes, Tests, and Experiments and Permanent Plant Modifications	
1	12/07/2015	12/11/2015	IP 7111117T	Evaluations of Changes, Tests, and Experiments and Permanent Plant Modifications	