

Exelon Nuclear

Job Performance Measure

Letdown Orifice Operation

JPM Number: CRa (N-63)

Revision Number: 10

Date: 1/24/2013

Revised By:	<u>Robert Peterson</u> Instructor	<u>3/18/2014</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See
File
Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP CV-9 Rev: 08
Procedure _____ Rev: ___
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Bill Hochstetter (Signature on file)
SME / Instructor

1/24/13
Date

Robert F. Peterson
SME / Instructor

3/18/2014
Date

Revision Record (Summary)

Revision 10

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Validated 03/03/13 by Bill Hochstetter and Rob Lawlor.
- Created from JPM No. N-63

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Line up letdown via BOP CV-9 so that 75 gpm is established. (In IC-100)
3. Turn on a set of Pzr BU heaters. (In IC-100)
4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
5. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Unit 1 NSO.
2. Letdown flow is currently 75 gpm

INITIATING CUE

1. You have been directed to raise letdown flow to 120 gallons per minute and then restore systems to automatic in accordance with BOP CV-9, "Letdown Orifice Isolation", step 2.
2. Inform the US when complete.
3. Another NSO will respond to ALL other Control Room annunciators and conditions.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: 3, 5 & 6

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>1. Refer to BOP CV-9, Letdown Orifice Operation</p> <p>Note: Step 1 may be performed at any time</p> <p>Cue: All prerequisites are met</p>	<ul style="list-style-type: none"> o Locate and OPEN BOP CV-9, step F.2 	_____	_____	_____
<p><u>NOTE</u></p> <p>Provide the examinee with a copy of the BOP CV-9</p> <p>The evaluator may judge the candidate by correctly performing the critical steps, and the candidates' competency by NOT receiving the following alarms:</p> <ul style="list-style-type: none"> • 1-9-B1 LP LTDWN REL TEMP HIGH • 1-9-A1 REGEN HX LTDWN TEMP HIGH <ul style="list-style-type: none"> • 1-9-E2 LTDWN TEMP HIGH • 1-9-D3 CHG LINE FLOW HI LOW • 1-7-B2 RCP SEAL WTR INJ FLOW LOW 				
<p>2. Adjust 1CV121 in MANUAL to compensate for additional letdown flow</p>	<p>At 1PM05J:</p> <ol style="list-style-type: none"> 1) Place 1CV121 in Manual 2) Raise charging flow to about 132 gpm using the raise pushbutton as indicated on 1FI-121A 	_____	_____	_____
<p>*3. Place 1PCV-CV131 to manual and lower letdown pressure to ~180 psig.</p>	<p>At 1PM05J:</p> <ul style="list-style-type: none"> • PLACE 1CV131 in MANUAL <li style="text-align: center;">AND • LOWER letdown pressure to ~180 psig by raising output on 1PK-131 	_____	_____	_____
<p><u>NOTE</u></p> <p>The examinee may decide that step 4 is NOT required and go to step 5.</p>				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
4. If required, ADJUST 1CC130A/B, as necessary	At 1PM05J: ○ Place 1TK-130 in MANUAL AND ○ RAISE Output	—	—	—
*5. Raise letdown flow from 75 gpm to 120 gpm letdown NOTE to Evaluator: Evaluate the alarms that annunciate to determine competency of manual operations of controls in previous 3 steps	At 1PM05J: • SIMULTANEOUSLY OPEN 1CV8149A AND • SIMULTANEOUSLY ADJUST PCV-1CV131 to maintain pressure ~370 psig	—	—	—
*6. Restore 1PCV-CV131 to AUTO	At 1PM05J: • PLACE 1CV131 in AUTO	—	—	—
<u>NOTE</u> If examinee manipulated 1CC130A/B in manual to control letdown temperature perform step 7. If the valve was not manipulated and temperature is normal, step 7 may be bypassed.				
7. Ensure 1CC130A/B is maintaining normal letdown temperature of about 120 °F.	At 1PM05J: ○ Check letdown temp. normal on 1TI-130 • Place 1TK-130 in AUTO	—	—	—

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>8. Adjust 1CV121, in manual to match charging and letdown flow while establishing PZR at program level.</p> <p><i>Cue: This JPM is completed.</i></p>	<p>At 1PM05J:</p> <ul style="list-style-type: none"> ○ Adjust 1CV121 in Manual ○ Verify charging flow is about 12 gpm greater than letdown flow and PZR level is trending to program. ● Place 1FK-121 in AUTO ○ Informs US that 120 gpm letdown flow is in service (and system is restored to automatic). 	<p>_____</p>	<p>_____</p>	<p>_____</p>

RECORD STOP TIME: _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: Letdown Orifice Operation

JPM Number: CRA (N-63) Revision Number: 00

Task Number and Title: 4C.CV-01 PERFORM lineups of the CVCS

K/A Number and Importance: 004A4.06 3.6/3.1

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s):

BOP CV-9 Rev.8 Letdown orifice operation

CRITICAL STEPS (*) 3, 5 & 6

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 NSO.
2. Letdown flow is currently 75 gpm.

INITIATING CUE

1. You have been directed to raise letdown flow to 120 gallons per minute and then restore systems to automatic in accordance with BOP CV-9, "Letdown Orifice Isolation", step 2.
2. Inform the US when complete.
3. Another NSO will respond to ALL other Control Room annunciators and conditions.

Exelon Nuclear

Job Performance Measure

Raise SI Accumulator Pressure (1SI8875B fails to close)

JPM Number: CRb (N-3a)

Revision Number: 3

Date: 9/22/2009

Revised By:	<u>Lynn Sanders *</u> Instructor	<u>9/22/09</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
 Procedure BOP SI-8 Rev: 15
 Procedure _____ Rev: _____
 Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Lynn Sanders / Brian Clark	9/24/09
SME / Instructor	Date

Robert F. Peterson	3/18/2014
SME / Instructor	Date

SME / Instructor	Date

Revision Record (Summary)

Revision 3

- Applied new template TQ-JA-150-02 Rev.1
- Verified/ updated KAs and TPOs to current revision
- Changed Non Licensed Operator to Equipment Operator

SIMULATOR SETUP INSTRUCTIONS

- 1) Reset to IC-101 (from IC-14) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

- 2) Lower 1B SI Accumulator pressure to 600 psig. (In IC-101)

(NOTE: if using a caep, the quotation marks must be straight (plain text) quotes, not "curly quotes" like Word uses.)

- a) `trgset 3 "ZLO1SI8875B(2).gt.0"`
- b) `trg 3 "ior ZDI1SI8875B open"`
- c) `irf nt78 on`

- 3) Put TR 57 on screen 3.

- 4) When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist

- 5) This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the unit NSO.
2. The unit is in Mode 1 steady state power.
3. An improper valve lineup resulted in reducing the 1B SI Accumulator pressure to 600 psig.
4. The improper valve lineup has been corrected.
5. 1BOL 5.1, Accumulators LCOAR, has been initiated.

INITIATING CUE

1. Annunciator 1-5-B2, ACCUM 1B PRESS HIGH LOW, is LIT.
2. The Unit Supervisor directs you to restore the 1B SI Accumulator pressure to within the Technical Specification limits.
3. The nitrogen tube trailer is aligned per BOP NT-9, Nitrogen Tube Trailer Connection/Disconnection.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: 2, 4, 6 & 8

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME: _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. Refer to BOP SI-8, Increasing SI Accumulator Pressure Cue: All prerequisites have been met Cue: (if asked) There are no personnel in CNMT	<ul style="list-style-type: none"> ◦ LOCATE and OPEN BOP SI-8 	_____	_____	_____
*2. Align nitrogen tube trailer Cue: EO reports the Nitrogen Tube Trailer Manifold Discharge Valve is OPEN Cue: EO reports ONT078 is OPEN	DIRECT EO to OPEN: <ul style="list-style-type: none"> • Nitrogen Tube Trailer Manifold Discharge Valve • ONT078 	_____	_____	_____
Evaluator's Note: The following steps are located at 1PM06J.				
3. VERIFY/CLOSE 1SI943, Accumulator vent control valve Cue: 1SI943 POT is set at 0.0	<ul style="list-style-type: none"> ◦ VERIFY/CLOSE 1SI943 	_____	_____	_____
*4. OPEN 1SI8880, Nitrogen supply isolation valve	<ul style="list-style-type: none"> • OPEN 1SI8880 	_____	_____	_____
5. Initiate 1BOL 5.1 Cue: 1BOL 5.1 has been initiated	<ul style="list-style-type: none"> ◦ INITIATE 1BOL 5.1 	_____	_____	_____
*6. OPEN 1SI8875B, 1B Accumulator Vent valve	Start raising accumulator pressure: <ul style="list-style-type: none"> • OPEN 1SI8875B 	_____	_____	_____
7. Monitor pressure increase	<ul style="list-style-type: none"> ◦ Monitor pressure using 1PI-962 & 963 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Evaluator's Note: Alternate path is initiated in the following step.				
*8. CLOSE 1SI8875B, 1B Accumulator Vent valve when accumulator pressure is between 602 and 647 psig. Cue: Unit Supervisor acknowledges that 1SI8875B has failed to close	Stop raising accumulator pressure <ul style="list-style-type: none"> ○ Attempt to CLOSE 1SI8875B when accumulator pressure is between 602 and 647 psig ● Close 1SI8880 to stop pressure increase ○ Inform US of 1SI8875B failure to close 			
Evaluator's Note: 1BOL 5.1 is not exited because 1CV8875B is open.				
10. VERIFY/CLOSE 1SI8880, Nitrogen supply isolation valve	<ul style="list-style-type: none"> ○ CLOSE 1SI8880 			
11. Isolate nitrogen tube trailer Cue: EO reports ONT078 is CLOSED Cue: EO reports the Nitrogen Tube Trailer Manifold Discharge Valve is CLOSED Cue: This JPM is completed	DIRECT EO to CLOSE: <ul style="list-style-type: none"> ● ONT078 ● Nitrogen Tube Trailer Manifold Discharge Valve 			

RECORD STOP TIME: _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** EO RO SRO FS
 STA/IA SRO Cert

JPM Title: Raise SI Accumulator Pressure (1SI8875B fails to close)

JPM Number: CRb (N-3a) Revision Number: 3

Task Number and Title: 4C.SI-04 ADJUST SI accumulator pressure.

K/A Number and Importance: 006A4.02 4.0/3.8

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s):

BOP SI-8, Increasing SI Accumulator Pressure (Rev. 15)

BAR 1-5-B2, ACCUM 1B PRESS HIGH LOW (Rev. 1)

Tech Spec 3.5.1

CRITICAL STEPS (*) 2, 4, 6 & 8

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 8 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the unit NSO.
2. The unit is in Mode 1 steady state power.
3. An improper valve lineup resulted in reducing the 1B SI Accumulator pressure to 600 psig.
4. The improper valve lineup has been corrected.
6. 1BOL 5.1, Accumulators LCOAR, has been initiated.

INITIATING CUE

1. Annunciator 1-5-B2, ACCUM 1B PRESS HIGH LOW, is LIT.
2. The Unit Supervisor directs you to restore the 1B SI Accumulator pressure to within the Technical Specification limits.
3. The nitrogen tube trailer is aligned per BOP NT-9, Nitrogen Tube Trailer Connection/Disconnection.

Exelon Nuclear
Job Performance Measure

Synchronize DG to Bus (Will Not Load)

JPM Number: CRc (N-19a)

Revision Number: 00

Date: 1/24/2013

Revised By: Bill Hochstetter 1/24/13
Instructor Date

Validated By: Pat Comerford 4/7/2014
Operations Dept. Date

Approved By: Brian Lewin 4/7/2014
Operations Representative Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP DG-11 Rev: 25
Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson
SME / Instructor

3/18/2014
Date

SME / Instructor

Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Override DG governor speed adjuster by: (In IC-100)
 - `trgset 3 "zlo1hsdg026(3)>0"`
 - Set trg 3 to neutral position (between Raise and Lower) of dialog box for "zdi1hsdg019"
3. Start 1A DG for loading per BOP DG-11, step F.1. (In IC-100)
 - Clear the local trouble alarm by MRF EG06 RESET.
4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist
5. This completes the setup for this JPM

INITIAL CONDITIONS

1. You are an extra NSO.
2. The unit's ESF busses are being supplied by the SATs.
3. The 1A Diesel Generator has been running unloaded for approximately fifteen minutes after a manual start.
4. Jacket water and lube oil temperatures are acceptable for loading the diesel generator.
5. BOP DG-11 steps F.1 through F.4 have been completed as indicated.

INITIATING CUE:

The Unit Supervisor directs you to parallel and load the 1A Diesel Generator to 5400 KW per step F.5 of BOP DG-11, "Diesel Generator Startup".

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: 6, 7, 8, 9, & 11

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>1. Refer to BOP DG-11, Diesel Generator Startup</p> <p>Cue: All prerequisites have been met</p> <p>Cue: (If asked) The 1A DG was started per step F.1</p> <p>Cue: (If asked) The 1A DG was started fifteen minutes ago</p> <p>Note: Provide the examinee a copy of BOP DG-11 and BOP DG-11T1.</p>	<ul style="list-style-type: none"> LOCATE and OPEN BOP DG-11, step F.5 	_____	_____	_____
<p>2. Notify Electric Operations of pending diesel generator parallel operation, estimated run time, and loading</p> <p>Cue: Electric Operations has been informed</p>	Notify Electric Operations	_____	_____	_____
<p>3. Auto Re-close Circuit Arm Selector Switch</p>	<p>At 1PM01J:</p> <ul style="list-style-type: none"> PLACE Auto Re-close Circuit Arm Selector Switch to SURV TEST 	_____	_____	_____
<p>4. Verify DG operating properly</p>	<p>At 1PM01J, CHECK:</p> <ul style="list-style-type: none"> DG frequency DG voltage 	_____	_____	_____
<p>5. Verify the same voltage across each phase.</p>	<p>At 1PM01J, CHECK:</p> <ul style="list-style-type: none"> DG phase voltages 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*6. Turn on the 1A DG Feed to 141 Sync Selector switch.	At 1PM01J: <ul style="list-style-type: none"> TURN Sync Selector switch for DG 1A Feed to 4KV Bus 141 to ON 	_____	_____	_____
*7. Adjust the incoming voltage.	At 1PM01J: <ul style="list-style-type: none"> ADJUST incoming voltage SLIGHTLY HIGHER than running voltage using DG 1A Volt Adj control 	_____	_____	_____
*8. Adjust 1A DG speed.	At 1PM01J: <ul style="list-style-type: none"> Adjust speed so synchroscope rotates SLOWLY in FAST DIRECTION using DG 1A Gov Adj control 	_____	_____	_____
*9. Synchronize the DG Cue: (If requested) NLO is locally monitoring temperatures per notes in BOP	At 1PM01J: <ul style="list-style-type: none"> PLACE control switch for ACB 1413 to CLOSE when synchroscope is slightly before 12 o'clock 	_____	_____	_____
10. Verify the synchroscope is locked in.	At 1PM01J: <ul style="list-style-type: none"> VERIFY synchroscope "locks in" at 12 o'clock 	_____	_____	_____
*11. Immediately load the 1A DG to 1000 KW. Note: The governor adjust switch is failed such that the diesel generator will NOT load.	At 1PM01J: <ul style="list-style-type: none"> IMMEDIATELY load DG to 1000 KW by going to RAISE on Gov Adj Control OPEN output breaker (Based on NOTE prior to step that closes 1413) 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>12. Notify the US of the unsuccessful loading of the diesel</p> <p>Cue: The Unit Supervisor acknowledges the failure and will initiate an WR for maintenance to investigate.</p> <p>Cue: This JPM is completed.</p>	<ul style="list-style-type: none"> ○ NOTIFY Unit Supervisor of the unsuccessful loading of the diesel 	<hr/>	<hr/>	<hr/>

RECORD STOP TIME: _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: Synchronize D/G to Bus (Will Not load)

JPM Number: CR-c (N-63) Revision Number: 00

Task Number and Title: 4C.DG-02

K/A Number and Importance: 064A2.09 3.1/3.3

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s): BOP DG-11 Rev. 25

CRITICAL STEPS (*) 6, 7, 8, 9, & 11

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are an extra NSO.
2. The unit's ESF busses are being supplied by the SATs.
3. The 1A Diesel Generator has been running unloaded for approximately fifteen minutes after a manual start.
4. Jacket water and lube oil temperatures are acceptable for loading the diesel generator.
5. BOP DG-11 steps F.1 through F.4 have been completed as indicated.

INITIATING CUE:

The Unit Supervisor directs you to parallel and load the 1A Diesel Generator to 5400 KW per step F.5 of BOP DG-1111, "Diesel Generator Startup".

Exelon Nuclear

Job Performance Measure

Turbine Driven Feedwater Pump Swap
(High Vibration)

JPM Number: CRd (N-80a)

Revision Number: 00

Date: 3/18/2014

Revised By:	<u>Robert Peterson</u> Instructor	<u>3/18/2014</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP FW-1 Rev: 18
Procedure _____ Rev:
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

3/18/2014

SME / Instructor

Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Ensure MW OUT is selected.
3. Start the 4th CD/CB pump and 1A MFP. Take 1C MFP off line and reset trip when it has stopped. Open 1FW0012C recirc valve. (In IC-100)
4. Set up triggers for alarms and action as shown: (In IC-100)
 - TRG 7: IMF PN1164 ON** (1C TDFP High Vibration)
 - TRG 8: SET YCY2903_1O=1** (Allows PPC parameter to be set)
 - TRG 9: SET YCY2903_1V=8** (PPC shows 8 MILS vibration on 1C TDFP Brg 2)
 - TRG 10: IMF FW02B 300** (Trips the 1C TDFP after 5 minutes)
5. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
6. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Unit NSO.
2. The unit is at 75% power.
3. 1A and 1B FW pumps are online.
4. The 4th CD/CD pump was started in preparation for this pumps swap.
5. The 1C FW pump is NOT running.

INITIATING CUES

1. The US directs you to place the 1C FW pump on line and take 1A FW pump off line.
2. BOP FW-1, "STARTUP AND SWAPPING OF TURBINE DRIVEN FW PUMPS", has been completed through step 3.e, inclusive, of the main body. The trip test and reset of steps 3.d and 3.e were completed successfully.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: 2, 3, 5 & 7

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p><u>NOTE</u></p> <p>The examinee may want to trend bearing temperatures on the computer per the limitations and actions section of the procedure. TR-34 is snapped into NSO screen 1 on the desk, facing 1PM07J.</p>				
<p>1. Refer to BOP FW-1, Startup and Swapping of a Turbine Driven Main Feedwater Pump</p> <p>Cue: <i>All Prerequisites have been met</i></p>	<p>LOCATE and OPEN BOP FW-1, step F.3.f.</p>	_____	_____	_____
<p>*2. Open LP stop valve</p>	<p>At 1PM04J:</p> <ul style="list-style-type: none"> • DEPRESS and HOLD LP stop valve open pushbutton until backlit 	_____	_____	_____
<p>*3. Open HP stop valve</p>	<p>At 1PM04J:</p> <ul style="list-style-type: none"> • DEPRESS and HOLD HP stop valve open pushbutton until backlit 	_____	_____	_____
<p>4. Ensure manual speed control</p>	<p>At 1PM04J:</p> <ul style="list-style-type: none"> • ENSURE speed setter control indicating light is lit 	_____	_____	_____
<p>*5. Increase speed and maintain for at least 15 minutes.</p>	<p>At 1PM04J:</p> <ul style="list-style-type: none"> • DEPRESS increase speed pushbutton to bring turbine to between 1500 and 2000 RPM. • HOLD speed for at least 15 minutes for warmup. 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p align="center">NOTE: This begins the Alternate Path.</p> <p>Booth operator: At evaluator's cue (~20 seconds after reaching \geq 1500 RPM), Insert Triggers 7, 8, 9 & 10 in order listed. (Triggers are in IC-100) TRG 7: IMF PN1164 ON (1C TDFP High Vibration) TRG 8: SET YCY2903_1O=1 (Allows next parameter to be set) TRG 9: SET YCY2903_1V=8 (PPC shows 8 MILS vibration on 1C TDFP Brg 2) TRG 10: IMF FW02B 300 (Trips 1C TDFP after 5 minutes)</p>				
<p>6. Respond to alarm FW PUMP TURB VIB (1-16-A4)</p> <p>Cue: Unit 2 Assist NSO reports 1VT-FW040 on 1PM12J: 1C TDFP #2 bearing vibration reads 8 MILs</p> <p>Cue: EO reports 1C TDFP is vibrating badly</p>	<p>At 1PM12J, CHECK:</p> <ul style="list-style-type: none"> • BAR 1-16-A4 • FW pump 1C vibration (1VT-FW040 is not modeled on the simulator) ○ Contact EO at 1C TDFP for vibration report 			
<p>*7. Trip 1C TDFP</p>	<p>Limitation E.2: Immediately trip FW pump 1C if excessive vibration of 5 MILS is detected.</p> <p>At 1PM04J:</p> <ul style="list-style-type: none"> • PRESS Turbine Trip Pushbutton ○ Verify Turbine Trip Alarm and backlight ILLUMINATE. 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;">Evaluator Note:</p> <p>If Candidate does NOT trip the 1C TDFP within 5 minutes of receiving the report of high vibration, MF FW02B will automatically insert to trip the 1C TDFP. In the event the TDFP automatically trips because the candidate failed to take action, Critical Step #7 was not met.</p> <p><i>Cue: EO reports he tripped the 1C TDFP locally because of high vibration.</i></p>				
Cue: <u>This JPM is completed</u>				

RECORD STOP TIME: _____



JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: Swap a Turbine Driven Feedwater Pump (High Vibration)

JPM Number: CRd (N-80a) Revision Number: 00

Task Number and Title: 4C.FW-06

K/A Number and Importance: 057A2.07 3.0/3.3

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s): 1BOP FW-1, Rev 18; BAR 1-16-A4

CRITICAL STEPS (*) 2, 3, 5 & 7

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 10 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit NSO.
2. The unit is at 75% power.
3. 1A and 1B FW pumps are online.
4. The 4th CD/CD pump was started in preparation for this pumps swap.
5. The 1C FW pump is NOT running.

INITIATING CUES

1. The US directs you to place the 1C FW pump on line and take 1A FW pump off line.
2. BOP FW-1, "STARTUP AND SWAPPING OF TURBINE DRIVEN FW PUMPS", has been completed through step 3.e, inclusive, of the main body. The trip test and reset of steps 3.d and 3.e were completed successfully.

Exelon Nuclear

Job Performance Measure

Transfer From Feedwater Bypass Valve
To Feedwater Regulating Valve

JPM Number: CRe

Revision Number: 00

Date: 3/18/2014

Revised By:	<u>Robert Peterson</u> Instructor	<u>3/18/2014</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure 1BGP 100-3 Rev: 85
Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson

3/18/2014

SME / Instructor

Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-101 (from IC-14) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
3. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. Unit 1 is in 1BGP 100-3, Power Ascension following a refueling outage.
3. Power is currently being held stable while transferring feed control to the Feed Water Reg Valves.

INITIATING CUES

The Unit Supervisor has directed you to perform 1BGP 100-3, Step 40, Transfer Feedwater Flow Control from the Feed Reg Bypass Valves to the Main Feed Reg Valves.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps: 7, 8, 9 & 10

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. Refer to 1BGP 100-3, Step 40. Note: Provide the examinee a copy of 1BGP 100-3, Step 40.	LOCATE and OPEN 1BGP 100-3, Step 40.	_____	_____	_____
2. Ensure Turbine Generator is at approximately 20% power (250 MW). If TG is NOT at 250 MW: Cue: The TG is online at 250 MW.	Determine TG is at 250 MW.	_____	_____	_____
3. Maintain SG levels using FWRBV.	Maintains levels at or slightly above program level.	_____	_____	_____
4. Verified closed FWRV 1FW510-540.	Verifies that 1FW510-540 are closed.	_____	_____	_____
5. Verify open FWR Isol Valves 1FW006A-D	Verifies 1FW006A-D are open.	_____	_____	_____

Evaluator's Note:
Valve adjustments will be made to one pair of valves on a SG at a time. Steps 6 – 10 will be repeated for each SG.

Evaluator's Note:
It is only necessary to have the candidate transfer TWO valve controls to complete the JPM.

6. Verify 1FW510/520 to MANUAL.	Verifies 1FW510/520 in MANUAL.	_____	_____	_____
*7. Place 1FW510A/520A to MANUAL.	Places 1FW510A/520A in MANUAL.	_____	_____	_____

ELEMENT

STANDARD

SAT

UNSAT

**Comment
Number**

NOTE:
Steps 8 and 9 will be done concurrently for one pair of valves at a time.

*8. Slowly close 1FW510A/520A.	1FW510A/520A are closed.	_____	_____	_____
*9. Slowly open 1FW510/520.	Controls feedwater flow and SG level near program level.	_____	_____	_____
*10. Place 1FW510/520 to AUTO.	1FW510A/520 are fully closed and feedwater flow and SG levels are stable with FWRV in AUTO.	_____	_____	_____

Cue: This JPM is completed.

RECORD STOP TIME: _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: Transfer From Feedwater Bypass Valve to Feedwater Regulating Valve

JPM Number: CRc Revision Number: 00

Task Number and Title: 4C.FW-01

K/A Number and Importance: 035A4.01 3.7/3.6

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s): 1BGP 100-3, Rev 85

CRITICAL STEPS (*) 7, 8, 9 & 10

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. Unit 1 is in 1BGP 100-3, Power Ascension following a refueling outage.
3. Power is currently being held stable while transferring feed control to the Feed Water Reg Valves.

INITIATING CUES

The Unit Supervisor has directed you to perform 1BGP 100-3, Step 40, Transfer Feedwater Flow Control from the Feed Reg Bypass Valves to the Main Feed Reg Valves.

Exelon Nuclear

Job Performance Measure

SX Flooding Requiring RCFC Isolation
(Running Train Leak)

JPM Number: CRf

Revision Number: 0

Date: 3/18/2014

Revised By:	<u>Robert Peterson</u> Instructor	<u>3/18/2014</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure 1BOA PRI-7 Rev: 106
Procedure _____ Rev: _____
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson
SME / Instructor

3/18/2014
Date

Revision Record (Summary)

Revision 0

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-100 (from IC-18, 75% power) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Insert MF SW02A at 10 GPM. (In IC-100)
3. Acknowledge CNMT DRAIN LEAK DETECT FLOW HIGH alarm (1-1-A2). (In IC-100)
4. IMF PN1423 OFF and PN1427 OFF to prevent nuisance alarms from the effects of this realignment on the 1A CNMT chiller.
5. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
6. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. Unit 1 is experiencing a loss of Essential Service Water.

INITIATING CUES

1. Cnmt Floor Drain Sump (1FT-RF008) indicates ~1.2 GPM flow.
2. The Unit Supervisor has directed you to perform the actions necessary to isolate the leak per 1BOA PRI-7, Essential Service Water Malfunction, step 5.d.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: 6, 7 & 8

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. Refer to 1BOA PRI-7, step 5.d, Essential Service Water Malfunction Note: Provide the examinee a copy of 1BOA PRI-7.	LOCATE and OPEN 1BOA PRI-7, step 5.d			
2. Shutdown the NON-running SX pump's train RCFCs.	Train 1B: <ul style="list-style-type: none"> • Stop 1B RCFC ○ Stop 1D RCFC 			
3. Close the associated RCFC train isolation valves.	Train 1B: <ul style="list-style-type: none"> • Close 1SX016B • Close 1SX027B 			
4. Check if the leak has stopped.	Leak has not stopped - CNMT sump recorders are still trending up.			
5. Open the associated RCFC train isolation valves.	Train 1B <ul style="list-style-type: none"> • Open 1SX016B • Open 1SX027B 			
EVALUATOR: The operator MAY start the NON-running SX pump's train RCFCs 1B and 1D in High Speed.				
BOOTH OPERATOR: Candidate may elect to have the EO start the Aux Lube Oil Pump(s) for either or both SX pumps. The RFs are: <ul style="list-style-type: none"> • MRF SW03 ON for 1A SX pump • MRF SW04 ON for 1B SX pump 				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*6. Start the NON-running SX Pump and stop the running SX Pump.	<ul style="list-style-type: none"> • Start 1B SX Pump • Stop 1A SX Pump 	_____	_____	_____
<p style="text-align: center;">EVALUATOR:</p> <p>The next realignment will cause the 1A CNMT chiller to trip on high condenser pressure after a few minutes. The alarms are overridden OFF to prevent a distraction. If the candidate addresses the need to realign the CNMT chiller or goes to check on the chiller status, provide the cue.</p> <p style="text-align: center;"><i>CUE: An extra NSO will be assigned to realign the CNMT Chiller. Continue the assigned task.</i></p>				
*7. Shutdown the NON-running SX pump's train RCFCs.	Train 1A: <ul style="list-style-type: none"> • Stop 1A RCFC • Stop 1C RCFC 	_____	_____	_____
*8. Close the associated RCFC train isolation valves.	Train 1A: <ul style="list-style-type: none"> • Close 1SX016A • Close 1SX027A 	_____	_____	_____
9. Check if the leak has stopped.	Leak has stopped - CNMT sump recorders stop trending up.	_____	_____	_____
10. Inform the US that leak is isolated. <i>Cue: This JPM is completed.</i>	Inform US that SX leak has stopped and one train of RCFC has been isolated.	_____	_____	_____

RECORD STOP TIME: _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: SX Flooding Requiring RCFC Isolation (Running Train Leak)

JPM Number: CRf Revision Number: 00

Task Number and Title: 4D.OA-69

K/A Number and Importance: 022A2.05 3.1/3.5

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s): 1BOA PRI-7. Rev 106

CRITICAL STEPS (*) 6, 7 & 8

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. Unit 1 is experiencing a loss of Essential Service Water.

INITIATING CUES

1. Cnmt Floor Drain Sump (1FT-RF008) indicates ~1.2 GPM flow.
2. The Unit Supervisor has directed you to perform the actions necessary to isolate the leak per 1BOA PRI-7, Essential Service Water Malfunction, step 5.d.

Exelon Nuclear

Job Performance Measure

Containment Release
(With Rad Alarm)

JPM Number: CRg

Revision Number: 02

Date: 3/18/2014

Revised By:	<u>Robert Peterson</u> Instructor	<u>3/18/2014</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP VQ-6 Rev: 7
Procedure BCP 400 TCNMT/ROUTINE Rev: 23
Procedure BAR RM11-4-1AR12J Rev: 10
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson _____

3/18/2014

SME / Instructor

Date

Revision Record (Summary)

Revision 2

Converted to current format and verified procedure steps. 3/18/2014 RFP

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-101 (from IC-14) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. Insert overrides and MF so CNMT pressure indicates 0.9 PSIG (in IC-101) SMDG CH6
 - IMF PN1259 ON (*CNMT Internal press HIGH alarm ON*)
 - IOR ZAO1PDIVP231 0.9 (*CNMT pressure indicated at 0.9#*)
 - IOR ZAO1PDIVP236 0.9
 - IOR ZAO1PIPC004 0.9
 - IOR ZAO1PIPC005 0.9
 - imf ch08a 0.9
 - imf ch08b 0.9
 - imf ch08c 0.9
 - imf ch08d 0.9
3. IMF RM05O to prevent automatic CNMT Vent Isolation actuation. (in IC-101)
4. IMF RM03R to cause 1AR12J alarm spike at evaluator's direction. (Trigger 12 in IC-101)
5. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
6. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. A Unit 1 Containment Vent Release Package is approved for release.

INITIATING CUES

The Unit Supervisor has directed you to perform BOP VQ-6, Containment Mini-Purge System Operation to vent Unit 1 Containment in accordance with step 6 of BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form, Routine Containment Release. All containment release paperwork has been verified acceptable up to step 6.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps: 5 & 8

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME _____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p style="text-align: center;"><u>NOTE</u></p> <p>Provide the candidate with a copy of BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form, Routine Containment Release completed up to step 6 with approval for release.</p>				
<p>1. Refer to BOP VQ-6, Containment Mini-Purge System Operation.</p> <p>Cue: Provide copy of BOP VQ-6 when candidate locates procedure book.</p>	<ul style="list-style-type: none"> LOCATE and OPEN BOP VQ-6 	_____	_____	_____
<p>2. Review BOP VQ-6, steps prior to main body.</p> <p>Cue: All prerequisites are met.</p>	<ul style="list-style-type: none"> Review Prerequisites, Precautions, and Limitations and Actions 	_____	_____	_____
<p style="text-align: center;"><u>NOTE:</u></p> <p style="text-align: center;">Steps 3 and 4 may be performed in any order.</p>				
<p>3. Enter data into release form</p>	<p>Record on release form:</p> <ul style="list-style-type: none"> Unit 1 Release expiration time 0.9 PSIG 	_____	_____	_____
<p>4. Verify aux building ventilation</p>	<ul style="list-style-type: none"> 0B VA Exhaust Fan is in operation. 	_____	_____	_____

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*5. Open CNMT Mini-Flow Purge Exhaust Isolation valves.	At 0PM02J: <ul style="list-style-type: none"> • 1VQ005A OPEN light is LIT • 1VQ005B OPEN light is LIT • 1VQ005C OPEN light is LIT 			
<p><u>EVALUATOR NOTE</u></p> <p>Shortly after the release is started, CUE the Booth Operator to insert Trigger 12 so 1AR12J, Unit 1 CNMT Fuel Handling Incident Rad monitor, will spike high.</p> <p>This would result in a CNMT Vent Isolation Signal that should close the B train valve 1VQ005B, but the isolation signal is not generated and the valve fails to automatically close.</p> <p>If the monitor is green by the time the candidate interrogates the RM-11, CUE the Booth Operator to spike it again.</p>				
6. Record the time the valves were opened and release began on the Gaseous Effluent Release Form.	<ul style="list-style-type: none"> • Record the start time of the release on the Gaseous Effluent Release Form. ○ Log in unit log 			
<p>NOTE:</p> <p>The alternate path starts here when a containment vent isolation signal from 1AR12J fails to close 1VQ005B.</p> <p>Booth Operator:</p> <p>IMF RM03R at Evaluator's discretion; after release has begun, and again when the candidate checks the RM-11, for candidate to see the spike on the RM11.</p>				

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>7. Respond to RM-11 alarm.</p> <p>NOTE: If the candidate does not respond to RM-11 alarm then:</p> <p>Cue: The Unit Supervisor directs you to respond to the RM-11 alarm.</p> <p>Cue: Grid 4, monitor 1AR12J is flashing red (if asked, after alarm acknowledged, channel is full scale high).</p> <p>Cue: (If asked) Annunciator CNMT VENT ISOLATION (1-5-C7) is NOT LIT.</p> <p>Provide BAR 1-5-C7 if candidate indicates they desire to check the alarm response.</p>	<ul style="list-style-type: none"> • Respond to RM-11 alarm • Determine alarming rad monitor ○ Refer to BAR RM11-4-1AR12J and BOP AR/PR-11 series for immediate and subsequent operator actions. • Recognize monitor is in interlock state and B train VQ valve should have closed automatically, but did not. 			
<p>Note: Applicant can use BAR RM11-2-1PR01J, RM11-4-1AR12J, or BOP VQ-6 Limitations and Actions E.2 as guidance to secure the Cnmt Release.</p>				
<p>*8. Stop release as directed per BAR or BOP.</p> <p>Cue: (if asked) CNMT pressure is now .75 psi</p>	<ul style="list-style-type: none"> • At 0PM02J Close: <ul style="list-style-type: none"> ○ 1VQ005A • 1VQ005B ○ 1VQ005C ○ Record data on Release Form 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>9. Inform Supervisor of Rad monitor 1AR12J status, failure of auto Cnmt Vent Isolation, and that release was manually terminated.</p> <p>Cue: The Unit Supervisor / Shift Manager acknowledges condition of 1AR12J, failure of CNMT Vent Isolation auto actuation, manual termination.</p> <p>Cue: This JPM is completed.</p>	<p>Notify Unit Supervisor of release termination.</p>	<hr/>	<hr/>	<hr/>

RECORD STOP TIME _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: Containment Release (With Rad Alarm)

JPM Number: CRh Revision Number: 02

Task Number and Title: IV.C.CC-05

K/A Number and Importance: 072A3.01 Imp Factor: 2.9/3.1

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s): BOP VQ-6 Rev 7 & BCP 400-TCNMT/ROUTINE Rev 23 & BAR RM11-4-1AR12J, Containment Fuel Handling ICDT Rev 10

CRITICAL STEPS (*) 5 & 8

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 10 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Unit 1 Assist NSO.
2. A Unit 1 Containment Vent Release Package is approved for release.

INITIATING CUES

The Unit Supervisor has directed you to perform BOP VQ-6, Containment Mini-Purge System Operation to vent Unit 1 Containment in accordance with step 6 of BCP 400-TCNMT/ROUTINE, Gaseous Effluent Release Form, Routine Containment Release. All containment release paperwork has been verified acceptable up to step 6.

Exelon Nuclear

Job Performance Measure

Start Hydrogen Monitoring System

JPM Number: CRh

Revision Number: 01

Date: 3/24/2014

Revised By:	<u>Robert Peterson</u> Instructor	<u>3/24/2014</u> Date
Validated By:	<u>Pat Comerford</u> Operations Dept.	<u>4/7/2014</u> Date
Approved By:	<u>Brian Lewin</u> Operations Representative	<u>4/7/2014</u> Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 and 12 below.

See File Copy

1. Task description and number, JPM description and number are identified.
2. Knowledge and Abilities (K/A) references are included.
3. Performance location specified. (in-plant, control room, simulator, or other)
4. Initial setup conditions are identified.
5. Initiating cue (and terminating cue if required) are properly identified.
6. Task standards identified and verified by SME review.
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
8. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure BOP PS-9 Rev: 4
Procedure 1BEP-1 Rev: 202
9. Verify cues both verbal and visual are free of conflict.
10. Verify performance time is accurate
11. If the JPM cannot be performed as written with proper responses, then revise the JPM.
12. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

Robert F. Peterson
SME / Instructor

3/24/2014
Date

Revision Record (Summary)

Revision 1

Converted to current format and verified procedure steps. 3/24/2014 RFP

SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC-101 (from IC-14) (password nrc14)

NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. VERIFY/CLOSE 1PS228A, 1PS228B, 1PS229A, 1PS229B (In IC-101)
3. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
4. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are an extra NSO in the control room during a LOCA event.
2. The crew has performed the actions contained in 1BEP-0, Reactor Trip or Safety Injection and is currently in 1BEP-1, Loss of Reactor or Secondary Coolant at step 11.c.
3. Containment Isolation Phase A has just been reset.

INITIATING CUE

The Unit Supervisor has just ordered you to perform step 11.c of 1BEP-1, Loss of Reactor or Secondary Coolant to place the Hydrogen Monitors in service per BOP PS-9, Post LOCA Containment Hydrogen Monitoring System Operation.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: 2, 3 & 5

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

RECORD START TIME

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<p>1. Refer to BOP PS-9, Post-LOCA Containment Hydrogen Monitoring System Operation</p> <p>Note: Step 1 may be performed at any time</p> <p>Cue: All prerequisites are met</p>	<p>Locate and OPEN BOP PS-9, Post LOCA Cnmt Hydrogen Monitoring System Operation</p>			
<p>*2. Open the following valves on 1PM11J.</p> <ul style="list-style-type: none"> • 1PS228A Pri Cnmt Isol to H₂ Monitor • 1PS230A Return Cnmt Isol from H₂ Monitor • 1PS228B Pri Cnmt Isol to H₂ Monitor • 1PS229A Sec Cnmt Isol to H₂ Monitor • 1PS229B Sec Cnmt Isol to H₂ Monitor • 1PS230B Return Cnmt Isol from H₂ Monitor 	<ul style="list-style-type: none"> • OPEN 1PS228A on 1PM11J • OPEN 1PS230A on 1PM11J • OPEN 1PS228B on 1PM11J • OPEN 1PS229A on 1PM11J • OPEN 1PS229B on 1PM11J • OPEN 1PS230B on 1PM11J 			
<p>*3. Direct EO to locally open the following valves at 1PS47J & 1PS48J</p> <ul style="list-style-type: none"> • 1PS232A Manual Inlet Isol to H₂ Monitor • 1PS233A Manual Outlet Isol from H₂ Monitor • 1PS232B Manual Inlet Isol to H₂ Monitor • 1PS233B Manual Outlet from H₂ Monitor <p>Cue: EO reports that valves have been locally Opened</p>	<ul style="list-style-type: none"> • 1PS232A locally OPENED • 1PS233A locally OPENED • 1PS232B locally OPENED • 1PS233B locally OPENED 			

<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
5. Direct EO to locally verify the ALARM SET / NORMAL switch is set to NORMAL on 1PS43J & 1PS44J Cue: EO reports that switch is in NORMAL	ALARM SET / NORMAL switch is set to NORMAL			
*5. Place the ON-OFF switch on 1HSU-PS345 & 1HSU-PS346 on 1PM12J to the ON position. Cue: Four minutes have elapsed.	ON-OFF switch on 1HSU-PS345 & 346 on 1PM12J are ON.			
6. Verify the H ₂ & System Status Alarm lights on 1HSU-PS345 & 1HSU-PS346 are NOT ON.	H ₂ & System Status Alarm lights are NOT ON.			
7. Verify on 1PM06J 1EL-PS343 & 1EL-PS344 LO RANGE lights are ON. Cue: This JPM is completed.	LO RANGE lights are ON.			

RECORD STOP TIME _____

JPM SUMMARY

Operator's Name: _____ **Job Title:** RO SRO

JPM Title: Start Hydrogen Monitoring System

JPM Number: CRh Revision Number: 01

Task Number and Title: 4C.PS-01

K/A Number and Importance: 029A2.04 2.5/3.2

Suggested Testing Environment: Simulator

Alternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s): BOP PS-9, Post LOCA Containment Hydrogen Monitoring System Operation
1BEP-1, Loss of Reactor of Secondary Coolant

CRITICAL STEPS (*) 2, 3 & 5

Actual Testing Environment: Simulator Control Room In-Plant Other

Testing Method: Simulate Perform

Estimated Time to Complete: 15 minutes **Actual Time Used:** _____ minutes

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____ (Print)

Evaluator's Signature: _____ **Date:** _____

INITIAL CONDITIONS

1. You are an extra NSO in the control room during a LOCA event.
2. The crew has performed the actions contained in 1BEP-0, Reactor Trip or Safety Injection and is currently in 1BEP-1, Loss of Reactor or Secondary Coolant at step 11.c.
3. Containment Isolation Phase A has just been reset.

INITIATING CUE

The Unit Supervisor has just ordered you to perform step 11.c of 1BEP-1, Loss of Reactor or Secondary Coolant to place the Hydrogen Monitors in service per BOP PS-9, Post LOCA Containment Hydrogen Monitoring System Operation.