



**Exelon Generation**®

**Dresden Nuclear Power Station**

6500 North Dresden Road  
Morris, IL 60450

815 942 2920 Telephone  
www.exeloncorp.com

10 CFR 50.73

SVPLTR # 14-0049

September 5, 2014

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Dresden Nuclear Power Station, Unit 2  
Renewed Facility Operating License No. DPR-19  
NRC Docket No. 50-237

**Subject:** Licensee Event Report 237/2014-003-01, Unit 2 Reactor Scram during Automatic Voltage Regulator Channel Transfer

Enclosed is Licensee Event Report 237/2014-003-01, Unit 2 Reactor Scram during Automatic Voltage Regulator Channel Transfer. This is an interim report which describes an event which is being reported in accordance with 10 CFR 50.73(a)(2)(iv)(A), any event or condition that resulted in manual or automatic actuation of any of the systems listed in paragraph (a)(2)(iv)(B).

There are no regulatory commitments contained in this submittal.

Should you have any questions concerning this letter, please contact Mr. Glen Morrow at (815) 416-2800.

Respectfully,

Shane M. Marik  
Site Vice President  
Dresden Nuclear Power Station

Enclosure Licensee Event Report 237/2014-003-01

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Dresden Nuclear Power Station

*IE22  
MLR*



**LICENSEE EVENT REPORT (LER)**  
(See Page 2 for required number of digits/characters for each block)

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

<b>1. FACILITY NAME</b> Dresden Nuclear Power Station, Unit 2	<b>2. DOCKET NUMBER</b> 05000237	<b>3. PAGE</b> 1 OF 3
--	-------------------------------------	--------------------------

**4. TITLE**  
Unit 2 Reactor Scram during Automatic Voltage Regulator Channel Transfer

5. EVENT DATE			6. LER NUMBER			7. REPORT DATE			8. OTHER FACILITIES INVOLVED	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO.	MONTH	DAY	YEAR	FACILITY NAME	DOCKET NUMBER
05	03	2014	2014	003	01	09	05	14	FACILITY NAME	DOCKET NUMBER

<b>9. OPERATING MODE</b>	<b>11. THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check all that apply)</b>			
1	<input type="checkbox"/> 20.2201(b)	<input type="checkbox"/> 20.2203(a)(3)(i)	<input type="checkbox"/> 50.73(a)(2)(i)(C)	<input type="checkbox"/> 50.73(a)(2)(vii)
	<input type="checkbox"/> 20.2201(d)	<input type="checkbox"/> 20.2203(a)(3)(ii)	<input type="checkbox"/> 50.73(a)(2)(ii)(A)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)
	<input type="checkbox"/> 20.2203(a)(1)	<input type="checkbox"/> 20.2203(a)(4)	<input type="checkbox"/> 50.73(a)(2)(ii)(B)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)
	<input type="checkbox"/> 20.2203(a)(2)(i)	<input type="checkbox"/> 50.36(c)(1)(i)(A)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(ix)(A)
10. POWER LEVEL  100	<input type="checkbox"/> 20.2203(a)(2)(ii)	<input type="checkbox"/> 50.36(c)(1)(ii)(A)	<input checked="" type="checkbox"/> 50.73(a)(2)(iv)(A)	<input type="checkbox"/> 50.73(a)(2)(x)
	<input type="checkbox"/> 20.2203(a)(2)(iii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(v)(A)	<input type="checkbox"/> 73.71(a)(4)
	<input type="checkbox"/> 20.2203(a)(2)(iv)	<input type="checkbox"/> 50.46(a)(3)(ii)	<input type="checkbox"/> 50.73(a)(2)(v)(B)	<input type="checkbox"/> 73.71(a)(5)
	<input type="checkbox"/> 20.2203(a)(2)(v)	<input type="checkbox"/> 50.73(a)(2)(i)(A)	<input type="checkbox"/> 50.73(a)(2)(v)(C)	<input type="checkbox"/> OTHER
	<input type="checkbox"/> 20.2203(a)(2)(vi)	<input type="checkbox"/> 50.73(a)(2)(i)(B)	<input type="checkbox"/> 50.73(a)(2)(v)(D)	Specify in Abstract below or in NRC Form 366A

**12. LICENSEE CONTACT FOR THIS LER**

LICENSEE CONTACT Glen Morrow – Regulatory Assurance Manager	TELEPHONE NUMBER (Include Area Code) 815-416-2800
--	--

**13. COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT**

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO EPIX	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO EPIX
X	EL	90	A576	Y					

<b>14. SUPPLEMENTAL REPORT EXPECTED</b> <input checked="" type="checkbox"/> YES (If yes, complete 15. EXPECTED SUBMISSION DATE) <input type="checkbox"/> NO	<b>15. EXPECTED SUBMISSION DATE</b>		
	MONTH	DAY	YEAR
	11	07	2014

**ABSTRACT** (Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines)

On May 03, 2014, Dresden Station was performing a channel swap of the Unit 2 Automatic Voltage Regulator. An automatic reactor protection system actuation, Turbine/Generator Trip, was received. All rods inserted to their full-in position. Following the reactor trip, all systems operated as expected.

This event is being reported in accordance with 10 CFR 50.73(a)(2)(iv)(A), any event or condition that resulted in manual or automatic actuation of any of the system listed in paragraph (a)(2)(iv)(B).



**LICENSEE EVENT REPORT (LER)  
CONTINUATION SHEET**

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME	2. DOCKET	6. LER NUMBER			3. PAGE		
Dresden Nuclear Power Station, Unit 2	05000237	YEAR	SEQUENTIAL NUMBER	REV NO.	2	OF	3
		2014	- 003	- 01			

**NARRATIVE**

**PLANT AND SYSTEM IDENTIFICATION**

Dresden Nuclear Power Station (DNPS), Unit 2, is a General Electric Company Boiling Water Reactor with a licensed maximum power level of 2957 megawatts thermal. The Energy Industry Identification System codes used in the text are identified as [XX].

**A. Plant Conditions Prior to Event:**

Unit: 02	Event Date: 05-03-2014	Event Time: 1209 hours CDT
Reactor Mode: 1	Mode Name: Power Operation	Power Level: 100 percent

**B. Description of Event:**

On May 03, 2014, Dresden Station was performing a channel swap of the Unit 2 Automatic Voltage Regulator [EL]. An automatic reactor protection system actuation [JC], Turbine/Generator Trip, was received. All control rods [AA] inserted to their full-in position. Following the reactor protection system actuation, all systems operated as expected.

This event is being reported in accordance with 10 CFR 50.73(a)(2)(iv)(A), any event or condition that resulted in manual or automatic actuation of any of the system listed in paragraph (a)(2)(iv)(B).

**C. Cause of Event:**

The cause of this event is under investigation and will be reported in a supplemental notification.

**LICENSEE EVENT REPORT (LER)  
CONTINUATION SHEET**

1. FACILITY NAME	2. DOCKET	6. LER NUMBER			3. PAGE
Dresden Nuclear Power Station, Unit 2	05000237	YEAR	SEQUENTIAL NUMBER	REV NO.	3 OF 3
		2014	- 003	- 01	

**NARRATIVE**

**D. Safety Analysis:**

Following the actuation, all systems responded as expected, therefore, this event is of low safety significance.

**E. Corrective Actions:**

Corrective actions will be developed during the ongoing root cause investigation.

**F. Previous Occurrences:**

Previous occurrences will be identified through the root cause investigation.

**G. Component Failure Data:**

Manufacturer	Model	S/N	Type
ABB	Unitrol 6080	101681-842-1	-