

Sequoyah Nuclear Plant (SQN)



AST Presentation
September 16, 2014

Purpose of Meeting

- **Discussion of AST as it pertains to RAI KAB-044**
 - **Current Licensing Bases**
 - **Improved Technical Specification Impact**

Introductions

- **NRC**
- **TVA**



Current Licensing Bases

- **TVA-SQN-TS-02-08 submitted to NRC, January 14, 2003**
 - Request to modify TS 3.9.4 “Containment Building Penetrations” and Partial scope implementation of the alternate source term
 - Modified applicability requirement for the containment building equipment door (CBED)
 - CBED closure only required during “recently irradiated fuel”
- **NRC approval received on October 28, 2003**

Current wording for T/S 3.9.4

3.9.4 The containment building penetrations shall be in the following status:

- a. The equipment door closed and held in place by a minimum of four bolts,
- b. A minimum of one door in each airlock is closed, and both doors of both containment personnel airlocks may be open if:
 - 1. One personnel airlock door in each airlock is capable of closure, and
 - 2. One train of the Auxiliary Building Gas Treatment System is OPERABLE in accordance with Technical Specification 3.9.12, and
- c. Each penetration* providing direct access from the containment atmosphere to the outside atmosphere shall be either:
 - 1. Closed by an isolation valve, blind flange, manual valve, or equivalent, or
 - 2. Be capable of being closed by an OPERABLE automatic Containment Ventilation isolation valve.

APPLICABILITY:

3.9.4.a. Containment Building Equipment Door - During movement of recently irradiated fuel within the containment.

3.9.4.b. and c. Containment Building Airlock Doors and Penetrations - During movement of irradiated fuel within the containment.]



Current Licensing Basis

- **TVA and NRC recognized that the Fuel Handling Accident (FHA) within containment is the only Design Basis Accident (DBA) affected by the proposed change**
- **TVA evaluated a FHA both inside and outside containment**
- **NRC found that the change to replace the current accident source term used in the design basis FHA within containment with an AST was acceptable**

Excerpt from NRC SE

analyses. The NRC staff finds that analysis methods and assumptions used were consistent with the conservative regulatory requirements and guidance. Additionally, the NRC staff finds that the EAB, LPZ, and control room doses will continue to comply with the applicable

OCT-29-2003 08:10

P. 17/21

- 4 -

regulatory criteria without credit being taken for containment isolation if the irradiated fuel has been allowed to decay for 100 hours prior to being moved.

Based on the above, the NRC staff finds the proposed change to replace the current accident source term used in the design basis FHA within containment radiological analyses with an AST is acceptable.

Excerpt from NRC SE

3.3 Design Basis

The licensee proposed to modify the SQN design basis to replace the current accident source term used in the design basis FHA analysis with an AST and to replace the previous whole body and thyroid accident dose guidelines with the TEDE criteria of 10 CFR 50.67(b)(2). TVA has supplemented the source term provided in RG 1.183 with tritium to reflect the tritium production core authorized for use at SQN.

This licensing action is considered a selective implementation of the AST. TVA addressed the use of AST described in RG 1.183 as the DBA source term in the evaluation of the radiological consequences of FHAs at SQN. As part of the implementation of the AST, the TEDE acceptance criterion of 10 CFR 50.67(b)(2) replaces the previous whole body and thyroid dose guidelines of 10 CFR 100.11 and 10 CFR Part 50, Appendix A, GDC 19, as the SQN licensing basis, with regard to the radiological consequences of the design basis FHAs inside and outside the containment.

With this approval, the selected characteristics of the AST and TEDE criteria become the design basis for the DBA FHA within the containment and outside the containment. This approval is limited to this specific implementation. Subsequent modifications based on the selected characteristic incorporated into the design basis by this action may be possible under



Current Licensing Basis

- **Analysis done for the FHA with AST assumes that the CBED is open and that ABGTS is out of service (no filtration of releases)**
- **TVA revised some of the assumptions in the FHA Analysis of Record (AOR) in June of 2013**
 - **Changed the time of the CVI from 30 to 300 seconds**
 - **Changed the containment air volume for mixing from 5% to 50%**
 - **Change was done under 10 CFR 50.59**
 - **Consequences to the FHA decreased by ~7%**



Current Licensing Basis

- **Analysis done for the FHA with AST assumes that the CBED is open and that ABGTS is out of service (no filtration of releases)**
- **TVA revised some of the assumptions in the FHA Analysis of Record (AOR) in June of 2013**
 - **Changed the time of the CVI from 30 to 300 seconds**
 - **Changed the containment air volume for mixing from 5% to 50%**
 - **Change was done under 10 CFR 50.59**
 - **Consequences to the FHA decreased by ~7%**


Unit 2 Purge Exhaust

Control Room
Emergency Intake

Auxiliary Building
Exhaust

Unit 1 Purge Exhaust

Control Room
Normal Intake




- LEGEND**
- TYPE 1, RADIATION ZONE, BARRIER AND POSTED
 - TYPE 2, RADIATION ZONE, REFLECTOR BOOM
 - TYPE 3, RADIATION ZONE, ALARM INDICATION AND REFLECTOR BOOM
 - SECONDARY CONTAINMENT SYSTEM DOUBLE DOORS
 - OVERHEAD RADIATION, AUTOMATIC CLAMP, RELEASE, CONTROL ROOM INDICATION
 - ACCESS POINTS, SEALS, LOCKET-LATCH
 - ACCESS CONTROL, AUTOMATIC CLAMP AND 3 PSI PRESSURE DIFFERENTIAL
 - VULCAN A FIRM DOOR
 - VULCAN B FIRM DOOR
 - VULCAN C, D, E, F, G, H, I, J, K, L, M, N, O, P, Q, R, S, T, U, V, W, X, Y, Z
- MATERIAL SERVICES**
- MANGA EXTRACTORS
 - WATER COOLER
 - 1" AIR HOSE VALVE
 - 1" DECONTAMINATED WATER HOSE VALVE
 - 1" RAN RATER HOSE VALVE
 - EMERGENCY EXTENDER AND SHOWER
 - AIRTELING-DIVISION SERVICE
- NOTES:**
1. ALL RADIATION ZONE AREAS MUST BE MAINTAINED AT ALL TIMES. THE CONTAINMENT SYSTEM LOCATION OF THE CONTAINMENT SYSTEM MUST BE MAINTAINED AT ALL TIMES. THE CONTAINMENT SYSTEM MUST BE MAINTAINED AT ALL TIMES. THE CONTAINMENT SYSTEM MUST BE MAINTAINED AT ALL TIMES.

ADDITIONAL CHANGES

FOR OFFICIAL INFORMATION IN TITLE BLOCK			
1	2	3	4
1	2	3	4
POWERHOUSE			
UNITS 1 & 2			
EQUIPMENT			
PLANS-ROOF			
SEQUOYAH NUCLEAR PLANT			
TENNESSEE VALLEY AUTHORITY			
DESIGNED BY		CHECKED BY	
DRAWN BY		APPROVED BY	
DATE		DATE	
SCALE		SCALE	
SHEET NO.		SHEET NO.	
TOTAL SHEETS		TOTAL SHEETS	
CDD		CDD	
1,2-47F200-1		1,2-47F200-1	



Current Licensing Basis







Improved Tech Spec Impact

- **Four T/S were changed in this conversation by changing the APPLICABILITY from “During movement of irradiated fuel” to “During movement of recently irradiated fuel”**
 - **3.3.6 Containment Ventilation Isolation Instrumentation**
 - **3.3.8 Auxiliary Building Gas Treatment System Actuation Instrumentation**
 - **3.7.12 Auxiliary Building Gas Treatment System**
 - **3.9.4 Containment Penetrations**
- **In none of these specifications, does SQN CTS have DURING CORE ALTERATIONS**

• 3.3.6 Containment Ventilation Isolation Instrumentation

3.3 INSTRUMENTATION

3.3.6A **Containment Purge and Exhaust Isolation Instrumentation** (Without Setpoint Control Program) 1

Ventilation

Ventilation

LCO 3.3.6 The Containment **Purge and Exhaust** Isolation instrumentation for each Function in Table 3.3.6-1 shall be OPERABLE. 1

APPLICABILITY: According to Table 3.3.6-1.

3. **Containment Radiation** Purge Air Monitor

a. Gaseous

1,2,3,4, (a)

{1}

INSERT 2

b. Particulate

1,2,3,4, (a)

{1}

(a) During movement of {recently} irradiated fuel assemblies within containment

SR 3.3.6.1

SR 3.3.6.1 4 $\leq [2 \times \text{background}]$

SR 3.3.6.6 7

SR 3.3.6.9

SR 3.3.6.8 $\leq [2 \times \text{background}]$

SR 3.3.6.1

SR 3.3.6.6

SR 3.3.6.9

$8.5 \times 10^{-3} \mu\text{Ci/cc}$

• 3.3.8 Auxiliary Building Gas Treatment System Actuation Instrumentation

3.3 INSTRUMENTATION

3.3.8A ~~Fuel Building Air Cleanup~~ System (~~FBACS~~) **Auxiliary Building Gas Treatment** ~~(Without Setpoint Control Program)~~ **Actuation Instrumentation**

LCO 3.3.8 **ABGTS** The ~~FBACS~~ actuation instrumentation for each Function in Table 3.3.8-1 shall be OPERABLE.

APPLICABILITY: **According to Table 3.3.8-1.**


~~and Actuation Relays~~
Spent **Pool Area** **Monitor**
 3. **Fuel Building Radiation**
 2
 a. ~~Gaseous~~ **[1,2,3,4], (a)**

(a) During movement of [recently] irradiated fuel assemblies in the fuel building


auxiliary

• 3.7.12 Auxiliary Building Gas Treatment System

3.7 PLANT SYSTEMS



APPLICABILITY:

~~MODES 1, 2, 3, and 4, 1~~
 During movement of ~~recently~~ irradiated fuel assemblies in the ~~fuel~~ building 

• 3.9.4 Containment Penetrations

3.9.4 Containment Penetrations

LCO 3.9.4

The containment penetrations shall be in the following status:

- a. The equipment ^{is} hatch closed and held in place by [;] {four} bolts ¹
- b. One door in each air lock is {capable of being} closed [;] and
- c. Each penetration providing direct access from the containment atmosphere to the outside atmosphere is either:
 1. Closed by a manual or automatic isolation valve, blind flange, or equivalent [;]
 2. Capable of being closed by an OPERABLE ^{automatic} Containment ~~Purge and Exhaust~~ Isolation ~~System~~ ^{valve}.

NOTE

Penetration flow path(s) providing direct access from the containment atmosphere ~~to the outside atmosphere~~ may be unisolated under administrative controls.

that transverse and terminate in the Auxiliary Building Secondary Containment Enclosure

APPLICABILITY:

During movement of {recently} irradiated fuel assemblies within containment