

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

October 14, 2014

Mr. K. Henderson Site Vice President Catawba Nuclear Station Duke Energy Carolinas, LLC 4800 Concord Road York, SC 29745

Mr. Steven D. Capps Vice President McGuire Nuclear Station Duke Energy Carolinas, LLC 12700 Hagers Ferry Road Huntersville, NC 28078

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2, AND MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION REGARDING LICENSE AMENDMENT REQUEST RE: METHODOLOGY REPORT DPC-NE-3001-P, REVISION 1, MULTIDIMENSIONAL REACTOR TRANSIENTS AND SAFETY ANALYSIS PHYSICS PARAMETERS METHODOLOGY (TAC NOS. MF3119, MF3120, MF3121, AND MF3122)

Dear Mr. Henderson and Mr. Capps:

By letter dated November 14, 2013 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML13325B142), Duke Energy Carolinas, LLC (Duke, the licensee), submitted a license amendment request for Catawba Nuclear Station, Units 1 and 2, and McGuire Nuclear Station, Units 1 and 2. The proposed amendment requested review and approval to the Methodology Report DPC-NE-3001-P, Revision 1, "Multidimensional Reactor Transients and Safety Analysis Physics Parameters Methodology." By letter dated June 27, 2014 (ADAMS Accession No. ML14183B259), Duke provided a response to NRC staff RAIs on the subject amendment request.

The Nuclear Regulatory Commission (NRC) staff is reviewing your submittal and response and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). The RAI questions were provided in draft form to Duke on September 24, 2014. The draft questions were sent to facilitate a teleconference to ensure that the questions were understandable, the regulatory basis for the guestions was clear, and to determine if the information was previously docketed.

On October 1, 2014, Duke staff indicated that they could respond within 30 days from the date of this letter.

K. Henderson and S. Capps

- 2 -

If you have any questions regarding this matter, I may be reached at (301) 415-2481 or by e-mail at ed.miller@nrc.gov.

Sincerely, Sous Million

G. Edward Miller, Project Manager Plant Licensing Branch II-1 Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket Nos. 50-369, 50-370, 50-413, and 50-414

REQUEST FOR ADDITIONAL INFORMATION

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

LICENSE AMENDMENT REQUEST

METHODOLOGY REPORT DPC-NE-3001-P, REVISION 1

DOCKET NOS. 50-369, 50-370, 50-413, AND 50-414

By letter dated November 14, 2013 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML13325B142), Duke Energy Carolinas, LLC (Duke, the licensee), submitted a license amendment request for Catawba Nuclear Station, Units 1 and 2, and McGuire Nuclear Station, Units 1 and 2. The proposed amendment requested review and approval to the Methodology Report DPC-NE-3001-P, Revision 1, "Multidimensional Reactor Transients and Safety Analysis Physics Parameters Methodology." By letter dated June 27, 2014 (ML14183B259), Duke provided a response to NRC staff RAIs on the subject amendment request.

The Nuclear Regulatory Commission (NRC) staff is reviewing your submittal and response and has determined that additional information is needed to complete its review.

SNPB-RAI-1) Please submit the following documents, which were referenced as support for the validation and verification of the models in SIMULATE-3K:

- SSP-98/13, Revision 6, "SIMULATE-3K Models & Methodology"
- SSP-04/443, Revision 2, "LWR Core Reactivity Transients. SIMULATE-3K Models and Assessment"

Please also provide the following document, which was referenced in support of the SIMULATE-3 methodology:

- SOA-95/18, "SIMULATE-3 Methodology, Advanced Three Dimensional Two-Group Reactor Analysis Code"
- SNPB-RAI-2) The hot full power (HFP) steam line break (SLB) analysis is initiated from nominal conditions, according to Section 5.3.1, because it uses the statistical core design (SCD) methodology described in DPC-NE-2005P-A. This is appropriate for departure from nucleate boiling ratio (DNBR) analysis, because the uncertainties have been statistically convoluted into the DNBR limit.

Duke appears to use the same analysis to check the fuel centerline temperature against the centerline fuel melt (CFM) limit. If this reading of the methodology is correct, please justify use of the nominal SCD initial conditions to be appropriate. If this reading is incorrect, please clarify the methodology that will be used to calculate fuel centerline temperature and compare to the limit.

SNPB-RAI-3) With respect to Section B2.2.1, How did Duke account for thermal conductivity degradation impacts. What, if any codes have been employed for the purpose described in the section, and how are they used?

K. Henderson and S. Capps

If you have any questions regarding this matter, I may be reached at (301) 415-2481 or by e-mail at ed.miller@nrc.gov.

- 2 -

Sincerely,

/RA/

G. Edward Miller, Project Manager Plant Licensing Branch II-1 Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket Nos. 50-369, 50-370, 50-413, and 50-414

DISTRIBUTION: PUBLIC LPLII-1 Reading RidsAcrsAcnw_MailCTR Resource

RidsNrrDssSnpb Resource RidsNrrDorlLpl2-1 Resource RidsNrrLASFigueroa Resource RidsNrrPMMcGuire Resource RidsOgcMailCenter Resource RidsRgn2MailCenter Resource

*via e-mail

ADAMS Accession No. ML14276A561

OFFICE	NRR/DORL/LPL2-1/PM	NRR/DORL/LPL2-1/LA	NRR/DSS/SNPB/BC	NRR/DORĽ/LPL2-1/BC
NAME	GEMiller	SFigueroa	JDean*	RPascarelli
DATE	08/08/14	10/06/14	09/22/14	10/14/14

OFFICIAL RECORD COPY