

SummerRAIsPEm Resource

From: McGovern, Denise
Sent: Wednesday, October 08, 2014 10:04 AM
To: SummerRAIsPEm Resource
Subject: REQUEST FOR ADDITIONAL INFORMATION- LICENSE AMENDMENT REQUEST 14-03 FOR THE V. C. SUMMER NUCLEAR STATION UNITS 2 AND 3: TIER 2(star) EDITORIAL CHANGES AND CLARIFICATIONS
Attachments: VC Summer 14-03 RAI 2.docx

Hearing Identifier: Summer_COL_eRAIs
Email Number: 104

Mail Envelope Properties (A41C2340DAB39B44AD0B9623285CB333ECB10D4AAE)

Subject: REQUEST FOR ADDITIONAL INFORMATION- LICENSE AMENDMENT
REQUEST 14-03 FOR THE V. C. SUMMER NUCLEAR STATION UNITS 2 AND 3: TIER 2(star)
EDITORIAL CHANGES AND CLARIFICATIONS

Sent Date: 10/8/2014 10:04:09 AM

Received Date: 10/8/2014 10:04:12 AM

From: McGovern, Denise

Created By: Denise.McGovern@nrc.gov

Recipients:

"SummerRAIsPEm Resource" <SummerRAIsPEm.Resource@nrc.gov>

Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	3	10/8/2014 10:04:12 AM
VC Summer 14-03 RAI 2.docx	37736	

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

October 8, 2014

Mr. Ronald A. Jones, Vice President
New Nuclear Operations
South Carolina Electric & Gas Company
14368 State Highway 213
Jenkinsville, SC 29065

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION: REQUEST FOR LICENSE
AMENDMENT (LAR 14-03) FOR THE VIRGIL C. SUMMER NUCLEAR STATION
UNITS 2 AND 3: TIER 2* EDITORIAL CHANGES AND CLARIFICATIONS

Dear Mr. Jones:

By letter dated July 9, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14164A098), South Carolina Electric & Gas Company (SCE&G) submitted a request for a license amendment (LAR) for the Virgil C. Summer Nuclear Station (VCSNS), Units 2 and 3. The proposed amendment would depart from VCSNS Units 2 and 3 plant-specific Design Control Document (DCD) Tier 2* material contained within the Updated Final Safety Analysis Report (UFSAR) by making editorial and consistency corrections.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

You are requested to respond, signed under oath or affirmation, by November 24, 2014. If changes are needed to the UFSAR, the staff requests that the RAI response include the proposed wording changes.

R.Jones

If you have any questions or comments concerning this matter, you may contact me at 301-415-0681 or denise.mcgovern@nrc.gov.

Sincerely,

/RA/

Denise L. McGovern, Senior Project Manager
Licensing Branch 4
Division of New Reactor Licensing
Office of New Reactors

Docket No(s): 52-027
52-028

eRAI Tracking No. 7671

Enclosure:
Request for Additional Information

cc: See next page

R.Jones

If you have any questions or comments concerning this matter, you may contact me at 301-415-0681 or denise.mcgovern@nrc.gov.

Sincerely,

/RA/

Denise L. McGovern, Senior Project Manager
Licensing Branch 4
Division of New Reactor Licensing
Office of New Reactors

Docket No(s): 52-027
52-028

eRAI Tracking No. 7671

Enclosure:
Request for Additional Information

DISTRIBUTION:

Public	RJoshi	LBurkhart	DMcGovern
RidsNroDnrlLB4	DJaffe	RReyes	TScarborough
RidsOgcMailCenter	PMoulding	JMartin	IJung
RidsNroDnrl	TClark		

*Approval captured electronically in the electronic RAI system

NRO-002

OFFICE	NSIR/DPR/DDEP/NRLB	NSIR/DPR/DDEP/NRLB	DNRL/LB4:PM
NAME	TScarborough*	IJung*	DMcGovern*
DATE	9/16/14	9/17/14	9/17/14

OFFICIAL RECORD COPY

Request for Additional Information

Virgil C. Summer Nuclear Station, Units 2 and 3
South Carolina Electric and Gas Company
Docket No. 52-027 and 52-028

Review Section: 05.02.01.01 - Compliance with the Codes and Standards Rule, 10 CFR 50.55a
Application Section: 5.2.1.1

QUESTION

In its letter dated July 9, 2014, the licensee of V.C. Summer Units 2 and 3 submitted License Amendment Request (LAR) 14-03, which proposes editorial and consistency changes within Tier 2* information in its Updated Final Safety Analysis Report (UFSAR). One requested change relates to Tier 2* information in Subsection 5.2.1.1, "Compliance with 10 CFR 50.55a," of the UFSAR. In particular, the licensee requests that the specification of Chapters IV, V, VI, and VII in the ASME B31.1 Code as Tier 2* information be changed to Chapters IV, V, and VI of the ASME B31.1 Code. The licensee indicates that Chapter VII appears in the 2007 version of the ASME B31.1 Code, but does not exist in the 1989 version of the ASME B31.1 Code referenced in the UFSAR. The NRC staff requests that the licensee specify where the provisions in Chapter VII, "Operation and Maintenance," in the 2007 version of the ASME B31.1 Code are addressed in the 1989 version of the ASME B31.1 Code.