

**Dresden Nuclear Power Station, Units 2 and 3  
Facility Operating License Nos. DPR-19 and DPR-25**

**Attachment 2**

**Dresden Nuclear Power Station Fourth Inservice Inspection (ISI) Interval Limited  
Coverage Non-Destructive Examination (NDE) Summary Sheets**

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h1 style="margin:0;">HITACHI Examination Summary Sheet</h1>	Report No.: D2R22-075
---	--	-----------------------

Site: Dresden Unit-2	Component ID: 2/1/RPV SHELL/2-SC1A-Vert Long Seam
Outage: D2R22	Configuration: Shell 1 Vert Weld
System: RPV	ASME Cat: B-A      ASME Item: B1.12      Aug. Requirements: N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier	II	10/30/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted due to the proximity of the jet pump diffuser.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.





No flaw indications were recorded.

The Auto coverage was calculated to be 88.0%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000100 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	11/6/11 Date:	 Utility Review By:	11-5-11 Date:
			 ANII Reviewed By:	11-7-11 Date:



**HITACHI**

## SP2000 RPV Examination Data Sheet

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1A-VERT

**Report No.:** DZR22-075

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
2-SC1A_3	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC1A_4	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications". Scan files 2-SC1A\_1 and 2 were voided.

Analyzed by: Brad Dummer Level III 11/2/2011



**HITACHI**

**SP2000 RPV Examination  
 Coverage Calculation Sheet**

Report No.: D2R22-075

**DRESDEN UNIT-2  
 Weld 2-SC1A**

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A	8.1	8.1	7.7%	117	3.4%
70° T-Scan CCW (S4 NS)	A	8.1	8.1	7.7%	117	3.4%
45° T-Scan (S6 FV)	A	44.4	44.4	84.6%	117	37.2%
70° P-Scan UP (S4 NS)	A	8.1	8.1	7.7%	117	3.4%
70° P-Scan DN (S4 NS)	A	8.1	8.1	7.7%	117	3.4%
45° P-Scan (S6 FV)	A	44.4	44.4	84.6%	117	37.2%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 88.0%

Rev. D 9/23/05

**Comments:**

A - Automated scanning was not restricted.  
 Scanning was limited due to the proximity of the jet pump diffuser.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1A-VERT  
**Report No.:** D2R22-075

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC1A_3	10/28/11	270.00	195.00	DN (Fwd)	-75.00	0245	0335
2-SC1A_4	10/28/11	196.00	141.50	DN (Fwd)	-54.50	0339	0420

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the jet pump diffuser. Scan files 2-SC1A\_1 and 2 were voided.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.106  
**Vessel Temp. (°F):** 106°F            **Couplant:** Water


**Operators:** Clint Gauthier Level II

SEARCH UNIT DATA:				Angle	Size	Freq.	Rotation
No.	Mfg.	S/N	Mode				
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°	
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°	
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°	
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°	
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°	
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°	
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°	
8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°	



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"





HITACHI


# Dresden Reference Drawings



Scanned Patches - Coverage "A"

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-076				
Site: Dresden Unit-2 Outage: D2R22 System: RPV	Component ID: 2/1/RPV SHELL/2-SC1B-Vert Long Seam Configuration: Shell 1 Vert Weld ASME Cat: B-A	ASME Item: B1.12 Aug. Requirements: N/A				
<b>Exams Performed:</b>	<b>Calibration Sheet(s):</b>	<b>Calibration Block:</b>	<b>Procedure:</b>	<b>Examination Personnel:</b>	<b>NDE Level:</b>	<b>Date:</b>
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the shroud repair lower contact.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.






Two (2) acceptable flaw indications were recorded. The indications are characteristic of fabrication artifacts and were not recorded during the previous examinations. This is attributed to differences in procedure recording criteria.

The Auto coverage was calculated to be 40.2%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000200 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	 Date:	 Utility Review By:	11-5-11 Date:
 ANII Reviewed By:				11-7-11 Date:



**HITACHI**

**SP2000 RPV Examination  
 Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1B-VERT

**Report No.:** D2R22-076

File	Scan Type	Scan												
		Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	
2-SC1B_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC1B_2	Head Down	NRI	NRI	NRI	NRI	NRI	RI (1)	NRI	RI (1)	NRI	~	~	~	~
2-SC1B_3	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".

Analyzed by: Brad Dummer Level III 11/2/2011



**HITACHI**

**SP2000 RPV Examination  
Indication Data Sheet**

**Project :** Dresden Unit-2, 2R22  
**Component :** 2-SC1B-VERT

**Report :** D2R22-076

Ind. No.	File	Channel	Maximum Amplitude Position				Indication Length Information				Remarks
			Amp dB	L Pos	W Pos	Depth	W Min	W Max	Length	Axis	
1	2-SC1B 2	6	-27.0	245.50	-2.60	0.45	-3.10	-2.35	0.75	Circ.	D1 = 0.29" D2 = 0.45"
2	2-SC1B 2	8	-18.5	249.00	-2.40	0.55	-2.90	-2.15	0.75	Circ.	D1 = 0.44" D2 = 0.55"

Comments: The symbol -- indicates "No entry required" or "Not Applicable". Measurements in inches.

Analyzed by: Brad Dummer Level III 11/2/2011



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC1B

Indication : 1

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.16	0.15	"T" nominal =	6.375	6.4
Flaw Length "P" =	0.75	0.75	"T" measured =	N/A	N/A
Surface Separation "S" =	0.10	0.1			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	-	-
0.05	2.0	2.2	-	-
0.10	2.2	2.5	2.20	2.50 Y
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	-	-
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed	Allowed
			2.20	2.50

a = 0.075  
a/l value = 0.100  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.5%  
a/t = 1.2%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

Evaluation by: Brad Dummer Level III *BD*

Reviewed by: Chris Minor Level III *CAM*

Utility Reviewed by: *[Signature]*



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

**Project :** Dresden Unit-2  
**Weld ID :** 2-SC1B

**Indication :** 2

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
<b>Flaw Through Wall =</b>	0.11	0.1	<b>"T" nominal =</b>	6.375	6.4
<b>Flaw Length "P" =</b>	0.75	0.75	<b>"T" measured =</b>	N/A	N/A
<b>Surface Separation "S" =</b>	0.25	0.25			

**ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	2.07	2.30 Y
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.07	2.30

a = 0.050  
a/l value = 0.067  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.3%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

Evaluation by: Brad Dummer Level III *BD*


Reviewed by: Chris Minor Level III *CAM*

Utility Reviewed by: \_\_\_\_\_



HITACHI

# Dresden Indication Prints




Indication 1



HITACHI

# Dresden Indication Prints



Indication 2



ATTACHMENT 2  
 Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
 Coverage Calculation Sheet**

Report No.: D2R22-076

**DRESDEN UNIT-2  
 Weld 2-SC1B**

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
70° T-Scan CCW (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
45° T-Scan (S6 FV)	A/B	44.4	44.4	84.6%	53.5	17.0%
70° P-Scan UP (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
70° P-Scan DN (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
45° P-Scan (S6 FV)	A/B	44.4	44.4	84.6%	53.5	17.0%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 40.2%

Rev. 0 9/23/05

**Comments:**

A/B - Automated scanning was not restricted.  
 Scanning was limited due to the proximity of the shroud repair lower contact.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**HITACHI**

**SP2000 RPV Examination  
Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1B-VERT  
**Report No.:** D2R22-076

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC1B_1	10/29/11	205.00	248.00	DN (Rev)	43.00	0952	1034
2-SC1B_2	10/29/11	253.00	238.00	DN (Fwd)	-15.00	1042	1058
2-SC1B_3	10/29/11	235.00	278.00	UP (Fwd)	43.00	1205	1244

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the shroud tie down lower contact bracket.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.106  
**Vessel Temp. (°F):** 106°F            **Couplant:** Water


**Operators:** Shane Gauthier Level II

<b>SEARCH UNIT DATA:</b>						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



**HITACHI**

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

# Dresden Reference Drawings




Scanned Patches - Coverage "A"



HITACHI

# Dresden Reference Drawings



Scanned Patches - Coverage "B"



**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<b>HITACHI</b>	<b>Examination Summary Sheet</b>	Report No.: D2R22-077
---	----------------	----------------------------------	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-5C1C-Vert Long Seam		
Outage:	D2R22	Configuration:	Shell 1 Vert Weld		
System:	RPV	ASME Cat:	B-A	ASME Item:	B1.12
				Aug. Requirements:	N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/29/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the shroud repair lower contact.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.








No flaw indications were recorded.

The Auto coverage was calculated to be 40.2%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000300 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	 Date:	 Utility Review By:	 Date:
 ANII Reviewed By:				 Date:

ATTACHMENT 2  
 Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
 Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1C-VERT

**Report No.:** D2R22-077

<u>File</u>	<u>Scan Type</u>	<u>Ch. 1</u>	<u>Ch. 2</u>	<u>Ch. 3</u>	<u>Ch. 4</u>	<u>Ch. 5</u>	<u>Ch. 6</u>	<u>Ch. 7</u>	<u>Ch. 8</u>	<u>Ch. 9</u>	<u>Ch.10</u>	<u>Ch.11</u>	<u>Ch.12</u>
2-SC1C_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC1C_2	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC1C_3	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".

Analyzed by: Brad Dummer Level III 11/2/2011



**HITACHI**

## SP2000 RPV Examination Coverage Calculation Sheet

Report No.: D2R22-077

### DRESDEN UNIT-2 Weld 2-SC1C

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
70° T-Scan CCW (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
45° T-Scan (S6 FV)	A/B	44.4	44.4	84.6%	53.5	17.0%
70° P-Scan UP (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
70° P-Scan DN (S4 NS)	A/B	8.1	8.1	7.7%	53.5	1.6%
45° P-Scan (S6 FV)	A/B	44.4	44.4	84.6%	53.5	17.0%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 40.2%

Rev. 0 9/23/05

**Comments:**

A/B - Automated scanning was not restricted.  
 Scanning was limited due to the proximity of the shroud repair lower contact.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.

ATTACHMENT 2  
 Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
 Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1C-VERT  
**Report No.:** D2R22-077

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC1C_1	10/29/11	205.00	230.00	DN (Rev)	25.00	1617	1638
2-SC1C_2	10/29/11	252.00	245.00	DN (Fwd)	-7.00	1706	1725
2-SC1C_3	10/29/11	227.50	260.50	UP (Fwd)	33.00	1822	1838

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the shroud tie down lower contact bracket.

SEARCH UNIT DATA:			Angle	Size	Freq.	Rotation
No.	Mfg.	S/N	Mode			
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°


**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 106°F            **Couplant:** Water

**Operators:** Shane Gauthier Level II



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"






HITACHI

# Dresden Reference Drawings



Scanned Patches - Coverage "A"

# Dresden Reference Drawings



Scanned Patches - Coverage "B"

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-078
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC1D-Vert Long Seam
Outage:	D2R22	Configuration:	Shell 1 Vert Weld
System:	RPV	ASME Cat:	B-A
		ASME Item:	B1.12
		Aug. Requirements:	N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	C.Gauthier	II	10/27/11

**Comments:**

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RI, search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted due to the proximity of the jet pump restrainers and jet pump diffuser.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.





No flaw indications were recorded.

The Auto coverage was calculated to be 71.4%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000400 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 _____ Prepared By:	 _____ Level:	11/6/11 _____ Date:	 _____ Utility Review By:	11-5-11 _____ Date:
 _____ ANII Reviewed By:				11-7-11 _____ Date:



**HITACHI**

**SP2000 RPV Examination  
 Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1D-VERT

**Report No.:** D2R22-078

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
2-SC1D_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC1D_2	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC1D_3	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".  
 Scan file 2-SC1D\_1 is 9 inches offset from weld CL. Rescanned as 2-SC1D\_2.

Analyzed by: Chris Minor Level III 10/27/2011



**HITACHI**

## SP2000 RPV Examination Coverage Calculation Sheet

Report No.: D2R22-078

### DRESDEN UNIT-2 Weld 2-SC1D

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A	8.1	8.1	7.7%	70.4	2.0%
70° T-Scan CCW (S4 NS)	A	8.1	8.1	7.7%	70.4	2.0%
45° T-Scan (S6 FV)	A	44.4	44.4	84.6%	70.4	22.4%
70° P-Scan UP (S4 NS)	A	8.1	8.1	7.7%	70.4	2.0%
70° P-Scan DN (S4 NS)	A	8.1	8.1	7.7%	70.4	2.0%
45° P-Scan (S6 FV)	A	44.4	44.4	84.6%	70.4	22.4%
70° T-Scan CW (S4 NS)	B	8.1	2.2	2.1%	20.6	0.2%
70° T-Scan CCW (S4 NS)	B	8.1	5.7	5.4%	20.6	0.4%
45° T-Scan (S6 FV)	B	44.4	29.8	56.8%	20.6	4.4%
70° P-Scan UP (S4 NS)	B	8.1	6.9	6.6%	20.6	0.5%
70° P-Scan DN (S4 NS)	B	8.1	1.1	1.0%	20.6	0.1%
45° P-Scan (S6 FV)	B	44.4	38.2	72.8%	20.6	5.6%
70° T-Scan CW (S4 NS)	C	8.1	3.5	3.3%	11	0.1%
70° T-Scan CCW (S4 NS)	C	8.1	7.2	6.9%	11	0.3%
45° T-Scan (S6 FV)	C	44.4	37.1	70.7%	11	2.9%
70° P-Scan UP (S4 NS)	C	8.1	8.1	7.7%	11	0.3%
70° P-Scan DN (S4 NS)	C	8.1	2.5	2.4%	11	0.1%
45° P-Scan (S6 FV)	C	44.4	44.4	84.6%	11	3.5%

% Total Composite Coverage = 71.4%

Rev. 0 9/23/05

**Comments:**

- A- Automated scanning was not restricted.
- B - Automated scanning was restricted due to jet pump restrainers.
- C - Automated scanning was restricted due to the jet pump diffuser.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in mm.



**HITACHI**

## SP2000 RPV Examination Scan Files Data Sheet

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC1D-VERT  
**Report No.:** D2R22-078

**Procedure No.:** GEH-UT-717  
**Revision:** V. 3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC1D_1	10/27/11	270.00	235.75	DN (Rev)	-34.25	0242	0318
2-SC1D_2	10/27/11	280.00	200.00	DN (Rev)	-80.00	0354	0451
2-SC1D_3	10/27/11	201.00	158.50	DN (Rev)	-42.50	0501	0532

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the jet pump diffuser and jet pump restrainer bracket.  
 All scans are offset down 5 inches as determined by UT.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 112°F            **Couplant:** Water

**Operators:** Clint Gauthier Level II


**SEARCH UNIT DATA:**

No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map





**HITACHI**

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI


# Dresden Reference Drawings



Cross Section of Achieved Coverage "B"



### Dresden Reference Drawings




Cross Section of Achieved Coverage "C"



**HITACHI**

# Dresden Reference Drawings



**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-079
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC2A-Vert Long Seam
Outage:	D2R22	Configuration:	Shell 2 Vert Weld
System:	RPV	ASME Cat:	B-A
		ASME Item:	B1.12
		Aug. Requirements:	N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/29/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RI. search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the jet pump riser brace, lower specimen and upper specimen brackets.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.





One (1) acceptable flaw indication was recorded. The indication is characteristic of fabrication artifacts in the original plate base material. The indication was recorded for reference purposes only and was not recorded during the previous examination.

The Auto coverage was calculated to be 69.0%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000500 from D2R18 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel

 Prepared By:	 Level:	11/4/11 Date:	 Utility Review By:	11-5-11 Date:
 ANIL Reviewed By:				11-7-11 Date:

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Data Sheet**

Project: Dresden Unit-2, 2R22  
Component: 2-SC2A-VERT

Report No.: D2R22-079

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
2-SC2A_1	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2A_2	Head Down	RI (1)	RI (1)	RI (1)	RI (1)	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2A_3	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".

Analyzed by: John Gilliard Level III 11/01/2011

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**HITACHI**

**SP2000 RPV Examination  
Indication Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC2A-VERT

**Report:** D2R22-079

Ind. No.	File	Channel	Maximum Amplitude Position			Indication Length Information				Remarks	
			Amp dB	L Pos	W Pos	Depth	L Min	L Max	Length		Axis
1	2-SC2A_2	1	-12.3	322.65	4.60	3.70	322.05	322.88	0.83	Circ.	No determinable thruwall
1	2-SC2A_2	2	-10.7	322.15	5.15	3.68	321.94	323.45	1.51	Circ.	No determinable thruwall
1	2-SC2A_2	3	-9.1	323.35	3.90	3.72	322.10	323.24	1.14	Circ.	No determinable thruwall
1	2-SC2A_2	4	-9.5	322.85	5.10	3.67	322.60	323.74	1.14	Circ.	No determinable thruwall

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". Measurements in inches.  
 Indication #1 was seen with Ch's 1,2,3 and 4 and is similar to other reflectors located in the plate base material.  
 Indication 1 was recorded for reference purposes only.

Analyzed by: John Gilliard Level III 10/31/2011



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC2A

Indication : 1

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "l" =	1.51	1.5	"T" measured =	N/A	N/A
Surface Separation "S" =	2.72	2.7			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.97	2.13 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.97	2.13

a = 0.050  
a/l value = 0.033  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.1%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/05

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JCG*

Reviewed by: Chris Minor Level III *CM*


Utility Reviewed by: *[Signature]*





HITACHI

# Dresden Indication Prints




Indication 1 - Channel 1



HITACHI

# Dresden Indication Prints




Indication 1 - Channel 2



HITACHI

# Dresden Indication Prints




Indication 1 - Channel 3



HITACHI

# Dresden Indication Prints




Indication 1 - Channel 4



HITACHI

# Dresden Indication Prints



Channel 4 – Typical base material reflectors similar to Indication 1.

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Coverage Calculation Sheet**

Report No.: D2R22-079

**DRESDEN UNIT-2  
Weld 2-SC2A**

Weld Length = Exam Volume =		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
133. 52.5	A/B	8.1	8.1	7.7%	89.5	2.6%
	A/B	8.1	8.1	7.7%	89.5	2.6%
	A/B	44.4	44.4	84.6%	89.5	28.5%
	A/B	8.1	8.1	7.7%	89.5	2.6%
	A/B	8.1	8.1	7.7%	89.5	2.6%
	A/B	44.4	44.4	84.6%	89.5	28.5%
	C	8.1	0	0.0%	11	0.0%
	C	8.1	1.4	1.3%	11	0.1%
	C	44.4	6.2	11.8%	11	0.5%
	C	8.1	2.4	2.3%	11	0.1%
	C	8.1	0	0.0%	11	0.0%
	C	44.4	13.4	25.5%	11	1.1%

% Total Composite Coverage = 69.0%

Rev. 0 9/23/05

Comments:

- A/B - Automated scanning was not restricted.
- C - Automated scanning was restricted due to the proximity of the lower specimen bracket.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC2A-VERT  
**Report No.:** D2R22-079

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC2A_1	10/28/11	386.00	334.00	UP (Rev)	-52.00	1852	1918
2-SC2A_2	10/28/11	305.00	355.70	DN (Fwd)	50.70	2050	2117
2-SC2A_3	10/29/11	282.00	246.00	UP (Rev)	-36.00	0004	0026

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the jet pump riser brace and the lower and upper surveillance specimen brackets.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 93°F            **Couplant:** Water


**Operators:** Clint Gauthier Level II  
                  Shane Gauthier Level II

SEARCH UNIT DATA:						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans





HITACHI

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



**HITACHI**

## Dresden Reference Drawings




Cross Section of Achieved Coverage "C"



**HITACHI**

# Dresden Reference Drawings




Scanned Patches - Coverage "A"



HITACHI

# Dresden Reference Drawings



Scanned Patches - Coverage "B" and "C"

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-080
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC2B-Vert Long Seam	
Outage:	D2R22	Configuration:	Shell 2 Vert Weld	
System:	RPV	ASME Cat:	B-A	ASME Item: B1.12    Aug. Requirements: N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the jet pump riser brace, lower specimen and upper specimen brackets.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.





No flaw indications were recorded.

The Auto coverage was calculated to be 78.2%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000600 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	11/3/11 Date:	 Utility Review By:	11-5-11 Date:
 ANII Reviewed By:				11-7-11 Date:

ATTACHMENT 2  
 Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
 Data Sheet**

Project: Dresden Unit-2, 2R22  
 Component: 2-SC2B-VERT

Report No.: D2R22-080

File	Scan Type	Scan												
		Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	
2-SC2B_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2B_2	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2B_3	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2B_4	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".

Analyzed by: Brad Dummer Level III 11/3/2011





**HITACHI**

## SP2000 RPV Examination Coverage Calculation Sheet

Report No.: D2R22-080

### DRESDEN UNIT-2 Weld 2-SC2B

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A/B	8.1	8.1	7.7%	102	3.0%
70° T-Scan CCW (S4 NS)	A/B	8.1	8.1	7.7%	102	3.0%
45° T-Scan (S6 FV)	A/B	44.4	44.4	84.6%	102	32.4%
70° P-Scan UP (S4 NS)	A/B	8.1	8.1	7.7%	102	3.0%
70° P-Scan DN (S4 NS)	A/B	8.1	8.1	7.7%	102	3.0%
45° P-Scan (S6 FV)	A/B	44.4	44.4	84.6%	102	32.4%
70° T-Scan CW (S4 NS)	C	8.1	0	0.0%	10	0.0%
70° T-Scan CCW (S4 NS)	C	8.1	1.4	1.3%	10	0.1%
45° T-Scan (S6 FV)	C	44.4	6.2	11.8%	10	0.4%
70° P-Scan UP (S4 NS)	C	8.1	2.4	2.3%	10	0.1%
70° P-Scan DN (S4 NS)	C	8.1	0	0.0%	10	0.0%
45° P-Scan (S6 FV)	C	44.4	13.4	25.5%	10	1.0%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 78.2%

Rev. 0 9/23/05

**Comments:**

A/B - Automated scanning was not restricted.

C - Automated scanning was restricted due to the proximity of the lower specimen bracket.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.



**HITACHI**

**SP2000 RPV Examination  
Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC2B-VERT  
**Report No.:** D2R22-080

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC2B_1	10/29/11	362.00	305.50	DN (Fwd)	-56.50	0211	0251
2-SC2B_2	10/29/11	390.00	337.25	UP (Rev)	-52.75	0405	0433
2-SC2B_3	10/30/11	290.00	258.00	UP (Rev)	-32.00	1222	1242
2-SC2B_4	10/30/11	265.00	248.00	UP (Rev)	-17.00	1409	1436

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the jet pump riser brace and the lower and upper surveillance specimen brackets.

SEARCH UNIT DATA:						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°


**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 93°F              **Couplant:** Water

**Operators:** Clint Gauthier Level II  
                  Shane Gauthier Level II



**HITACHI**

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings



VERTICAL WELD	X	AZIMUTH
2-SC1A-VERT	168.70	77°
2-SC1B-VERT	241.01	110°
2-SC1C-VERT	431.83	187°
2-SC1D-VERT	694.85	317°
2-SC2A-VERT	214.72	88°
2-SC2B-VERT	438.20	218°
2-SC2C-VERT	497.36	250°
2-SC2D-VERT	790.28	338°
2-SC3A-VERT	168.70	77°
2-SC3B-VERT	431.83	187°
2-SC3C-VERT	694.85	317°
2-SC3E-VERT	773.42	353°
2-SC4A-VERT	216.91	99°
2-SC4B-VERT	328.65	150°
2-SC4C-VERT	479.83	219°
2-SC4D-VERT	723.03	330°
2-SC4E-VERT	742.75	339°

GIRTH WELD Y  
 2-SC4-FLG 654.41  
 Vessel ID Circum. 789"  
 1 Degree Azimuth = 2.0°


**DRESDEN 2 RPV ID MAP**  
 vs-d2\_r2.dwg 10/24/11

Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "C"



**HITACHI**

# Dresden Reference Drawings




Scanned Patches - Coverage "A"





**HITACHI**

# Dresden Reference Drawings



Scanned Patches - Coverage "B" and "C"

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<b>HITACHI Examination Summary Sheet</b>	Report No.: D2R22-081
---	--	-----------------------

Site: Dresden Unit-2	Component ID: 2/1/RPV SHELL/2-SC2C-Vert Long Seam
Outage: D2R22	Configuration: Shell 2 Vert Weld
System: RPV	ASME Cat: B-A      ASME Item: B1.12      Aug. Requirements: N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S. Gauthier	II	10/30/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave and 70° RI-search units. Automated IJT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the jet pump riser brace, lower specimen and upper specimen brackets.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.





No flaw indications were recorded.

The Auto coverage was calculated to be 87.0%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000700 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	11/6/11 Date:	 Utility Review By:	11-5-11 Date:
 ANII Reviewed By:				11-7-11 Date:

**ATTACHMENT 2**  
**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**HITACHI**

**SP2000 RPV Examination**  
**Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC2C-VERT

**Report No.:** D2R22-081

<i>File</i>	<i>Scan Type</i>	<i>Ch. 1</i>	<i>Ch. 2</i>	<i>Ch. 3</i>	<i>Ch. 4</i>	<i>Ch. 5</i>	<i>Ch. 6</i>	<i>Ch. 7</i>	<i>Ch. 8</i>	<i>Ch. 9</i>	<i>Ch.10</i>	<i>Ch.11</i>	<i>Ch.12</i>
2-SC2C_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2C_2	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2C_3	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2C_4	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2C_5	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2C_6	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC2C_7	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".

Analyzed by: Brad Dummer Level III 11/3/2011

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Coverage Calculation Sheet**

Report No.: D2R22-081

**DRESDEN UNIT-2  
Weld 2-SC2C**

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A/B	8.1	8.1	7.7%	97.5	2.8%
70° T-Scan CCW (S4 NS)	A/B	8.1	8.1	7.7%	97.5	2.8%
45° T-Scan (S6 FV)	A/B	44.4	44.4	84.6%	97.5	31.0%
70° P-Scan UP (S4 NS)	A/B	8.1	8.1	7.7%	97.5	2.8%
70° P-Scan DN (S4 NS)	A/B	8.1	8.1	7.7%	97.5	2.8%
45° P-Scan (S6 FV)	A/B	44.4	44.4	84.6%	97.5	31.0%
70° T-Scan CW (S4 NS)	C	8.1	8.1	7.7%	5.5	0.2%
70° T-Scan CCW (S4 NS)	C	8.1	8.1	7.7%	5.5	0.2%
45° T-Scan (S6 FV)	C	44.4	44.4	84.6%	5.5	1.7%
70° P-Scan UP (S4 NS)	C	8.1	8.1	7.7%	5.5	0.2%
70° P-Scan DN (S4 NS)	C	8.1	8.1	7.7%	5.5	0.2%
45° P-Scan (S6 FV)	C	44.4	44.4	84.6%	5.5	1.7%
70° T-Scan CW (S4 NS)	D	8.1	6.2	5.9%	13	0.3%
70° T-Scan CCW (S4 NS)	D	8.1	8.1	7.7%	13	0.4%
45° T-Scan (S6 FV)	D	44.4	44.4	84.6%	13	4.1%
70° P-Scan UP (S4 NS)	D	8.1	8.1	7.7%	13	0.4%
70° P-Scan DN (S4 NS)	D	8.1	5.1	4.9%	13	0.2%
45° P-Scan (S6 FV)	D	44.4	44.4	84.6%	13	4.1%

% Total Composite Coverage = 87.0%

Rev. 0 9/23/05

Comments:

- A/B - Automated scanning was not restricted.
- C - Automated scanning was restricted due to the proximity of the upper specimen bracket.
- D - Automated scanning was restricted due to the proximity of the lower specimen bracket.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.



**HITACHI**

**SP2000 RPV Examination  
 Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC2C-VERT  
**Report No.:** D2R22-081

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC2C_1	10/29/11	400.00	341.50	DN (Fwd)	-58.50	0547	0617
2-SC2C_2	10/29/11	390.00	341.00	DN (Fwd)	-49.00	0600	0731
2-SC2C_3	10/30/11	307.00	358.00	UP (Fwd)	51.00	0814	0840
2-SC2C_4	10/30/11	361.00	352.00	UP (Rev)	-9.00	0848	0853
2-SC2C_5	10/30/11	361.00	307.00	DN (Fwd)	-54.00	0933	1001
2-SC2C_6	10/30/11	290.00	248.00	UP (Rev)	-42.00	1830	1851
2-SC2C_7	10/30/11	250.00	282.60	UP (Fwd)	32.60	1826	1842

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the jet pump riser bracket.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.106  
**Vessel Temp. (°F):** 93°F            **Couplant:** Water


**Operators:** Clint Gauthier Level II  
 Shane Gauthier Level II

SEARCH UNIT DATA:						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"





HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "C"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "D"



**HITACHI**

# Dresden Reference Drawings




Scanned Patches – Coverage "A"



**HITACHI**

# Dresden Reference Drawings



Scanned Patches - Coverage "B", "C" and "D"

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-083
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC3A-Vert Long Seam		
Outage:	D2R22	Configuration:	Shell 3 Vert Weld		
System:	RPV	ASME Cat:	B-A	ASME Item:	B1.12
				Aug. Requirements:	N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	S.Gauthier / C.Gauthier	II	10/24/11

**Comments:**

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted due to the proximity of the feedwater sparger and core spray downcomer piping.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.








No flaw indications were recorded.

The Auto coverage was calculated to be 69.1%.

Previous data was reviewed with no changes.

The examination results were compared with data report 000900 from D2R18 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	 Date:	 Utility Review By:	 Date:
 ANII Reviewed By:				 Date:

ATTACHMENT 2  
 Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
 Data Sheet**

Project : Dresden Unit-2, 2R22  
 Component : 2-SC3A-VERT

Report No.: D2R22-083

File	Scan Type	Scan											
		Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch.10	Ch.11	Ch.12
2-SC3A_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3A_2	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3A_3	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3A_4	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".

Analyzed by: Brad Dummer Level III 11/1/2011

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Coverage Calculation Sheet**

Report No.: D2R22-083

**DRESDEN UNIT-2  
Weld 2-SC3A**

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A	8.1	8.1	7.7%	26.5	0.8%
70° T-Scan CCW (S4 NS)	A	8.1	8.1	7.7%	26.5	0.8%
45° T-Scan (S6 FV)	A	44.4	44.4	84.6%	26.5	8.4%
70° P-Scan UP (S4 NS)	A	8.1	8.1	7.7%	26.5	0.8%
70° P-Scan DN (S4 NS)	A	8.1	8.1	7.7%	26.5	0.8%
45° P-Scan (S6 FV)	A	44.4	44.4	84.6%	26.5	8.4%
70° T-Scan CW (S4 NS)	B/C	8.1	7.6	7.2%	71.5	1.9%
70° T-Scan CCW (S4 NS)	B/C	8.1	4.2	4.0%	71.5	1.1%
45° T-Scan (S6 FV)	B/C	44.4	40.1	76.4%	71.5	20.5%
70° P-Scan UP (S4 NS)	B/C	8.1	3.1	3.0%	71.5	0.8%
70° P-Scan DN (S4 NS)	B/C	8.1	8.1	7.7%	71.5	2.1%
45° P-Scan (S6 FV)	B/C	44.4	44.4	84.6%	71.5	22.7%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 69.1%

Rev. 0 9/23/05

**Comments:**

A - Automated scanning was not restricted.

B/C - Automated scanning was restricted due to the proximity of the core spray downcomer piping.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.



**ATTACHMENT 2**  
**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**HITACHI**

**SP2000 RPV Examination**  
**Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC3A-VERT  
**Report No.:** D2R22-083

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC3A_1	10/22/11	539.00	498.00	DN (Fwd)	-41.00	0809	0830
2-SC3A_2	10/24/11	400.00	424.00	DN (Fwd)	24.00	1805	1824
2-SC3A_3	10/24/11	414.00	431.00	DN (Fwd)	17.00	1829	1839
2-SC3A_4	10/24/11	463.00	431.00	UP (Fwd)	-32.00	2024	2100

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the feedwater sparger and core spray piping downcomer

**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 92°F              **Couplant:** Water


**Operators:** Shane Gauthier Level II  
 Clint Gauthier Level II

SEARCH UNIT DATA:						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map



**HITACHI**

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

Dresden  
Reference Drawings




Cross Section of Achieved Coverage "C"



**HITACHI**

# Dresden Reference Drawings




Scanned Patches Coverage "A" and "C"



**HITACHI**

# Dresden Reference Drawings



Scanned Patches Coverage "B"



**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-084
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC3B-Vert Long Seam				
Outage:	D2R22	Configuration:	Shell 3 Vert Weld				
System:	RPV	ASME Cat:	B-A	ASME Item:	B1.12	Aug. Requirements:	N/A
Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:	
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	
45°S	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier/C.Gauthier	II/II	10/29/11	

**Comments:**

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted due to the proximity of the lower guide rod, feedwater sparger and core spray piping.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.








No flaw indications were recorded.

The Auto coverage was calculated to be 72.9%.

Previous data was reviewed with no changes.

The examination results were compared with data report 001000 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	 Date:	 Utility Review By:	 Date:
 ANII Reviewed By:				 Date:

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Data Sheet**

Project: Dresden Unit-2, 2R22  
Component: 2-SC3B-VERT

Report No.: D2R22-084

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
2-SC3B_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3B_3	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3B_4	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".  
Scan files 2-SC3B\_2 was voided.

Analyzed by: Brad Dummer Level III 11/1/2011



**HITACHI**

**SP2000 RPV Examination  
 Coverage Calculation Sheet**

Report No.: D2R22-084

**DRESDEN UNIT-2  
 Weld 2-SC3B**

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A	8.1	8.1	7.7%	97	2.8%
70° T-Scan CCW (S4 NS)	A	8.1	8.1	7.7%	97	2.8%
45° T-Scan (S6 FV)	A	44.4	44.4	84.6%	97	30.8%
70° P-Scan UP (S4 NS)	A	8.1	8.1	7.7%	97	2.8%
70° P-Scan DN (S4 NS)	A	8.1	8.1	7.7%	97	2.8%
45° P-Scan (S6 FV)	A	44.4	44.4	84.6%	97	30.8%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 72.9%

Rev. 0 9/23/05

**Comments:**

A- Automated scanning was not restricted.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in mm.



**HITACHI**

**SP2000 RPV Examination  
Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC3B-VERT  
**Report No.:** D2R22-084

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC3B_1	10/23/11	497.50	539.50	DN (Fwd)	42.00	1052	1114
2-SC3B_3	10/29/11	461.00	421.00	UP (Fwd)	-40.00	2147	2212
2-SC3B_4	10/29/11	389.50	429.25	DN (Fwd)	39.75	2307	2327

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the feedwater sparger and tie rod repair bracket.  
\*8 search unit was replaced 10-29-11 prior to 2-SC3B\_3 exam.  
Scan file 2-SC3B\_2 was voided.

SEARCH UNIT DATA:			Angle	Size	Freq.	Rotation
No.	Mfg.	S/N	Mode			
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°
*8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°


**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 92°F            **Couplant:** Water

**Operators:** Shane Gauthier Level II  
                  Clint Gauthier Level II



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings



Weld Location Map


# ATTACHMENT 2

## Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



HITACHI

### Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"





HITACHI

# Dresden Reference Drawings




Scanned Patches Coverage "A"



HITACHI

# Dresden Reference Drawings



**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-085
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC3C-Vert Long Seam	
Outage:	D2R22	Configuration:	Shell 3 Vert Weld	
System:	RPV	ASME Cat:	B-A	ASME Item: B1.12    Aug. Requirements: N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted due to the proximity of the shroud repair tie rod, feedwater sparger and core spray piping.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.








No flaw indications were recorded.

The Auto coverage was calculated to be 68.7%.

Previous data was reviewed with no changes.

The examination results were compared with data report 001100 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	 Date:	 Utility Review By:	 Date:
 ANII Reviewed By:				 Date:

**ATTACHMENT 2**  
**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**HITACHI**

**SP2000 RPV Examination**  
**Data Sheet**

Project: Dresden Unit-2, 2R22  
 Component: 2-SC3C-VERT

Report No.: D2R22-085

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
2-SC3C_2	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3C_3	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3C_4	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3C_5	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3C_6	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".  
 Scan files 2-SC3C\_1 was voided.

Analyzed by: Brad Dummer Level III 10/31/2011



**HITACHI**

## SP2000 RPV Examination Coverage Calculation Sheet

Report No.: D2R22-085

### DRESDEN UNIT-2 Weld 2-SC3C

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. in.	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A/B	8.1	8.1	7.7%	85.5	2.5%
70° T-Scan CCW (S4 NS)	A/B	8.1	8.1	7.7%	85.5	2.5%
45° T-Scan (S6 FV)	A/B	44.4	44.4	84.6%	85.5	27.2%
70° P-Scan UP (S4 NS)	A/B	8.1	8.1	7.7%	85.5	2.5%
70° P-Scan DN (S4 NS)	A/B	8.1	8.1	7.7%	85.5	2.5%
45° P-Scan (S6 FV)	A/B	44.4	44.4	84.6%	85.5	27.2%
70° T-Scan CW (S4 NS)	C	8.1	8.1	7.7%	6	0.2%
70° T-Scan CCW (S4 NS)	C	8.1	6.4	6.1%	6	0.1%
45° T-Scan (S6 FV)	C	44.4	44.4	84.6%	6	1.9%
70° P-Scan UP (S4 NS)	C	8.1	5.4	5.1%	6	0.1%
70° P-Scan DN (S4 NS)	C	8.1	8.1	7.7%	6	0.2%
45° P-Scan (S6 FV)	C	44.4	44.4	84.6%	6	1.9%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 68.7%

Rev. 0 9/23/05

**Comments:**

A/B- Automated scanning was not restricted.

B - Automated scanning was restricted due to the proximity of the shroud repair bracket.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.

**ATTACHMENT 2**  
**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**HITACHI**

**SP2000 RPV Examination**  
**Scan Files Data Sheet**

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC3C-VERT  
**Report No.:** D2R22-085

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

<b>Scan File</b>	<b>Date</b>	<b>Drive Start (in.)</b>	<b>Drive Stop (in.)</b>	<b>Drive Direction</b>	<b>Drive Distance (in.)</b>	<b>Start Time</b>	<b>Stop Time</b>
2-SC3C_2	10/22/11	535.00	515.00	DN (Fwd)	-20.00	1708	1719
2-SC3C_3	10/22/11	516.00	494.00	DN (Fwd)	-22.00	1734	1745
2-SC3C_4	10/28/11	463.00	431.00	UP (Rev)	-32.00	1329	1357
2-SC3C_5	10/28/11	432.00	419.00	UP (Rev)	-13.00	1407	1414
2-SC3C_6	10/28/11	397.00	430.00	UP (Fwd)	33.00	1513	1530

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the feedwater sparger, core spray piping bracket and tie rod repair bracket.  
 \*B search unit was replaced 10-27-11 prior to 2-SC3C\_4 exam.  
 Scan file 2-SC3C\_1 was voided.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 89°F            **Couplant:** Water


**Operators:** Shane Gauthier Level II

<b>SEARCH UNIT DATA:</b>							
<b>No.</b>	<b>Mfg.</b>	<b>S/N</b>	<b>Angle Mode</b>	<b>Size</b>	<b>Freq.</b>	<b>Rotation</b>	
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°	
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°	
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°	
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°	
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°	
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°	
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°	
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°	
*8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°	



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings



Weld Location Map




ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



HITACHI

Dresden  
Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "C"



HITACHI

# Dresden Reference Drawings




Scanned Patches Coverage "A"



HITACHI

# Dresden Reference Drawings



Scanned Patches Coverage "B" and "C"

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h1 style="margin:0;">HITACHI Examination Summary Sheet</h1>	Report No.: D2R22-086
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC3D-Vert Long Seam		
Outage:	D2R22	Configuration:	Shell 3 Vert Weld		
System:	RPV	ASME Cat:	B-A	ASME Item:	B1.12
				Aug. Requirements:	N/A

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/28/11

**Comments:**

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the core spray piping and feed water spargers.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.








Eight (8) acceptable flow indications were recorded. The indications are characteristic of fabrication artifacts and were not recorded during the previous examinations. This is attributed to differences in procedure recording criteria.

The Auto coverage was calculated to be 73.7%.

Previous data was reviewed with no changes.

The examination results were compared with data report 001200 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	 Date:	 Utility Review By:	 Date:
			 ANII Reviewed By:	 Date:

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Data Sheet**

Project : Dresden Unit-2, 2R22  
Component : 2-SC3D-VERT

Report No.: D2R22-086

File	Scan Type	Ch.1	Ch.2	Ch.3	Ch.4	Ch.5	Ch.6	Ch.7	Ch.8	Ch.9	Ch.10	Ch.11	Ch.12
2-SC3D_1	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	-	-	-	-
2-SC3D_3	Head Up	RI (2)	RI (1)	RI (1)	NRI	NRI	NRI	NRI	NRI	-	-	-	-
2-SC3D_4	Head Up	RI (2)	RI (2)	NRI	NRI	NRI	NRI	NRI	NRI	-	-	-	-
2-SC3D_5	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	-	-	-	-

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".  
Scan file 2-SC3D\_2 was voided.

Analyzed by: John Gilliard Level III 10/31/2011

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

**SP2000 RPV Examination  
Indication Data Sheet**

Project: Dresden Unit-2, 2R22  
Component: 2-SC3D-VERT

Report: D2R22-086

Ind. No.	File	Channel	Maximum Amplitude Position				Indication Length Information				Remarks
			Amp dB	L Pos	W Pos	Depth	L Min	L Max	Length	Axis	
1	2-SC3D_3	1	-8.2	397.59	0.15	4.83	397.08	398.18	1.10	Axial	No determinable thruwall
2	2-SC3D_3	1	-11.7	414.85	0.15	4.83	413.97	415.25	1.28	Axial	No determinable thruwall
3	2-SC3D_3	2	-11.7	405.10	1.35	5.05	404.23	405.62	1.39	Circ.	No determinable thruwall
4	2-SC3D_3	3	-7.9	410.65	-1.15	5.53	409.43	411.17	1.74	Axial	No determinable thruwall
5	2-SC3D_4	1	-13.0	415.6	0.65	4.83	414.75	415.95	1.20	Axial	No determinable thruwall
6	2-SC3D_4	1	-12.3	419.4	0.15	4.92	419.02	419.80	0.78	Axial	No determinable thruwall
7	2-SC3D_4	2	-7.3	432.4	0.60	3.50	431.77	433.13	1.36	Circ.	No determinable thruwall
8	2-SC3D_4	2	-9.3	453.9	1.35	3.24	453.17	454.17	1.00	Circ.	No determinable thruwall

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". Measurements in inches.

Analyzed by: John Gilliard Level III 10/31/2011





**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC3D

Indication : 1

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "l" =	1.10	1.1	"T" measured =	N/A	N/A
Surface Separation "S" =	1.61	1.6			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.99	2.18 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.99	2.18

a = 0.050  
a/l value = 0.045  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.2%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/05

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JG*

Reviewed by: Chris Minor Level III *CM*

Utility Reviewed by: *[Signature]*



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weid ID : 2-SC3D

Indication : 2

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "l" =	1.28	1.3	"T" measured =	N/A	N/A
Surface Separation "S" =	1.61	1.6			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.98	2.15 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.98	2.15

a = 0.050  
a/l value = 0.038  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.2%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III JCG

Reviewed by: Chris Minor Level III CAM

Utility Reviewed by:



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC3D

Indication : 3

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "l" =	1.39	1.4	"T" measured =	N/A	N/A
Surface Separation "S" =	1.39	1.4			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.97	2.14 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.97	2.14

a = 0.050  
a/l value = 0.036  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.1%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JCG*

Reviewed by: Chris Minor Level III *CAM*

Utility Reviewed by: *J. Miller*



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC3D

Indication : 4

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "P" =	1.74	1.7	"T" measured =	N/A	N/A
Surface Separation "S" =	0.91	0.9			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.96	2.12 Y
0.05	2.0	2.2	-	-
0.10	2.2	2.5	-	-
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	-	-
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed	Allowed
			1.96	2.12

a = 0.050  
a/l value = 0.029  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.1%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JCG*

Reviewed by: Chris Minor Level III *CAM*

Utility Reviewed by: *[Signature]*



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

**Project :** Dresden Unit-2  
**Weld ID :** 2-SC3D

**Indication :** 5

**Flaw Through Wall =** Measured 0.075 Rounded 0.1  
**Flaw Length "l" =** 1.20 1.2  
**Surface Separation "S" =** 1.64 1.6

**"T" nominal =** Measured 6.25 Rounded 6.2  
**"T" measured =** N/A N/A

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.98	2.17 Y
0.05	2.0	2.2	-	-
0.10	2.2	2.5	-	-
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	-	-
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed 1.98	Allowed 2.17

a = 0.050  
a/l value = 0.042  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.2%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III JCG

Reviewed by: Chris Minor Level III CAM

Utility Reviewed by:



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC3D

Indication : 6

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "l" =	0.78	0.8	"T" measured =	N/A	N/A
Surface Separation "S" =	1.54	1.5			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	-	-
0.05	2.0	2.2	2.05	2.28 Y
0.10	2.2	2.5	-	-
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	-	-
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed	Allowed
			2.05	2.28

a = 0.050  
a/l value = 0.063  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.3%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JCG*

Reviewed by: Chris Minor Level III *CAM*

Utility Reviewed by: *[Signature]*



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-5C3D

Indication : 7

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "L" =	1.36	1.4	"T" measured =	N/A	N/A
Surface Separation "S" =	2.94	2.9			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.97	2.14 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.97	2.14

a = 0.050  
a/l value = 0.036  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.1%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JCG*

Reviewed by: Chris Minor Level III *CAN*

Utility Reviewed by: *[Signature]*



**HITACHI**

**Reactor Pressure Vessel  
Flaw Evaluation Sheet**

Project : Dresden Unit-2  
Weld ID : 2-SC3D

Indication : 8

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.25	6.2
Flaw Length "l" =	1.00	1.0	"T" measured =	N/A	N/A
Surface Separation "S" =	3.20	3.2			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	-	-
0.05	2.0	2.2	2.00	2.20 Y
0.10	2.2	2.5	-	-
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	-	-
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed 2.00	Allowed 2.20

a = 0.050  
a/l value = 0.050  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.2%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/05

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: John Gilliard Level III *JCG*

Reviewed by: Chris Minor Level III *CAM*


Utility Reviewed by: *[Signature]*





HITACHI

# Dresden Indication Prints




Indication 1 - Channel 1



HITACHI

# Dresden Indication Prints




Indication 2 - Channel 1



HITACHI

# Dresden Indication Prints




Indication 3 - Channel 2



HITACHI

# Dresden Indication Prints




Indication 4 - Channel 3



HITACHI

# Dresden Indication Prints




Indication 5 - Channel 1



HITACHI

# Dresden Indication Prints




Indication 6 - Channel 1



HITACHI

# Dresden Indication Prints




Indication 7 - Channel 2



HITACHI

# Dresden Indication Prints



Indication 8 - Channel 2





**HITACHI**

**SP2000 RPV Examination  
 Coverage Calculation Sheet**

Report No.: D2R22-086

**DRESDEN UNIT-2  
 Weld 2-SC3D**

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A/B	8.1	8.1	7.7%	98	2.8%
70° T-Scan CCW (S4 NS)	A/B	8.1	8.1	7.7%	98	2.8%
45° T-Scan (S6 FV)	A/B	44.4	44.4	84.6%	98	31.2%
70° P-Scan UP (S4 NS)	A/B	8.1	8.1	7.7%	98	2.8%
70° P-Scan DN (S4 NS)	A/B	8.1	8.1	7.7%	98	2.8%
45° P-Scan (S6 FV)	A/B	44.4	44.4	84.6%	98	31.2%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 73.7%

Rev. 0 9/23/05

**Comments:**

A/B- Automated scanning was not restricted.  
 Scanning was limited due to the proximity of the feed water sparger and core spray piping.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in mm.

ATTACHMENT 2

Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets



**HITACHI**

## SP2000 RPV Examination Scan Files Data Sheet

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC3D-VERT  
**Report No.:** D2R22-086

**Procedure No.:** GEH-UT-717  
**Revision:** V.3  
**DRR No.:** 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC3D_1	10/22/11	498.00	541.00	DN (Rev)	43.00	1239	1306
2-SC3D_3	10/28/11	420.00	382.00	UP (Rev)	-38.00	1118	1137
2-SC3D_4	10/28/11	410.00	460.00	UP (Fwd)	50.00	1150	1219
2-SC3D_5	10/28/11	455.00	463.00	UP (Fwd)	8.00	1227	1232

**Comments:** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the feedwater sparger, and core spray piping bracket.  
\*8 search unit was replaced 10-27-11 prior to 2-SC3D\_3, 4 and 5 exams.  
Scan file 2-SC3D\_2 was voided.

**Thermometer S/N:** Control Room    **Software Rev.:** V1.1Q6  
**Vessel Temp. (°F):** 90°F            **Couplant:** Water


**Operators:** Shane Gauthier Level II

SEARCH UNIT DATA;						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°
*8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

# Dresden Reference Drawings



Scanned Patches

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<h2 style="margin:0;">HITACHI Examination Summary Sheet</h2>	Report No.: D2R22-087
---	--	-----------------------

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC3E-Vert Long Seam				
Outage:	D2R22	Configuration:	Shell 4 Vert Weld				
System:	RPV	ASME Cat:	B-A	ASME Item:	B1.12	Aug. Requirements:	N/A
Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:	
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	
70°L	RPV-ID-10	CAL-IIW2-043	GEH-UT-717 V3	S. Gauthier	II	10/27/11	

**Comments:**  
 Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted by the proximity of the upper guide rod, core spray piping and feed water spargers.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.





Two (2) acceptable flaw indications were recorded. The indications are characteristic of fabrication artifacts and were not recorded during the previous examinations. This is attributed to differences in procedure recording criteria.

The Auto coverage was calculated to be 74.2%.

Previous data was reviewed with no changes.

The examination results were compared with data report 001300 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	 Level:	11/3/11 Date:	 Utility Review By:	11-5-11 Date:
 ANII Reviewed By:				11-7-11 Date:





**HITACHI**

## SP2000 RPV Examination Data Sheet

**Project:** Dresden Unit-2, 2R22  
**Component:** 2-SC3E-VERT

**Report No.:** D2R22-087

File	Scan Type	Ch.1	Ch.2	Ch.3	Ch.4	Ch.5	Ch.6	Ch.7	Ch.8	Ch.9	Ch.10	Ch.11	Ch.12
2-SC3E_2	Head Down	RI (2)	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC3E_4	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".  
 Scan files 2-SC3E\_1, 3 were voided.

Analyzed by: Brad Dummer Level III 10/30/2011



**HITACHI**

## SP2000 RPV Examination Indication Data Sheet

Project : Dresden Unit-2, 2R22  
Component : 2-SC3E-VERT

Report : D2R22-087

Ind. No.	File	Channel	Maximum Amplitude Position				Indication Length Information				Remarks
			Amp dB	L Pos	W Pos	Depth	L Min	L Max	Length	Axis	
1	2-SC3E_2	1	-18.5	517.39	0.35	3.05	505.89	519.39	13.50	Axial	No determinable thruwall
2	2-SC3E_2	1	-24.8	513.89	-0.90	2.14	513.89	515.89	2.00	Axial	No determinable thruwall

Comments: The symbol ~ indicotes "No entry required" or "Not Applicable". Measurements in inches.

Analyzed by: Brad Dummer Level III 10/30/2011



HITACHI

Reactor Pressure Vessel  
Flaw Evaluation Sheet

Project : Dresden Unit-2  
Weld ID : 2-SC3E

Indication : 1

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
Flaw Through Wall =	0.075	0.1	"T" nominal =	6.375	6.4
Flaw Length "P" =	13.50	13.5	"T" measured =	N/A	N/A
Surface Separation "S" =	2.8625	2.9			

ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.91	2.01 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.91	2.01

a = 0.050  
a/l value = 0.004  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.0%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/05

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.

This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: Brad Dummer Level III *BD*

Reviewed by: Chris Minor Level III *CAM*

Utility Reviewed by: *[Signature]*

 <b>HITACHI</b>	<h2 style="margin: 0;">Reactor Pressure Vessel Flaw Evaluation Sheet</h2>
--	---

**Project :** Dresden Unit-2  
**Weld ID :** 2-SC3E

**Indication :** 2

	<u>Measured</u>	<u>Rounded</u>		<u>Measured</u>	<u>Rounded</u>
<b>Flaw Through Wall =</b>	0.075	0.1	<b>"T" nominal =</b>	6.375	6.4
<b>Flaw Length "l" =</b>	2.00	2.0	<b>"T" measured =</b>	N/A	N/A
<b>Surface Separation "S" =</b>	1.95	2.0			

**ASME Section XI, 1995 Edition, with the 1996 Addenda  
TABLE IWB-3510-1 for 4" to 12"**

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	1.95	2.10 Y
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			1.95	2.10

a = 0.050  
a/l value = 0.025  
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.1%  
a/t = 0.8%

Flaw is acceptable by Table IWB-3510-1.

Revised: 1/27/06

**Comments:** ASME Section XI rounding performed in accordance with IWA-3200 and ASTM E29.  
This indication had no determinable through wall dimension. The 0.075" dimension is an assigned value for evaluation purposes only.

Evaluation by: Brad Dummer Level III *BD*


Reviewed by: Chris Minor Level III *CM*

Utility Reviewed by: *J. Malcom*



HITACHI

# Dresden Indication Prints




Indication 1



HITACHI

# Dresden Indication Prints



Indication 2



**HITACHI**

## SP2000 RPV Examination Coverage Calculation Sheet

Report No.: D2R22-087

### DRESDEN UNIT-2 Weld 2-SC3E

Weld Length = Exam Volume =	133. 52.5	CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. mm	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
70° T-Scan CW (S4 NS)	A	8.1	8.1	7.7%	71.5	2.1%
70° T-Scan CCW (S4 NS)	A	8.1	8.1	7.7%	71.5	2.1%
45° T-Scan (S6 FV)	A	44.4	44.4	84.6%	71.5	22.7%
70° P-Scan UP (S4 NS)	A	8.1	8.1	7.7%	71.5	2.1%
70° P-Scan DN (S4 NS)	A	8.1	8.1	7.7%	71.5	2.1%
45° P-Scan (S6 FV)	A	44.4	44.4	84.6%	71.5	22.7%
70° T-Scan CW (S4 NS)	B	8.1	8.1	7.7%	27.5	0.8%
70° T-Scan CCW (S4 NS)	B	8.1	7.5	7.1%	27.5	0.7%
45° T-Scan (S6 FV)	B	44.4	44.4	84.6%	27.5	8.7%
70° P-Scan UP (S4 NS)	B	8.1	6.7	6.4%	27.5	0.7%
70° P-Scan DN (S4 NS)	B	8.1	8.1	7.7%	27.5	0.8%
45° P-Scan (S6 FV)	B	44.4	44.4	84.6%	27.5	8.7%
70° T-Scan CW (S4 NS)						
70° T-Scan CCW (S4 NS)						
45° T-Scan (S6 FV)						
70° P-Scan UP (S4 NS)						
70° P-Scan DN (S4 NS)						
45° P-Scan (S6 FV)						

% Total Composite Coverage = 74.2%

Rev. 0 9/23/05

**Comments:**

- A - Automated scanning was not restricted.
- B - Automated scanning was restricted due to the proximity of the upper guide rod.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.



HITACHI

### SP2000 RPV Examination Scan Files Data Sheet

Project : Dresden Unit-2, 2R22  
Component : 2-SC3E-VERT  
Report No. : D2R22-087

Procedure No. : GEH-UT-717  
Revision : V.3  
DRR No. : 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC3E_2	10/22/11	540.00	497.00	DN (Fwd)	-43.00	1101	1120
2-SC3E_4	10/27/11	463.00	382.00	DN (Fwd)	-81.00	1155	0040

**Comments :** Rotation angles specified are for the head down configuration. Scanning was restricted due to the proximity of the feedwater sparger, lower guide rod and core spray piping bracket.  
\*8 search unit was replaced 10-27-11 prior to 2-SC3E\_4 exam.  
Scan files 2-SC3E\_1, 3 were voided.

Thermometer S/N : Control Room    Software Rev. : V1.1Q6  
Vessel Temp. (°F) : 90°F            Couplant : Water

Operators : Clint Gauthier Level II  
              Shane Gauthier Level II


SEARCH UNIT DATA:							
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation	
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°	
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°	
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°	
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°	
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°	
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°	
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°	
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°	
*8	GEIT	01V5N6	70°L	2(12 x 25)mm	2.25	90°	





HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map





HITACHI

### Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

# Dresden Reference Drawings



Scanned Patches

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



# HITACHI Examination Summary Sheet

Report No.: D2R22-090

Site:	Dresden Unit-2	Component ID:	2/1/RPV SHELL/2-SC4C-Vert Long Seam				
Outage:	D2R22	Configuration:	Shell 4 Vert Weld				
System:	RPV	ASME Cat:	B-A	ASME Item:	B1.12	Aug. Requirements:	N/A
Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:	
45°S	RPV-ID-01	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
45°S	RPV-ID-02	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
45°S	RPV-ID-09	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
45°S	RPV-ID-04	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
70°L	RPV-ID-05	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
70°L	RPV-ID-06	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
70°L	RPV-ID-07	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	
70°L	RPV-ID-08	CAL-IIW2-043	GEH-UT-717 V3	C. Gauthier/S.Gauthier	II / II	10/24/11	

**Comments:**

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-717 V3, DRR-11-20 R1, using 45° Shear wave, and 70° RL search units. Automated UT scanning was performed from the vessel ID surface.

Automated scanning was performed on the left and right side of the weld simultaneously.

Automated scanning was restricted due to the proximity of the steam dryer support.

For Auto RPV ID Calibrations refer to calibration report D2R22-150.

No flaw indications were recorded.

The Auto coverage was calculated to be 85.7%.

Previous data was reviewed with no changes.

The examination results were compared with data report 001600 from D2R17 outage with  No Change  
 These examinations were performed under Work Order: 1289140-1  Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

CO NT Prepared By: \_\_\_\_\_ Level: II Date: 11/5/11  
 Utility Review By: [Signature] Date: \_\_\_\_\_  
 ANI Reviewed By: [Signature] Date: 11-7-11



**HITACHI**

**SP2000 RPV Examination  
 Data Sheet**

**Project:** Dresden Unit-2, D2R22  
**Component:** 2-SC4C-VERT

**Report No.:** D2R22-090

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
2-SC4C_4	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC4C_5	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC4C_6	Head Up	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~
2-SC4C_9	Head Down	NRI	NRI	NRI	NRI	NRI	NRI	NRI	NRI	~	~	~	~

Comments: The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications". RI indicates "Recordable Indications".  
 Scan Files 2-SC4C\_1, 2, 3, 7, and 8 were voided.

Analyzed by: Chris Minor Level III 10/24/2011



**HITACHI**

## SP2000 RPV Examination Coverage Calculation Sheet

Report No.: D2R22-090

**Dresden Unit-2, D2R22  
Weld 2-SC4C-VERT**

Weld Length = Exam Volume =	CODE CROSS-SECTIONAL AREA	TOTAL CODE COVERAGE				
		Required Exam Area Sq. in.	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
133. 52.5						
	A/B	8.1	8.1	7.7%	114	3.3%
	A/B	8.1	8.1	7.7%	114	3.3%
	A/B	44.4	44.4	84.6%	114	36.2%
	A/B	8.1	8.1	7.7%	114	3.3%
	A/B	8.1	8.1	7.7%	114	3.3%
	A/B	44.4	44.4	84.6%	114	36.2%

% Total Composite Coverage = 85.7%

Rev. D 9/23/05

Comments: A/B - Automated scanning was not restricted.  
Scanning was limited due to the proximity of the steam dryer support.

Note - Rounding methods may affect calculated values. FV-Full volume, NS-Near Surface. Weld length in inches.





**HITACHI**

## SP2000 RPV Examination Scan Files Data Sheet

Project: Dresden Unit-2, 2R22  
Component: 2-SC4C-VERT  
Report No.: D2R22-090

Procedure No.: GEH-UT-717  
Revision: V.3  
DRR No.: 11-20

Scan File	Date	Drive Start (in.)	Drive Stop (in.)	Drive Direction	Drive Distance (in.)	Start Time	Stop Time
2-SC4C_4	10/22/11	508.00	552.00	UP (Rev)	44.00	2239	2303
2-SC4C_5	10/23/11	578.00	560.00	DN(Fwd)	-18.00	1506	1556
2-SC4C_6	10/23/11	562.00	521.00	DN(Fwd)	-41.00	1607	1707
2-SC4C_9	10/24/11	597.00	660.00	UP (Rev)	63.00	1319	1356

Comments: Rotation angles specified are for the head down configuration.  
Scan files 2-SC4C\_1, 2, 3, 7 and 8 were voided.

SEARCH UNIT DATA:						
No.	Mfg.	S/N	Angle Mode	Size	Freq.	Rotation
1	GEIT	01V5NC	45°S	23 x 25mm	2.25	0°
2	GEIT	01V5ND	45°S	23 x 25mm	2.25	270°
3	GEIT	01V5NJ	45°S	23 x 25mm	2.25	180°
4	GEIT	01V5NH	45°S	23 x 25mm	2.25	90°
5	GEIT	01V5NB	70°L	2(12 x 25)mm	2.25	0°
6	GEIT	01V5N7	70°L	2(12 x 25)mm	2.25	270°
7	GEIT	01V5N8	70°L	2(12 x 25)mm	2.25	180°
8	GEIT	01V5N9	70°L	2(12 x 25)mm	2.25	90°


Thermometer S/N: Control Room      Software Rev.: V1.1Q6  
Vessel Temp. (°F): 98°F                  Couplant: Water

Operators: Clint Gauthier Level II  
Shane Gauthier Level II



HITACHI

# Dresden Reference Drawings




ID RPV Vessel Scanner Package Configuration for Vertical Weld Scans



HITACHI

# Dresden Reference Drawings




Weld Location Map



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "A"



HITACHI

# Dresden Reference Drawings




Cross Section of Achieved Coverage "B"



HITACHI

Dresden  
Reference Drawings




Scanned Patches - Head Up Configuration



**HITACHI**

# Dresden Reference Drawings

**500"**



Scanned Patches - Head Down Configuration

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

	<b>Examination Summary Sheet</b>	Report No.: N19A-7
---	----------------------------------	--------------------

Site: Dresden Unit 2	Component ID: 2/1/RPV SHELL/N19A-2	ASME Cat: B-D	ASME Item: B3.90
Outage: D2R20	Configuration: Nozz-Shell / N/V IRS	Aug. Requirements: N/A	
System: Core Spray			

Exams Performed:	Calibration Sheet(s):	Calibration Block:	Procedure:	Examination Personnel:	NDE Level:	Date:
45/S	D-COD-001 thru 012	99978AQC	GE-UT-716 V1	C. Gauthier	LV II	11/03/07
60/L			GE-UT-718 V0	J. Guillote	LV II	
70/L				M. Hilborn	LV II	
60/S						
60/L	D-037, D-038	99978AQC	GE-UT-300 V10	C. Gauthier	LV II	11/04/07
60/S	D-039		GE-UT-311 V15	C. Gauthier	LV II	11/04/07

**Comments:**

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Nozzle-to-Vessel Weld.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-716, V1, using 45° Shear wave, 60° RL, and 70° RL search units, supplemental 0° L-Wave scans were also performed. Supplemental Manual exams were performed in accordance with procedure GE-UT-300 V10, using 60° RL search units

Automated 60° Shear Inner Radius Nozzle to Vessel examinations were performed in accordance with procedure GE-UT-718 V0, DRR No. 07-07 and validated by modeling; Reference, "The General Electric Dresden Nozzle Modeling Document". Supplemental Manual 60° Shear Inner Radius Nozzle to Vessel examinations were performed in accordance with procedure GE-UT-311 V15 and validated by modeling; Reference, "The General Electric Dresden Nozzle Modeling Document".

Automated UT scanning was performed from the vessel OD surface and was restricted due to the nozzle configuration and insulation support interference. Manual UT scanning was performed from the vessel OD surface and was restricted due to the nozzle configuration.

Supplemental manual exams were performed in the restricted area of the insulation support.

The SP 2000 OD automated UT system 0 reference is located at TDC of nozzle.




For SP 2000 automated calibrations refer to report CAL-01.

No relevant indications were recorded.

Previous examination data was reviewed, with no significant changes noted.  
Automated and Manual UT Composite Coverage = 47.7%.

The examination results were compared with data report N19A-2 from 1998 outage with	<input checked="" type="checkbox"/>	No Change
These examinations were performed under Work Order: 871143-06	<input type="checkbox"/>	Change

This summary and the following data sheets have been reviewed and accepted by the following personnel:

 Prepared By:	III Level:	11-5-07 Date:	 Utility Review By:	11-8-07 Date:
			 ANII Reviewed By:	11/11/07 Date:





GE Hitachi Nuclear Energy

# SP2000 Examination Data Sheet

**Project :** Dresden Unit-2  
**Component :** Feedwater Nozz-Shell

**Summary No.:** N19A-2  
**Exam Data Sheet:** N19A-2-01

File	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12
n19a tl_01	TL	NRI	NRI	NRI	NRI	~	~	~	~	~	~	~	~
n19a tl_02	TL	NRI	NRI	NRI	NRI	~	~	~	~	~	~	~	~
n19a p1_01	P	NRI	NRI	NRI	NRI	~	~	~	~	~	~	~	~
n19a n/z1_01	NV/Z1	NRI	NRI	NRI	NRI	~	~	~	~	~	~	~	~

**Comments:** Analyzed by Brad Dummer Level III 11/04/07 *BD*

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Page 2 of 15

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**GE ENERGY, NUCLEAR**

**Ultrasonic Calibration and Examination Record  
RPV Components**

Site/Unit: Dresden / 2

Data Report Number: N19A-2 NOZ-RPV Linearity Sheet: L-004

Outage: D2R20

Data Sheet Number: D-037

Procedure: GE-UT-300

Rev.: 10

DRR: N/A

Calibration Block: 99978AQC

<u>CS</u> Material	<u>Flat</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>2030</u>	Exam Start: <u>21:30</u>	
Cal Check: <u>N/A</u>	Exam End: <u>22:43</u>	
Cal Check: <u>N/A</u>	<u>Ultrage II</u> Couplant:	<u>02125</u> Batch
Final Cal: <u>0103</u>		
<u>255152</u> Thermometer	<u>75° F</u> Initial Cal Temp.	<u>75° F</u> Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
<u>ID Notch</u>	<u>7.0</u>	<u>1X</u>	<u>80</u>	<u>11.79</u>	<u>13.62</u>	<u>6.8</u>
		<u>1X</u>				
		<u>1X</u>				
		<u>1X</u>				
		<u>1X</u>				

DAC 1X= 70.1

Sweep 0-10 = 10 Depth

Note: N/A dB difference between 3/8 and 5/8 Vee

Search Unit Data

Sigma 22BC-02005 271.1x.62 / Rect.  
 Manufacturer: Serial Number: Size / Shape:  
0.50° 60° 60°  
 Incident Point: Nominal Angle: Measured Angle:  
3.0 MHz SDC-3 RL  
 Frequency: Model: Mode:

Search Unit Cable

RG-174 9' 0  
 Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031572811  
 Manufacturer/Model: Serial Number:  
7.655 us 0.2245 in./usec. 0.8 - 3.0 MHz  
 Delay/Zero: Velocity: Narrowband Filter:  
Auto Fullwave 20.0 in. Sq. / Med  
 Rep Rate: Rectification: Range: Pulse:  
400 Ohms 0% 3.03 MHz Dual  
 Damping: Reject: Frequency: Mode:  
Off: Off: Off: Off:  
 DAC: TVG: CSC: DGS:

Exam Data for Weld: 2/1/RPV SHELL/N19A-2

NOZ-RPV  
 Configuration:

OD 98° F  
 Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>T&amp;P</u>	<u>60</u>	<u>NRI</u>	<u>60</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 10/19/2007

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.  
 Calibration for full volume examination. Calibration for nozzle to vessel weld (N/A).  
 Exams performed to maintain a minimum 10-20% FSH clad roll.  
 Exam performed from 65° to 268° clockwise and counter-clockwise in automated limited area.

CD Clint Gauthier II 11/4/2007  
 Initials: Examiner Level: Cal/Exam Date:

N/A N/A  
 Initials: Examiner Level: Date:  
J.C. D... III 11-5-07  
 Reviewed By: Level: Date:

[Signature] III 11-4-07  
 Utility Reviewed By: Date:

[Signature] III 11/11/07  
 ANI Reviewed By: Date:

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**GE ENERGY, NUCLEAR**

**Ultrasonic Calibration and Examination Record  
RPV Components**

Site/Unit: Dresden / 2

Data Report Number: N19A-2 NOZ-RPV Linearity Sheet: L-004

Outage: D2R20

Data Sheet Number: D-038

Procedure: GE-UT-300

Rev.: 10

DRR: N/A

Calibration Block: CAL-IIW2-047

<u>CS</u> Material	<u>Flat</u> Size	<u>4.0"</u> Thickness
Initial Cal: <u>2025</u>	Exam Start: <u>21:10</u>	
Cal Check: <u>N/A</u>	Exam End: <u>22:43</u>	
Cal Check: <u>N/A</u>	<u>Ultraget II</u> Couplant:	<u>02125</u> Batch
Final Cal: <u>0055</u>		
<u>255152</u> Thermometer:	<u>75° F</u> Initial Cal Temp.	<u>75° F</u> Final Cal Temp.

**Search Unit Data**

<u>Sigma</u> Manufacturer:	<u>22BC-02005</u> Serial Number:	<u>2(1.1x.62) / Rect.</u> Size / Shape:
<u>0.50"</u>	<u>60°</u>	<u>60°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:

**Search Unit Cable**

<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:
------------------------------	----------------------	-------------------------

**Instrument Settings**

<u>Panametrics / Epoch 4</u> Manufacturer/Model:		<u>031572811</u> Serial Number:	
<u>7.655 us</u> Delay/Zero:	<u>0.2245 in./usec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>4.0 in.</u> Range:	<u>Sq. / Med</u> Pulser:
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:	<u>Dual</u> Mode:
<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:	<u>Off:</u> DGS:

**DAC Construction**

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
SDH	<u>.60</u>	1X	<u>80</u>	<u>1.17</u>	<u>1.17</u>	<u>3.4</u>
		1X				
		1X				
		1X				
		1X				

DAC 1X= 55.1

Sweep 0-10 = 2 Depth

Note: N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: 2/1/RPV SHELL/N19A-2

NOZ-RPV  
Configuration:

<u>OD</u> Exam Surface:	<u>98° F</u> Component Temperature
----------------------------	---------------------------------------

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>T&amp;P</u>	<u>69.1</u>	<u>NR</u>	<u>60</u>

**Calibration Verification**

Field Simulator Block S/N: N/A

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 10/19/2007

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.  
Calibration for near surface examination. Calibration for nozzle to vessel weld (N/A).  
Exams performed a minimum of 14 dB above reference.  
Exam performed from 65° to 268° clockwise and counter-clockwise in automated limited area.

<u>Clint Gauthier</u> Initials: Examiner	<u>II</u> Level:	<u>11/4/2007</u> Cal/Exam Date:
<u>CS</u> Initials: Examiner	<u>N/A</u> Level:	
<u>J.C. Rice</u> Gr Reviewed By:	<u>III</u> Level:	<u>11-5-07</u> Date:

<u>[Signature]</u> Utility Reviewed By:	<u>11-7-07</u> Date:
<u>[Signature]</u> ANII Reviewed By:	<u>11/11/07</u> Date:

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**Ultrasonic Calibration and Examination Record  
Inner Radius Examinations**

Site/Unit: Dresden / 2  
Outage: D2R20

Print Report Number: N19A-2 Linearity Sheet: L-004  
Data Sheet Number: D-039

Procedure: GE-UT-311

Rev: 15 DRR: N/A

Calibration Data for Block: 99978AQC

<u>CS</u> Material	<u>Flat</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>2037</u>	Exam Start: <u>2110</u>	
Cal Check: <u>N/A</u>	Exam End: <u>2243</u>	
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>02125</u>
Final Cal: <u>0109</u>	Couplant:	Batch
<u>255152</u> Thermometer	<u>75° F</u> Initial Cal Temp.	<u>75° F</u> Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.0</u>	1X	<u>80</u>	<u>11.63</u>	<u>13.42</u>	<u>6.8</u>
		1X				

DAC @ 1X= 45.7

Sweep 0-10 = 20" Metal Path

Acceptable Linearity performed: 10/19/2007

Search Unit data

KBA 001323 .50" x 1.0" Rect.  
Manufacturer: Serial No: Size/Shape:  
0.65 in. 60° 60°  
Incident Point: Nominal Angle: Measured Angle:  
1.0 MHz 113-291-600 Shear  
Frequency: Model: Mode:

Search Unit Cable

RG-174 9' 0  
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031572811  
Manufacturer/Model: Serial No.:  
15.62 us 0.1277 in /usec 0.8 - 3.0 MHz  
Zero: Velocity: Narrowband Filter:  
Auto Fullwave 20.0 in. Sq. / Med  
Rep Rate: Rectification: Range: Pulse/Energy  
400 Ohms 0% 1.0 MHz Pulse/Echo  
Damping: Reject: Frequency: Mode:  
Off: Off: Off: Off:  
DAC: TVG: CSC: DGS:

Exam Data for Component: 2/1/RPV SHELL/N19A-1

NV / Zone 1  
Configuration:

<u>OD</u> Exam Surface:	<u>98° F</u> Component Temp.				
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications
<u>0" - 7"</u>	<u>60°</u>	<u>±15°-55°</u>	<u>N/A</u>	<u>56</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.

Calibration for Zone 1.

Calibration for nozzle to vessel weld (NV-IRS)

Calibration for nozzle inner radius exam.

Exams performed to maintain 20-30% FSH clad roll.

Exam performed from 65° to 268° clockwise and counter-clockwise in automated limited area.

CB Clint Gauthier

Initials: Examiner:

II 11/4/2007

Level: Cal/Exam Date:

[Signature]  
Utility Reviewed By:

11-7-07  
Date:

[Signature]  
GE Reviewed By:

III 11-5-07  
Level: Date:


[Signature]  
ANII Reviewed By:

11/11/07  
Date:

## Dresden 2 CORE SPRAY (N19)

70° Exam Volume = 27.8 Sq. In.  
45° Exam Volume = 40.3 Sq. In.  
Inner 15%T Exam Volume 8.7 Sq. In. (RS & 60°T)


70° T-Scan Achieved = 3.3 Sq. In.  
45° T-Scan Achieved = 22.5 Sq. In.  
60° T-Scan Achieved = 8.7 Sq. In.



## Dresden 2 CORE SPRAY (N19)


70° Exam Volume = 27.8 Sq. In.  
45° Exam Volume = 40.3 Sq. In.  
Inner 15%T Exam Volume 8.7 Sq. In. (IRS & 60°T)

70° P-Scan Achieved = 2.1 Sq. In.  
45° P-Scan Achieved = 15.8 Sq. In.  
IRS P-Scan Achieved = 8.7 Sq. In. (By Modeling)



## Dresden 2 CORE SPRAY (N19) Manual Exam


60° S6 NS Exam Volume = 27.8 Sq. In.  
60° S6 FV Exam Volume = 40.3 Sq. In.  
Inner 15%T Exam Volume = 8.7 Sq. In. (IRS & 60°T)  
60° NS T-Scan Achieved = 2.7 Sq. In.  
60° S6 FV T-Scan Achieved = 31.6 Sq. In.  
60° S4 T-Scan Achieved = 8.7 Sq. In.  
60° NS P-Scan Achieved = 2.3 Sq. In.  
60° S6 FV P-Scan Achieved = 28.7 Sq. In.  
IRS P-Scan Achieved = 8.7 Sq. In. (By Modeling)



ATTACHMENT 2

Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets

Dresden 2  
Core Spray  
N19A Nozzle



N19A nozzle, Automated UT Nozz-Shell and N/V scans, restricted due to insulation support.



Dresden Unit 2 / D2R20



## Reactor Pressure Vessel Coverage Calculation Sheet

Dresden Unit 2 / D2R20  
 N19A-2 Core Spray (Noz-Shell)  
 Fall / 2007

Weld Length = 360. Exam Volume = 76.8		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Automated	Percent of Area Automated	Weld Length Automated	Percent Automated
60° T-Scan (S4 UC)	A	8.7	8.7	11.3%	157	2.5%
45° T-Scan (S6 FV)	A	40.3	22.5	29.3%	167	6.4%
70° T-Scan (S6 NS)	A	27.8	3.3	4.3%	157	0.9%
IRS P-Scan (S4 UC)	A*	8.7	8.7	11.3%	157	2.5%
45° P-Scan (S6 FV)	A	40.3	15.8	20.6%	167	4.5%
70° P-Scan (S6 NS)	A	27.8	2.1	2.7%	157	0.6%
60° T-Scan (S4 UC)			0		0	
45° T-Scan (S6 FV)			0		0	
70° T-Scan (S6 NS)			0		0	
IRS P-Scan (S4 UC)			0		0	
45° P-Scan (S6 FV)			0		0	
70° P-Scan (S6 NS)			0		0	
60° T-Scan (S4 UC)			0		0	
45° T-Scan (S6 FV)			0		0	
70° T-Scan (S6 NS)			0		0	
IRS P-Scan (S4 UC)			0		0	
45° P-Scan (S6 FV)			0		0	
70° P-Scan (S6 NS)			0		0	

% Total Composite Coverage = 17.3%

Rev. C 8/23/05

Comments: A - Automated scanning was restricted due to insulation support, manual pick-ups required.

A\* - Single side access, 50% credit of the achieved Supplement 4 T-scan volume claimed.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in degrees.

Page 10 of 15

Dresden Unit 2 / D2R20



GE Hitachi Nuclear Energy

## Reactor Pressure Vessel Coverage Calculation Sheet

Dresden Unit 2 / D2R20  
 N19A-2 Core Spray (Noz-Shell)  
 Fall / 2007

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length =	360.	Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
Exam Volume =	76.8					
60° T-Scan (S4 UC)	A	8.7	8.7	11.3%	203	3.2%
60° T-Scan (S6 FV)	A	40.3	31.6	41.1%	203	11.6%
60° T-Scan (S6 NS)	A	27.8	2.7	3.5%	203	1.0%
IRS P-Scan (S4 UC)	A	8.7	8.7	11.3%	203	3.2%
60° P-Scan (S6 FV)	A	40.3	28.7	37.4%	203	10.5%
60° P-Scan (S6 NS)	A	27.8	2.3	3.0%	203	0.8%
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						

% Total Composite Coverage = 30.4%

Rev. 0 9/25/05

Comments: A - Supplemental manual exam scanning was not restricted.

A\* - Single side access, 50% credit of the achieved Supplement 4 T-scan volume claimed.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in inches or degrees.

Page 11 of 15



GE Hitachi Nuclear Energy

SP2000 - RPV OD

Scan Plan for Nozzle Welds

Dresden Unit 2 / D2R20

Component: N19 Core Spray Nozzle N19A-2  
 ASME Volume OD Radius: 21.0

Description: Nozz Shell  
 Weld Centerline Radius: 10.3  
 Nominal Thickness: 6.4

SP2000 Quad Package - Radial TL- Scan Table - GE-UT-716

Channel	Probe ID	Cable (Jack)	Skew		Scan Offset	Index		Freq. (MHz)
			Entry	Fixture		Entry	Fixture	
1-0°L	~	1 (P1)	180°	0°	0.0	-12.3°	-4.5	2.25
2-45°ST	~	2 (P2)	180°	5°	0.0	-4.1°	-1.5	1.0
3-60°LT	~	4 (P3)	180°	356°	0.0	4.1°	1.5	2.0
4-70°LT	~	5(P4) / 6(R4)	180°	340°	0.0	12.3°	4.5	2.0

**Radial TL-Scans**  
 Index Start: -5°  
 Index Stop: 365°  
 Max. Index Increment: ≤ 0.5°

Scanner Start: Onset of liftoff  
 Scanner Stop: MAX  
 Max. Scanner Resolution: ≤ .25 in  
 Max. Scanner Velocity: ≤ 6.0 in/sec.

SP2000 Quad Package - Circumferential P-Scan Table - GE-UT-716

Channel	Probe ID	Cable (Jack)	Skew		Scan Offset	Index		Freq. (MHz)
			Entry	Fixture		Entry	Fixture	
1-45°S LKCC	~	1 (P1)	180°	306°	0.0	-4.1°	-1.5	1.0
2-70°L LKCC	~	2(P2) / 3(R2)	180°	297°	0.0	-12.3°	-4.5	2.0
3-45°S LKCW	~	4 (P3)	180°	54°	0.0	4.1°	1.5	1.0
4-70°L LKCW	~	5(P4) / 6(R4)	180°	63°	0.0	12.3°	4.5	2.0

**Circumferential P-Scans**  
 Index Start: -5°  
 Index Stop: 365°  
 Max. Index Increment: ≤ 0.6°

Scanner Start: Onset of liftoff  
 Scanner Stop: MAX  
 Max. Scanner Resolution: ≤ .25 in  
 Max. Scanner Velocity: ≤ 6.0 in/sec.



GE Hitachi Nuclear Energy

SP2000 - RPV OD

Scan Plan for Nozzle Welds

Dresden Unit 2 / D2R20

Component: N19A-1 Core Spray Nozz  
 ASME Volume OD Radius: 21.0

Description: Nozzle Inner Radius  
 Weld Centerline Radius: 10.3  
 Nominal Thickness: 6.4

ATTENTION - CHANGE OF PROCEDURE, INDEX INCREMENT AND SCANNER VELOCITY

SP2000 Quad Package - Circumferential N/V IRS-Scan Table - GE-UT-718

Channel	Probe ID	Cable	Skew		Scan Offset	Index		Freq. (MHz)
			Entry	Fixture		Entry	Fixture	
1-60° LKCC NV/Z1	~	1 (P1)	180°	335.1°	0.0	-4.1°	-1.5	1.0
2-60° LKCC NV	~	2 (P2)	180°	331.5°	0.0	-12.3°	-4.5	1.0
3-60° LKCW NV/Z1	~	4 (P3)	180°	24.9°	0.0	4.1°	1.5	1.0
4-60° LKCW NV	~	5 (P4)	180°	28.5°	0.0	12.3°	4.5	1.0

<u>Circumferential N/V IRS-Scans</u>			Scanner Start: Onset of liftoff
Index Start: -5°			Scanner Stop: MAX
Index Stop: 365°			Max. Scanner Resolution: ≤ .25 in.
Max. Index Increment: ≤ 1.3°			Max. Scanner Velocity: ≤ 3.9

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

Detection

NIR 1711r2 (rev 5)

MANUAL / AUTOMATED DETECTION								
NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Dresden 2						
PREPARED BY		S.C. MORTENSON			DATE 10/28/07			
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
<b>RECIRC INLET</b>								
N/V Weld (M)	PLATE	0 - 5.5"	60.0°	-	± 30° - 60°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 9.0"	70.0°	-	± 30°	FLAT	24.6"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	67.5°	-	18.1°	3.3"	12.0"	1 MHz
<b>FEEDWATER</b>								
N/V Weld	PLATE	0 - 8.0"	60.0°	1.5"	48.2° (43.7°)	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	60.0°	4.5"	38.9° (23.2°)	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	2.5"	40.3° (31.8°)	3.5"	14.5"	1 MHz
Zone 2a	ODBR	50° - 90°	67.5°	2.5"	21.7° (13.2°)	3.5"	12.5"	1 MHz
Zone 2b	NOZOD	ALL	28.0°	2.5"	68.0°	FLAT	8.7"	2 MHz
Zone 3	NOZOD	ALL	20.0°	2.5"	90°	FLAT	7.4"	2 MHz
<b>FEEDWATER</b>								
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	-	35° - 55°	FLAT	14.0"	1 MHz
N/V Weld / Zone 1-2A (M)	ODBR	50° - 90°	43.8°	-	40.3°	3.5"	14.5"	1 MHz
Zone 2A (M)	ODBR	50° - 90°	67.5°	-	21.7°	3.5"	12.5"	1 MHz
Zone 2b (M)	NOZOD	ALL	28.0°	-	68.0°	FLAT	8.7"	2 MHz
Zone 3 (M)	NOZOD	ALL	20.0°	-	90°	FLAT	7.4"	2 MHz
<b>CORE SPRAY</b>								
N/V Weld/Zone 1	PLATE	0 - 8.0"	60.0°	1.5"	31.1° (24.9°)	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 10.0"	60.0°	4.5"	45.9° (28.5°)	FLAT	14.0"	1 MHz
Zone 1	PLATE	0 - 10.0"	65.0°	4.5"	23.0° (5.7°)	FLAT	17.5"	1 MHz
Zone 1	PLATE	0 - 10.0"	70.0°	1.5"	12.3° (8.5°)	FLAT	22.2"	1 MHz
Zone 2A	ODBR	55° - 90°	66.3°	2.5"	16.7° (5.1°)	3.1"	10.8"	1 MHz
<b>CORE SPRAY</b>								
N/V Weld/Zone 1 (M)	PLATE	0 - 7.0"	60.0°	-	± 15° - 55°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 23°	FLAT	19.6"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	10.6"	1 MHz

W-025, W-026

W-027, W-028  
W-029, W-030

W-027, W-028  
W-029, W-030

W-031, W-032

W-031, W-032

NOTES: (M) MANUAL  
XXXX° (XXXX°) WEDGE / (FIXTURE) ROTATION ANGLE

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 577-3770

**Chris Minor**  
SME Review / Date

*Amiel*  
Site Review / Date

DRESDEN UNIT 2, B2B220



## SP2000 OD Examination Scan Files Data Sheet

**Project :** Dresden Unit-2  
**Component :** N19A-2  
**Procedure No.:** GE-UT-716 V1  
GE-UT-718 V0

**Revision** N/A  
**Revision** N/A

**Calibration Report No.:** CAL-01  
**DRR No.:** N/A  
**DRR No.:** 07-07

File Name	Date	Drive Start (deg)	Drive Stop (deg)	Drive Direction	Drive Distance (deg)	Start Time	Stop Time
n19a_t_01	11/4/07	79	245	CCW	194	1244	1314
n19a_t_02	11/4/07	65	268	CCW	157	1810	1825
n19a_p_01	11/4/07	79	245	CCW	194	1601	1624
n19a_nv/z1_01	11/4/07	79	245	CCW	194	1533	1550

**COMMENTS:** \* Rotation angles per the SP2000 scan plan.

**Software Revision:** 2.2Q14  
**Couplant:** Water  
**Thermometer S/N:** 255152  
**Vessel Temp.(°F)** 92°

**OPERATORS:** Jonathan Guillote Lv. II  
Clint Gauthier Lv. II  
Mark Hilborn Lv. III

SEARCH UNIT DATA;			Angle/	Size	Freq.	Rotation
No.	Mf.	S/N	Mode			
1	RTD	07-188	0°L	1.0"	2.25	*
2	RTD	07-1645	45°S	32 x 22 mm	1.0	*
3	RTD	07-192	60°L	30 x 25 mm	2.0	*
4	RTD	07-1651	70°L	2(12 x 25)mm	2.0	*
1	RTD	07-782	45°S	32 x 22 mm	1.0	*
2	RTD	07-1649	70°L	2(12 x 25)mm	2.0	*
3	RTD	07-783	45°S	32 x 22 mm	1.0	*
4	RTD	07-1650	70°L	2(12 x 25)mm	2.0	*
1	KBA	01LW0V	60°S	0.5 x 1.0"	1.0	*
2	KBA	01LW0W	60°S	0.5 x 1.0"	1.0	*
3	KBA	01LW0X	60°S	0.5 x 1.0"	1.0	*
4	KBA	01LW0Y	60°S	0.5 x 1.0"	1.0	*

PAGE 15 OF 15

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**GE NUCLEAR ENERGY**

**EXAMINATION SUMMARY SHEET**

Report No.:  
2R18-009

Site and Unit: Dresden Unit 2 Component ID: 2/1/RPV SHELL/M19B-2  
 Outage: D2R18 NOZ-RPV  
 System: RPV ASME Cat.: B-D ASME Item B3.90 Aug Requirements: Section XI

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° Shear	UT-085	UT-085	GE-UT-311	VESSEL SHELL	Jack Reisewitz	II	10/22/2003
60° Long.	UT-083	UT-083	GE-UT-300	CAL-IW2-013	Jack Reisewitz	II	10/22/2003
60° Long.	UT-084	UT-084	GE-UT-300	VESSEL SHELL	Jack Reisewitz	II	10/22/2003

**Examination Results:**

During the manual ultrasonic examination of the above referenced component, no recordable indications were detected using 60° RL and 60° shear wave search units.

Scanning was limited due to the nozzle configuration and an insulation support bracket below the nozzle.

36% of the required examination volume was examined.

This examination meets the requirements of ASME B&PV Code Section XI, Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

Examination results were compared to data report D326 from 1995 outage with  No Change  
 These examinations were performed under Work Order: 00813889-04  Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

<u>C.P. M</u>	<u>IV</u>	<u>10/25/03</u>	<u>[Signature]</u>	<u>III</u>	<u>10-24-03</u>
Prepared By:	Level:	Date:	Utility Reviewed By:	Title:	Date:
N/A	N/A	N/A	<u>[Signature]</u>	<u>10-31-03</u>	
Reviewed By:	Level:	Date:	ANII Reviewed By:	Title:	Date:

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**GE NUCLEAR ENERGY**

**Ultrasonic Calibration and Examination Record  
RPV Components**

Site/Unit: Dresden / 2

Data Report Number: 2R18-009

Linearity Sheet: L-013

Outage: D2R18

Data Sheet Number: UT-083

Beam Spread: N/A

Procedure: GE-UT-300

Ver.: I

DRR: N/A

Calibration Block: CAL-RW2-013

<u>CS</u> Material	<u>N/A</u> Size	<u>4.0"</u> Thickness
Initial Cal: <u>1524</u>	Exam Start: <u>1645</u>	
Cal Check: <u>N/A</u>	Exam End: <u>1705</u>	
Cal Check: <u>NA</u>	<u>Ultrage II</u> Couplant	<u>02125</u> Batch
Final Cal: <u>1818</u>	<u>229344</u> Thermometer	<u>72° F</u> Initial Cal Temp.
	<u>74° F</u> Final Cal Temp.	

**Search Unit Data**

<u>Sigma</u> Manufacturer:	<u>22BC-03001</u> Serial Number:	<u>2(1.1x.62)/Rect.</u> Size / Shape:
<u>0.70"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:
<u>3.0 MHz</u> Frequency:	<u>SDC3</u> Model:	<u>Long.</u> Mode:

**DAC Construction**

Hole "	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	<u>0.60</u>	1X	<u>80%</u>	<u>1.04</u>	<u>0.6</u>	<u>3.0</u>
1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
ID	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC 1X= 60.0 dB  
Sweep 0-10 2.0" Depth  
Note N/A dB difference between 3/8 and 5/8 Vee

**Search Unit Cable**

<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

**Instrument Settings**

<u>Panometrics / EPOCH 4</u> Manufacturer/Model:	<u>031524305</u> Serial Number:		
<u>9.4 us</u> Delay:	<u>0.233 in./sec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Filter:	<u>Auto</u> Rep Rate:
<u>4.0 in.</u> Range:	<u>Sq. / Med</u> Pulser:	<u>400 Ohms</u> Damping:	
<u>Off</u> Reject:	<u>3.03 MHz</u> Frequency:	<u>Dual</u> Mode:	

Exam Data for Weld: 2/1/RPV SHELL/N19B-2

NOZ-RPV

Configuration:

OD / Plate

94° F

Exam Surface:

Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>360°</u>	<u>T/P</u>	<u>74.0</u>	<u>NRI</u>	<u>60°</u>

**Calibration Verification**

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 10/15/2003

Comments: Cal/Exam Date is the date of initial calibration.  
Rectification - Full wave; TVG, CSG and DGS disabled.  
Calibration for near surface examination.  
Exams performed a minimum of 14 dB above reference.

JAR Jack Rejewitz    II    10/22/2003  
Initials: Examiner    Level: Cal/Exam Date:

[Signature]    10-26-03  
Utility Reviewed By:    Date:

N/A    N/A  
Initials: Examiner    Level:  
[Signature]    [Signature]    10/26/03  
GE Reviewed By:    Level:    Date:

[Signature]    10-30-03  
ANII Reviewed By:    Date:





**GE NUCLEAR ENERGY**

**Ultrasonic Calibration and Examination Record  
RPV Components**

Site/Unit: Dresden / 2  
Outage: D2R18

Data Report Number: 2R18-009  
Data Sheet Number: UT-084

Linearity Sheet: L-013  
Beam Spread: N/A

Procedure: GE-UT-300

Ver.: I

DRR: N/A

Calibration Block: VESSEL SHELL

CS N/A 7.0"  
Material Size Thickness  
Initial Cal: 1525 Exam Start: 1705  
Cal Check: N/A Exam End: 1725  
Cal Check: NA Ultragel II 02125  
Final Cal: 1820 Couplant: Batch  
229344 72° F 74° F  
Thermometer Initial Cal Temp. Final Cal Temp.

Search Unit Data

Sigma 22BC-03001 2(1.1x.02)/Rect.  
Manufacturer: Serial Number: Size / Shape:  
0.70" 60° 60°  
Incident Point: Nominal Angle: Measured Angle:  
3.0 MHz SDC3 Long.  
Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0  
Cable Type: Length: Connectors:

Instrument Settings

Panametrix / EPOCH 4 031534305  
Manufacturer/Model: Serial Number:  
7.00 us 0.224 in./ussec. 0.8 x 3.0 MHz AUTO  
Delay: Velocity: Filter: Rep Rate:  
20.0 in. Sq. / Med 400 Ohms  
Range: Pulsar: Damping:  
Off 3.03 MHz Dual  
Reject: Frequency: Mode:

DAC Construction

Hole T"	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	N/A	1X	N/A	N/A	N/A	N/A
1/2	N/A	1X	N/A	N/A	N/A	N/A
3/4	N/A	1X	N/A	N/A	N/A	N/A
ID	7.0	1X	80%	12.04	6.85	7.0
5/4	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 73.0 dB  
Sweep 0-10 10" Depth  
Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: 2/1/RPV SHELL/N19B-2

NOZ-RPV  
Configuration:  
OD / Plate 84° F  
Exam Surface: Component Temperature

Calibration Verification

Field Simulator Block S/N: N/A

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>360°</u>	<u>T/P</u>	<u>73.0</u>	<u>NRI</u>	<u>60°</u>

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 10/15/2003

Comments: Cal/Exam Date is the date of initial calibration.  
Rectification - Full wave; TVG, CSG and DGS disabled.  
Calibration for full volume examination.  
Exams performed to maintain 10-20% clad roll.  
Scanning limited due to insulation support.

JAR Jack Reiszewitz II 10/22/2003  
Initials: Examiner Level: Cal/Exam Date:  
NA NA  
Initials: Examiner Level:  
GE Level: Date:  
GE Reviewed By: Level: Date:

10-26-03  
Reviewed By: Date:  
10-22-03  
Reviewed By: Date:

**ATTACHMENT 2**

**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**



**Ultrasonic Calibration and Examination Record  
Inner Radius Examinations**

Site/Unit: Dresden / 2

Data Report Number: 2R18-009

Linearity Sheet: L-013

Outage: D2R18

Date Sheet Number: UT-085

Procedure: GE-UT-311

Rev: 10

DRR: N/A

**Calibration Data for Block: VESSEL SHELL**

<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>1503</u>	Exam Start: <u>1630</u>	
Cal Check: <u>N/A</u>	Exam End: <u>1645</u>	
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>02125</u>
Final Cal: <u>1832</u>	Couplant:	Batch
<u>229344</u> Thermometer	<u>12° F</u> Initial Cal Temp.	<u>74° F</u> Final Cal Temp.

**DAC Construction**

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
	<u>7.0</u>	<u>1X</u>	<u>80%</u>	<u>11.2</u>	<u>13.2</u>	<u>7.8</u>
<u>N/A</u>	<u>N/A</u>	<u>1X</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC @ 1X 44.5 dB

Sweep 0-10 17.5" Metal Path

Acceptable Linearity performed : 10/16/2003

**Search Unit Data**

<u>KBA</u> Manufacturer:	<u>M21322</u> Serial No.:	<u>0.5"x1.0"/Recl</u> Size/Shape:
<u>0.7 in.</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>58°</u> Measured Angle:
<u>1.0 MHz</u> Frequency:	<u>113-291-600</u> Model:	<u>Shear</u> Mode:

**Search Unit Cable**

<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

**Instrument Settings**

<u>Panametrics / EPOCH 4</u> Manufacturer/Model:	<u>031534305</u> Serial No.:		
<u>16.6 us</u> Delay:	<u>0.1255 u/sec</u> Velocity:	<u>0.8 - 3.0 MHz</u> Filter:	<u>Auto</u> Rep Rate:
<u>17.5 in.</u> Range:	<u>Sq. / Med</u> Pulser:	<u>400 ohms</u> Damping:	
<u>Off</u> Reject:	<u>1.0 MHz</u> Frequency:	<u>P/E</u> Mode:	

**Exam Data for Component: 2/1/RPV SHELL/N19B-2**

**NOZ-RPV**

Configuration:

<u>OD / Plate</u> Exam Surface:	<u>94° F</u> Component Temp.
------------------------------------	---------------------------------

Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications
<u>360°</u>	<u>60°</u>	<u>+55°</u>	<u>N/A</u>	<u>84.6</u>	<u>NRI</u>
<u>360°</u>	<u>60°</u>	<u>-55°</u>	<u>N/A</u>	<u>84.6</u>	<u>NRI</u>

**Calibration Verification**

Field Simulator Block S/N: N/A

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

**Rectification - Full wave; TVG, CSG, and DGS disabled.**  
**Calibration for nozzle to vessel weld (N/A).**  
**Exams performed to maintain a 20-30% FSH clad roll.**  
**Scanned CW and CCW.**

<u>JAR</u> Initials: Examiner:	<u>II</u> Level:	<u>10/22/03</u> Cal/Exam Date:	<u>[Signature]</u> Utility Reviewed By:	<u>10-26-03</u> Date:
<u>CIP</u> GE Reviewed By:	<u>III</u> Level:	<u>10/26/03</u> Date:	<u>[Signature]</u> ANIR Reviewed By:	<u>10-26-03</u> Date:

**ATTACHMENT 2**  
**Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets**

**Dresden Unit-2, D2R18**  
**N19B-2 - Core Spray**  
**Fall 2003**

Weld Length = 360. Exam Volume = 75.8		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° T-Scan	A	75.8	39.5	52.1%	304.0	22.0%
60° P-Scan, 85%T	A	67.3	10.1	13.3%	304.0	5.6%
IRS-Scan, 15%T	A	8.5	8.5	11.2%	304.0	4.7%
60° T-Scan	B	75.8	36.7	48.4%	56.0	3.8%
60° P-Scan, 85%T	B	67.3	10.1	13.3%	56.0	1.0%
IRS-Scan, 15%T	B	8.5	8.5	11.2%	56.0	0.9%
60° T-Scan						
60° P-Scan, 85%T						
IRS-Scan, 15%T						
60° T-Scan						
60° P-Scan, 85%T						
IRS-Scan, 15%T						
60° T-Scan						
60° P-Scan, 85%T						
IRS-Scan, 15%T						

% Total Composite Coverage = 38%

Comments: A - Examined 304° length. Scanning limited due to nozzle configuration.  
 B - Examined 56° length. Scanning limited due to nozzle configuration and insulation support below nozzle.  
 Weld length in degrees. IRS examination coverage determined by modeling.

Note - Rounding methods may make calculated values appear in error.

Dresden Unit-2, D2R18


Page 5 of 9

ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets

# Dresden Unit-2 Core Spray - N19B

60°T Exam Volume = 75.8 Sq. In.  
60°P Exam Volume = 67.3 Sq. In.  
Inner 15°T Exam Volume (IRS & 60°T) = 8.5 Sq. In.

60° T-Scan achieved = 39.5 Sq. In.  
60° P-Scan achieved = 10.1 Sq. In.  
Inner 15°T IRS Scan achieved = 8.5 Sq. In.




ATTACHMENT 2  
Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets

### Dresden Unit-2 Core Spray - N19B

60°T Exam Volume = 75.8 Sq. In.  
60°P Exam Volume = 67.3 Sq. In.  
Inner 15°T Exam Volume (IRS & 60°T) = 8.5 Sq. In.

60° T-Scan achieved = 39.5 Sq. In.  
60° P-Scan achieved = 10.1 Sq. In.  
Inner 15° T IRS Scan achieved = 8.5 Sq. In.



ATTACHMENT 2

Dresden Nuclear Power Station Fourth ISI Interval Limited Coverage NDE Summary Sheets

Dresden Unit-2, 2003

# Dresden Unit-2 Core Spray - N19B

60°T Exam Volume = 75.8 Sq. In.  
60°P Exam Volume = 67.3 Sq. In.  
Inner 15°T Exam Volume (IRS & 60°T) = 8.5 Sq. In.

60° T-Scan achieved = 36.7 Sq. In.  
60° P-Scan achieved = 10.1 Sq. In.  
Inner 15°T IRS Scan achieved = 8.5 Sq. In.

Area limited due to insulation support below.

