

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components																																																
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-300</u>		Data Report Number: <u>2QR19-120</u> Data Sheet Number: <u>D-071</u> Rev.: <u>10</u> DRR: <u>N/A</u>																																																
Calibration Block: <u>CAL-11W2-045</u>		Search Unit Data																																																
<table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>4.0"</u></td> </tr> <tr> <td style="text-align: center;">Material</td> <td style="text-align: center;">Size</td> <td style="text-align: center;">Thickness</td> </tr> <tr> <td>Initial Cal: <u>1255</u></td> <td></td> <td>Exam Start: <u>1345</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>1500</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultragel II</u></td> <td style="text-align: center;"><u>06225</u></td> </tr> <tr> <td>Final Cal: <u>1623</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255562</u></td> <td style="text-align: center;"><u>89° F</u></td> <td style="text-align: center;"><u>88° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table>		<u>CS</u>	<u>N/A</u>	<u>4.0"</u>	Material	Size	Thickness	Initial Cal: <u>1255</u>		Exam Start: <u>1345</u>	Cal Check: <u>N/A</u>		Exam End: <u>1500</u>	Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>06225</u>	Final Cal: <u>1623</u>	Couplant:	Batch	<u>255562</u>	<u>89° F</u>	<u>88° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	<table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u></td> <td style="text-align: center;"><u>22BC-03009</u></td> <td style="text-align: center;"><u>20.1"x.62"/ Rect</u></td> </tr> <tr> <td style="text-align: center;">Manufacturer:</td> <td style="text-align: center;">Serial Number:</td> <td style="text-align: center;">Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7"</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td style="text-align: center;">Incident Point:</td> <td style="text-align: center;">Nominal Angle:</td> <td style="text-align: center;">Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u></td> <td style="text-align: center;"><u>SDC-3</u></td> <td style="text-align: center;"><u>RL</u></td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Model:</td> <td style="text-align: center;">Mode:</td> </tr> </table>	<u>Sigma</u>	<u>22BC-03009</u>	<u>20.1"x.62"/ Rect</u>	Manufacturer:	Serial Number:	Size / Shape:	<u>0.7"</u>	<u>60°</u>	<u>60°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>	Frequency:	Model:	Mode:						
<u>CS</u>	<u>N/A</u>	<u>4.0"</u>																																																
Material	Size	Thickness																																																
Initial Cal: <u>1255</u>		Exam Start: <u>1345</u>																																																
Cal Check: <u>N/A</u>		Exam End: <u>1500</u>																																																
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>06225</u>																																																
Final Cal: <u>1623</u>	Couplant:	Batch																																																
<u>255562</u>	<u>89° F</u>	<u>88° F</u>																																																
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																
<u>Sigma</u>	<u>22BC-03009</u>	<u>20.1"x.62"/ Rect</u>																																																
Manufacturer:	Serial Number:	Size / Shape:																																																
<u>0.7"</u>	<u>60°</u>	<u>60°</u>																																																
Incident Point:	Nominal Angle:	Measured Angle:																																																
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>																																																
Frequency:	Model:	Mode:																																																
DAC Construction		Search Unit Cable																																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>SDH</td> <td><u>0.6"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>1.2"</u></td> <td><u>0.7"</u></td> <td><u>3.7</u></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.2"</u>	<u>0.7"</u>	<u>3.7</u>			1X							1X							1X							1X					<table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>9'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td style="text-align: center;">Cable Type:</td> <td style="text-align: center;">Length:</td> <td style="text-align: center;">Connectors:</td> </tr> </table>	<u>RG-174</u>	<u>9'</u>	<u>0</u>	Cable Type:	Length:	Connectors:
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																												
SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.2"</u>	<u>0.7"</u>	<u>3.7</u>																																												
		1X																																																
		1X																																																
		1X																																																
		1X																																																
<u>RG-174</u>	<u>9'</u>	<u>0</u>																																																
Cable Type:	Length:	Connectors:																																																
DAC 1X= <u>59.4dB</u> Sweep 0-10 = <u>2.0'</u> <u>Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee		Instrument Settings																																																
Exam Data for Weld: <u>N9 NOZ</u> <u>VESSEL-NOZZLE (CRD RETURN)</u> Configuration:		<table style="width:100%;"> <tr> <td style="text-align: center;"><u>Panometrics / Epoch 4</u></td> <td style="text-align: center;"><u>031572811</u></td> </tr> <tr> <td style="text-align: center;">Manufacturer/Model:</td> <td style="text-align: center;">Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>6.120 μs</u></td> <td style="text-align: center;"><u>0.2127 in./μsec.</u></td> </tr> <tr> <td style="text-align: center;">Delay/Zero:</td> <td style="text-align: center;">Velocity:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> </tr> <tr> <td style="text-align: center;">Rep Rate:</td> <td style="text-align: center;">Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> </tr> <tr> <td style="text-align: center;">Damping:</td> <td style="text-align: center;">Reject:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td style="text-align: center;">DAC:</td> <td style="text-align: center;">TVG:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td style="text-align: center;">CSC:</td> <td style="text-align: center;">DGS:</td> </tr> </table>	<u>Panometrics / Epoch 4</u>	<u>031572811</u>	Manufacturer/Model:	Serial Number:	<u>6.120 μs</u>	<u>0.2127 in./μsec.</u>	Delay/Zero:	Velocity:	<u>Auto</u>	<u>Fullwave</u>	Rep Rate:	Rectification:	<u>400 Ohms</u>	<u>0%</u>	Damping:	Reject:	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	<u>Off:</u>	<u>Off:</u>	CSC:	DGS:																								
<u>Panometrics / Epoch 4</u>	<u>031572811</u>																																																	
Manufacturer/Model:	Serial Number:																																																	
<u>6.120 μs</u>	<u>0.2127 in./μsec.</u>																																																	
Delay/Zero:	Velocity:																																																	
<u>Auto</u>	<u>Fullwave</u>																																																	
Rep Rate:	Rectification:																																																	
<u>400 Ohms</u>	<u>0%</u>																																																	
Damping:	Reject:																																																	
<u>Off:</u>	<u>Off:</u>																																																	
DAC:	TVG:																																																	
<u>Off:</u>	<u>Off:</u>																																																	
CSC:	DGS:																																																	
<table style="width:100%;"> <tr> <td style="text-align: center;"><u>OD Plate</u></td> <td style="text-align: center;"><u>102° F</u></td> </tr> <tr> <td style="text-align: center;">Exam Surface:</td> <td style="text-align: center;">Component Temperature</td> </tr> </table>		<u>OD Plate</u>	<u>102° F</u>	Exam Surface:	Component Temperature	Calibration Verification																																												
<u>OD Plate</u>	<u>102° F</u>																																																	
Exam Surface:	Component Temperature																																																	
<table style="width:100%;"> <tr> <td style="text-align: center;">Weld Examination Area:</td> <td style="text-align: center;">Exam Access</td> <td style="text-align: center;">Scan dB</td> <td style="text-align: center;">Recordable Indications</td> <td style="text-align: center;">Exam Angle</td> </tr> <tr> <td style="text-align: center;"><u>Plate</u></td> <td style="text-align: center;"><u>I</u></td> <td style="text-align: center;"><u>73.4</u></td> <td style="text-align: center;"><u>NRI</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td style="text-align: center;"><u>Plate cw/ccw</u></td> <td style="text-align: center;"><u>P</u></td> <td style="text-align: center;"><u>73.4</u></td> <td style="text-align: center;"><u>NRI</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td style="text-align: center;"><u>N/A</u></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;"><u>N/A</u></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>Plate</u>	<u>I</u>	<u>73.4</u>	<u>NRI</u>	<u>60°</u>	<u>Plate cw/ccw</u>	<u>P</u>	<u>73.4</u>	<u>NRI</u>	<u>60°</u>	<u>N/A</u>					<u>N/A</u>					<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th><u>N/A</u></th> <th><u>N/A</u></th> <th><u>N/A</u></th> </tr> </thead> <tbody> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </tbody> </table>	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>							
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																														
<u>Plate</u>	<u>I</u>	<u>73.4</u>	<u>NRI</u>	<u>60°</u>																																														
<u>Plate cw/ccw</u>	<u>P</u>	<u>73.4</u>	<u>NRI</u>	<u>60°</u>																																														
<u>N/A</u>																																																		
<u>N/A</u>																																																		
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																															
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																															
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																															
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																															
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for near surface examination. Exams performed a minimum of 14 dB above reference. 45° S not used.		Acceptable Linearity performed : <u>2/21/2008</u>																																																
Signature: <u>Scott R Erickson</u> FOR <u>Phillip Hopkins</u> Initials: <u>ER</u> Level: <u>II</u> Cal/Exam Date: <u>3/7/2008</u>		Signature: <u>Jim Kline</u> Date: <u>3/17/08</u>																																																
Signature: <u>N/A</u> Level: <u>N/A</u> Initials: <u>ER</u> Level: <u>III</u> Date: <u>3/16/08</u>		Signature: <u>Jeff Sample</u> Date: <u>3/21/08</u>																																																
Signature: <u>John C. Smith</u> Date: <u>3/16/08</u>		Signature: <u>ANIK</u> Date: <u>3/21/08</u>																																																

REPORT NO. 202R19-120

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON				DATE 02/25/08		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
MAIN STEAM								
N/V Weld (M)	PLATE	0 - 4.0"	60.0°	-	± 25° - 70°	FLAT	14.0"	1 MHz
N/V Weld/Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 45°	FLAT	25.3"	1 MHz
Zone 2a (M)	ODBR	60° - 90°	66.4°	-	24.1°	4.0"	16.3"	1 MHz
CORE SPRAY								
N/V Weld/Zone 1 (M)	PLATE	0 - 7.0"	60.0°	-	± 55°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 25°	FLAT	19.6"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	10.6"	1 MHz
CRD. 29								
N/V Weld (M)	PLATE	0 - 6.5"	45°	-	± 20.0° - 60.0°	FLAT	9.3"	1 MHz
Zone 1 (M)	PLATE	0 - 7.5"	60.0°	-	± 15°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 11.0°	70.0°	-	± 15°	FLAT	17.2"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	3.6"	1 MHz
JET PUMP INSTRUMENT								
N/V Weld (M)	PLATE	5.0 - 10.0"	55.0°	-	± 20° - 60°	FLAT	11.8"	1 MHz
Zone 1 (M)	PLATE	6.0 - 11.0"	60.0°	-	± 20°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 14.0"	70.0°	-	± 25°	FLAT	17.2"	1 MHz
Zone 2A (M)	PLATE	0 - 6.0"	80.0°	-	± 20°	FLAT	9.0"	1 MHz
TOP HEAD VENT (N7) - 0° Offset								
N/V Weld (M)	PLATE	0 - 9.0"	60.0°	-	± 25.0° - 55.0°	FLAT	8.4"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	70.0°	-	± 20°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	-	± 17°	FLAT	13.0"	1.0 MHz
ZONE 2A (M)	ODBR	40° - 90°	50.0°	-	26°	1.9"	2.5"	1.0 MHz
TOP HEAD SPRAY (N6) - 48° Offset								
N/V Weld (M)	PLATE	0 - 8.0"	45.0°	-	± 15.0° - 85.0°	FLAT	5.7"	1.0 MHz
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	-	± 15.0° - 90.0°	FLAT	8.4"	1.0 MHz
ZONE 1 (M)	PLATE	0 - 7.5"	70.0°	-	± 45°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	-	± 21°	FLAT	17.0"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	13°	1.9"	6.8"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	30°	1.9"	6.4"	1.0 MHz
ZONE 2A (M)	ODBR	45° - 70°	50.0°	-	26°	1.9"	9.4"	1.0 MHz
SBLC N10								
N/V Weld (M)	PLATE	4.5 - 9.0"	45.0°	-	± 17° - 51°	FLAT	9.1"	1 MHz
NOTES: (M) MANUAL XOX (XOX) WEDGE / (FIXTURE) ROTATION ANGLE Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 577-3770								

W-039 ✓

W-031, W-032 ✓

W-031, W-032 ✓

W-131 /

W-180 ✓
W-132 ✓
W-131 ✓

Chris Minor
Digitally signed by Chris Minor
DN: cn=Chris Minor, o=CC, email=
Chris.Minor@quadcities.com, c=US

SME Review / Date

P. L. MAY
03/04/08
Site Review/ Date


QUAD CITIES UNIT 2, 02R19

Quad Cities Unit 2, 2019

Quad Cities Unit-2 N9 - CRD

60° NS Exam Volume = 13.5 Sq. In.
60° FV S6 Exam Volume = 31.4 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 6.6 Sq. In.

60° NS T-Scan achieved = 5.7 Sq. In.
60° FV S6 T-Scan achieved = 31.0 Sq. In.
60° FV S4 T-Scan achieved = 6.6 Sq. In.




Quad Cities Unit-2, 02R19

Quad Cities Unit-2 N9 - CRD

60° NS Exam Volume = 13.5 Sq. In.
60° FV S6 Exam Volume = 31.4 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 6.6 Sq. In.

60° NS P-Scan achieved = 5.0 Sq. In.
60° FV S6 P-Scan achieved = 28.5 Sq. In.
Inner 15%T IRS-Scan achieved = 6.6 Sq. In. (By modeling.)



REPORT NO. 20R19-170

Quad Cities Unit 2, 020219

Quad Cities Unit-2 N9 - CRD

60° NS Exam Volume = 13.5 Sq. In.


60° FV S6 Exam Volume = 31.4 Sq. In.

60° FV S4 / 15°T IRS Exam Volume = 6.6 Sq. In.

60° NS T-Scan achieved = 5.0 Sq. In.

60° FV S6 T-Scan achieved = 9.7 Sq. In.

60° FV S4 T-Scan achieved = 0.0 Sq. In.




REPORT NO. 20219-120


QUAD CITIES UNIT 2, Q2R19

Quad Cities Unit-2 N9 - CRD

60° NS Exam Volume = 13.5 Sq. In.
60° FV S6 Exam Volume = 31.4 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 6.6 Sq. In.

60° NS P-Scan achieved = 4.8 Sq. In.
60° FV S6 P-Scan achieved = 18.6 Sq. In.
Inner 15%T IRS-Scan achieved = 2.3 Sq. In.





Quad cities Unit 2, Q2R19

Page 10 of 11

REPORT NO. 2019-120

Quad Cities Unit 2 / Q2R19



GE Hitachi Nuclear Energy

Reactor Pressure Vessel Coverage Calculation Sheet

Quad Cities Unit 2 / Q2R19
N9 VES-NOZ (CRD)
Spring / 2008

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
Weld Length = 360. Exam Volume = 51.5						
60° T-Scan (S4 UC)	A	6.6	6.6	12.8%	330	5.9%
60° T-Scan (S6 FV)	A	31.4	31	60.2%	330	27.6%
60° T-Scan (S6 NS)	A	13.5	5.7	11.1%	330	5.1%
IRS P-Scan (S4 UC)	A	6.6	6.6	12.8%	330	5.9%
60° P-Scan (S6 FV)	A	31.4	28.5	55.3%	330	25.4%
60° P-Scan (S6 NS)	A	13.5	5	9.7%	330	4.4%
60° T-Scan (S4 UC)	B	6.6	0	0.0%	30	0.0%
60° T-Scan (S6 FV)	B	31.4	9.7	18.8%	30	0.8%
60° T-Scan (S6 NS)	B	13.5	5	9.7%	30	0.4%
IRS P-Scan (S4 UC)	B	6.6	2.3	4.5%	30	0.2%
60° P-Scan (S6 FV)	B	31.4	18.6	36.1%	30	1.5%
60° P-Scan (S6 NS)	B	13.5	4.9	9.5%	30	0.4%
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						

% Total Composite Coverage = 77.5%

Rev. 0 9/23/05

Comments: A - Manual exam was restricted due to the nozzle configuration and the proximity of an insulation support bracket.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in inches or degrees.

REPORT NO. 20019-120



**GE NUCLEAR ENERGY
UT EXAMINATION SUMMARY SHEET**

Report No: Q2R17-85
WO No: 579936, 579937

PROJECT: Quad Cities Unit-2, Q2R17
WELD ID: N2A NOZ and N2A IRS
SYSTEM: Reactor Pressure Vessel

CALIBRATION ID: NOZ.IN, NOZ.IN.2, IRS.IN
GERIS DATA: Scan file types: P1, P2, P3, TL and Z1
MANUAL DATA: UT-095, UT-096
EXAMINERS: S. Gauthier Lv II, K. Montgomery Lv II, B. Dummer Lv III

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

Examination volumes were in accordance with Section XI, Figure IWB-2500-7 (a).

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-705 V4, using 0° L, 60° RL, and 45° S, search units. Nozzle Inner Radius and Inner 15%T examination volume parallel scans were performed using model validated shear wave search units.

Manual examinations from the ODBR surface (Zone 2A) were performed in accordance with procedure GE-UT-311 V10.

Scanning was performed from the vessel OD shell and OD Blend Radius surfaces examining the nozzle to shell weld and nozzle inner radius section regions.

Six (6) acceptable indications were recorded.

Previous data (R-167, R-170, R-173, R-176 from 1997) was reviewed prior to completing this summary. No significant changes were noted.

Scanning was limited due to the nozzle configuration.

Coverage = 28% Nozzle to Shell weld.

Coverage = 100% Nozzle Inner Radius Section.

	3/19/04		3-10-04		3/19/04		3/19/04
PREPARED BY	DATE	REVIEWED BY	DATE	UTILITY REVIEW	DATE	AUDIT REVIEW	DATE
UT Level: III		UT Level: III					

GERIS 2000 Examination Data Sheet



Project : Quad Cities Unit-2, 2004
Component : N2A-NOZ

Report No.: Q2R17-85
Exam Data Sheet: N2A-01

File	Disk	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
n2a.p1.1	06B	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	1
n2a.p2.1	06A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n2a.p2.2	06A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n2a.p2.3	06A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	2
n2a.p2.4	06A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	2
n2a.p3.1	06A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n2a.tl.1	06A	TL	NRI	001	NRI	~	~	~	~	~	~	~	~	~	~	~	1
n2a.tl.2	06A	TL	NRI	003	002	~	~	~	~	~	~	~	~	~	~	~	1

Comments: 1 - Plate segregates observed plate side. 2 - Store process error, data acceptable.

Scanning performed with high profile triple pack, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CPM
Level: IV
Date: 3/9/04

Reviewed By: RMD
Level: III
Date: 3-10-04

GERIS 2000 Examination Data Sheet



Project : Quad Cities Unit-2, 2004
Component : N2A-IRS

Report No.: Q2R17-85
Exam Data Sheet: N2A-02

File	Disk	Scan		Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type																
n2a.70z1.1	06B	Z1		~	~	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~
n2a.68z1.1	06B	Z1		~	~	~	~	NRI	NRI	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with high profile triple pack, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CPM
Level: III
Date: 3/9/04

Reviewed By: B/M Dunn
Level: III
Date: 3-10-04



Report No.: Q2R17-085
Exam Data Sheet: N2A-01
Ind. Data Sheet: N2A-001

Page 756 of 945












Page 757 of 945












Report No.: Q2R17-085
Exam Data Sheet: N2A-01
Ind. Data Sheet: N2A-003






Page 758 of 945


















Quad Cities Unit-2, Q2R17

Q2R17-85

Page 13 of 24

PROCEDURE NO. : <u>GE-UT-705 V4</u>				REVISION : <u>N/A</u>				DRR : <u>N/A</u>				
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD
n2a.p2.1	N2A	06A	03/08/04	16:37	17:27	270°	82°	-189°	98°	N/A	N/A	NOZ.IN
n2a.p2.2	N2A	06A	03/08/04	17:41	17:49	83°	51°	-32°	98°	N/A	N/A	NOZ.IN
n2a.p2.3	N2A	06A	03/08/04	19:39	20:00	53°	270°	-143°	98°	N/A	N/A	NOZ.IN
n2a.p2.4	N2A	06A	03/08/04	20:08	20:09	272°	269°	-3°	98°	N/A	N/A	NOZ.IN
n2a.tl.1	N2A	06A	03/08/04	23:13	23:26	270°	317°	47°	98°	N/A	N/A	NOZ.IN.2
n2a.tl.2	N2A	06A	03/08/04	23:37	00:50	318°	271°	313°	98°	N/A	N/A	NOZ.IN.2
n2a.p3.1	N2A	06A	03/09/04	01:16	02:29	270°	269°	-361°	98°	N/A	N/A	NOZ.IN.2
n2a.p1.1	N2A	06B	03/09/04	02:55	03:43	270°	271°	361°	98°	N/A	N/A	NOZ.IN.2
COMMENTS : * Rotation angles for TL and P exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached).												
The GERIS 0° reference is located 90° CW of nozzle TDC.						Search Unit Data:				Freq.	Rot.	
						No.	Model / Mode	S/N	Size	(MHz.)	Angle	
						1	RTD, 0° L2.25 / L	01-231	1.0 Dia	2.25	N/A	
						2	RTD, 45° T1-St / S	01-233	32x22mm	1.00	*	
						3	RTD, 60° L2-St / L	97-152	30x25mm	2.00	*	
Automated scanning was restricted due to the nozzle weld configuration.						4	RTD, 45° T1-St / S	04-8	32x22mm	1.00	*	
OPERATORS: SHANE GAUTHIER LvII				SOFTWARE REVISION: 5.26		6	RTD, 70° TRL2-St / L	96-228	2(12x25)mm	2.00	*	
KENT MONTGOMERY LvII				THERMOMETER S/N : 235018		13	RTD, 60° T1-St / S	01-234	32x18mm	1.00	*	
						14	RTD, 60° T1-St / S	01-235	32x18mm	1.00	*	
				COUPLANT : Demineralized Water								

CUSTOMER: Exelon
SITE: Quad Cities Unit-2
OUTAGE: Q2R17

N/A

Q2R17-85

No.	Model / Mode	S/N	Size	(MHz.)	Angle
3	RTD, 68° T1-St / S	98-287	32x16mm	1.00	*
4	RTD, 68° T1-St / S	98-288	32x16mm	1.00	*
5	RTD, 70° T1-St / S	94-503	32x16mm	1.00	*
6	RTD, 70° T1-St / S	01-237	32x16mm	1.00	*

COUPLANT : Demineralized Water



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Data Report Number: Q2R17-85

Linearity Sheet: L-008

Outage: Q2R17

Data Sheet Number: UT-095

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSCI</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1145</u>		Exam Start: <u>12:10</u>
Cal Check: <u>N/A</u>		Exam End: <u>13:05</u>
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>Q1225</u>
Final Cal: <u>1320</u>	Couplant:	Batch
<u>255018</u> <u>235018</u>	<u>88° F</u>	<u>88° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>19.4</u>	<u>20.65</u>	<u>7.9</u>
		<u>1X</u>				

DAC @ 1X 51.3

Sweep 0-10 26 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>00L323</u>	<u>0.5"x1.0" / Rect.</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.85 in.</u>	<u>70°</u>	<u>68°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>1.0 MHz</u>	<u>113-291-800</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RQ-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Penametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>16.43 us</u>	<u>0.1283 in / uscc</u>
Zero:	Velocity:
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>26.0 in.</u>	<u>Sq. / Med</u>
Range:	Pulse/Energy:
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>1.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off</u>	<u>Off</u>
DAC:	TVG:
<u>Off</u>	<u>Off</u>
CSC:	DGS:

Exam Data for Component: N2A IRS

VESSEL-NOZZLE (RECIRCULATION)

Configuration:

<u>ODBR</u>	<u>98° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>67.5</u>
<u>18.1</u>	<u>W-025A</u>
<u>64</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 2A Clockwise

Exams performed to maintain a 20% - 30% FSH ID roll

BD Brad Dummer

Initials: Examiner:

III

Level

3/9/04

Cal/Exam Date:

David [Signature]

Utility Reviewed By:

3/10/04

Date:

CLM

GE Reviewed By:

IV

Level:

3/19/04

Date:

[Signature]

Utility Reviewed By:

3/19/04

Date:

Page 15 of 24

Report No.: Q2R17-85

**Recirculation Inlet N2A-NOZ
Quad Cities Unit-2, 2004**

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Weld Length = 360. Exam Volume = 80.5						
70° T-Scan	A	29.3	2	2.5%	360	1.2%
45° T-Scan	A	42.1	17	21.1%	360	10.6%
60° T-Scan	A	9.1	5.9	7.3%	360	3.7%
70° P-Scan	A	29.3	0	0.0%	360	0.0%
45° P-Scan	A	42.1	11.7	14.5%	360	7.3%
60° P-Scan	A	9.1	9.1	11.3%	360	5.7%
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						

% Total Composite Coverage = 28%


Comments: A - Examined accessible length. Scanning limited due to scanner access.

Note - Rounding methods may make calculated values appear in error.

Quad Cities Unit-2 Recirculation Inlet

70° Exam Volume = 29.3 Sq. In.
45° Exam Volume = 42.1 Sq. In.
Inner 15%T Exam Volume (IRS & 60°T) = 9.1 Sq. In.

70° T-Scan achieved = 2.0 Sq. In.
45° T-Scan achieved = 17.0 Sq. In.
60° T-Scan achieved = 5.9 Sq. In.



Quad Cities Unit-2 Recirculation Inlet

70° Exam Volume = 29.3 Sq. In.


45° Exam Volume = 42.1 Sq. In.

Inner 15%T Exam Volume (IRS & 60°T) = 9.1 Sq. In.

70° P-Scan achieved = 0.0 Sq. In.

45° P-Scan achieved = 11.7 Sq. In.

IRS P-Scan achieved = 9.1 Sq. In. (By model)



Guideline for Deciding when to Perform Manual UT Examination of Areas Not Covered by Automated Examinations

Component/Configuration: N2A No 2

A. DETERMINE

1. Percent coverage obtained with automated UT: 28 %
2. Approximate radiation dose received to complete automated UT: 1800 mR

B. ESTIMATE

1. Percent coverage increases if manual UT was performed: + 9 % *
2. Radiation dose expected if manual UT was performed: 1500 mR

Decision to Proceed: YES X NO Based On: Dose

Prepared By: R. L. May Date: 03/09/04

* ALL SHELL BASE METAL COVERAGE,
NOT WELD OR HAZ ON I.D.

Q2 R17-85
20 OF 24

Report No.: Q2R17-85

**Recirculation Inlet N2A-IRS
Quad Cities Unit-2, 2004**

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area %	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Weld Length = 360. Exam Volume = 100%						
Z1 CW	A	100%	100%	100.0%	360	50.0%
Z1 CCW	A	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2A CW	B	100%	100%	100.0%	360	50.0%
Z2A CCW	B	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
% Total Composite Coverage =						
% Total Composite Coverage =						

Comments: A - Examined accessible length with the GERIS 2000. Exam volume determined by modeling, 100% assigned volume.
B - Examined accessible length using manual techniques. Exam volume determined by modeling, 100% assigned volume.

Note - Rounding methods may make calculated values appear in error.

Quad Cities Unit-2, Q2R17

Page 21 of 24



GE Nuclear Energy

GERIS 2000 OD Nozzle Examination Scan Plan

Quad Cities Unit-2, 2004
Nozzle Scanning Limits
Nozzle(s) N2

12.85 Weld CL Radius
17.67 ASME OD Radius
15.25 Outside Radius of ODBR
12.50 Outside Radius of NOZOD

125.50 Vessel ID Radius
6.38 Vessel Nom. Thickness
131.88 Vessel OD Radius
1.0 Overscan Distance

Package Configuration: Triple Pack and ODBR Package.

Beam CPU Fixture					SU Parameters				Scan	Scanner		A-Gate			C-Gate	
Channel	Angle	Angle	Angle	Type	Delay	Velocity	X-Off	Y-Off	Area	Min	Max	Start	Stop	Max MP	Start	Stop
N2 T-Scan. Supplement 4 and 6 radial scans.										Step →	0.25	Index →	0.4°			
1	0	0.0	0.0	WM	4	0.233	0.0	0.0	N/A	Note 1	18.75	0	75	8.3	18	54
2	45	-9.0	9.0	T	15	0.128	3.0	0.0	N/A	Note 1	12.75	0	230	13.8	37	191
3	60	7.2	352.8	T	15	0.233	-3.0	0.0	N/A	Note 1	18.75	0	180	19.2	32	152
N2 P1. 45° S for outer 85%T volume.										Step →	0.25	Index →	0.6°			
2	45	51.5	308.5	P	15	0.128	3.0	0.0	N/A	Note 1	10.75	0	230	13.8	37	191
4	45	-51.5	51.5	P	15	0.128	-3.0	0.0	N/A	Note 1	10.75	0	230	13.8	37	191
N2 P2. N/V Inner 15%T P-scan examination from PLATE with 70T-scan.										Step →	0.15	Index →	0.5°			
13	60	27.3	332.7	N/V	15	0.128	-3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
6	70	0.0	0.0	T	10	0.233	0.0	0.0	N/A	Note 1	8.70	0	50	4.7	10	48
14	60	-27.3	27.3	N/V	15	0.128	3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
N2 P3. N/V Inner 15%T P-scan examination from PLATE.										Step →	0.15	Index →	0.5°			
13	60	35.5	324.5	N/V	15	0.128	-3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
14	60	-35.5	35.5	N/V	15	0.128	3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
N2 Z1. Z1 Inner Radius Section examination from PLATE.										Step →	0.15	Index →	0.5°			
3	68	16.0	344.0	Z1	15	0.128	-3.0	0.0	8.0	Note 1	11.40	0	450	21.2	180	365
4	68	-16.0	16.0	Z1	15	0.128	3.0	0.0	8.0	Note 1	11.40	0	450	21.2	180	365

QC2-2004-85
22 of 24

Channel	Beam	CPU	Fixture	Type	SU Parameters				Scan	Scanner		A-Gate			C-Gate		
	Angle	Angle	Angle		Delay	Velocity	X-Off	Y-Off	Area	Min	Max	Start	Stop	Max MP	Start	Stop	
N2 Z1. Z1 Inner Radius Section examination from PLATE.																	
										Step →	0.15	Index →	0.5°				
5	70	8.5	351.5	Z1	15	0.128	-3.0	0.0	9.0	Note 1	12.45	0	485	22.9	190	390	
6	70	-8.5	8.5	Z1	15	0.128	3.0	0.0	9.0	Note 1	12.45	0	485	22.9	190	390	
N2 Z2A. Z2A Inner Radius Section examination from ODBR																	
										Step →	0.07	Index →	1.8°				
7	67.5	8.2	351.8	Z2A	15	0.128	-2.5	0.0	N/A	55°	90°	0	260	12.0	105	220	
8	67.5	-8.2	8.2	Z2A	15	0.128	2.5	0.0	N/A	55°	90°	0	260	12.0	105	220	
Notes: Vessel ID radius from B&W drawing Shell Course Subassembly 151825E-1.																	
Vessel nominal thickness from B&W drawing Shell Forming Details 104186D-1 (ordered thickness).																	
Note 1 - Scan into nozzle until onset of liftoff or limited by physical limitations.																	
Site Revision 0 2/22/04																	

Site Revision 0 2/22/04

QC2R17-85
23 of 24

Nir_PDI Qc2.XLS

MANUAL/GERIS 2000 DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Quad Cities 2					
PREPARED BY		S.C. MORTENSON			DATE		
					01/17/04		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld	PLATE	0 - 8.0"	66.0°	57.8° (52.4°) *	FLAT	18.5"	1 MHz
N/V Weld	PLATE	0 - 9.0"	70.0°	42.1° (37.0°) *	FLAT	25.3"	1 MHz
Zone 1/NV (M)	ODBR	20° - 45°	35.0°	90.0°	5.5"	20.7"	1 MHz
Zone 2A	ODBR	45° - 90°	60.0°	35.0° (30.6°) **	5.5"	20.4"	1 MHz
RECIRC INLET							
N/V Weld	PLATE	0 - 8.0"	60.0°	38.0° (27.3°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.5"	60.0°	45.0° (35.5°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	PLATE	0 - 8.0"	68.0°	25.7° (16.0°) *	FLAT	21.2"	1 MHz
Zone 1	PLATE	0 - 9.0"	70.0°	15.6° (8.5°) *	FLAT	22.9"	1 MHz
Zone 2A	ODBR	55° - 90°	67.5°	18.1° (8.2°) **	3.3"	12.0"	1 MHz
FEEDWATER							
N/V Weld	PLATE	0 - 8.0"	60.0°	48.2° (39.2°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	60.0°	38.9° (28.3°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	40.3° (31.8°) **	3.5"	19.3"	2.25 MHz
Zone 2A	ODBR	50° - 90°	67.5°	21.7° (13.2°) **	3.5"	13.4"	2.25 MHz
Zone 2B	NOZOD	ALL	28.0°	68.0°	FLAT	7.5"	2 MHz
Zone 3	NOZOD	ALL	28.0°	90°	FLAT	6.7"	2 MHz

W-021, W-022
W-023, W-024

W-025, W-026

W-027, W-028
W-029, W-030

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0" PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45" PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5" OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5" PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0263

Q2R17-85
24 of 24
1/28/2004

 GE NUCLEAR ENERGY		EXAMINATION SUMMARY SHEET				Report No.: Q2R18-102	
Site: Quad Cities		Component ID: N2B NOZ					
Outage: Q2R18		Nozzle to Shell					
System: Recirc	ASME Cat.: B-D	ASME Item: B3.90	Aug Req: N/A				

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° RL	D-168	N/A	GE-UT-300 Ver/Rev 8	CAL-IIW2-062	Mark Hilborn	II	4/1/2006
60° RL	D-169	N/A	GE-UT-300 Ver/Rev 8	99978AQC	Mark Hilborn	II	4/1/2006
60° Shear	D-170	N/A	GE-UT-311 Ver/Rev 10	99978AQC	Mark Hilborn	II	4/1/2006

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.




The Inner 15% and the Supplement 6 Examination volume scans performed from the vessel OD surface in accordance with procedure GE-UT-300 V10, using shear and longitudinal wave search units as specified by the General Electric "Quad Cities Unit 2 Nozzle Modeling" document.

Examined 360 degrees.

Composite Examination Coverage = 37.2%

On calibration/data sheets, reject is recorded as 0% as indicated on the UT instrument used. The procedure essential variable calls this setting as "off". This is the same as 0%. Therefore this meets the essential variables of the procedure.

Examination results were compared to data report D-065 from Q2R13 outage with ☒ No Change	
These examinations were performed under Work Order: 00828881-02 ☐ Change	

This Summary and the following data sheets have been reviewed and accepted by the following personnel:			
Prepared By: 	Level: II	Date: 4-7-06	Utility Review:  04-07-06 ANII Review:  4/8/06
			RWP: 5984 Dose: 120 mr.
			Page <u>1</u> of <u>8</u>

GE NUCLEAR ENERGY	Ultrasonic Calibration and Examination Record RPV Components																																																																																																																										
Site/Unit: Quad Cities / 2 Outage: Q2R18 Procedure: GE-UT-300	Data Report Number: Q2R18-102 Linearity Sheet: L-011 Data Sheet Number: D-168 Rev.: 8 DRR: N/A																																																																																																																										
Calibration Block: CAL-IIW2-052 <table style="width:100%;"> <tr> <td style="text-align: center;">CS</td> <td style="text-align: center;">N/A</td> <td style="text-align: center;">4.0"</td> </tr> <tr> <td style="text-align: center;">Material</td> <td style="text-align: center;">Size</td> <td style="text-align: center;">Thickness</td> </tr> <tr> <td>Initial Cal: 0800 4/01</td> <td></td> <td>Exam Start: 13:31</td> </tr> <tr> <td>Cal Check: N/A</td> <td></td> <td>Exam End: 13:50</td> </tr> <tr> <td>Cal Check: N/A</td> <td style="text-align: center;">UltraGel II</td> <td style="text-align: center;">04225</td> </tr> <tr> <td>Final Cal: 1615 4/01</td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;">246540</td> <td style="text-align: center;">80° F</td> <td style="text-align: center;">67° F</td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>1/4</td> <td>0.6"</td> <td>1X</td> <td>80%</td> <td>1.17</td> <td>1.2</td> <td>3</td> </tr> <tr> <td>1/2</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>3/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>ID</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>5/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> DAC 1X= 61.4 Db Sweep 0-10 2.0 Depth Note N/A dB difference between 3/8 and 5/8 Vee	CS	N/A	4.0"	Material	Size	Thickness	Initial Cal: 0800 4/01		Exam Start: 13:31	Cal Check: N/A		Exam End: 13:50	Cal Check: N/A	UltraGel II	04225	Final Cal: 1615 4/01	Couplant:	Batch	246540	80° F	67° F	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	1/4	0.6"	1X	80%	1.17	1.2	3	1/2	N/A	1X	N/A	N/A	N/A	N/A	3/4	N/A	1X	N/A	N/A	N/A	N/A	ID	N/A	1X	N/A	N/A	N/A	N/A	5/4	N/A	1X	N/A	N/A	N/A	N/A	Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;">Sigma</td> <td style="text-align: center;">22BC-03006</td> <td style="text-align: center;">2(1.1"X.62") / Rect.</td> </tr> <tr> <td style="text-align: center;">Manufacturer:</td> <td style="text-align: center;">Serial Number:</td> <td style="text-align: center;">Size / Shape:</td> </tr> <tr> <td style="text-align: center;">0.65"</td> <td style="text-align: center;">60°</td> <td style="text-align: center;">61°</td> </tr> <tr> <td style="text-align: center;">Incident Point:</td> <td style="text-align: center;">Nominal Angle:</td> <td style="text-align: center;">Measured Angle:</td> </tr> <tr> <td style="text-align: center;">3.0 MHz</td> <td style="text-align: center;">SDC-3</td> <td style="text-align: center;">RL</td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Model:</td> <td style="text-align: center;">Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;">RG-174</td> <td style="text-align: center;">12'</td> <td style="text-align: center;">0</td> </tr> <tr> <td style="text-align: center;">Cable Type:</td> <td style="text-align: center;">Length:</td> <td style="text-align: center;">Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td style="text-align: center;">Panametrics / Epoch 4</td> <td style="text-align: center;">031573011</td> </tr> <tr> <td style="text-align: center;">Manufacturer/Model:</td> <td style="text-align: center;">Serial Number:</td> </tr> <tr> <td style="text-align: center;">9.628 µs</td> <td style="text-align: center;">0.2345 in./µsec.</td> </tr> <tr> <td style="text-align: center;">Delay/Zero:</td> <td style="text-align: center;">Velocity:</td> </tr> <tr> <td style="text-align: center;">Auto</td> <td style="text-align: center;">Fullwave</td> </tr> <tr> <td style="text-align: center;">Rep Rate:</td> <td style="text-align: center;">Rectification:</td> </tr> <tr> <td style="text-align: center;">400 Ohms</td> <td style="text-align: center;">0%</td> </tr> <tr> <td style="text-align: center;">Damping:</td> <td style="text-align: center;">Reject:</td> </tr> <tr> <td style="text-align: center;">Off:</td> <td style="text-align: center;">Off:</td> </tr> <tr> <td style="text-align: center;">DAC:</td> <td style="text-align: center;">TVG:</td> </tr> <tr> <td style="text-align: center;">4.0 in.</td> <td style="text-align: center;">Sq. / Med</td> </tr> <tr> <td style="text-align: center;">Range:</td> <td style="text-align: center;">Pulser:</td> </tr> <tr> <td style="text-align: center;">3.03 MHz</td> <td style="text-align: center;">Dual</td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Mode:</td> </tr> <tr> <td style="text-align: center;">Off:</td> <td style="text-align: center;">Off:</td> </tr> <tr> <td style="text-align: center;">CSC:</td> <td style="text-align: center;">DGS:</td> </tr> </table>	Sigma	22BC-03006	2(1.1"X.62") / Rect.	Manufacturer:	Serial Number:	Size / Shape:	0.65"	60°	61°	Incident Point:	Nominal Angle:	Measured Angle:	3.0 MHz	SDC-3	RL	Frequency:	Model:	Mode:	RG-174	12'	0	Cable Type:	Length:	Connectors:	Panametrics / Epoch 4	031573011	Manufacturer/Model:	Serial Number:	9.628 µs	0.2345 in./µsec.	Delay/Zero:	Velocity:	Auto	Fullwave	Rep Rate:	Rectification:	400 Ohms	0%	Damping:	Reject:	Off:	Off:	DAC:	TVG:	4.0 in.	Sq. / Med	Range:	Pulser:	3.03 MHz	Dual	Frequency:	Mode:	Off:	Off:	CSC:	DGS:
CS	N/A	4.0"																																																																																																																									
Material	Size	Thickness																																																																																																																									
Initial Cal: 0800 4/01		Exam Start: 13:31																																																																																																																									
Cal Check: N/A		Exam End: 13:50																																																																																																																									
Cal Check: N/A	UltraGel II	04225																																																																																																																									
Final Cal: 1615 4/01	Couplant:	Batch																																																																																																																									
246540	80° F	67° F																																																																																																																									
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																									
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																																					
1/4	0.6"	1X	80%	1.17	1.2	3																																																																																																																					
1/2	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																					
3/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																					
ID	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																					
5/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																					
Sigma	22BC-03006	2(1.1"X.62") / Rect.																																																																																																																									
Manufacturer:	Serial Number:	Size / Shape:																																																																																																																									
0.65"	60°	61°																																																																																																																									
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																									
3.0 MHz	SDC-3	RL																																																																																																																									
Frequency:	Model:	Mode:																																																																																																																									
RG-174	12'	0																																																																																																																									
Cable Type:	Length:	Connectors:																																																																																																																									
Panametrics / Epoch 4	031573011																																																																																																																										
Manufacturer/Model:	Serial Number:																																																																																																																										
9.628 µs	0.2345 in./µsec.																																																																																																																										
Delay/Zero:	Velocity:																																																																																																																										
Auto	Fullwave																																																																																																																										
Rep Rate:	Rectification:																																																																																																																										
400 Ohms	0%																																																																																																																										
Damping:	Reject:																																																																																																																										
Off:	Off:																																																																																																																										
DAC:	TVG:																																																																																																																										
4.0 in.	Sq. / Med																																																																																																																										
Range:	Pulser:																																																																																																																										
3.03 MHz	Dual																																																																																																																										
Frequency:	Mode:																																																																																																																										
Off:	Off:																																																																																																																										
CSC:	DGS:																																																																																																																										
Exam Data for Weld: N2B NOZ Nozzle to Shell Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;">OD Plate</td> <td style="text-align: center;">94° F</td> </tr> <tr> <td style="text-align: center;">Exam Surface:</td> <td style="text-align: center;">Component Temperature</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td>Plate</td> <td>I</td> <td>75.4</td> <td>NRI</td> <td>60°</td> </tr> <tr> <td>Plate CW/CCW</td> <td>P</td> <td>75.4</td> <td>NRI</td> <td>60°</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table>	OD Plate	94° F	Exam Surface:	Component Temperature	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	Plate	I	75.4	NRI	60°	Plate CW/CCW	P	75.4	NRI	60°	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Calibration Verification Field Simulator Block S/N: N/A <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>N/A</th> <th>N/A</th> <th>N/A</th> </tr> <tr> <th>Amplitude</th> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <th>Gain (dB)</th> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <th>Sweep (SD)</th> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> Acceptable Linearity performed : 3/28/2006	Reflector	N/A	N/A	N/A	Amplitude	N/A	N/A	N/A	Gain (dB)	N/A	N/A	N/A	Sweep (SD)	N/A	N/A	N/A																																																																													
OD Plate	94° F																																																																																																																										
Exam Surface:	Component Temperature																																																																																																																										
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																																																																																																							
Plate	I	75.4	NRI	60°																																																																																																																							
Plate CW/CCW	P	75.4	NRI	60°																																																																																																																							
N/A	N/A	N/A	N/A	N/A																																																																																																																							
N/A	N/A	N/A	N/A	N/A																																																																																																																							
Reflector	N/A	N/A	N/A																																																																																																																								
Amplitude	N/A	N/A	N/A																																																																																																																								
Gain (dB)	N/A	N/A	N/A																																																																																																																								
Sweep (SD)	N/A	N/A	N/A																																																																																																																								
Comments: Cal/Exam Date is the date of initial calibration. Calibration for near surface examination. Exams performed a minimum of 14 dB above reference. Scanned 360°.																																																																																																																											
<table style="width:100%;"> <tr> <td style="text-align: center;">Mark Hilborn</td> <td style="text-align: center;">II</td> <td style="text-align: center;">4/1/2006</td> </tr> <tr> <td style="text-align: center;">Initials: Examiner</td> <td style="text-align: center;">Level</td> <td style="text-align: center;">Cal/Exam Date:</td> </tr> <tr> <td style="text-align: center;">N/A</td> <td style="text-align: center;">N/A</td> <td style="text-align: center;">N/A</td> </tr> <tr> <td style="text-align: center;">Initials: Examiner</td> <td style="text-align: center;">Level</td> <td style="text-align: center;">Date:</td> </tr> <tr> <td style="text-align: center;">4.7.06</td> <td style="text-align: center;">TLB</td> <td style="text-align: center;">4.7.06</td> </tr> <tr> <td style="text-align: center;">GE Reviewed By:</td> <td style="text-align: center;">Level:</td> <td style="text-align: center;">Date:</td> </tr> </table>	Mark Hilborn	II	4/1/2006	Initials: Examiner	Level	Cal/Exam Date:	N/A	N/A	N/A	Initials: Examiner	Level	Date:	4.7.06	TLB	4.7.06	GE Reviewed By:	Level:	Date:	<table style="width:100%;"> <tr> <td style="text-align: center;"></td> <td style="text-align: center;">04-01-06</td> </tr> <tr> <td style="text-align: center;">Utility Reviewed By:</td> <td style="text-align: center;">Date:</td> </tr> <tr> <td style="text-align: center;"></td> <td style="text-align: center;">4/8/06</td> </tr> <tr> <td style="text-align: center;">ANII Reviewed By:</td> <td style="text-align: center;">Date:</td> </tr> </table>		04-01-06	Utility Reviewed By:	Date:		4/8/06	ANII Reviewed By:	Date:																																																																																																
Mark Hilborn	II	4/1/2006																																																																																																																									
Initials: Examiner	Level	Cal/Exam Date:																																																																																																																									
N/A	N/A	N/A																																																																																																																									
Initials: Examiner	Level	Date:																																																																																																																									
4.7.06	TLB	4.7.06																																																																																																																									
GE Reviewed By:	Level:	Date:																																																																																																																									
	04-01-06																																																																																																																										
Utility Reviewed By:	Date:																																																																																																																										
	4/8/06																																																																																																																										
ANII Reviewed By:	Date:																																																																																																																										

GE NUCLEAR ENERGY	Ultrasonic Calibration and Examination Record RPV Components																																																																																																																																												
Site/Unit: Quad Cities / 2 Outage: Q2R18 Procedure: GE-UT-300	Data Report Number: Q2R18-102 Linearity Sheet: L-011 Data Sheet Number: D-169 Rev.: 8 DRR: N/A																																																																																																																																												
Calibration Block: 99978AQC <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u></td> <td style="text-align: center;"><u>Flat</u></td> <td style="text-align: center;"><u>7.0"</u></td> </tr> <tr> <td style="text-align: center;">Material</td> <td style="text-align: center;">Size</td> <td style="text-align: center;">Thickness</td> </tr> <tr> <td>Initial Cal: 0826 4/01</td> <td></td> <td>Exam Start: 12:30</td> </tr> <tr> <td>Cal Check: N/A</td> <td></td> <td>Exam End: 13:30</td> </tr> <tr> <td>Cal Check: N/A</td> <td style="text-align: center;"><u>Ultrage II</u></td> <td style="text-align: center;"><u>04225</u></td> </tr> <tr> <td>Final Cal: 1617 4/01</td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>246540</u></td> <td style="text-align: center;"><u>80° F</u></td> <td style="text-align: center;"><u>67° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>1/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>1/2</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>3/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>ID</td> <td>7.0"</td> <td>1X</td> <td>80%</td> <td>12.05</td> <td>13.82</td> <td>6.9</td> </tr> <tr> <td>5/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> DAC 1X= 72.1 Db Sweep 0-10 10.0 Depth Note N/A dB difference between 3/8 and 5/8 Vee	<u>CS</u>	<u>Flat</u>	<u>7.0"</u>	Material	Size	Thickness	Initial Cal: 0826 4/01		Exam Start: 12:30	Cal Check: N/A		Exam End: 13:30	Cal Check: N/A	<u>Ultrage II</u>	<u>04225</u>	Final Cal: 1617 4/01	Couplant:	Batch	<u>246540</u>	<u>80° F</u>	<u>67° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	1/4	N/A	1X	N/A	N/A	N/A	N/A	1/2	N/A	1X	N/A	N/A	N/A	N/A	3/4	N/A	1X	N/A	N/A	N/A	N/A	ID	7.0"	1X	80%	12.05	13.82	6.9	5/4	N/A	1X	N/A	N/A	N/A	N/A	Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u></td> <td style="text-align: center;"><u>22BC-03006</u></td> <td style="text-align: center;"><u>2(1.1"X.62") / Rect.</u></td> </tr> <tr> <td style="text-align: center;">Manufacturer:</td> <td style="text-align: center;">Serial Number:</td> <td style="text-align: center;">Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.65"</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>61°</u></td> </tr> <tr> <td style="text-align: center;">Incident Point:</td> <td style="text-align: center;">Nominal Angle:</td> <td style="text-align: center;">Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u></td> <td style="text-align: center;"><u>SDC-3</u></td> <td style="text-align: center;"><u>RL</u></td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Model:</td> <td style="text-align: center;">Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>12'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td style="text-align: center;">Cable Type:</td> <td style="text-align: center;">Length:</td> <td style="text-align: center;">Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031573011</u></td> </tr> <tr> <td style="text-align: center;">Manufacturer/Model:</td> <td style="text-align: center;">Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>9.628 us</u></td> <td style="text-align: center;"><u>0.2345 in./usec.</u></td> </tr> <tr> <td style="text-align: center;">Delay/Zero:</td> <td style="text-align: center;">Velocity:</td> </tr> <tr> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u></td> <td style="text-align: center;">Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> </tr> <tr> <td style="text-align: center;">Rep Rate:</td> <td style="text-align: center;">Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>20.0 in.</u></td> <td style="text-align: center;">Range:</td> </tr> <tr> <td style="text-align: center;"><u>Sq. / Med</u></td> <td style="text-align: center;">Pulser:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> </tr> <tr> <td style="text-align: center;">Damping:</td> <td style="text-align: center;">Reject:</td> </tr> <tr> <td style="text-align: center;"><u>3.03 MHz</u></td> <td style="text-align: center;">Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Dual</u></td> <td style="text-align: center;">Mode:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td style="text-align: center;">DAC:</td> <td style="text-align: center;">TVG:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;">CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;">DGS:</td> </tr> </table> Calibration Verification Field Simulator Block S/N: N/A <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Amplitude</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Gain (dB)</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Sweep (SD)</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> Acceptable Linearity performed : 3/28/2006	<u>Sigma</u>	<u>22BC-03006</u>	<u>2(1.1"X.62") / Rect.</u>	Manufacturer:	Serial Number:	Size / Shape:	<u>0.65"</u>	<u>60°</u>	<u>61°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>12'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panametrics / Epoch 4</u>	<u>031573011</u>	Manufacturer/Model:	Serial Number:	<u>9.628 us</u>	<u>0.2345 in./usec.</u>	Delay/Zero:	Velocity:	<u>0.8 - 3.0 MHz</u>	Narrowband Filter:	<u>Auto</u>	<u>Fullwave</u>	Rep Rate:	Rectification:	<u>20.0 in.</u>	Range:	<u>Sq. / Med</u>	Pulser:	<u>400 Ohms</u>	<u>0%</u>	Damping:	Reject:	<u>3.03 MHz</u>	Frequency:	<u>Dual</u>	Mode:	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	<u>Off:</u>	CSC:	<u>Off:</u>	DGS:	Reflector	N/A	N/A	N/A	Amplitude	N/A	N/A	N/A	Gain (dB)	N/A	N/A	N/A	Sweep (SD)	N/A	N/A	N/A
<u>CS</u>	<u>Flat</u>	<u>7.0"</u>																																																																																																																																											
Material	Size	Thickness																																																																																																																																											
Initial Cal: 0826 4/01		Exam Start: 12:30																																																																																																																																											
Cal Check: N/A		Exam End: 13:30																																																																																																																																											
Cal Check: N/A	<u>Ultrage II</u>	<u>04225</u>																																																																																																																																											
Final Cal: 1617 4/01	Couplant:	Batch																																																																																																																																											
<u>246540</u>	<u>80° F</u>	<u>67° F</u>																																																																																																																																											
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																																											
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																																																							
1/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																																							
1/2	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																																							
3/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																																							
ID	7.0"	1X	80%	12.05	13.82	6.9																																																																																																																																							
5/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																																							
<u>Sigma</u>	<u>22BC-03006</u>	<u>2(1.1"X.62") / Rect.</u>																																																																																																																																											
Manufacturer:	Serial Number:	Size / Shape:																																																																																																																																											
<u>0.65"</u>	<u>60°</u>	<u>61°</u>																																																																																																																																											
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																																											
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>																																																																																																																																											
Frequency:	Model:	Mode:																																																																																																																																											
<u>RG-174</u>	<u>12'</u>	<u>0</u>																																																																																																																																											
Cable Type:	Length:	Connectors:																																																																																																																																											
<u>Panametrics / Epoch 4</u>	<u>031573011</u>																																																																																																																																												
Manufacturer/Model:	Serial Number:																																																																																																																																												
<u>9.628 us</u>	<u>0.2345 in./usec.</u>																																																																																																																																												
Delay/Zero:	Velocity:																																																																																																																																												
<u>0.8 - 3.0 MHz</u>	Narrowband Filter:																																																																																																																																												
<u>Auto</u>	<u>Fullwave</u>																																																																																																																																												
Rep Rate:	Rectification:																																																																																																																																												
<u>20.0 in.</u>	Range:																																																																																																																																												
<u>Sq. / Med</u>	Pulser:																																																																																																																																												
<u>400 Ohms</u>	<u>0%</u>																																																																																																																																												
Damping:	Reject:																																																																																																																																												
<u>3.03 MHz</u>	Frequency:																																																																																																																																												
<u>Dual</u>	Mode:																																																																																																																																												
<u>Off:</u>	<u>Off:</u>																																																																																																																																												
DAC:	TVG:																																																																																																																																												
<u>Off:</u>	CSC:																																																																																																																																												
<u>Off:</u>	DGS:																																																																																																																																												
Reflector	N/A	N/A	N/A																																																																																																																																										
Amplitude	N/A	N/A	N/A																																																																																																																																										
Gain (dB)	N/A	N/A	N/A																																																																																																																																										
Sweep (SD)	N/A	N/A	N/A																																																																																																																																										
Exam Data for Weld: N2B NOZ <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Nozzle to Shell</u></td> </tr> <tr> <td style="text-align: center;">Configuration:</td> </tr> <tr> <td style="text-align: center;"><u>OD Plate</u></td> </tr> <tr> <td style="text-align: center;"><u>94° F</u></td> </tr> <tr> <td style="text-align: center;">Exam Surface:</td> </tr> <tr> <td style="text-align: center;">Component Temperature</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td>Plate</td> <td>I</td> <td>72.1</td> <td>NRI</td> <td>60°</td> </tr> <tr> <td>Plate CW/CCW</td> <td>P</td> <td>72.1</td> <td>NRI</td> <td>60°</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> Comments: Cal/Exam Date is the date of initial calibration. Calibration for full volume examination. Exams performed to maintain a 10-20% FSH clad roll. Scanned 360°.		<u>Nozzle to Shell</u>	Configuration:	<u>OD Plate</u>	<u>94° F</u>	Exam Surface:	Component Temperature	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	Plate	I	72.1	NRI	60°	Plate CW/CCW	P	72.1	NRI	60°	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A																																																																																																													
<u>Nozzle to Shell</u>																																																																																																																																													
Configuration:																																																																																																																																													
<u>OD Plate</u>																																																																																																																																													
<u>94° F</u>																																																																																																																																													
Exam Surface:																																																																																																																																													
Component Temperature																																																																																																																																													
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																																																																																																																									
Plate	I	72.1	NRI	60°																																																																																																																																									
Plate CW/CCW	P	72.1	NRI	60°																																																																																																																																									
N/A	N/A	N/A	N/A	N/A																																																																																																																																									
N/A	N/A	N/A	N/A	N/A																																																																																																																																									
M.A.B. Mark Hilborn II 4/1/2006 Initials: Examiner Level Cal/Exam Date: N/A N/A N/A Initials: Examiner Level GE Reviewed By: Level: Date: 4-7-06	Utility Reviewed By: Date: 4-27-06 ANII Reviewed By: Date: 4/8/06																																																																																																																																												
Page 3 of 8																																																																																																																																													

GE NUCLEAR ENERGY	Ultrasonic Calibration and Examination Record RPV Components																																																																																																																														
Site/Unit: Quad Cities / 2 Outage: Q2R18 Procedure: GE-UT-311	Data Report Number: Q2R18-102 Linearity Sheet: L-011 Data Sheet Number: D-170 Rev.: 10 DRR: N/A																																																																																																																														
Calibration Block: 99978AQC <table style="width:100%;"> <tr> <td style="text-align: center;">CS</td> <td style="text-align: center;">Flat</td> <td style="text-align: center;">7.0"</td> </tr> <tr> <td style="text-align: center;">Material</td> <td style="text-align: center;">Size</td> <td style="text-align: center;">Thickness</td> </tr> <tr> <td>Initial Cal: 0845 4/01</td> <td></td> <td>Exam Start: 13:51</td> </tr> <tr> <td>Cal Check: N/A</td> <td></td> <td>Exam End: 14:15</td> </tr> <tr> <td>Cal Check: N/A</td> <td style="text-align: center;">Ultragel II</td> <td style="text-align: center;">04225</td> </tr> <tr> <td>Final Cal: 1619 4/01</td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;">246540</td> <td style="text-align: center;">80° F</td> <td style="text-align: center;">67° F</td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>1/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>1/2</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>3/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>ID</td> <td>7.0"</td> <td>1X</td> <td>80%</td> <td>12"</td> <td>14.29</td> <td>5.75</td> </tr> <tr> <td>5/4</td> <td>N/A</td> <td>1X</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> DAC 1X= 44.5 dB Sweep 0-10 25 Metal Path Note N/A dB difference between 3/8 and 5/8 Vee	CS	Flat	7.0"	Material	Size	Thickness	Initial Cal: 0845 4/01		Exam Start: 13:51	Cal Check: N/A		Exam End: 14:15	Cal Check: N/A	Ultragel II	04225	Final Cal: 1619 4/01	Couplant:	Batch	246540	80° F	67° F	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	1/4	N/A	1X	N/A	N/A	N/A	N/A	1/2	N/A	1X	N/A	N/A	N/A	N/A	3/4	N/A	1X	N/A	N/A	N/A	N/A	ID	7.0"	1X	80%	12"	14.29	5.75	5/4	N/A	1X	N/A	N/A	N/A	N/A	Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;">KBA</td> <td style="text-align: center;">010HWX</td> <td style="text-align: center;">50" x 1.0" / Rect.</td> </tr> <tr> <td style="text-align: center;">Manufacturer:</td> <td style="text-align: center;">Serial Number:</td> <td style="text-align: center;">Size / Shape:</td> </tr> <tr> <td style="text-align: center;">700</td> <td style="text-align: center;">60°</td> <td style="text-align: center;">60°</td> </tr> <tr> <td colspan="3">Incident Point: Nominal Angle: Measured Angle:</td> </tr> <tr> <td style="text-align: center;">1.0 MHz</td> <td style="text-align: center;">113-891-600</td> <td style="text-align: center;">Shear</td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Model:</td> <td style="text-align: center;">Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;">RG-174</td> <td style="text-align: center;">12'</td> <td style="text-align: center;">0</td> </tr> <tr> <td style="text-align: center;">Cable Type:</td> <td style="text-align: center;">Length:</td> <td style="text-align: center;">Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;">Panametrics / Epoch 4</td> <td style="text-align: center;">031573011</td> </tr> <tr> <td colspan="2" style="text-align: center;">Manufacturer/Model:</td> <td style="text-align: center;">Serial Number:</td> </tr> <tr> <td style="text-align: center;">15.38 µs</td> <td style="text-align: center;">0.1289 in./µsec.</td> <td style="text-align: center;">0.8 - 3.0 MHz</td> </tr> <tr> <td style="text-align: center;">Delay/Zero:</td> <td style="text-align: center;">Velocity:</td> <td style="text-align: center;">Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;">Auto</td> <td style="text-align: center;">Fullwave</td> <td style="text-align: center;">25.0 in.</td> </tr> <tr> <td style="text-align: center;">Rep Rate:</td> <td style="text-align: center;">Rectification:</td> <td style="text-align: center;">Range:</td> </tr> <tr> <td style="text-align: center;">400 Ohms</td> <td style="text-align: center;">0%</td> <td style="text-align: center;">1.0 MHz</td> </tr> <tr> <td style="text-align: center;">Damping:</td> <td style="text-align: center;">Reject:</td> <td style="text-align: center;">Frequency:</td> </tr> <tr> <td style="text-align: center;">Off:</td> <td style="text-align: center;">Off:</td> <td style="text-align: center;">Off:</td> </tr> <tr> <td style="text-align: center;">DAC:</td> <td style="text-align: center;">TVG:</td> <td style="text-align: center;">CSC:</td> </tr> <tr> <td style="text-align: center;">Off:</td> <td style="text-align: center;">Off:</td> <td style="text-align: center;">Off:</td> </tr> <tr> <td style="text-align: center;">DAC:</td> <td style="text-align: center;">TVG:</td> <td style="text-align: center;">CSC:</td> </tr> </table>	KBA	010HWX	50" x 1.0" / Rect.	Manufacturer:	Serial Number:	Size / Shape:	700	60°	60°	Incident Point: Nominal Angle: Measured Angle:			1.0 MHz	113-891-600	Shear	Frequency:	Model:	Mode:	RG-174	12'	0	Cable Type:	Length:	Connectors:	Panametrics / Epoch 4		031573011	Manufacturer/Model:		Serial Number:	15.38 µs	0.1289 in./µsec.	0.8 - 3.0 MHz	Delay/Zero:	Velocity:	Narrowband Filter:	Auto	Fullwave	25.0 in.	Rep Rate:	Rectification:	Range:	400 Ohms	0%	1.0 MHz	Damping:	Reject:	Frequency:	Off:	Off:	Off:	DAC:	TVG:	CSC:	Off:	Off:	Off:	DAC:	TVG:	CSC:
CS	Flat	7.0"																																																																																																																													
Material	Size	Thickness																																																																																																																													
Initial Cal: 0845 4/01		Exam Start: 13:51																																																																																																																													
Cal Check: N/A		Exam End: 14:15																																																																																																																													
Cal Check: N/A	Ultragel II	04225																																																																																																																													
Final Cal: 1619 4/01	Couplant:	Batch																																																																																																																													
246540	80° F	67° F																																																																																																																													
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																													
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																																									
1/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																									
1/2	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																									
3/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																									
ID	7.0"	1X	80%	12"	14.29	5.75																																																																																																																									
5/4	N/A	1X	N/A	N/A	N/A	N/A																																																																																																																									
KBA	010HWX	50" x 1.0" / Rect.																																																																																																																													
Manufacturer:	Serial Number:	Size / Shape:																																																																																																																													
700	60°	60°																																																																																																																													
Incident Point: Nominal Angle: Measured Angle:																																																																																																																															
1.0 MHz	113-891-600	Shear																																																																																																																													
Frequency:	Model:	Mode:																																																																																																																													
RG-174	12'	0																																																																																																																													
Cable Type:	Length:	Connectors:																																																																																																																													
Panametrics / Epoch 4		031573011																																																																																																																													
Manufacturer/Model:		Serial Number:																																																																																																																													
15.38 µs	0.1289 in./µsec.	0.8 - 3.0 MHz																																																																																																																													
Delay/Zero:	Velocity:	Narrowband Filter:																																																																																																																													
Auto	Fullwave	25.0 in.																																																																																																																													
Rep Rate:	Rectification:	Range:																																																																																																																													
400 Ohms	0%	1.0 MHz																																																																																																																													
Damping:	Reject:	Frequency:																																																																																																																													
Off:	Off:	Off:																																																																																																																													
DAC:	TVG:	CSC:																																																																																																																													
Off:	Off:	Off:																																																																																																																													
DAC:	TVG:	CSC:																																																																																																																													
Exam Data for Weld: N2B NOZ Nozzle to Shell Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;">OD Plate</td> <td style="text-align: center;">94° F</td> </tr> <tr> <td style="text-align: center;">Exam Surface:</td> <td style="text-align: center;">Component Temperature</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td>0-4.5"</td> <td>I</td> <td>70</td> <td>NFI</td> <td>60°</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table>	OD Plate	94° F	Exam Surface:	Component Temperature	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	0-4.5"	I	70	NFI	60°	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Calibration Verification Field Simulator Block S/N: N/A <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Amplitude</th> <th>Gain (dB)</th> <th>Sweep (SD)</th> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table> Acceptable Linearity performed : 3/28/2006	Reflector	Amplitude	Gain (dB)	Sweep (SD)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A																																																																																	
OD Plate	94° F																																																																																																																														
Exam Surface:	Component Temperature																																																																																																																														
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																																																																																																											
0-4.5"	I	70	NFI	60°																																																																																																																											
N/A	N/A	N/A	N/A	N/A																																																																																																																											
N/A	N/A	N/A	N/A	N/A																																																																																																																											
N/A	N/A	N/A	N/A	N/A																																																																																																																											
Reflector	Amplitude	Gain (dB)	Sweep (SD)																																																																																																																												
N/A	N/A	N/A	N/A																																																																																																																												
N/A	N/A	N/A	N/A																																																																																																																												
N/A	N/A	N/A	N/A																																																																																																																												
Comments: Cal/Exam Date is the date of initial calibration. Calibration for nozzle to vessel weld N/V. Exams performed to maintain a 20-30% FSH clad roll. Rotational angle is ±30°-60°. Scanned CW and CCW. Scanned 360°.																																																																																																																															
M.P. Mark Hilborn II 4/1/2006 Initials: Examiner Level Cal/Exam Date: n/a N/A N/A Initials: Examiner Level J.W. III 4-7-06 GE Reviewed By: Level: Date:	 Utility Reviewed By: Date: 04-07-06 ANII Reviewed By: Date: 4/8/06																																																																																																																														
Page 4 of 8																																																																																																																															

**Quad Cities Unit-2
N2 Recirc Inlet
Spring 2006**

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 80.5		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	29.3	1.5	1.9%	360.0	0.9%
60° S6 T-Scan	A	42.1	27.4	34.0%	360.0	17.0%
60° S4 T-Scan	A	9.1	9.1	11.3%	360.0	5.7%
60° NS P-Scan	A	29.3	1.0	1.2%	360.0	0.6%
60° S6 P-Scan	A	42.1	11.8	14.7%	360.0	7.3%
IRS S4 P-Scan	A	9.1	9.1	11.3%	360.0	5.7%
60° NS T-Scan						
60° S6 T-Scan						
60° S4 T-Scan						
60° NS P-Scan						
60° S6 P-Scan						
IRS S4 P-Scan						

% Total Composite Coverage = 37.2%

Comments: A - Examined 360° scan limited due to nozzle configuration only.

Note - Rounding methods may affect calculated values.

Nir_PDI Qc2_Rev 1.XLS

MANUAL / GERIS DETECTION								
NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON				DATE 02/11/06		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET								
N/V Weld (M)	PLATE	0 - 4.5"	60.0°	-	±40°- 80°	FLAT	14.0"	1 MHz
N/V Weld (M)	PLATE	0 - 4.0"	70.0°	-	±40°- 75°	FLAT	25.3"	1 MHz
Zone 1 (M)	ODBR	20° - 45°	35.0°	-	90.0°	5.5"	20.7"	1 MHz
Zone 2a (M)	ODBR	45° - 90°	60.0°	-	35.0°	5.5"	20.4"	1 MHz
RECIRC INLET								
N/V Weld (M)	PLATE	0 - 5.5"	60.0°	-	±30°- 60°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 9.0"	70.0°	-	± 30°	FLAT	24.4"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	67.5°	-	18.1°	3.3"	12.0"	1 MHz
					NOTES: (M) MANUAL XX.X° (XX.X°) WEDGE / (FIXTURE) ROTATION ANGLE			
Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 948-0253								

W-021, W-022
W-023, W-024

W-025, W-026


Q2R1B-102
6 of 8

JLS
4-7-06

Quad Cities Unit-2 N2 Nozzle - Recirculation Inlet

60° NS Exam Volume = 29.3 Sq. In
60° FV Exam Volume = 42.1 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 9.1 Sq. In

60° NS S6 T-Scan achieved = 1.5 Sq. In
60° FV S6 T-Scan achieved = 27.4 Sq. In
60° FV S4 T-Scan achieved = 9.1 Sq. In




Quad Cities Unit-2, 2006

Q2R18-102
Juls-4706
Page 7 of 8

Quad Cities Unit-2 N2 Nozzle - Recirculation Inlet

60° NS Exam Volume = 29.3 Sq. In
60° FV Exam Volume = 42.1 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 9.1 Sq. In

60° NS S6 P-Scan achieved = 1.0 Sq. In
60° FV S6 P-Scan achieved = 11.8 Sq. In
Inner 15%T (IRS) achieved = 9.1 Sq. In



Quad Cities Unit-2, 2006

02/18/02
JUL 4.7.01
Page 8 of 8



GE NUCLEAR ENERGY
UT EXAMINATION SUMMARY SHEET

Report No: Q2R17-87
WO No: 579932, 579933

PROJECT Quad Cities Unit-2, Q2R17
WELD ID: N2C NOZ and N2C IRS
SYSTEM: Reactor Pressure Vessel

CALIBRATION ID: NOZ.IN, NOZ.IN.2, IRS.IN
GERIS DATA: Scan file types: P1, P2, P3, TL and Z1
MANUAL DATA: UT-101, UT-102, UT-104
EXAMINERS: S. Gauthier Lv II, K. Montgomery Lv II, B. Dummer Lv III

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

Examination volumes were in accordance with Section XI, Figure IWB-2500-7 (a).

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-705 V4, using 0° L, 60° RL, and 45° S, search units. Nozzle Inner Radius and Inner 15%T examination volume parallel scans were performed using model validated shear wave search units.

Manual examinations from the vessel OD shell and ODBR surfaces (Nozzle to Vessel P-scan and Zone 2A) were performed in accordance with procedure GE-UT-311 V10.

Scanning was performed from the vessel OD shell and OD Blend Radius surfaces examining the nozzle to shell weld and nozzle inner radius section regions.

No indications were recorded.

Previous data (R-168, R-171, R-174, R-177 from 1997) was reviewed prior to completing this summary. No significant changes were noted.

Scanning was limited due to the nozzle configuration.

Coverage = 28% Nozzle to Shell weld.

Coverage = 100% Nozzle Inner Radius Section.

 PREPARED BY UT Level: III	3/11/04 DATE	 REVIEWED BY UT Level: III	3-11-04 DATE	 UTILITY REVIEW	3/12/04 DATE	 ANII REVIEW	3/19/04 DATE
----------------------------------	-----------------	----------------------------------	-----------------	--------------------	-----------------	-----------------	-----------------

Quad Cities Unit-2, 2004

Page 2 of 16



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N2C-NOZ

Report No.: Q2R17-87
Exam Data Sheet: N2C-01

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n2c.p1.1	09A	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	~
n2c.p1.2	09A	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	~
n2c.p2.1	07B	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n2c.p2.2	07B	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n2c.p2.3	Void	Void	~	~	~	~	~	Void	~	~	~	~	~	~	Void	Void	~
n2c.p2.4	09A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n2c.p3.1	09A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n2c.p3.2	09A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n2c.p3.3	09A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n2c.tl.1	07B	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1
n2c.tl.2	07B	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1

Comments: Scan file n2c.p2.3 void.

1 - Repair areas observed at 60° and 90° GERIS azimuth.

Scanning performed with high profile triple pack, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: COM

Level: III

Date: 3/16/04

Reviewed By: RPM

Level: III

Date: 3-11-04

Quad Cities Unit-2, 2004



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N2C-IRS

Report No.: Q2R17-87
Exam Data Sheet: N2C-02

		Scan															Remarks
File	Disk	Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	
n2c.68z1.1	07A	Z1	~	~	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~
n2c.68z1.2	07A	Z1	~	~	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~
n2c.70z1.1	07A	Z1	~	~	~	~	NRI	NRI	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with high profile triple pack, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: <u>CPM</u> Level: <u>TU</u> Date: <u>3/10/04</u>	Reviewed By: <u>TS/M. Dunn</u> Level: <u>III</u> Date: <u>3-10-04</u>
---	---

Page 3 of 16

Quad Cities Unit-2, Q2R17

Q2R17-87

Page 4 of 16

				GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET						CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17			
PROCEDURE NO. : <u>GE-UT-705 V4</u>				REVISION : <u>N/A</u>		DRR : <u>N/A</u>							
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD	
n2c.p1.1	N2C NOZ	09A	03/09/04	2046	2117	270°	70°	200°	98°	N/A	N/A	NOZ.IN	
n2c.p1.2	N2C NOZ	09A	03/09/04	2135	2159	72°	269°	163°	98°	N/A	N/A	NOZ.IN	
n2c.p2.1	N2C NOZ	07B	03/09/04	1709	1801	270°	161°	251°	98°	N/A	N/A	NOZ.IN	
n2c.p2.2	N2C NOZ	07B	03/09/04	1825	1844	160°	255°	95°	98°	N/A	N/A	NOZ.IN	
n2c.p2.3	Void	Void	~	~	~	~	~	~	~	~	~	~	
n2c.p2.4	N2C NOZ	09A	03/09/04	2009	2013	253°	271°	18°	98°	N/A	N/A	NOZ.IN	
n2c.p3.1	N2C NOZ	09A	03/09/04	2239	2246	270°	305°	35°	98°	N/A	N/A	NOZ.IN	
n2c.p3.2	N2C NOZ	09A	03/09/04	2331	0003	300°	103°	163°	98°	N/A	N/A	NOZ.IN	
n2c.p3.3	N2C NOZ	09A	03/10/04	0009	0034	101°	132°	31°	98°	N/A	N/A	NOZ.IN	
n2c.tl.1	N2C NOZ	07B	03/09/04	1508	1555	270°	78°	192°	98°	N/A	N/A	NOZ.IN.2	
n2c.tl.2	N2C NOZ	07B	03/09/04	1605	1645	79°	270°	169°	98°	N/A	N/A	NOZ.IN.2	
COMMENTS : * Rotation angles for TL and P exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached).						Search Unit Data:				Freq.	Rot.		
The GERIS 0° reference is located 90° CW of nozzle TDC.						No.	Model / Mode	S/N	Size	(MHz.)	Angle		
P3 scans skipped from 132° CW thru 270°.						1	RTD, 0° L2-25 / L	01-231	1.0 Dia	2.25	N/A		
						2	RTD, 45° T1-St / S	01-233	32x22mm	1.00	*		
						3	RTD, 60° L2-St / L	97-152	30x25mm	2.00	*		
Automated scanning was restricted due to the nozzle weld configuration.						4	RTD, 45° T1-St / S	04-8	32x22mm	1.00	*		
OPERATORS: SHANE GAUTHIER LvII KENT MONTGOMERY LvII _____ _____				SOFTWARE REVISION: 5.26		6	RTD, 70° TRL2-St / L	96-228	2(12x25)mm	2.00	*		
				THERMOMETER S/N : 235018		13	RTD, 60° T1-St / S	01-234	32x18mm	1.00	*		
				235074		14	RTD, 60° T1-St / S	01-235	32x18mm	1.00	*		
				COUPLANT : Demineralized Water									

Page 789 of 945



Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2
Outage: Q2R17

Data Report Number: Q2R17-87 Linearity Sheet: L-008
Data Sheet Number: UT-101

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSCI</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1510</u>		Exam Start: <u>15:35</u>
Cal Check: <u>N/A</u>		Exam End: <u>16:10</u>
Cal Check: <u>N/A</u>	<u>Ultraseal II</u>	<u>01225</u>
Final Cal: <u>1705</u>	Couplant:	Batch
<u>3-1401</u> <u>255048 235018</u>	<u>78° F</u>	<u>78° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>12.1</u>	<u>14.1</u>	<u>7.0</u>
		<u>1X</u>				

DAC @ 1X 52.1

Sweep 0-10 20 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>0000LT</u>	<u>0.5"x1.0" / Round</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.65 in.</u>	<u>60°</u>	<u>58°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>1.0 MHz</u>	<u>113-291-600</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Penametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>15.2 us</u>	<u>0.1283 in / ussec</u>
Zero:	Velocity:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>Off</u>	<u>Off</u>
DAC:	TVG:
<u>Off</u>	<u>Off</u>
	CSC:
	DGS:

Exam Data for Component: N2C NOZZLE

Vessel-Nozzle (Recirculation)

Configuration:

<u>ODBR</u>	<u>94° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>Note 1</u>	<u>60</u>
<u>+/- 95</u>	<u>N/A</u>
<u>70</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for nozzle to vessel weld (N/V) CW and CCW.

Note 1: Examined from 120° CW through 280°

Exams performed to maintain a 20% - 30% FSH ID roll.

<u>BD</u> <u>Brad Dummer</u>	<u>III</u>	<u>3/10/04</u>	<u>Donna H. Chitt</u>	<u>3/12/04</u>
Initials: Examiner:	Level	Cal/Exam Date:	Utility Reviewed By:	Date:
<u>CGM</u>	<u>III</u>	<u>3/11/04</u>	<u>Joe Smith</u>	<u>3/19/04</u>
GE Reviewed By:	Level:	Date:	AMT Reviewed By:	Date:

GE NUCLEAR ENERGY		Ultrasonic Calibration and Examination Record Inner Radius Examinations																																																																																																						
Site/Unit: Quad Cities / 2 Outage: Q2R17 Procedure: GE-UT-311		Data Report Number: Q2R17-87 Linearity Sheet: L-008 Data Sheet Number: UT-104 Rev: V10 DRR: N/A																																																																																																						
Calibration Data for Block: 99978 AQC <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>CSC</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>7.3"</u></td> </tr> <tr> <td style="text-align: center;">Material</td> <td style="text-align: center;">Size</td> <td style="text-align: center;">Thickness</td> </tr> <tr> <td>Initial Cal: 1505</td> <td></td> <td>Exam Start: 15:35</td> </tr> <tr> <td>Cal Check: N/A</td> <td></td> <td>Exam End: 16:10</td> </tr> <tr> <td>Cal Check: N/A</td> <td style="text-align: center;"><u>Ultracal II</u></td> <td style="text-align: center;"><u>01225</u></td> </tr> <tr> <td>Final Cal: 1702</td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td>31404 <u>255048 235018</u></td> <td style="text-align: center;"><u>78° F</u></td> <td style="text-align: center;"><u>78° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp.</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Side</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID</td> <td>7.3</td> <td>1X</td> <td>80</td> <td>19.4</td> <td>20.65</td> <td>7.9</td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </table> DAC @ 1X 51.3 Sweep 0-10 26 <u>Metal Path</u> Acceptable Linearity performed : <u>2/10/2004</u>		<u>CSC</u>	<u>N/A</u>	<u>7.3"</u>	Material	Size	Thickness	Initial Cal: 1505		Exam Start: 15:35	Cal Check: N/A		Exam End: 16:10	Cal Check: N/A	<u>Ultracal II</u>	<u>01225</u>	Final Cal: 1702	Couplant:	Batch	31404 <u>255048 235018</u>	<u>78° F</u>	<u>78° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp.	Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID	7.3	1X	80	19.4	20.65	7.9			1X					Search Unit Data <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>KBA</u></td> <td style="text-align: center;"><u>00L323</u></td> <td style="text-align: center;"><u>0.5"x1.0" / Rect.</u></td> </tr> <tr> <td style="text-align: center;">Manufacturer:</td> <td style="text-align: center;">Serial No.:</td> <td style="text-align: center;">Size/Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.85 in.</u></td> <td style="text-align: center;"><u>70°</u></td> <td style="text-align: center;"><u>68°</u></td> </tr> <tr> <td style="text-align: center;">Incident Point:</td> <td style="text-align: center;">Nominal Angle:</td> <td style="text-align: center;">Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u></td> <td style="text-align: center;"><u>113-291-600</u></td> <td style="text-align: center;"><u>Shear</u></td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Model:</td> <td style="text-align: center;">Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>12'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td style="text-align: center;">Cable Type:</td> <td style="text-align: center;">Length:</td> <td style="text-align: center;">Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031573711</u></td> </tr> <tr> <td style="text-align: center;">Manufacturer/Model:</td> <td style="text-align: center;">Serial No.:</td> </tr> <tr> <td style="text-align: center;"><u>16.43 us</u></td> <td style="text-align: center;"><u>0.1283 in /usec</u></td> </tr> <tr> <td style="text-align: center;">Zero:</td> <td style="text-align: center;">Velocity:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Full</u></td> </tr> <tr> <td style="text-align: center;">Rep Rate:</td> <td style="text-align: center;">Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>26.0 in.</u></td> <td style="text-align: center;"><u>Sq. / Med</u></td> </tr> <tr> <td style="text-align: center;">Range:</td> <td style="text-align: center;">Pulser/Energy</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>Off</u></td> </tr> <tr> <td style="text-align: center;">Damping:</td> <td style="text-align: center;">Reject:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u></td> <td style="text-align: center;"><u>P/E</u></td> </tr> <tr> <td style="text-align: center;">Frequency:</td> <td style="text-align: center;">Mode:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td style="text-align: center;">DAC:</td> <td style="text-align: center;">TVG:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td style="text-align: center;">CSC:</td> <td style="text-align: center;">DGS:</td> </tr> </table>		<u>KBA</u>	<u>00L323</u>	<u>0.5"x1.0" / Rect.</u>	Manufacturer:	Serial No.:	Size/Shape:	<u>0.85 in.</u>	<u>70°</u>	<u>68°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>1.0 MHz</u>	<u>113-291-600</u>	<u>Shear</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>12'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panametrics / Epoch 4</u>	<u>031573711</u>	Manufacturer/Model:	Serial No.:	<u>16.43 us</u>	<u>0.1283 in /usec</u>	Zero:	Velocity:	<u>Auto</u>	<u>Full</u>	Rep Rate:	Rectification:	<u>26.0 in.</u>	<u>Sq. / Med</u>	Range:	Pulser/Energy	<u>400 Ohms</u>	<u>Off</u>	Damping:	Reject:	<u>1.0 MHz</u>	<u>P/E</u>	Frequency:	Mode:	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	<u>Off:</u>	<u>Off:</u>	CSC:	DGS:
<u>CSC</u>	<u>N/A</u>	<u>7.3"</u>																																																																																																						
Material	Size	Thickness																																																																																																						
Initial Cal: 1505		Exam Start: 15:35																																																																																																						
Cal Check: N/A		Exam End: 16:10																																																																																																						
Cal Check: N/A	<u>Ultracal II</u>	<u>01225</u>																																																																																																						
Final Cal: 1702	Couplant:	Batch																																																																																																						
31404 <u>255048 235018</u>	<u>78° F</u>	<u>78° F</u>																																																																																																						
Thermometer	Initial Cal Temp.	Final Cal Temp.																																																																																																						
Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																		
ID	7.3	1X	80	19.4	20.65	7.9																																																																																																		
		1X																																																																																																						
<u>KBA</u>	<u>00L323</u>	<u>0.5"x1.0" / Rect.</u>																																																																																																						
Manufacturer:	Serial No.:	Size/Shape:																																																																																																						
<u>0.85 in.</u>	<u>70°</u>	<u>68°</u>																																																																																																						
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																						
<u>1.0 MHz</u>	<u>113-291-600</u>	<u>Shear</u>																																																																																																						
Frequency:	Model:	Mode:																																																																																																						
<u>RG-174</u>	<u>12'</u>	<u>0</u>																																																																																																						
Cable Type:	Length:	Connectors:																																																																																																						
<u>Panametrics / Epoch 4</u>	<u>031573711</u>																																																																																																							
Manufacturer/Model:	Serial No.:																																																																																																							
<u>16.43 us</u>	<u>0.1283 in /usec</u>																																																																																																							
Zero:	Velocity:																																																																																																							
<u>Auto</u>	<u>Full</u>																																																																																																							
Rep Rate:	Rectification:																																																																																																							
<u>26.0 in.</u>	<u>Sq. / Med</u>																																																																																																							
Range:	Pulser/Energy																																																																																																							
<u>400 Ohms</u>	<u>Off</u>																																																																																																							
Damping:	Reject:																																																																																																							
<u>1.0 MHz</u>	<u>P/E</u>																																																																																																							
Frequency:	Mode:																																																																																																							
<u>Off:</u>	<u>Off:</u>																																																																																																							
DAC:	TVG:																																																																																																							
<u>Off:</u>	<u>Off:</u>																																																																																																							
CSC:	DGS:																																																																																																							
Exam Data for Component: N2C IRS VESSEL-NOZZLE (RECIRCULATION) Configuration: <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>QDBR</u></td> <td style="text-align: center;"><u>84° F</u></td> </tr> <tr> <td style="text-align: center;">Exam Surface:</td> <td style="text-align: center;">Component Temp.</td> </tr> </table> <table style="width:100%; border: none;"> <tr> <th>Examination Area</th> <th>Exam Angle</th> <th>Rotation Angle</th> <th>Wedge S/N</th> <th>Scan dB</th> <th>Recordable Indications</th> </tr> <tr> <td>360°</td> <td>87.5</td> <td>18.1</td> <td>W-025A</td> <td>64</td> <td>NRI</td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>		<u>QDBR</u>	<u>84° F</u>	Exam Surface:	Component Temp.	Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications	360°	87.5	18.1	W-025A	64	NRI																			Calibration Verification Field Simulator Block S/N: N/A <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Amplitude</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Gain (dB)</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Sweep (SD)</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </table>		Reflector	N/A	N/A	N/A	Amplitude	N/A	N/A	N/A	Gain (dB)	N/A	N/A	N/A	Sweep (SD)	N/A	N/A	N/A																																																			
<u>QDBR</u>	<u>84° F</u>																																																																																																							
Exam Surface:	Component Temp.																																																																																																							
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications																																																																																																			
360°	87.5	18.1	W-025A	64	NRI																																																																																																			
Reflector	N/A	N/A	N/A																																																																																																					
Amplitude	N/A	N/A	N/A																																																																																																					
Gain (dB)	N/A	N/A	N/A																																																																																																					
Sweep (SD)	N/A	N/A	N/A																																																																																																					
Comments: Cal/Exam Date is the date of initial calibration. Calibration for Zone 2A Clockwise. Exams performed to maintain a 20% - 30% FSH ID roll.																																																																																																								
<table style="width:100%; border: none;"> <tr> <td style="width:25%; vertical-align: top;"> Brad Dummer Initials: Examiner: </td> <td style="width:10%; text-align: center; vertical-align: top;"> III Level </td> <td style="width:20%; text-align: center; vertical-align: top;"> 3/10/04 Cal/Exam Date: </td> <td style="width:25%; text-align: center; vertical-align: top;"> Utility Reviewed By: </td> <td style="width:20%; text-align: center; vertical-align: top;"> 3/12/04 Date: </td> </tr> <tr> <td style="vertical-align: top;"> GE Reviewed By: </td> <td style="text-align: center; vertical-align: top;"> Level: </td> <td style="text-align: center; vertical-align: top;"> 3/11/04 Date: </td> <td style="vertical-align: top;"> ANI Reviewed By: </td> <td style="text-align: center; vertical-align: top;"> 3/19/04 Date: </td> </tr> </table>				 Brad Dummer Initials: Examiner:	III Level	3/10/04 Cal/Exam Date:	 Utility Reviewed By:	3/12/04 Date:	 GE Reviewed By:	 Level:	3/11/04 Date:	 ANI Reviewed By:	3/19/04 Date:																																																																																											
 Brad Dummer Initials: Examiner:	III Level	3/10/04 Cal/Exam Date:	 Utility Reviewed By:	3/12/04 Date:																																																																																																				
 GE Reviewed By:	 Level:	3/11/04 Date:	 ANI Reviewed By:	3/19/04 Date:																																																																																																				



Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Data Report Number: Q2R17-87

Linearity Sheet: L-008

Outage: Q2R17

Data Sheet Number: UT-102

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSCI</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1500</u>		Exam Start: <u>15:35</u>
Cal Check: <u>N/A</u>		Exam End: <u>16:10</u>
Cal Check: <u>N/A</u>	<u>Ultraset II</u>	<u>01225</u>
Final Cal: <u>1700</u>	Couplant:	Batch
<u>3-19-07</u> <u>255910 235018</u>	<u>78° F</u>	<u>78° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	1X	<u>80</u>	<u>19.4</u>	<u>20.65</u>	<u>7.9</u>
		1X				

DAC @ 1X 51.3

Sweep 0-10 26 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>00L321</u>	<u>0.5"x1.0" / Rect.</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.85 In.</u>	<u>70°</u>	<u>68°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>1.0 MHz</u>	<u>113-291-800</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>16.43 us</u>	<u>0.1283 In / ussec</u>
Zero:	Velocity:
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>26.0 In.</u>	<u>Sq. / Med</u>
Range:	Pulsar/Energy
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>1.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off:</u>	<u>Off:</u>
DAC:	TVG:
<u>Off:</u>	<u>Off:</u>
CSC:	DGS:

Exam Data for Component: N2C IRS

Vessel-Nozzle (Recirculation)

Configuration:

<u>ODBR</u>	<u>94° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>67.5</u>
<u>18.1</u>	<u>W-025B</u>
<u>64</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 2A Counter-clockwise.

Exams performed to maintain a 20% - 30% FSH ID roll.

BD Bred Dummer

Initials: Examiner:

III

Level

3/10/04

Cal/Exam Date:

[Signature]

Utility Reviewed By:

3/12/04

Date:

OPM

GE Reviewed By:

IV

Level:

3/11/04

Date:

[Signature]

AMII Reviewed By:

3/19/04

Date:

Report No.: Q2R17-87

Recirculation Inlet N2C-NOZ Quad Cities Unit-2, 2004

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 80.5		Required Exam Area Sq. In.	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
70° T-Scan	A	29.3	2	2.5%	360	1.2%
45° T-Scan	A	42.1	17	21.1%	360	10.6%
60° T-Scan	A	9.1	5.9	7.3%	360	3.7%
70° P-Scan	A	29.3	0	0.0%	360	0.0%
45° P-Scan	A	42.1	11.7	14.5%	360	7.3%
60° P-Scan	A	9.1	9.1	11.3%	360	5.7%
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						

% Total Composite Coverage = 28%

Comments: A - Examined accessible length. Scanning limited due to scanner access.


A - Weld length includes manually examined portion from 120° CW thru 280° 60° P-scan due to ALARA considerations.

Note - Rounding methods may make calculated values appear in error.

Quad Cities Unit-2 Recirculation Inlet

70° Exam Volume = 29.3 Sq. In.
45° Exam Volume = 42.1 Sq. In.
Inner 15%T Exam Volume (IRS & 60°T) = 9.1 Sq. In.


70° T-Scan achieved = 2.0 Sq. In.
45° T-Scan achieved = 17.0 Sq. In.
60° T-Scan achieved = 5.9 Sq. In.



Quad Cities Unit-2 Recirculation Inlet

70° Exam Volume = 29.3 Sq. In.
45° Exam Volume = 42.1 Sq. In.
Inner 15%T Exam Volume (IRS & 60°T) = 9.1 Sq. In.

70° P-Scan achieved = 0.0 Sq. In.
45° P-Scan achieved = 11.7 Sq. In.
IRS P-Scan achieved = 9.1 Sq. In. (By model)



Guideline for Deciding when to Perform Manual UT Examination of Areas Not Covered by Automated Examinations

Component/Configuration: N2C No2

A. DETERMINE

1. Percent coverage obtained with automated UT: 28 %
2. Approximate radiation dose received to complete automated UT: 1800 mR

B. ESTIMATE

1. Percent coverage increases if manual UT was performed: + 9 % *
2. Radiation dose expected if manual UT was performed: 1500 mR

Decision to Proceed: YES X NO Based On: DOSK

Prepared By: R.L. My Date: 03/09/04

* ALL SHELL BASE METAL COVERAGE,
NOT WELD OR HAZ ON I.D.

Q2R17-87
12 OF 16

Report No.: Q2R17-87

Recirculation Inlet N2C-IRS Quad Cities Unit-2, 2004

Weld Length = 360. Exam Volume = 100%		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area %	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Z1 CW	A	100%	100%	100.0%	360	50.0%
Z1 CCW	A	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2A CW	B	100%	100%	100.0%	360	50.0%
Z2A CCW	B	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
% Total Composite Coverage =						
% Total Composite Coverage =						

Comments: A - Examined accessible length with the GERIS 2000. Exam volume determined by modeling, 100% assigned volume.
B - Examined accessible length using manual techniques. Exam volume determined by modeling, 100% assigned volume.

Note - Rounding methods may make calculated values appear in error.



GE Nuclear Energy

GERIS 2000 OD Nozzle Examination Scan Plan

Quad Cities Unit-2, 2004
Nozzle Scanning Limits
Nozzle(s) N2

12.85 Weld CL Radius
17.67 ASME OD Radius
15.25 Outside Radius of ODBR
12.50 Outside Radius of NOZOD

125.50 Vessel ID Radius
6.38 Vessel Nom. Thickness
131.88 Vessel OD Radius
1.0 Overscan Distance

Package Configuration: Triple Pack and ODBR Package.

Channel	Beam Angle	CPU Angle	Fixture Angle	Type	Delay	SU Parameters Velocity	X-Off	Y-Off	Scan Area	Scanner Min	Scanner Max	A-Gate Start	A-Gate Stop	A-Gate Max MP	C-Gate Start	C-Gate Stop
N2 T-Scan. Supplement 4 and 6 radial scans.										Step →	0.25	Index →	0.4°			
1	0	0.0	0.0	WM	4	0.233	0.0	0.0	N/A	Note 1	18.75	0	75	8.3	18	54
2	45	-9.0	9.0	T	15	0.128	3.0	0.0	N/A	Note 1	12.75	0	230	13.8	37	191
3	60	7.2	352.8	T	15	0.233	-3.0	0.0	N/A	Note 1	18.75	0	180	19.2	32	152
N2 P1. 45° S for outer 85%T volume.										Step →	0.25	Index →	0.6°			
2	45	51.5	308.5	P	15	0.128	3.0	0.0	N/A	Note 1	10.75	0	230	13.8	37	191
4	45	-51.5	51.5	P	15	0.128	-3.0	0.0	N/A	Note 1	10.75	0	230	13.8	37	191
N2 P2. N/V Inner 15%T P-scan examination from PLATE with 70T-scan.										Step →	0.15	Index →	0.5°			
13	60	27.3	332.7	N/V	15	0.128	-3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
6	70	0.0	0.0	T	10	0.233	0.0	0.0	N/A	Note 1	8.70	0	50	4.7	10	48
14	60	-27.3	27.3	N/V	15	0.128	3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
N2 P3. N/V Inner 15%T P-scan examination from PLATE.										Step →	0.15	Index →	0.5°			
13	60	35.5	324.5	N/V	15	0.128	-3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
14	60	-35.5	35.5	N/V	15	0.128	3.0	0.0	8.5	Note 1	12.00	0	300	14.0	120	250
N2 Z1. Z1 Inner Radius Section examination from PLATE.										Step →	0.15	Index →	0.5°			
3	68	16.0	344.0	Z1	15	0.128	-3.0	0.0	8.0	Note 1	11.40	0	450	21.2	180	365
4	68	-16.0	16.0	Z1	15	0.128	3.0	0.0	8.0	Note 1	11.40	0	450	21.2	180	365

QUAD CITIES
REPORT NO. QC 2R17-87
PAGE 14 OF 116

Channel	Beam	CPU	Fixture	Type	SU Parameters				Scan	Scanner		A-Gate			C-Gate	
	Angle	Angle	Angle		Delay	Velocity	X-Off	Y-Off	Area	Min	Max	Start	Stop	Max MP	Start	Stop
N2 Z1. Z1 Inner Radius Section examination from PLATE.																
										Step →	0.15	Index →	0.5°			
5	70	8.5	351.5	Z1	15	0.128	-3.0	0.0	9.0	Note 1	12.45	0	485	22.9	190	390
6	70	-8.5	8.5	Z1	15	0.128	3.0	0.0	9.0	Note 1	12.45	0	485	22.9	190	390
N2 Z2A. Z2A Inner Radius Section examination from ODBR																
										Step →	0.07	Index →	1.8°			
7	67.5	8.2	351.8	Z2A	15	0.128	-2.5	0.0	N/A	55°	90°	0	260	12.0	105	220
8	67.5	-8.2	8.2	Z2A	15	0.128	2.5	0.0	N/A	55°	90°	0	260	12.0	105	220
Notes: Vessel ID radius from B&W drawing Shell Course Subassembly 151825E-1.																
Vessel nominal thickness from B&W drawing Shell Forming Details 104186D-1 (ordered thickness).																
Note 1 - Scan into nozzle until onset of liftoff or limited by physical limitations.																
															Site Revision 0 2/22/04	

QUAD CITIES
REPORT NO. QC2-R17-87
PAGE 15 OF 16

Nir_PDI Qc2.XLS

MANUAL/GERIS 2000 DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Quad Cities 2					
PREPARED BY		S.C. MORTENSON			DATE 01/17/04		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld	PLATE	0 - 9.0"	66.0°	57.8° (52.4°) *	FLAT	18.5"	1 MHz
N/V Weld	PLATE	0 - 9.0"	70.0°	42.1° 37.0°) *	FLAT	25.3"	1 MHz
Zone 1/NV (M)	ODBR	20° - 45°	35.0°	90.0°	5.5"	20.7"	1 MHz
Zone 2A	ODBR	45° - 90°	60.0°	35.0° (30.6°) **	5.5"	20.4"	1 MHz
RECIRC INLET							
N/V Weld	PLATE	0 - 8.0"	60.0°	38.0° (27.3°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.5"	60.0°	45.0° (35.5°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	PLATE	0 - 8.0"	68.0°	25.7° (16.0°) *	FLAT	21.2"	1 MHz
Zone 1	PLATE	0 - 9.0"	70.0°	15.6° (8.5°) *	FLAT	22.9"	1 MHz
Zone 2A	ODBR	55° - 90°	67.5°	18.1° (8.2°) **	3.3"	12.0"	1 MHz
FEEDWATER							
N/V Weld	PLATE	0 - 8.0"	60.0°	48.2° (39.2°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	60.0°	38.9° (28.3°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	40.3° (31.8°) **	3.5"	19.3"	2.25 MHz
Zone 2A	ODBR	50° - 90°	67.5°	21.7° (13.2°) **	3.5"	13.4"	2.25 MHz
Zone 2B	NOZOD	ALL	28.0°	68.0°	FLAT	7.5"	2 MHz
Zone 3	NOZOD	ALL	28.0°	90°	FLAT	6.7"	2 MHz

W-021, W-022
W-023, W-024

W-025, W-026

W-027, W-028
W-029, W-030

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0° PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45° PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5° OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5° PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253

 GE NUCLEAR ENERGY		EXAMINATION SUMMARY SHEET				Report No.: Q2R18-104	
Site: Quad Cities		Component ID: N2D NOZ					
Outage: Q2R18		Nozzle to Shell					
System: Recirc	ASME Cat.: B-D	ASME Item: B3.90	Aug Req: N/A				

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° RL	D-173	N/A	GE-UT-300 Var/Rev 8	CAL-I/W2-052	Mark Hilborn	II	4/2/2006
60° RL	D-174	N/A	GE-UT-300 Var/Rev 8	99978AQC	Mark Hilborn	II	4/2/2006
60° Shear	D-175	N/A	GE-UT-311 Var/Rev 10	99978AQC	Mark Hilborn	II	4/2/2006

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1996 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.


The Inner 15% and the Supplement 6 Examination volume scans performed from the vessel OD surface in accordance with procedure GE-UT-300 V10, using shear and longitudinal wave search units as specified by the General Electric "Quad Cities Unit 2 Nozzle Modeling" document.

Examined 360 degrees.

Composite Examination Coverage = 37.2%

On calibration/data sheets, reject is recorded as 0% as indicated on the UT instrument used. The procedure essential variable calls this setting as "off". This is the same as 0%. Therefore this meets the essential variables of the procedure.

Examination results were compared to data report R-172 from Q2R14 outage with ☒ No Change
These examinations were performed under Work Order: 00828881-02 ☐ Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:				RWP: 5984
Prepared By: 	Level: IIb	Date: 4-7-06	Utility Review: 	Date: 04-07-06
ANII Review: 				Date: 4/18/06
				Page <u>1</u> of <u>8</u>



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Quad Cities / 2
Outage: Q2R18

Data Report Number: Q2R18-104 Linearity Sheet: L-011
Data Sheet Number: D-173

Procedure: GE-UT-300

Rev.: 8

DRR: N/A

Calibration Block: CAL-IIW2-052

CS N/A 4.0"
Material Size Thickness
Initial Cal: 0937 4/02 Exam Start 13:16
Cal Check: N/A Exam End 13:30
Cal Check: N/A Ultracal II 04225
Final Cal: 1630 4/02 Couplant: Batch
246540 90° F 70° F
Thermometer Initial Cal Temp. Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	<u>0.6"</u>	1X	<u>80%</u>	<u>1.17</u>	<u>1.2</u>	<u>3</u>
1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC 1X= 61.4 dB

Sweep 0-10 2.0 Depth

Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: N2D NOZ

Nozzle to Shell
Configuration:

OD Plate 97° F
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>75.4</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>75.4</u>	<u>NRI</u>	<u>60°</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for near surface examination.

Exams performed a minimum of 14 dB above reference.

Scanned 360°.

Search Unit Data

Sigma 22BC-03006 2(1.1"X.62") / Rect.
Manufacturer: Serial Number: Size / Shape:
0.65" 60° 60°
Incident Point: Nominal Angle: Measured Angle:
3.0 MHz SDC-3 RL
Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031573011
Manufacturer/Model: Serial Number:
9.628 us 0.2345 in./usec 0.8 - 3.0 MHz
Delay/Zero: Velocity: Narrowband Filter:
Auto Fullwave 4.0 in. Sq. / Med
Rep Rate: Rectification: Range: Pulsar:
400 Ohms 0% 3.03 MHz Dual
Damping: Reject: Frequency: Mode:
Off: Off: Off: Off:
DAC: TVG: CSC: DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 3/28/2006

MAH Mark Hilborn II 4/2/2006
Initials: Examiner Level Cal/Exam Date:
1/1 N/A N/A
Initials: Examiner Level
[Signature] TS 4-7-06
GE Reviewed By: Level: Date:

[Signature] 04-07-06
Utility Reviewed By: Date:
[Signature] 4/8/06
ANII Reviewed By: Date:



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: **Quad Cities / 2**

Data Report Number: **Q2R18-104**

Linearity Sheet: **L-011**

Outage: **Q2R18**

Data Sheet Number: **D-175**

Procedure: **GE-UT-311**

Rev.: **10**

DRR: **N/A**

Calibration Block: **99978AQC**

CS **Flat** **7.0"**
Material Size Thickness

Initial Cal: **0945 4/02** Exam Start: **12:00**
Cal Check: **N/A** Exam End: **12:30**
Cal Check: **N/A** **Ultracal II** **04225**
Final Cal: **1620 4/02** Couplant: Batch

246540 **90° F** **70° F**
Thermometer Initial Cal Temp. Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	N/A	1X	N/A	N/A	N/A	N/A
1/2	N/A	1X	N/A	N/A	N/A	N/A
3/4	N/A	1X	N/A	N/A	N/A	N/A
	7.0"	1X	80%	12"	14.29	5.75
5/4	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= **44.5 dB**

Sweep 0-10 **25** **Metal Path**

Note **N/A** dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: **N2D NOZ**

Nozzle to Shell

Configuration:

OD Plate **97° F**
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
0-4.5"	I	70	NRI	60°
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for nozzle to vessel weld **N/V**.

Exams performed to maintain a 20-30% FSH clad roll.

Rotational angle is $\pm 30^\circ$ - 60° .

Scanned CW and CCW.

Scanned 360°.

Search Unit Data

KBA **010HMX** **.50" x 1.0" / Rect.**
Manufacturer: Serial Number: Size / Shape:

.700 **60°** **60°**
Incident Point: Nominal Angle: Measured Angle:

1.0 MHz **113-891-600** **Shear**
Frequency: Model: Mode:

Search Unit Cable

RG-174 **12'** **0**
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 **031573011**
Manufacturer/Model: Serial Number:

15.38 μ s **0.1289 in./ μ sec.** **0.8 - 3.0 MHz**
Delay/Zero: Velocity: Narrowband Filter:

Auto **Fullwave** **25.0 in.** **Sq. / Med**
Rep Rate: Rectification: Range: Pulsar:

400 Ohms **0%** **1.0 MHz** **P/E**
Damping: Reject: Frequency: Mode:

Off: **Off:** **Off:** **Off:**
DAC: TVG: CSC: DGS:

Calibration Verification

Field Simulator Block S/N: **N/A**

Reflector	N/A	N/A	N/A
Amplitude	N/A	N/A	N/A
Gain (dB)	N/A	N/A	N/A
Sweep (SD)	N/A	N/A	N/A

Acceptable Linearity performed : **3/28/2006**

M.H. Mark Hilborn

II

4/2/2006

Initials: Examiner

Level Cal/Exam Date:

N/A **N/A**

N/A

Initials: Examiner

Level

GE Reviewed By:

Level:

Date:

Kevin L. Moore
Utility Reviewed By:

04-07-06

Date:

Paul C. Ouyang
Anti Reviewed By:

4/8/06

Date:

Quad Cities Unit-2

Quad Cities Unit-2
N2D Recirc Inlet
Spring 2006

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 80.5		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	29.3	1.5	1.9%	360.0	0.9%
60° S6 T-Scan	A	42.1	27.4	34.0%	360.0	17.0%
60° S4 T-Scan	A	9.1	9.1	11.3%	360.0	5.7%
60° NS P-Scan	A	29.3	1.0	1.2%	360.0	0.6%
60° S6 P-Scan	A	42.1	11.8	14.7%	360.0	7.3%
IRS S4 P-Scan	A	9.1	9.1	11.3%	360.0	5.7%
60° NS T-Scan						
60° S6 T-Scan						
60° S4 T-Scan						
60° NS P-Scan						
60° S6 P-Scan						
IRS S4 P-Scan						

% Total Composite Coverage = 37.2%

Comments: A - Examined 360° scan limited due to nozzle configuration only.

Note - Rounding methods may affect calculated values.

02R18-104
1.1.17 27.00

Page 5 of 18

Nir_PDI Qc2_Rev 1.XLS

MANUAL / GERIS DETECTION								
NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON				DATE 02/11/06		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET								
N/V Weld (M)	PLATE	0 - 4.5"	80.0°	-	±40° - 80°	FLAT	14.0"	1 MHz
N/V Weld (M)	PLATE	0 - 4.0"	70.0°	-	±40° - 75°	FLAT	25.3"	1 MHz
Zone 1 (M)	ODBR	20° - 45°	35.0°	-	90 0°	5.5"	20.7"	1 MHz
Zone 2a (M)	ODBR	45° - 90°	60.0°	-	35.0°	5.5"	20.4"	1 MHz
RECIRC INLET								
N/V Weld (M)	PLATE	0 - 5.5"	60.0°	-	±30° - 80°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 9.0"	70.0°	-	± 30°	FLAT	24.4"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	67.5°	-	18.1°	3.3"	12.0"	1 MHz
					NOTES: (M) MANUAL XX.X° (XX.X°) WEDGE / (FIXTURE) ROTATION ANGLE			
Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 948-0253								

W-021, W-022
W-023, W-024

W-025, W-026

Q2R1B-104


6 of 8

JWS. 4-706

Quad Cities Unit-2 N2 Nozzle - Recirculation Inlet

60° NS Exam Volume = 29.3 Sq. In
60° FV Exam Volume = 42.1 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 9.1 Sq. In


60° NS S6 T-Scan achieved = 1.5 Sq. In
60° FV S6 T-Scan achieved = 27.4 Sq. In
60° FV S4 T-Scan achieved = 9.1 Sq. In



Quad Cities Unit-2 N2 Nozzle - Recirculation Inlet

60° NS Exam Volume = 29.3 Sq. In
60° FV Exam Volume = 42.1 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 9.1 Sq. In

60° NS S6 P-Scan achieved = 1.0 Sq. In
60° FV S6 P-Scan achieved = 11.8 Sq. In
Inner 15%T (IRS) achieved = 9.1 Sq. In



GE NUCLEAR ENERGY		EXAMINATION SUMMARY SHEET				Report No.: Q2R18-106	
Site: <u>Quad Cities</u>		Component ID: <u>N2E NOZ</u>					
Outage: <u>Q2R18</u>		Nozzle to Shell					
System: <u>Recirc</u>	ASME Cat.: <u>B-D</u>	ASME Item: <u>B3.90</u>	Aug Req: <u>N/A</u>				

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° RL	D-179	N/A	GE-UT-300 Ver/Rev 8	CAL-IIW2-052	Mark Hilborn	II	4/4/2006
60° RL	D-180	N/A	GE-UT-300 Ver/Rev 8	99978AQC	Mark Hilborn	II	4/4/2006
60° Shear	D-181	N/A	GE-UT-311 Ver/Rev 10	99978AQC	Mark Hilborn	II	4/4/2006

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

The Inner 15% and the Supplement 6 Examination volume scans performed from the vessel OD surface in accordance with procedure GE-UT-300 V10, using shear and longitudinal wave search units as specified by the General Electric "Quad Cities Unit 2 Nozzle Modeling" document.

Examined 360 degrees.

Composite Examination Coverage = 37.2%

On calibration/data sheets, reject is recorded as 0% as indicated on the UT instrument used. The procedure essential variable calls this setting as "off". This is the same as 0%. Therefore this meets the essential variables of the procedure.

Examination results were compared to data report D-069 - D-072 from Q2R13 outage with ☒ No Change	
These examinations were performed under Work Order: 00828881-02 ☐ Change	

This Summary and the following data sheets have been reviewed and accepted by the following personnel:				RWP: 5984 Dose: 204 mr.	
Prepared By:	Level: <u>III</u>	Date: <u>4-7-06</u>	Utility Review:	Date: <u>04/07/06</u>	Page <u>1</u> of <u>8</u>
ANR Review:				Date: <u>4/9/06</u>	



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: **Quad Cities / 2**

Data Report Number: **Q2R18-106**

Linearity Sheet: **L-011**

Outage: **Q2R18**

Data Sheet Number: **D-179**

Procedure: **GE-UT-300**

Rev.: **8**

DRR: **N/A**

Calibration Block: **CAL-IIW2-052**

CS **N/A** **4.0"**
Material Size Thickness
Initial Cal: **0940 4/04** Exam Start **16:26**
Cal Check: **N/A** Exam End **16:40**
Cal Check: **N/A** **Ultracal II** **04225**
Final Cal: **1730 4/04** Couplant: Batch
246540 **90° F** **69° F**
Thermometer Initial Cal Temp. Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	0.6"	1X	80%	1.17	1.2	3
1/2	N/A	1X	N/A	N/A	N/A	N/A
3/4	N/A	1X	N/A	N/A	N/A	N/A
1D	N/A	1X	N/A	N/A	N/A	N/A
5/4	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= **61.4 dB**

Sweep 0-10 **2.0** **Depth**

Note **N/A** dB difference between 3/8 and 5/8 Vee

Search Unit Data

Sigma **22BC-03006** **2(1.1"X.62") / Rect.**
Manufacturer: Serial Number: Size / Shape:
0.65" **60°** **61°**
Incident Point: Nominal Angle: Measured Angle:
3.0 MHz **SDC-3** **RL**
Frequency: Model: Mode:

Search Unit Cable

RG-174 **12'** **0**
Cable Type: Length: Connectors:

Instrument Settings

Panometrics / Epoch 4 **031573011**
Manufacturer/Model: Serial Number:
0.628 us **0.2345 in./usec.** **0.8 - 3.0 MHz**
Delay/Zero: Velocity: Narrowband Filter:
Auto **Fullwave** **4.0 in.** **Sq. / Mod**
Rep Rate: Rectification: Range: Pulsar:
400 Ohms **0%** **3.03 MHz** **Dual**
Damping: Reject: Frequency: Mode:
Off: **Off:** **Off:** **Off:**
DAC: TVG: CSC: DGS:

Exam Data for Weld: **N2E NOZ**

Nozzle to Shell

Configuration:

OD Plate **94° F**
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
Plate	I	75.4	NRI	60°
Plate CW/CCW	P	75.4	NRI	60°
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

Calibration Verification

Field Simulator Block S/N: **N/A**

Reflector	N/A	N/A	N/A
Amplitude	N/A	N/A	N/A
Gain (dB)	N/A	N/A	N/A
Sweep (SD)	N/A	N/A	N/A

Acceptable Linearity performed : **3/28/2006**

Comments: Cal/Exam Date is the date of initial calibration.
Calibration for near surface examination.
Exams performed a minimum of 14 dB above reference.
Scanned 360°.

MRH **Mark Hilborn** **II** **4/4/2006**
Initials: Examiner Level Cal/Exam Date:

N/A **N/A**
Initials: Examiner Level
GE **90** **4.70°**
GE Reviewed By: Level: Date:

John Z. ... **04-07-06**
Utility Reviewed By: Date:
John C. ... **4/9/06**
AMT Reviewed By: Date:



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Quad Cities / 2

Data Report Number: Q2R18-106

Linearity Sheet: L-011

Outage: Q2R18

Data Sheet Number: D-180

Procedure: GE-UT-300

Rev.: 8

DRR: N/A

Calibration Block: 99978AQC

<u>CS</u> Material	<u>Flat</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>0943 4/04</u>	Exam Start	<u>15:40</u>
Cal Check: <u>N/A</u>	Exam End	<u>16:25</u>
Cal Check: <u>N/A</u>	<u>Ultraset II</u> Couplant:	<u>04225</u> Batch
Final Cal: <u>1733 4/04</u>		
<u>246540</u> Thermometer	<u>90° F</u> Initial Cal Temp.	<u>69° F</u> Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
ID	<u>7.0"</u>	1X	<u>80%</u>	<u>12.05</u>	<u>13.82</u>	<u>6.2</u>
5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC 1X= 72.1 dB

Sweep 0-10 10.0 Depth

Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: N2E NOZ

Nozzle to Shell

Configuration:

<u>OD Plate</u> Exam Surface:	<u>94° F</u> Component Temperature
----------------------------------	---------------------------------------

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>72.1</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>72.1</u>	<u>NRI</u>	<u>60°</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Search Unit Data

<u>Sigma</u> Manufacturer:	<u>22BC-03006</u> Serial Number:	<u>2(1.1"x.62") / Rect</u> Size / Shape:
<u>0.65"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>61°</u> Measured Angle:
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:

Search Unit Cable

<u>BG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

Instrument Settings

<u>Panometrics / Epoch 4</u> Manufacturer/Model:	<u>031573011</u> Serial Number:
<u>9.628 us</u> Delay/Zero:	<u>0.2345 in./uscc</u> Velocity:
<u>0.8 - 3.0 MHz</u> Narrowband Filter:	
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:
<u>20.0 in.</u> Range:	<u>Sq. / Med</u> Pulser:
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:
<u>3.03 MHz</u> Frequency:	<u>Dual</u> Mode:
<u>Off:</u> DAC:	<u>Off:</u> TVG:
<u>Off:</u> CSC:	<u>Off:</u> DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 3/28/2006

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for full volume examination.

Exams performed to maintain a 10-20% FSH clad roll.

Scanned 360°.

<u>M.H.</u> <u>Mark Hilborn</u>	<u>H</u>	<u>4/4/2006</u>
Initials: Examiner	Level	Cal/Exam Date:

<u>N/A</u>	<u>N/A</u>	<u>4.700</u>
Initials: Examiner	Level	Date:
<u>GE</u>	<u>Reviewed By:</u>	<u>Level:</u>

<u>Utility Reviewed By:</u>	<u>04-07-06</u>
<u>Date:</u>	
<u>ANII Reviewed By:</u>	<u>4/19/06</u>
<u>Date:</u>	



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Quad Cities / 2

Data Report Number: Q2R18-106

Linearity Sheet: L-011

Outage: Q2R18

Data Sheet Number: D-181

Procedure: GE-UT-311

Rev.: 10

DRR: N/A

Calibration Block: 99978AQC

CS **Flat** **7.0"**
Material Size Thickness
Initial Cal: 0948 4/04 Exam Start: 16:41
Cal Check: N/A Exam End: 17:10
Cal Check: N/A Ultracal II 04225
Final Cal: 1738 4/04 Couplant: Batch
245540 80° F 69° F
Thermometer Initial Cal Temp. Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
ID	<u>7.0"</u>	1X	<u>80%</u>	<u>12"</u>	<u>14.29</u>	<u>5.75</u>
5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC 1X= 44.5 dB

Sweep 0-10 25 Metal Path

Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: N2E NOZ

Nozzle to Shell

Configuration:

OD Plate 94° F
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>0-4.5"</u>	<u>I</u>	<u>70</u>	<u>NRI</u>	<u>60°</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Search Unit Data

KBA **010HWX** **50" x 1.0" / Rect.**
Manufacturer: Serial Number: Size / Shape:
700 60° 60°
Incident Point: Nominal Angle: Measured Angle:
1.0 MHz 113-891-600 Shear
Frequency: Model: Mode:

Search Unit Cable

RG-174 **12'** **0**
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 **031573011**
Manufacturer/Model: Serial Number:
15.38 us 0.1289 in./usec. 0.8 - 3.0 MHz
Delay/Zero: Velocity: Narrowband Filter:
Auto Fullwave 25.0 in. Sq. / Med
Rep Rate: Rectification: Range: Pulsar:
400 Ohms 0% 1.0 MHz P/E
Damping: Reject: Frequency: Mode:
Off: Off: Off: Off:
DAC: TVG: CSC: DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 3/28/2006

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for nozzle to vessel weld N/V.

Exams performed to maintain a 20-30% FSH clad roll.

Rotational angle is ±30°-60°.

Scanned CW and CCW.

Scanned 360°.

mpk Mark Hillborn II 4/4/2006

Initials: Examiner Level Cal/Exam Date:

mt N/A N/A

Initials: Examiner Level

gws 15 4.7.06
GE Reviewed By: Level: Date:

Kevin Y. Lee 04-01-06
Utility Reviewed By: Date:
J. C. O'Connell 4/19/06
ANII Reviewed By: Date:

**Quad Cities Unit-2
N2E Recirc Inlet
Spring 2006**

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 80.5		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	29.3	1.5	1.9%	360.0	0.9%
60° S6 T-Scan	A	42.1	27.4	34.0%	360.0	17.0%
60° S4 T-Scan	A	9.1	9.1	11.3%	360.0	5.7%
60° NS P-Scan	A	29.3	1.0	1.2%	360.0	0.6%
60° S6 P-Scan	A	42.1	11.8	14.7%	360.0	7.3%
IRS S4 P-Scan	A	9.1	9.1	11.3%	360.0	5.7%
60° NS T-Scan						
60° S6 T-Scan						
60° S4 T-Scan						
60° NS P-Scan						
60° S6 P-Scan						
IRS S4 P-Scan						

% Total Composite Coverage = 37.2%

Comments: A - Examined 360° scan limited due to nozzle configuration only.

Note - Rounding methods may affect calculated values.

Quad Cities Unit-2

Q2E18-106
JUS 4-7-06
Page 5 of 88

Nir_PDI Qc2_Rev 1 XLS

MANUAL / GERIS DETECTION								
NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON				DATE		02/11/06
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET								
N/V Weld (M)	PLATE	0 - 4.5"	60.0°	-	±40° - 80°	FLAT	14.0"	1 MHz
N/V Weld (M)	PLATE	0 - 4.0"	70.0°	-	±40° - 75°	FLAT	25.3"	1 MHz
Zone 1 (M)	ODBR	20° - 45°	35.0°	-	90.0°	5.5"	20.7"	1 MHz
Zone 2a (M)	ODBR	45° - 90°	60.0°	-	35.0°	5.5"	20.4"	1 MHz
RECIRC INLET								
N/V Weld (M)	PLATE	0 - 5.5"	60.0°	-	±30° - 60°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 9.0"	70.0°	-	± 30°	FLAT	24.4"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	67.5°	-	18.1°	3.3"	12.0"	1 MHz
					NOTES: (M) MANUAL XX.X° (XX.X°) WEDGE / (FIXTURE) ROTATION ANGLE			
Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 948-0253								

W-021, W-022
W-023, W-024

W-025, W-026


Q2R1B-106
JWC 4-7-06

6 of 8

Quad Cities Unit-2 N2 Nozzle - Recirculation Inlet

60° NS Exam Volume = 29.3 Sq. In
60° FV Exam Volume = 42.1 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 9.1 Sq. In


60° NS S6 P-Scan achieved = 1.0 Sq. In
60° FV S6 P-Scan achieved = 11.8 Sq. In
Inner 15%T (IRS) achieved = 9.1 Sq. In



Quad Cities Unit-2 N2 Nozzle - Recirculation Inlet

60° NS Exam Volume = 29.3 Sq. In
60° FV Exam Volume = 42.1 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 9.1 Sq. In

60° NS S6 T-Scan achieved = 1.5 Sq. In
60° FV S6 T-Scan achieved = 27.4 Sq. In
60° FV S4 T-Scan achieved = 9.1 Sq. In



 GE NUCLEAR ENERGY		EXAMINATION SUMMARY SHEET				Report No.: Q2R18-100	
Site: Quad Cities		Component ID: N1A NOZ					
Outage: Q2R18		ASME Cat.: B-D		ASME Item: B3.90		Aug Req: N/A	
System: Recirc		ASME Item: B3.90		Aug Req: N/A			

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° RL	D-163	N/A	GE-UT-300 Ver/Rev 8	99978AQC	Mark Hilborn	II	4/1/2006
60° Shear	D-164	N/A	GE-UT-311 Ver/Rev 10	99978AQC	Jack Reisewitz	II	4/1/2006
70° Shear	D-165	N/A	GE-UT-311 Ver/Rev 10	99978AQC	Mark Hilborn	II	4/1/2006

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

The Inner 15% and the Supplement 6 Examination volume scans performed from the vessel OD surface in accordance with procedure GE-UT-300 V10, using shear and longitudinal wave search units as specified by the General Electric "Quad Cities Unit 2 Nozzle Modeling" document.

Examined 360 degrees.

Composite Examination Coverage = 21%

On calibration/data sheets, reject is recorded as 0% as indicated on the UT instrument used. The procedure essential variable calls this setting as "off". This is the same as 0%. Therefore this meets the essential variables of the procedure.



Examination results were compared to data report D-116 - D-120 from 1995 outage with ☒ No Change

These examinations were performed under Work Order: 00828881-02 ☐ Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: <u><i>JW Sitzer</i></u>	Level: <u><i>III</i></u>	Date: <u>4-7-06</u>	Utility Review: <u><i>Kevin L. Noel</i></u>	Date: <u>04-07-06</u>	RWP: 5984 Dose: 168 mr.
ANII Review: <u><i>David C. Cuyang</i></u>					Date: <u>4/8/06</u>

Page 1 of 8

 GE NUCLEAR ENERGY	Ultrasonic Calibration and Examination Record RPV Components																																																																																																																		
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R18</u> Procedure: <u>GE-UT-300</u>	Data Report Number: <u>Q2R18-100</u> Linearity Sheet: <u>L-011</u> Data Sheet Number: <u>D-163</u> Rev.: <u>8</u> DRR: <u>N/A</u>																																																																																																																		
Calibration Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>Flat</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>0826 4/01</u></td> <td>Exam Start: <u>10:40</u></td> <td></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td>Exam End: <u>11:20</u></td> <td></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td><u>Ultrage II</u></td> <td><u>04225</u></td> </tr> <tr> <td>Final Cal: <u>1617 4/01</u></td> <td>Couplant:</td> <td>Batch</td> </tr> <tr> <td><u>246540</u></td> <td><u>80° F</u></td> <td><u>67° F</u></td> </tr> <tr> <td>Thermometer</td> <td>Initial Cal Temp.</td> <td>Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>1/4</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>1/2</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>3/4</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>ID</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>12.05</u></td> <td><u>13.82</u></td> <td><u>6.9</u></td> </tr> <tr> <td>5/4</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> DAC 1X= <u>72.1 dB</u> Sweep 0-10 <u>10.0 Depth</u> Note <u>N/A</u> dB difference between 3/8 and 5/8 Vee	<u>CS</u> Material	<u>Flat</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>0826 4/01</u>	Exam Start: <u>10:40</u>		Cal Check: <u>N/A</u>	Exam End: <u>11:20</u>		Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>04225</u>	Final Cal: <u>1617 4/01</u>	Couplant:	Batch	<u>246540</u>	<u>80° F</u>	<u>67° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	1/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	ID	<u>7.0"</u>	1X	<u>80%</u>	<u>12.05</u>	<u>13.82</u>	<u>6.9</u>	5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u> Manufacturer:</td> <td style="text-align: center;"><u>22BC-03006</u> Serial Number:</td> <td style="text-align: center;"><u>2(1.1"X.62") / Rect.</u> Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.65"</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>61°</u></td> </tr> <tr> <td colspan="3">Incident Point: Nominal Angle: Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>SDC-3</u> Model:</td> <td style="text-align: center;"><u>RL</u> Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>12'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031573011</u></td> </tr> <tr> <td colspan="2">Manufacturer/Model:</td> <td>Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>9.628 us</u></td> <td style="text-align: center;"><u>0.2345 in./usec.</u></td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u></td> </tr> <tr> <td>Delay/Zero:</td> <td>Velocity:</td> <td>Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> <td style="text-align: center;"><u>20.0 in.</u></td> </tr> <tr> <td>Rep Rate:</td> <td>Rectification:</td> <td>Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> <td style="text-align: center;"><u>3.03 MHz</u></td> </tr> <tr> <td>Damping:</td> <td>Reject:</td> <td>Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td>DAC:</td> <td>TVG:</td> <td>CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td></td> <td></td> <td>DGS:</td> </tr> </table>	<u>Sigma</u> Manufacturer:	<u>22BC-03006</u> Serial Number:	<u>2(1.1"X.62") / Rect.</u> Size / Shape:	<u>0.65"</u>	<u>60°</u>	<u>61°</u>	Incident Point: Nominal Angle: Measured Angle:			<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:	<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u>		<u>031573011</u>	Manufacturer/Model:		Serial Number:	<u>9.628 us</u>	<u>0.2345 in./usec.</u>	<u>0.8 - 3.0 MHz</u>	Delay/Zero:	Velocity:	Narrowband Filter:	<u>Auto</u>	<u>Fullwave</u>	<u>20.0 in.</u>	Rep Rate:	Rectification:	Range:	<u>400 Ohms</u>	<u>0%</u>	<u>3.03 MHz</u>	Damping:	Reject:	Frequency:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	CSC:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>			DGS:
<u>CS</u> Material	<u>Flat</u> Size	<u>7.0"</u> Thickness																																																																																																																	
Initial Cal: <u>0826 4/01</u>	Exam Start: <u>10:40</u>																																																																																																																		
Cal Check: <u>N/A</u>	Exam End: <u>11:20</u>																																																																																																																		
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>04225</u>																																																																																																																	
Final Cal: <u>1617 4/01</u>	Couplant:	Batch																																																																																																																	
<u>246540</u>	<u>80° F</u>	<u>67° F</u>																																																																																																																	
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																	
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																													
1/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																													
1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																													
3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																													
ID	<u>7.0"</u>	1X	<u>80%</u>	<u>12.05</u>	<u>13.82</u>	<u>6.9</u>																																																																																																													
5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																													
<u>Sigma</u> Manufacturer:	<u>22BC-03006</u> Serial Number:	<u>2(1.1"X.62") / Rect.</u> Size / Shape:																																																																																																																	
<u>0.65"</u>	<u>60°</u>	<u>61°</u>																																																																																																																	
Incident Point: Nominal Angle: Measured Angle:																																																																																																																			
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:																																																																																																																	
<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:																																																																																																																	
<u>Panametrics / Epoch 4</u>		<u>031573011</u>																																																																																																																	
Manufacturer/Model:		Serial Number:																																																																																																																	
<u>9.628 us</u>	<u>0.2345 in./usec.</u>	<u>0.8 - 3.0 MHz</u>																																																																																																																	
Delay/Zero:	Velocity:	Narrowband Filter:																																																																																																																	
<u>Auto</u>	<u>Fullwave</u>	<u>20.0 in.</u>																																																																																																																	
Rep Rate:	Rectification:	Range:																																																																																																																	
<u>400 Ohms</u>	<u>0%</u>	<u>3.03 MHz</u>																																																																																																																	
Damping:	Reject:	Frequency:																																																																																																																	
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																	
DAC:	TVG:	CSC:																																																																																																																	
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																	
		DGS:																																																																																																																	
Exam Data for Weld: <u>N1A NOZ</u> <u>Nozzle to Shell</u> Configuration: <u>OD Plate</u> <u>94° F</u> Exam Surface: Component Temperature <table style="width:100%;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td><u>Plate</u></td> <td><u>I</u></td> <td><u>72.1</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>Plate</u>	<u>I</u>	<u>72.1</u>	<u>NRI</u>	<u>60°</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> Acceptable Linearity performed : <u>3/28/2006</u>	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																									
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																																																																																															
<u>Plate</u>	<u>I</u>	<u>72.1</u>	<u>NRI</u>	<u>60°</u>																																																																																																															
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
Comments: Cal/Exam Date is the date of initial calibration. Calibration for full volume examination. Exams performed to maintain a 10-20% FSH clad roll. Scanned 360°.																																																																																																																			
Mark Hilborn II 4/1/2006 Initials: Examiner Level Cal/Exam Date: <u>n/a</u> <u>N/A</u> <u>N/A</u> Initials: Examiner Level <u>juw</u> <u>II</u> <u>4-7-06</u> GE Reviewed By: Level: Date:	 Utility Reviewed By: Date: <u>4-07-06</u>  ARII Reviewed By: Date: <u>4/8/06</u>																																																																																																																		
Page 2 of 8																																																																																																																			



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Quad Cities / 2

Data Report Number: Q2R18-100

Linearity Sheet: L-010

Outage: Q2R18

Data Sheet Number: D-164

Procedure: GE-UT-311

Rev.: 10

DRR: N/A

Calibration Block: 99978AQC

<u>CS</u> Material	<u>Flat</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>0925 4/01</u>	Exam Start	<u>10:43</u>
Cal Check: <u>N/A</u>	Exam End	<u>12:27</u>
Cal Check: <u>N/A</u>	<u>UltraGel II</u> Couplant:	<u>04225</u> Batch
Final Cal: <u>1642 4/01</u>	<u>246540</u> Thermometer	<u>80° F</u> Initial Cal Temp.
		<u>67° F</u> Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
1/2	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
3/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
ID	<u>7.0"</u>	1X	<u>80%</u>	<u>12.15</u>	<u>14.03</u>	<u>5.6</u>
5/4	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC 1X= 44.5 dB

Sweep 0-10 25 Metal Path

Note N/A dB difference between 3/8 and 5/8 Vee

Search Unit Data

<u>KBA</u> Manufacturer:	<u>010HWX</u> Serial Number:	<u>.50" x 1.0" / Rect.</u> Size / Shape:
<u>.700</u>	<u>60°</u>	<u>60°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>1.0 MHz</u> Frequency:	<u>113-891-600</u> Model:	<u>Shear</u> Mode:

Search Unit Cable

<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

Instrument Settings

<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031526704</u> Serial Number:
<u>14.65 µs</u> Delay/Zero:	<u>0.1275 in./µsec.</u> Velocity:
	<u>0.8 - 3.0 MHz</u> Narrowband Filter:
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:
	<u>25.0 in.</u> Range:
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:
	<u>1.0 MHz</u> Frequency:
<u>Off:</u> DAC:	<u>Off:</u> TVG:
	<u>Off:</u> CSC:
	<u>Off:</u> DGS:

Exam Data for Weld: N1A NOZ

Nozzle to Shell

Configuration:

OD Plate

94° F

Exam Surface:

Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>0-6.5"</u>	<u>Tangential</u>	<u>70</u>	<u>NRI</u>	<u>60°</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 3/28/2006

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for nozzle to vessel weld N/V

Rotational angle is ±40°-80°

Scanned CW and CCW

Exams performed to maintain a 20-30% FSH clad roll

Scanned 360°

<u>JAR</u> Initials: Examiner	<u>II</u> Level	<u>4/1/2006</u> Cal/Exam Date:
<u>N/A</u> Initials: Examiner	<u>N/A</u> Level	<u>4.7.06</u> Date:
<u>GE</u> Reviewed By:	<u>II</u> Level:	

<u>Kevin Z. Reed</u> Utility Reviewed By:	<u>04-07-06</u> Date:
<u>John C. Ouyang</u> ANII Reviewed By:	<u>4/18/06</u> Date:

Quad Cities Unit-2

**Quad Cities Unit-2
N1 Recirc Inlet
Spring 2006**

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 73.2		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	30.1	0.0	0.0%	360.0	0.0%
60° S6 T-Scan	A	35.4	15.6	21.3%	360.0	10.7%
60° S4 T-Scan	A	7.7	7.4	10.1%	360.0	5.1%
60° NS P-Scan	A	30.1	0.0	0.0%	360.0	0.0%
60° S6 P-Scan	A	35.4	0.0	0.0%	360.0	0.0%
IRS S4 P-Scan	A	7.7	7.7	10.5%	360.0	5.3%
60° NS T-Scan						
60° S6 T-Scan						
60° S4 T-Scan						
60° NS P-Scan						
60° S6 P-Scan						
IRS S4 P-Scan						

% Total Composite Coverage = 21.0%

Comments: A - Examined 360° scan limited due to nozzle configuration only.
No 60° P-scans due to ODBR configuration.

Note - Rounding methods may affect calculated values.

Q2218-100 Page 5 of 8
JWS 4-7-06

Nir_PDI Qc2_Rev 1.XLS

MANUAL / GERIS DETECTION								
NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT	Quad 2							
PREPARED BY	S.C. MORTENSON				DATE	02/11/06		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET								
N/V Weld (M)	PLATE	0 - 4.5"	60.0°	-	±40° - 80°	FLAT	14.0"	1 MHz
N/V Weld (M)	PLATE	0 - 4.0"	70.0°	-	±40° - 75°	FLAT	25.3"	1 MHz
Zone 1 (M)	ODBR	20° - 45°	35.0°	-	90.0°	5.5"	20.7"	1 MHz
Zone 2a (M)	ODBR	45° - 90°	60.0°	-	35.0°	5.5"	20.4"	1 MHz
RECIRC INLET								
N/V Weld (M)	PLATE	0 - 5.5"	60.0°	-	±30° - 60°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 9.0"	70.0°	-	± 30°	FLAT	24.4"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	67.5°	-	18.1°	3.3"	12.0"	1 MHz
					NOTES: (M) MANUAL XX.X° (XX.X°) WEDGE / (FIXTURE) ROTATION ANGLE			
Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 948-0253								

W-021, W-022
W-023, W-024


W-025, W-026

Q2R18-100
6 of 8

JUL 4-7-06

60° NS Exam Volume = 30.1 Sq. In
60° FV Exam Volume = 35.4 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 7.7 Sq. In

60° NS S6 T-Scan achieved = 0.0 Sq. In
60° FV S6 T-Scan achieved = 15.6 Sq. In
60° FV S4 T-Scan achieved = 7.4 Sq. In




Quad Cities Unit-2

N1 Nozzle - Recirc. Outlet

60° NS Exam Volume = 30.1 Sq. In
60° FV Exam Volume = 35.4 Sq. In
Inner 15%T Exam Volume (60°T & IRS) = 7.7 Sq. In

60° NS S6 P-Scan achieved = 0.0 Sq. In
60° FV S6 P-Scan achieved = 0.0 Sq. In
Inner 15%T (IRS) achieved = 7.7 Sq. In

No 60°RL P-scans due to ODBR configuration.



Quad Cities Unit-2, 2006

Q2210-100
Puls 4.7.06
Page 8 of 8

	HITACHI	EXAMINATION SUMMARY SHEET	Report No.: Q2R20-072				
Site: <u>Quad</u> Component ID: <u>N18 NOZ</u> Outage: <u>RFO 20</u> <u>VESSEL-NOZZLE (RECIRCULATION)</u> System: <u>RPV</u> ASME Cat.: <u>B-D</u> ASME Item <u>B3.90</u> Aug Req <u>N/A</u>							
Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Exam / Oper. Personnel	Cert Level	Date
60° Shear	D-066	N/A	GEH-UT-311 Ver/Rev V16A	99978AQC	Jimmy Johnson	II	3/22/2010
70° Shear	D-067	N/A	GEH-UT-311 Ver/Rev V16A	99978AQC	Jimmy Johnson	II	3/22/2010
60° RL	D-068	N/A	GE-UT-300 Ver/Rev V10	CAL-IIW2-045	David Hancock	II	3/22/2010
60° RL	D-069	N/A	GE-UT-300 Ver/Rev V10	99978AQC	David Hancock	II	3/22/2010
Examination Results: During the manual ultrasonic examination of the above referenced nozzle to shell weld, no recordable indications were detected utilizing the above procedures. The inner 15% examination volume as defined by 10 CFR 50 (Supplement 7), searching for flaws oriented perpendicular to the weld axis, was performed per procedure GEH-UT-311 V16A utilizing search units validated by modeling. Manual examinations were restricted due to the nozzle configuration. 35.4% code coverage was achieved. This examination meets the requirements of ASME Section XI, 1995 Edition through 1996 Addenda.							
Examination results were compared to Data Report Q2R16-79 from: Q2R16					☐ Change		
These examinations were performed under Work Order: 1179267					☒ No Change		
This Summary and the following data sheets have been reviewed and accepted by the following personnel:						RWP: 10010890 Dose: 47 mr.	
Prepared By: <u>Scott R. Erickson</u> Level: <u>III</u>		Date: <u>03/24/10</u> Utility Review: <u>Jeff Snyder</u>		Date: <u>3-29-10</u>		Page <u>1</u> of <u>11</u>	
GE Review By: <u>Scott R. Erickson</u> Level: <u>III</u>		Date: <u>03/24/10</u> ANII Review: <u>Jeff Snyder</u>		Date: <u>3/30/10</u>			

	HITACHI	Ultrasonic Calibration and Examination Record Inner Radius Examinations																																	
Site/Unit: <u>Quad / 2</u> Outage: <u>RFO 20</u> Procedure: <u>GEH-UT-311</u>		Data Report Number: <u>Q2R20-072</u> Data Sheet Number: <u>D-066</u>		Linearity Sheet: <u>L-008</u> Rev: <u>V16A</u> DRR: <u>10-02</u>																															
Calibration Data for Block: <u>99978AQC</u>			Search Unit Data																																
CS Material Initial Cal: <u>0925</u> Cal Check: <u>N/A</u> Cal Check: <u>N/A</u> Final Cal: <u>1416</u> <u>269040</u> Thermometer	N/A Size Exam Start: <u>1005</u> Exam End: <u>1207</u> <u>Ultragel II</u> Couplant:	7.0" Thickness <u>08125</u> Batch <u>72° F</u> Initial Cal Temp.	KBA Manufacturer:	01LK56 Serial No.:	0.50" x 1.0" / Rect Size/Shape:																														
DAC Construction			Search Unit Cable																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>ID Notch</td> <td><u>7.0</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>12.1</u></td> <td><u>14.40</u></td> <td><u>7.2</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </tbody> </table>			Reflector	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0</u>	1X	<u>80%</u>	<u>12.1</u>	<u>14.40</u>	<u>7.2</u>	<u>N/A</u>	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	RG-174 6' 0 Cable Type: Length: Connectors:											
Reflector	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																													
ID Notch	<u>7.0</u>	1X	<u>80%</u>	<u>12.1</u>	<u>14.40</u>	<u>7.2</u>																													
<u>N/A</u>	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																													
DAC @ 1X= <u>46.8</u> Sweep 0-10 = <u>20.0'</u> <u>METAL PATH</u> Acceptable Linearity performed : <u>3/11/2010</u>			Instrument Settings																																
Exam Data for Component: <u>N18 NOZ</u> <u>VESSEL-NOZZLE (RECIRCULATION)</u> Configuration:			Panametrics / Epoch 4 031538006 Manufacturer/Model: Serial No.:																																
O.D. PLATE 95° F Exam Surface: Component Temp.			16.52 μs 0.1296 in / μsec 0.8 - 3.0 MHz Zero: Velocity: Narrowband Filter:																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Examination Area</th> <th>Exam Angle</th> <th>Rotation Angle</th> <th>Wedge S/N</th> <th>Scan dB</th> <th>Recordable Indications</th> </tr> </thead> <tbody> <tr> <td><u>0-4.5"</u></td> <td><u>60°</u></td> <td><u>±40°-80°</u></td> <td><u>N/A</u></td> <td><u>6Z</u></td> <td><u>NR</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </tbody> </table>			Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications	<u>0-4.5"</u>	<u>60°</u>	<u>±40°-80°</u>	<u>N/A</u>	<u>6Z</u>	<u>NR</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Auto Fullwave 20.0 in. Sq. / Med Rep Rate: Rectification: Range: Pulsar/Energy		
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications																														
<u>0-4.5"</u>	<u>60°</u>	<u>±40°-80°</u>	<u>N/A</u>	<u>6Z</u>	<u>NR</u>																														
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																														
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																														
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																														
			400 Ohms 0% 1.0 MHz P/E Damping: Reject: Frequency: Mode:																																
			Off: Off: Off: Off: DAC: TVG: CSC: DGS:																																
			Calibration Verification																																
			Field Simulator Block S/N: <u>N/A</u>																																
			<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th><u>N/A</u></th> <th><u>N/A</u></th> <th><u>N/A</u></th> </tr> </thead> <tbody> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </tbody> </table>			Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>														
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for vessel to nozzle weld (V/N). Exams performed to maintain a 20-30% FSH clad roll. Scanned CW and CCW. Calibration Sweep is 30.0" metal path, Examination Range setting is 20.0".																																			
<table style="width:100%;"> <tr> <td style="width:25%;">  <u>Jimmy Johnson</u> Initials: Examiner: </td> <td style="width:10%;"> <u>II</u> Level: </td> <td style="width:15%;"> <u>3/22/2010</u> Cal/Exam Date: </td> <td style="width:20%;"> See Summary Sheet for Signature Utility Reviewed By: </td> <td style="width:15%;"> Date: </td> <td style="width:15%;"></td> </tr> <tr> <td>  <u>Scott R. Erickson</u> GE Reviewed By: </td> <td> <u>III</u> Level: </td> <td> <u>03/24/10</u> Date: </td> <td> See Summary Sheet for Signature ANII Reviewed By: </td> <td> Date: </td> <td> Page <u>2</u> of <u>11</u> </td> </tr> </table>						 <u>Jimmy Johnson</u> Initials: Examiner:	<u>II</u> Level:	<u>3/22/2010</u> Cal/Exam Date:	See Summary Sheet for Signature Utility Reviewed By:	Date:		 <u>Scott R. Erickson</u> GE Reviewed By:	<u>III</u> Level:	<u>03/24/10</u> Date:	See Summary Sheet for Signature ANII Reviewed By:	Date:	Page <u>2</u> of <u>11</u>																		
 <u>Jimmy Johnson</u> Initials: Examiner:	<u>II</u> Level:	<u>3/22/2010</u> Cal/Exam Date:	See Summary Sheet for Signature Utility Reviewed By:	Date:																															
 <u>Scott R. Erickson</u> GE Reviewed By:	<u>III</u> Level:	<u>03/24/10</u> Date:	See Summary Sheet for Signature ANII Reviewed By:	Date:	Page <u>2</u> of <u>11</u>																														

	HITACHI	Ultrasonic Calibration and Examination Record Inner Radius Examinations																																																																																																																			
Site/Unit: <u>Quad / 2</u> Outage: <u>RFO 20</u> Procedure: <u>GEH-UT-311</u>		Data Report Number: <u>Q2R20-072</u> Linearity Sheet: <u>L-008</u> Data Sheet Number: <u>D-067</u> Rev: <u>V16A</u> DRR: <u>10-02</u>																																																																																																																			
Calibration Data for Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>0929</u></td> <td colspan="2">Exam Start: <u>1005</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td colspan="2">Exam End: <u>1207</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultragel II</u></td> <td style="text-align: center;"><u>08125</u></td> </tr> <tr> <td>Final Cal: <u>1419</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>269040</u></td> <td style="text-align: center;"><u>72° F</u></td> <td style="text-align: center;"><u>72° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID Notch</td> <td><u>7.0</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>19.7</u></td> <td><u>21.56</u></td> <td><u>6.6</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> DAC @ 1X= <u>46.7</u> Sweep 0-10 = <u>32.5"</u> <u>METAL PATH</u> Acceptable Linearity performed : <u>3/11/2010</u>		<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>0929</u>	Exam Start: <u>1005</u>		Cal Check: <u>N/A</u>	Exam End: <u>1207</u>		Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>08125</u>	Final Cal: <u>1419</u>	Couplant:	Batch	<u>269040</u>	<u>72° F</u>	<u>72° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0</u>	1X	<u>80%</u>	<u>19.7</u>	<u>21.56</u>	<u>6.6</u>	<u>N/A</u>	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>KBA</u> Manufacturer:</td> <td style="text-align: center;"><u>010HX4</u> Serial No.:</td> <td style="text-align: center;"><u>0.50" x 1.0"/Rect.</u> Size/Shape:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 in.</u></td> <td style="text-align: center;"><u>70°</u></td> <td style="text-align: center;"><u>70°</u></td> </tr> <tr> <td>Incident Point:</td> <td>Nominal Angle:</td> <td>Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u></td> <td style="text-align: center;"><u>113-891-600</u></td> <td style="text-align: center;"><u>Shear</u></td> </tr> <tr> <td>Frequency:</td> <td>Model:</td> <td>Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>6'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td>Cable Type:</td> <td>Length:</td> <td>Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Panometrics / Epoch 4</u></td> <td style="text-align: center;"><u>031538006</u></td> </tr> <tr> <td>Manufacturer/Model:</td> <td>Serial No.:</td> </tr> <tr> <td style="text-align: center;"><u>16.44 µs</u></td> <td style="text-align: center;"><u>0.1287 in /µsec</u></td> </tr> <tr> <td>Zero:</td> <td>Velocity:</td> </tr> <tr> <td colspan="2" style="text-align: center;"><u>0.8 - 3.0 MHz</u></td> </tr> <tr> <td colspan="2">Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> </tr> <tr> <td>Rep Rate:</td> <td>Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>32.5 in.</u></td> <td style="text-align: center;"><u>Sq. / Med</u></td> </tr> <tr> <td>Range:</td> <td>Pulsar/Energy</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> </tr> <tr> <td>Damping:</td> <td>Reject:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u></td> <td style="text-align: center;"><u>P/E</u></td> </tr> <tr> <td>Frequency:</td> <td>Mode:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td>DAC:</td> <td>TVG:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td>CSC:</td> <td>DGS:</td> </tr> </table> Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th><u>N/A</u></th> <th><u>N/A</u></th> <th><u>N/A</u></th> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>	<u>KBA</u> Manufacturer:	<u>010HX4</u> Serial No.:	<u>0.50" x 1.0"/Rect.</u> Size/Shape:	<u>1.0 in.</u>	<u>70°</u>	<u>70°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>1.0 MHz</u>	<u>113-891-600</u>	<u>Shear</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>6'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panometrics / Epoch 4</u>	<u>031538006</u>	Manufacturer/Model:	Serial No.:	<u>16.44 µs</u>	<u>0.1287 in /µsec</u>	Zero:	Velocity:	<u>0.8 - 3.0 MHz</u>		Narrowband Filter:		<u>Auto</u>	<u>Fullwave</u>	Rep Rate:	Rectification:	<u>32.5 in.</u>	<u>Sq. / Med</u>	Range:	Pulsar/Energy	<u>400 Ohms</u>	<u>0%</u>	Damping:	Reject:	<u>1.0 MHz</u>	<u>P/E</u>	Frequency:	Mode:	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	<u>Off:</u>	<u>Off:</u>	CSC:	DGS:	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																																																			
Initial Cal: <u>0929</u>	Exam Start: <u>1005</u>																																																																																																																				
Cal Check: <u>N/A</u>	Exam End: <u>1207</u>																																																																																																																				
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>08125</u>																																																																																																																			
Final Cal: <u>1419</u>	Couplant:	Batch																																																																																																																			
<u>269040</u>	<u>72° F</u>	<u>72° F</u>																																																																																																																			
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																			
Reflector	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																															
ID Notch	<u>7.0</u>	1X	<u>80%</u>	<u>19.7</u>	<u>21.56</u>	<u>6.6</u>																																																																																																															
<u>N/A</u>	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
<u>KBA</u> Manufacturer:	<u>010HX4</u> Serial No.:	<u>0.50" x 1.0"/Rect.</u> Size/Shape:																																																																																																																			
<u>1.0 in.</u>	<u>70°</u>	<u>70°</u>																																																																																																																			
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																			
<u>1.0 MHz</u>	<u>113-891-600</u>	<u>Shear</u>																																																																																																																			
Frequency:	Model:	Mode:																																																																																																																			
<u>RG-174</u>	<u>6'</u>	<u>0</u>																																																																																																																			
Cable Type:	Length:	Connectors:																																																																																																																			
<u>Panometrics / Epoch 4</u>	<u>031538006</u>																																																																																																																				
Manufacturer/Model:	Serial No.:																																																																																																																				
<u>16.44 µs</u>	<u>0.1287 in /µsec</u>																																																																																																																				
Zero:	Velocity:																																																																																																																				
<u>0.8 - 3.0 MHz</u>																																																																																																																					
Narrowband Filter:																																																																																																																					
<u>Auto</u>	<u>Fullwave</u>																																																																																																																				
Rep Rate:	Rectification:																																																																																																																				
<u>32.5 in.</u>	<u>Sq. / Med</u>																																																																																																																				
Range:	Pulsar/Energy																																																																																																																				
<u>400 Ohms</u>	<u>0%</u>																																																																																																																				
Damping:	Reject:																																																																																																																				
<u>1.0 MHz</u>	<u>P/E</u>																																																																																																																				
Frequency:	Mode:																																																																																																																				
<u>Off:</u>	<u>Off:</u>																																																																																																																				
DAC:	TVG:																																																																																																																				
<u>Off:</u>	<u>Off:</u>																																																																																																																				
CSC:	DGS:																																																																																																																				
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																		
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																		
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																		
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																		
Exam Data for Component: <u>N1B NOZ</u> <u>VESSEL-NOZZLE (RECIRCULATION)</u> Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;"><u>O.D. Plate</u></td> <td style="text-align: center;"><u>95° F</u></td> </tr> <tr> <td>Exam Surface:</td> <td>Component Temp.</td> </tr> </table> <table style="width:100%;"> <tr> <th>Examination Area</th> <th>Exam Angle</th> <th>Rotation Angle</th> <th>Wedge S/N</th> <th>Scan dB</th> <th>Recordable Indications</th> </tr> <tr> <td><u>0-4.0"</u></td> <td><u>70°</u></td> <td><u>±40°-75°</u></td> <td><u>N/A</u></td> <td><u>68</u></td> <td><u>NRI</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>			<u>O.D. Plate</u>	<u>95° F</u>	Exam Surface:	Component Temp.	Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications	<u>0-4.0"</u>	<u>70°</u>	<u>±40°-75°</u>	<u>N/A</u>	<u>68</u>	<u>NRI</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																	
<u>O.D. Plate</u>	<u>95° F</u>																																																																																																																				
Exam Surface:	Component Temp.																																																																																																																				
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications																																																																																																																
<u>0-4.0"</u>	<u>70°</u>	<u>±40°-75°</u>	<u>N/A</u>	<u>68</u>	<u>NRI</u>																																																																																																																
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for vessel to nozzle weld (V/N). Exams performed to maintain a 20-30% FSH clad roll. Scanned CW and CCW.																																																																																																																					
<table style="width:100%;"> <tr> <td style="width:33%; vertical-align: top;"> <u>JJ</u> <u>Jimmy Johnson</u> Initials: Examiner: </td> <td style="width:33%; vertical-align: top;"> <u>II</u> <u>3/22/2010</u> Level: Cal/Exam Date: </td> <td style="width:33%; vertical-align: top;"> See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____ </td> </tr> <tr> <td style="vertical-align: top;"> <u>Scott R Epichom</u> GE Reviewed By: </td> <td style="vertical-align: top;"> <u>III</u> <u>03/24/10</u> Level: Date: </td> <td style="vertical-align: top;"> See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____ </td> </tr> </table>			<u>JJ</u> <u>Jimmy Johnson</u> Initials: Examiner:	<u>II</u> <u>3/22/2010</u> Level: Cal/Exam Date:	See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____	<u>Scott R Epichom</u> GE Reviewed By:	<u>III</u> <u>03/24/10</u> Level: Date:	See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____																																																																																																													
<u>JJ</u> <u>Jimmy Johnson</u> Initials: Examiner:	<u>II</u> <u>3/22/2010</u> Level: Cal/Exam Date:	See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____																																																																																																																			
<u>Scott R Epichom</u> GE Reviewed By:	<u>III</u> <u>03/24/10</u> Level: Date:	See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____																																																																																																																			

 HITACHI	Ultrasonic Calibration and Examination Record RPV Components	
	Site/Unit: <u>Quad / 2</u> Outage: <u>RFO 20</u> Procedure: <u>GE-UT-300</u>	Data Report Number: <u>Q2R20-072</u> Data Sheet Number: <u>D-068</u> Ver.: <u>V10</u>

Calibration Block: <u>CAL-IIW2-045</u> <table style="width:100%;"> <tr> <td align="center"><u>CS</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>4.0"</u></td> </tr> <tr> <td align="center">Material</td> <td align="center">Size</td> <td align="center">Thickness</td> </tr> <tr> <td>Initial Cal: <u>0935</u></td> <td></td> <td>Exam Start: <u>1005</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>1207</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td align="center"><u>Ultragel II</u></td> <td align="center"><u>08125</u></td> </tr> <tr> <td>Final Cal: <u>1410</u></td> <td align="center">Couplant:</td> <td align="center">Batch</td> </tr> <tr> <td align="center"><u>269040</u></td> <td align="center"><u>72° F</u></td> <td align="center"><u>72° F</u></td> </tr> <tr> <td align="center">Thermometer</td> <td align="center">Initial Cal Temp.</td> <td align="center">Final Cal Temp.</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>SDH</td> <td><u>0.6"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>1.0</u></td> <td><u>0.6</u></td> <td><u>3.0</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> DAC 1X= <u>55.0</u> Sweep 0-10 = <u>2.0" DEPTH</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee	<u>CS</u>	<u>N/A</u>	<u>4.0"</u>	Material	Size	Thickness	Initial Cal: <u>0935</u>		Exam Start: <u>1005</u>	Cal Check: <u>N/A</u>		Exam End: <u>1207</u>	Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>08125</u>	Final Cal: <u>1410</u>	Couplant:	Batch	<u>269040</u>	<u>72° F</u>	<u>72° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp.	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.0</u>	<u>0.6</u>	<u>3.0</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Search Unit Data <table style="width:100%;"> <tr> <td align="center"><u>Sigma</u></td> <td align="center"><u>228C-06006</u></td> <td align="center"><u>2(L1"x.62") / Rect</u></td> </tr> <tr> <td align="center">Manufacturer:</td> <td align="center">Serial Number:</td> <td align="center">Size / Shape:</td> </tr> <tr> <td align="center"><u>0.7"</u></td> <td align="center"><u>60°</u></td> <td align="center"><u>60°</u></td> </tr> <tr> <td align="center">Incident Point:</td> <td align="center">Nominal Angle:</td> <td align="center">Measured Angle:</td> </tr> <tr> <td align="center"><u>3.0 MHz</u></td> <td align="center"><u>SDC-3</u></td> <td align="center"><u>RL</u></td> </tr> <tr> <td align="center">Frequency:</td> <td align="center">Model:</td> <td align="center">Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td align="center"><u>RG-174</u></td> <td align="center"><u>12'</u></td> <td align="center"><u>0</u></td> </tr> <tr> <td align="center">Cable Type:</td> <td align="center">Length:</td> <td align="center">Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td align="center"><u>Panametrics / Epoch 4</u></td> <td align="center"><u>031526804</u></td> </tr> <tr> <td align="center">Manufacturer/Model:</td> <td align="center">Serial Number:</td> </tr> <tr> <td align="center"><u>8.941 μs</u></td> <td align="center"><u>0.2334 in./μsec.</u></td> </tr> <tr> <td align="center">Delay/Zero:</td> <td align="center">Velocity:</td> </tr> <tr> <td align="center"><u>Auto</u></td> <td align="center"><u>Fullwave</u></td> </tr> <tr> <td align="center">Rep Rate:</td> <td align="center">Rectification:</td> </tr> <tr> <td align="center"><u>400 Ohms</u></td> <td align="center"><u>0%</u></td> </tr> <tr> <td align="center">Damping:</td> <td align="center">Reject:</td> </tr> <tr> <td align="center"><u>Off:</u></td> <td align="center"><u>Off:</u></td> </tr> <tr> <td align="center">DAC:</td> <td align="center">TVG:</td> </tr> <tr> <td align="center"><u>Off:</u></td> <td align="center"><u>Off:</u></td> </tr> <tr> <td align="center">CSC:</td> <td align="center">DGS:</td> </tr> <tr> <td align="center"><u>Off:</u></td> <td align="center"><u>Off:</u></td> </tr> </table>	<u>Sigma</u>	<u>228C-06006</u>	<u>2(L1"x.62") / Rect</u>	Manufacturer:	Serial Number:	Size / Shape:	<u>0.7"</u>	<u>60°</u>	<u>60°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>12'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panametrics / Epoch 4</u>	<u>031526804</u>	Manufacturer/Model:	Serial Number:	<u>8.941 μs</u>	<u>0.2334 in./μsec.</u>	Delay/Zero:	Velocity:	<u>Auto</u>	<u>Fullwave</u>	Rep Rate:	Rectification:	<u>400 Ohms</u>	<u>0%</u>	Damping:	Reject:	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	<u>Off:</u>	<u>Off:</u>	CSC:	DGS:	<u>Off:</u>	<u>Off:</u>
<u>CS</u>	<u>N/A</u>	<u>4.0"</u>																																																																																																																			
Material	Size	Thickness																																																																																																																			
Initial Cal: <u>0935</u>		Exam Start: <u>1005</u>																																																																																																																			
Cal Check: <u>N/A</u>		Exam End: <u>1207</u>																																																																																																																			
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>08125</u>																																																																																																																			
Final Cal: <u>1410</u>	Couplant:	Batch																																																																																																																			
<u>269040</u>	<u>72° F</u>	<u>72° F</u>																																																																																																																			
Thermometer	Initial Cal Temp.	Final Cal Temp.																																																																																																																			
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																															
SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.0</u>	<u>0.6</u>	<u>3.0</u>																																																																																																															
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																															
<u>Sigma</u>	<u>228C-06006</u>	<u>2(L1"x.62") / Rect</u>																																																																																																																			
Manufacturer:	Serial Number:	Size / Shape:																																																																																																																			
<u>0.7"</u>	<u>60°</u>	<u>60°</u>																																																																																																																			
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																			
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>																																																																																																																			
Frequency:	Model:	Mode:																																																																																																																			
<u>RG-174</u>	<u>12'</u>	<u>0</u>																																																																																																																			
Cable Type:	Length:	Connectors:																																																																																																																			
<u>Panametrics / Epoch 4</u>	<u>031526804</u>																																																																																																																				
Manufacturer/Model:	Serial Number:																																																																																																																				
<u>8.941 μs</u>	<u>0.2334 in./μsec.</u>																																																																																																																				
Delay/Zero:	Velocity:																																																																																																																				
<u>Auto</u>	<u>Fullwave</u>																																																																																																																				
Rep Rate:	Rectification:																																																																																																																				
<u>400 Ohms</u>	<u>0%</u>																																																																																																																				
Damping:	Reject:																																																																																																																				
<u>Off:</u>	<u>Off:</u>																																																																																																																				
DAC:	TVG:																																																																																																																				
<u>Off:</u>	<u>Off:</u>																																																																																																																				
CSC:	DGS:																																																																																																																				
<u>Off:</u>	<u>Off:</u>																																																																																																																				

Exam Data for Weld: <u>N1B NOZ</u> <u>VESSEL-NOZZLE (RECIRCULATION)</u> Configuration: <table style="width:100%;"> <tr> <td align="center"><u>PLATE</u></td> <td align="center"><u>95° F</u></td> </tr> <tr> <td align="center">Exam Surface:</td> <td align="center">Component Temperature</td> </tr> </table> <table style="width:100%;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td><u>360°</u></td> <td align="center"><u>I</u></td> <td align="center"><u>69.0</u></td> <td align="center"><u>NRI</u></td> <td align="center"><u>60°</u></td> </tr> <tr> <td><u>360°</u></td> <td align="center"><u>P</u></td> <td align="center"><u>69.0</u></td> <td align="center"><u>NRI</u></td> <td align="center"><u>60°</u></td> </tr> <tr> <td><u>N/A</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>N/A</u></td> <td align="center"><u>N/A</u></td> </tr> </table>	<u>PLATE</u>	<u>95° F</u>	Exam Surface:	Component Temperature	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>360°</u>	<u>I</u>	<u>69.0</u>	<u>NRI</u>	<u>60°</u>	<u>360°</u>	<u>P</u>	<u>69.0</u>	<u>NRI</u>	<u>60°</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th><u>N/A</u></th> <th><u>N/A</u></th> <th><u>N/A</u></th> </tr> <tr> <th>Amplitude</th> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <th>Gain (dB)</th> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <th>Sweep (SD)</th> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> Acceptable Linearity performed: <u>3/11/2010</u>	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>PLATE</u>	<u>95° F</u>																																													
Exam Surface:	Component Temperature																																													
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																										
<u>360°</u>	<u>I</u>	<u>69.0</u>	<u>NRI</u>	<u>60°</u>																																										
<u>360°</u>	<u>P</u>	<u>69.0</u>	<u>NRI</u>	<u>60°</u>																																										
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																										
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																										
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.
 Calibration for near surface examination.
 Exams performed a minimum of 14 dB above reference.

 Initials: Examiner	Level: <u>II</u> Cal/Exam Date: <u>3/22/2010</u>	See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____
Initials: Examiner GE Reviewed By:	Level: <u>III</u> Date: <u>03/24/10</u>	See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____

Page **4** of **11**

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components																																																																																																																											
Site/Unit: <u>Quad / 2</u> Outage: <u>RFO 20</u> Procedure: <u>GE-UT-300</u>		Data Report Number: <u>Q2R20-072</u> Linearity Sheet: <u>L-007</u> Data Sheet Number: <u>D-069</u> Ver.: <u>V10</u> DRR: <u>N/A</u>																																																																																																																											
Calibration Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>730"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>0940</u></td> <td></td> <td>Exam Start: <u>1005</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>1207</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultracel II</u></td> <td style="text-align: center;"><u>08125</u></td> </tr> <tr> <td>Final Cal: <u>1410</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>269040</u></td> <td style="text-align: center;"><u>72° F</u></td> <td style="text-align: center;"><u>72° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>D. NOTCH</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>11.9</u></td> <td><u>6.86</u></td> <td><u>6.9</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>N/A</td> <td><u>N/A</u></td> <td>1X</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> DAC 1X= <u>69.7</u> Sweep 0-10 = <u>10.0" DEPTH</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee		<u>CS</u> Material	<u>N/A</u> Size	<u>730"</u> Thickness	Initial Cal: <u>0940</u>		Exam Start: <u>1005</u>	Cal Check: <u>N/A</u>		Exam End: <u>1207</u>	Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>08125</u>	Final Cal: <u>1410</u>	Couplant:	Batch	<u>269040</u>	<u>72° F</u>	<u>72° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	D. NOTCH	<u>7.0"</u>	1X	<u>80%</u>	<u>11.9</u>	<u>6.86</u>	<u>6.9</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>Search Unit Data</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u></td> <td style="text-align: center;"><u>228C-06006</u></td> <td style="text-align: center;"><u>2(1.1"x.62") / Rect</u></td> </tr> <tr> <td>Manufacturer:</td> <td>Serial Number:</td> <td>Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td>Incident Point:</td> <td>Nominal Angle:</td> <td>Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u></td> <td style="text-align: center;"><u>SDC-3</u></td> <td style="text-align: center;"><u>RL</u></td> </tr> <tr> <td>Frequency:</td> <td>Model:</td> <td>Mode:</td> </tr> </table> <u>Search Unit Cable</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>12'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td>Cable Type:</td> <td>Length:</td> <td>Connectors:</td> </tr> </table> <u>Instrument Settings</u> <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031526804</u></td> </tr> <tr> <td colspan="2">Manufacturer/Model:</td> <td>Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>8.941 μs</u></td> <td style="text-align: center;"><u>0.2334 in./μsec.</u></td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u></td> </tr> <tr> <td>Delay/Zero:</td> <td>Velocity:</td> <td>Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> <td style="text-align: center;"><u>20.0 in.</u></td> </tr> <tr> <td>Rep Rate:</td> <td>Rectification:</td> <td>Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> <td style="text-align: center;"><u>3.03 MHz</u></td> </tr> <tr> <td>Damping:</td> <td>Reject:</td> <td>Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td>DAC:</td> <td>TVG:</td> <td>CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td></td> <td></td> <td>DGS:</td> </tr> </table>	<u>Sigma</u>	<u>228C-06006</u>	<u>2(1.1"x.62") / Rect</u>	Manufacturer:	Serial Number:	Size / Shape:	<u>0.7</u>	<u>60°</u>	<u>60°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>12'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panametrics / Epoch 4</u>		<u>031526804</u>	Manufacturer/Model:		Serial Number:	<u>8.941 μs</u>	<u>0.2334 in./μsec.</u>	<u>0.8 - 3.0 MHz</u>	Delay/Zero:	Velocity:	Narrowband Filter:	<u>Auto</u>	<u>Fullwave</u>	<u>20.0 in.</u>	Rep Rate:	Rectification:	Range:	<u>400 Ohms</u>	<u>0%</u>	<u>3.03 MHz</u>	Damping:	Reject:	Frequency:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	CSC:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>			DGS:
<u>CS</u> Material	<u>N/A</u> Size	<u>730"</u> Thickness																																																																																																																											
Initial Cal: <u>0940</u>		Exam Start: <u>1005</u>																																																																																																																											
Cal Check: <u>N/A</u>		Exam End: <u>1207</u>																																																																																																																											
Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>08125</u>																																																																																																																											
Final Cal: <u>1410</u>	Couplant:	Batch																																																																																																																											
<u>269040</u>	<u>72° F</u>	<u>72° F</u>																																																																																																																											
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																											
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																																							
D. NOTCH	<u>7.0"</u>	1X	<u>80%</u>	<u>11.9</u>	<u>6.86</u>	<u>6.9</u>																																																																																																																							
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																							
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																							
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																							
N/A	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																							
<u>Sigma</u>	<u>228C-06006</u>	<u>2(1.1"x.62") / Rect</u>																																																																																																																											
Manufacturer:	Serial Number:	Size / Shape:																																																																																																																											
<u>0.7</u>	<u>60°</u>	<u>60°</u>																																																																																																																											
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																											
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>																																																																																																																											
Frequency:	Model:	Mode:																																																																																																																											
<u>RG-174</u>	<u>12'</u>	<u>0</u>																																																																																																																											
Cable Type:	Length:	Connectors:																																																																																																																											
<u>Panametrics / Epoch 4</u>		<u>031526804</u>																																																																																																																											
Manufacturer/Model:		Serial Number:																																																																																																																											
<u>8.941 μs</u>	<u>0.2334 in./μsec.</u>	<u>0.8 - 3.0 MHz</u>																																																																																																																											
Delay/Zero:	Velocity:	Narrowband Filter:																																																																																																																											
<u>Auto</u>	<u>Fullwave</u>	<u>20.0 in.</u>																																																																																																																											
Rep Rate:	Rectification:	Range:																																																																																																																											
<u>400 Ohms</u>	<u>0%</u>	<u>3.03 MHz</u>																																																																																																																											
Damping:	Reject:	Frequency:																																																																																																																											
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																											
DAC:	TVG:	CSC:																																																																																																																											
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																											
		DGS:																																																																																																																											
Exam Data for Weld: <u>N1B NOZ</u> <u>VESSEL-NOZZLE (RECIRCULATION)</u> Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;"><u>PLATE</u></td> <td style="text-align: center;"><u>95° F</u></td> </tr> <tr> <td>Exam Surface:</td> <td>Component Temperature</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td><u>360°</u></td> <td><u>I</u></td> <td><u>75.7</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> <tr> <td><u>360°</u></td> <td><u>P</u></td> <td><u>75.7</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>		<u>PLATE</u>	<u>95° F</u>	Exam Surface:	Component Temperature	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>360°</u>	<u>I</u>	<u>75.7</u>	<u>NRI</u>	<u>60°</u>	<u>360°</u>	<u>P</u>	<u>75.7</u>	<u>NRI</u>	<u>60°</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>Calibration Verification</u> Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table> Acceptable Linearity performed : <u>3/11/2010</u>	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																														
<u>PLATE</u>	<u>95° F</u>																																																																																																																												
Exam Surface:	Component Temperature																																																																																																																												
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																																																																																																									
<u>360°</u>	<u>I</u>	<u>75.7</u>	<u>NRI</u>	<u>60°</u>																																																																																																																									
<u>360°</u>	<u>P</u>	<u>75.7</u>	<u>NRI</u>	<u>60°</u>																																																																																																																									
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																									
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																									
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																										
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																										
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																										
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																										
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for full volume examination. Exams performed to maintain a 10 - 20% clad roll.																																																																																																																													
<table style="width:100%;"> <tr> <td style="width:33%; vertical-align: top;"> <u>David Hancock</u> Initials: Examiner Level: <u>II</u> Cal/Exam Date: <u>3/22/2010</u> </td> <td style="width:33%; vertical-align: top;"> See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____ See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____ </td> <td style="width:33%; vertical-align: top;"> Initials: Examiner Level: <u>N/A</u> <u>Scott R. Erickson</u> GE Reviewed By: _____ Level: <u>III</u> Date: <u>03/24/10</u> </td> </tr> </table>			 <u>David Hancock</u> Initials: Examiner Level: <u>II</u> Cal/Exam Date: <u>3/22/2010</u>	See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____ See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____	Initials: Examiner Level: <u>N/A</u> <u>Scott R. Erickson</u> GE Reviewed By: _____ Level: <u>III</u> Date: <u>03/24/10</u>																																																																																																																								
 <u>David Hancock</u> Initials: Examiner Level: <u>II</u> Cal/Exam Date: <u>3/22/2010</u>	See Summary Sheet for Signature Utility Reviewed By: _____ Date: _____ See Summary Sheet for Signature ANII Reviewed By: _____ Date: _____	Initials: Examiner Level: <u>N/A</u> <u>Scott R. Erickson</u> GE Reviewed By: _____ Level: <u>III</u> Date: <u>03/24/10</u>																																																																																																																											

NAB 3/26/10

Q2R20 - 072



HITACHI

Reactor Pressure Vessel Coverage Calculation Sheet

Quad Cities Unit 2 / Q2R20
N1(Noz-Sh)
Spring / 2010

Weld Length = 360. Exam Volume = 79.2		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° T-Scan (S4 UC)	A	30.2	8.7	11.0%	360	5.5%
45° T-Scan (S6 FV)	A	40.3	25.6	32.3%	360	16.2%
70° T-Scan (S6 NS)	A	8.7	1.1	1.4%	360	0.7%
IRS P-Scan (S4 UC)	A	30.2	8.7	11.0%	360	5.5%
45° P-Scan (S6 FV)	A	40.3	11.2	14.1%	360	7.1%
70° P-Scan (S6 NS)	A	8.7	0.7	0.9%	360	0.4%
60° T-Scan (S4 UC)						
45° T-Scan (S6 FV)						
70° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
45° P-Scan (S6 FV)						
70° P-Scan (S6 NS)						
60° T-Scan (S4 UC)						
45° T-Scan (S6 FV)						
70° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
45° P-Scan (S6 FV)						
70° P-Scan (S6 NS)						

% Total Composite Coverage = 35.4%

Rev. 0 9/23/05


Comments: A - Manual UT scanning was restricted due to the nozzle configuration.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in degrees.

Pg 6 of 11

Quad Cities N1 - Recirculation Outlet

Quad Cities Unit 2, 2010
NAB 3/24/10



SQC 3/24/10
4048
Pg 70 of 11

02R20-072

Quad Cities N1 - Recirculation Outlet

60°T-scan proposed scan area

17.1"

7.3"

60°T

60°T

60°T

02R20-072

Quad Cities Unit 2, 2010

NAE 2.1.10


NS

8 OF 11

SL 2/24/10

6-01-0

Quad Cities N1 - Recirculation Outlet



Q2P20-072

Quad Cities N1 - Recirculation Outlet

NA8312v1w

Quad Cities Unit 2, 2010

60° Nozzle to Vessel scan proposed exam area

4.5"
60°N/V
60°N/V

40° to 80° Skew

SPC 3/24/10
7448
PR 100411

02R20-072

Q2R20-072

Manual Detection

Nir_PDI Qc2_Rev 4.XLS

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON				DATE 02/21/2010		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET								
N/V Weld (M)	PLATE	0 - 4.5"	60.0°	-	±40° - 80°	FLAT	14.0"	1 MHz
N/V Weld (M)	PLATE	0 - 4.0"	70.0°	-	±40° - 75°	FLAT	25.3"	1 MHz
Zone 1 (M)	ODBR	20° - 45°	35.0°	-	90.0°	5.5"	20.7"	1 MHz
Zone 2a (M)	ODBR	45° - 90°	60.0°	-	35.0°	5.5"	20.4"	1 MHz
SILC N10								
N/V Weld (M)	PLATE	4.5" - 9.0"	45.0°	-	± 17° - 51°	FLAT	9.1"	1 MHz
NOTES:					(M)	MANUAL		
					100% (100%)	WEDGE / (FIXTURE) ROTATION ANGLE		
Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 577-3770								

W-021, W-022
W-023, W-024

Chris Minor
SME Review / Date

3-9-10
Site Review / Date

N/A B 3/26/10

P8 110FH

	HITACHI	EXAMINATION SUMMARY SHEET	Report No: 2QR19-093	
Site: Quad Cities Component ID: N5A NOZ				
Outage: Q2R19 VESSEL-NOZZLE (CORE SPRAY)				
System: RPV ASME Cat: B-D ASME Item B3.90 Aug Req N/A				

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Exam / Oper. Personnel	Cert Level	Date
60° RL	D-087	N/A	GE-UT-300 Ver/Rev 10	CAL-IIW2-045	Edward Fish	II	3/8/2008
60° RL	D-088	N/A	GE-UT-300 Ver/Rev 10	99978AQC	Edward Fish	II	3/8/2008
60° Shear	D-089	N/A	GE-UT-311 Ver/Rev 15	99978AQC	Mark Hilborn	III	3/8/2008

Examination Results:

During the manual ultrasonic examination of the above referenced nozzle to vessel weld, no recordable indications were detected utilizing the above procedure. The inner 15%T examination volume as defined by 10 CFR 50 (Supplement 7) searching for flaws oriented perpendicular to the weld axis was performed per procedure GE-UT-311 V15, utilizing search units validated by modeling.

This examination is acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Manual examinations were restricted due to the nozzle configuration and insulation support bracket.

43.1% code coverage was achieved.

Previous examination results supplied by customer for review from ISI Program documents? ☒ Yes ☐ Change

These examinations were performed under Work Order: 1025573 ☐ No ☒ No Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:				RWP: 8603
Prepared By: <u>John C. Dierck</u>	Level: <u>III</u>	Date: <u>3/11/08</u>	Utility Review: <u>Lamin Y. Hase</u>	Date: <u>3/15/08</u>
ANII Review: <u>Jeff Ameyden</u>				Date: <u>3/19/08</u>
				Page <u>1</u> of <u>9</u>

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components		
Site/Unit: <u>Quad Cities / 2</u>		Data Report Number: <u>2QR19-093</u>		Linearity Sheet: <u>L-005</u>
Outage: <u>Q2R19</u>		Data Sheet Number: <u>D-087</u>		
Procedure: <u>GE-UT-300</u>		Rev.: <u>10</u>	DRR: <u>N/A</u>	

Calibration Block: <u>CAL-IIW2-045</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>4.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>2227</u></td> <td></td> <td>Exam Start: <u>0255</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>0415</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>UltraGel II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>0427</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255223</u></td> <td style="text-align: center;"><u>85° F</u></td> <td style="text-align: center;"><u>85° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>SDH</td> <td><u>.6"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>1.179"</u></td> <td><u>0.681"</u></td> <td><u>3.5</u></td> </tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> </table> DAC 1X= <u>53.4dB</u> Sweep 0-10 = <u>2.0" Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee	<u>CS</u> Material	<u>N/A</u> Size	<u>4.0"</u> Thickness	Initial Cal: <u>2227</u>		Exam Start: <u>0255</u>	Cal Check: <u>N/A</u>		Exam End: <u>0415</u>	Cal Check: <u>N/A</u>	<u>UltraGel II</u>	<u>07225</u>	Final Cal: <u>0427</u>	Couplant:	Batch	<u>255223</u>	<u>85° F</u>	<u>85° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	SDH	<u>.6"</u>	1X	<u>80%</u>	<u>1.179"</u>	<u>0.681"</u>	<u>3.5</u>			1X							1X							1X							1X					<u>Search Unit Data</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u> Manufacturer:</td> <td style="text-align: center;"><u>22BC-06006</u> Serial Number:</td> <td style="text-align: center;"><u>20.1"X.62"/ Rect.</u> Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7"</u> Incident Point:</td> <td style="text-align: center;"><u>60°</u> Nominal Angle:</td> <td style="text-align: center;"><u>60°</u> Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>SDC-3</u> Model:</td> <td style="text-align: center;"><u>RL</u> Mode:</td> </tr> </table> <u>Search Unit Cable</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>12'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> <u>Instrument Settings</u> <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u> Manufacturer/Model:</td> <td style="text-align: center;"><u>031574912</u> Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>6.645 μs</u> Delay/Zero:</td> <td style="text-align: center;"><u>0.2120 in./μsec.</u> Velocity:</td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u> Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u> Rep Rate:</td> <td style="text-align: center;"><u>Fullwave</u> Rectification:</td> <td style="text-align: center;"><u>4.0 in.</u> Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u> Damping:</td> <td style="text-align: center;"><u>0%</u> Reject:</td> <td style="text-align: center;"><u>3.03 MHz</u> Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> DAC:</td> <td style="text-align: center;"><u>Off:</u> TVG:</td> <td style="text-align: center;"><u>Off:</u> CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Sq. / Med</u> Pulser:</td> <td style="text-align: center;"><u>Dual</u> Mode:</td> <td style="text-align: center;"><u>Off:</u> DGS:</td> </tr> </table>	<u>Sigma</u> Manufacturer:	<u>22BC-06006</u> Serial Number:	<u>20.1"X.62"/ Rect.</u> Size / Shape:	<u>0.7"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:	<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:	<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u> Manufacturer/Model:		<u>031574912</u> Serial Number:	<u>6.645 μs</u> Delay/Zero:	<u>0.2120 in./μsec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>4.0 in.</u> Range:	<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:	<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:	<u>Sq. / Med</u> Pulser:	<u>Dual</u> Mode:	<u>Off:</u> DGS:
<u>CS</u> Material	<u>N/A</u> Size	<u>4.0"</u> Thickness																																																																																												
Initial Cal: <u>2227</u>		Exam Start: <u>0255</u>																																																																																												
Cal Check: <u>N/A</u>		Exam End: <u>0415</u>																																																																																												
Cal Check: <u>N/A</u>	<u>UltraGel II</u>	<u>07225</u>																																																																																												
Final Cal: <u>0427</u>	Couplant:	Batch																																																																																												
<u>255223</u>	<u>85° F</u>	<u>85° F</u>																																																																																												
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																												
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																								
SDH	<u>.6"</u>	1X	<u>80%</u>	<u>1.179"</u>	<u>0.681"</u>	<u>3.5</u>																																																																																								
		1X																																																																																												
		1X																																																																																												
		1X																																																																																												
		1X																																																																																												
<u>Sigma</u> Manufacturer:	<u>22BC-06006</u> Serial Number:	<u>20.1"X.62"/ Rect.</u> Size / Shape:																																																																																												
<u>0.7"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:																																																																																												
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:																																																																																												
<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:																																																																																												
<u>Panametrics / Epoch 4</u> Manufacturer/Model:		<u>031574912</u> Serial Number:																																																																																												
<u>6.645 μs</u> Delay/Zero:	<u>0.2120 in./μsec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:																																																																																												
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>4.0 in.</u> Range:																																																																																												
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:																																																																																												
<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:																																																																																												
<u>Sq. / Med</u> Pulser:	<u>Dual</u> Mode:	<u>Off:</u> DGS:																																																																																												

Exam Data for Weld: <u>NSA NOZ</u>				
<u>VESSEL-NOZZLE (CORE SPRAY)</u>				
Configuration:				
<u>OD Plate</u> Exam Surface:		<u>105° F</u> Component Temperature		
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>67.4</u>	<u>NRI</u>	<u>60°</u>
<u>Plate cw/ccw</u>	<u>P</u>	<u>67.4</u>	<u>NRI</u>	<u>60°</u>

<u>Calibration Verification</u>			
Field Simulator Block S/N: <u>N/A</u>			
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Acceptable Linearity performed: <u>2/21/2008</u>			

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.
Calibration for near surface examination.
Exams performed a minimum of 14 dB above reference.
45° Shear not used.

<u>EWF</u> <u>Edward Fish</u> Initials: Examiner	<u>II</u> <u>3/8/2008</u> Level: Cal/Exam Date:	<u>John L. Deel</u> <u>3/15/08</u> Utility Reviewed By: Date:
<u>N/A</u> Initials: Examiner	<u>N/A</u> Level:	<u>Jeff Snyder</u> <u>3/17/08</u> ANII Reviewed By: Date:
<u>John C. Deel</u> Reviewed By:	<u>III</u> <u>3/13/08</u> Level: Date:	

Page 2 of 9

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components			
Site/Unit: <u>Quad Cities / 2</u>		Data Report Number: <u>2QR19-093</u>		Linearity Sheet: <u>L-005</u>	
Outage: <u>Q2R19</u>		Data Sheet Number: <u>D-088</u>			
Procedure: <u>GE-UT-300</u>		Rev.: <u>10</u>		DRR: <u>N/A</u>	

Calibration Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>2226</u></td> <td></td> <td>Exam Start: <u>0255</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>0415</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultragel II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>0426</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255223</u></td> <td style="text-align: center;"><u>85° F</u></td> <td style="text-align: center;"><u>85° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>11.99"</u></td> <td><u>6.92"</u></td> <td><u>6.9</u></td> </tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> </tbody> </table> DAC 1X= <u>69.5dB</u> Sweep 0-10 = <u>10.0" Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee				<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>2226</u>		Exam Start: <u>0255</u>	Cal Check: <u>N/A</u>		Exam End: <u>0415</u>	Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>07225</u>	Final Cal: <u>0426</u>	Couplant:	Batch	<u>255223</u>	<u>85° F</u>	<u>85° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>11.99"</u>	<u>6.92"</u>	<u>6.9</u>			1X							1X							1X							1X					Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u> Manufacturer:</td> <td style="text-align: center;"><u>22BC-06006</u> Serial Number:</td> <td style="text-align: center;"><u>2(1.1"X.62") / Rect.</u> Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7"</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td>Incident Point:</td> <td>Nominal Angle:</td> <td>Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u></td> <td style="text-align: center;"><u>SDC-3</u></td> <td style="text-align: center;"><u>RL</u></td> </tr> <tr> <td>Frequency:</td> <td>Model:</td> <td>Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>12'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td>Cable Type:</td> <td>Length:</td> <td>Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031574912</u></td> </tr> <tr> <td colspan="2">Manufacturer/Model:</td> <td>Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>6.645 μs</u></td> <td style="text-align: center;"><u>0.2119 in./μsec.</u></td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u></td> </tr> <tr> <td>Delay/Zero:</td> <td>Velocity:</td> <td>Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> <td style="text-align: center;"><u>20.0 in.</u></td> </tr> <tr> <td>Rep Rate:</td> <td>Rectification:</td> <td>Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> <td style="text-align: center;"><u>3.03 MHz</u></td> </tr> <tr> <td>Damping:</td> <td>Reject:</td> <td>Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td>DAC:</td> <td>TVG:</td> <td>CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td></td> <td>DGS:</td> <td></td> </tr> </table>		<u>Sigma</u> Manufacturer:	<u>22BC-06006</u> Serial Number:	<u>2(1.1"X.62") / Rect.</u> Size / Shape:	<u>0.7"</u>	<u>60°</u>	<u>60°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>12'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panametrics / Epoch 4</u>		<u>031574912</u>	Manufacturer/Model:		Serial Number:	<u>6.645 μs</u>	<u>0.2119 in./μsec.</u>	<u>0.8 - 3.0 MHz</u>	Delay/Zero:	Velocity:	Narrowband Filter:	<u>Auto</u>	<u>Fullwave</u>	<u>20.0 in.</u>	Rep Rate:	Rectification:	Range:	<u>400 Ohms</u>	<u>0%</u>	<u>3.03 MHz</u>	Damping:	Reject:	Frequency:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	CSC:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>		DGS:	
<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																																																											
Initial Cal: <u>2226</u>		Exam Start: <u>0255</u>																																																																																																																											
Cal Check: <u>N/A</u>		Exam End: <u>0415</u>																																																																																																																											
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>07225</u>																																																																																																																											
Final Cal: <u>0426</u>	Couplant:	Batch																																																																																																																											
<u>255223</u>	<u>85° F</u>	<u>85° F</u>																																																																																																																											
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																											
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																																							
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>11.99"</u>	<u>6.92"</u>	<u>6.9</u>																																																																																																																							
		1X																																																																																																																											
		1X																																																																																																																											
		1X																																																																																																																											
		1X																																																																																																																											
<u>Sigma</u> Manufacturer:	<u>22BC-06006</u> Serial Number:	<u>2(1.1"X.62") / Rect.</u> Size / Shape:																																																																																																																											
<u>0.7"</u>	<u>60°</u>	<u>60°</u>																																																																																																																											
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																											
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>RL</u>																																																																																																																											
Frequency:	Model:	Mode:																																																																																																																											
<u>RG-174</u>	<u>12'</u>	<u>0</u>																																																																																																																											
Cable Type:	Length:	Connectors:																																																																																																																											
<u>Panametrics / Epoch 4</u>		<u>031574912</u>																																																																																																																											
Manufacturer/Model:		Serial Number:																																																																																																																											
<u>6.645 μs</u>	<u>0.2119 in./μsec.</u>	<u>0.8 - 3.0 MHz</u>																																																																																																																											
Delay/Zero:	Velocity:	Narrowband Filter:																																																																																																																											
<u>Auto</u>	<u>Fullwave</u>	<u>20.0 in.</u>																																																																																																																											
Rep Rate:	Rectification:	Range:																																																																																																																											
<u>400 Ohms</u>	<u>0%</u>	<u>3.03 MHz</u>																																																																																																																											
Damping:	Reject:	Frequency:																																																																																																																											
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																											
DAC:	TVG:	CSC:																																																																																																																											
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																											
	DGS:																																																																																																																												

Exam Data for Weld: <u>N5A NOZ</u> <u>VESSEL-NOZZLE (CORE SPRAY)</u> Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;"><u>OD Plate</u></td> <td style="text-align: center;"><u>105° F</u></td> </tr> <tr> <td>Exam Surface:</td> <td>Component Temperature</td> </tr> </table> <table style="width:100%;"> <tr> <td style="text-align: center;">Weld Examination Area:</td> <td style="text-align: center;">Exam Access</td> <td style="text-align: center;">Scan dB</td> <td style="text-align: center;">Recordable Indications</td> <td style="text-align: center;">Exam Angle</td> </tr> <tr> <td style="text-align: center;"><u>Plate</u></td> <td style="text-align: center;"><u>I</u></td> <td style="text-align: center;"><u>69.5</u></td> <td style="text-align: center;"><u>NRI</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td style="text-align: center;"><u>Plate cw/ccw</u></td> <td style="text-align: center;"><u>P</u></td> <td style="text-align: center;"><u>69.5</u></td> <td style="text-align: center;"><u>NRI</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> </table>					<u>OD Plate</u>	<u>105° F</u>	Exam Surface:	Component Temperature	Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>Plate</u>	<u>I</u>	<u>69.5</u>	<u>NRI</u>	<u>60°</u>	<u>Plate cw/ccw</u>	<u>P</u>	<u>69.5</u>	<u>NRI</u>	<u>60°</u>	Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">Reflector</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> <tr> <td style="text-align: center;">Amplitude</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> <tr> <td style="text-align: center;">Gain (dB)</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> <tr> <td style="text-align: center;">Sweep (SD)</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> </table> Acceptable Linearity performed : <u>2/21/2008</u>		Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>OD Plate</u>	<u>105° F</u>																																								
Exam Surface:	Component Temperature																																								
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																					
<u>Plate</u>	<u>I</u>	<u>69.5</u>	<u>NRI</u>	<u>60°</u>																																					
<u>Plate cw/ccw</u>	<u>P</u>	<u>69.5</u>	<u>NRI</u>	<u>60°</u>																																					
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																						
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																						
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																						
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																						

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.
 Calibration for full volume examination.
 Exams performed to maintain a 10 - 20% clad roll.
 Scanning limited due to insulation support.
 45° Shear not used.

<u>EF</u> Edward Fish Initials: Examiner Level: <u>N/A</u> Date: <u>3/8/2008</u>	<u>III</u> Level: <u>III</u> Date: <u>3/13/08</u>	<u>Sheel</u> Utility Reviewed By: Date: <u>3-15-08</u>	
<u>h.c. [signature]</u> GE Reviewed By: Level: <u>III</u> Date: <u>3/13/08</u>	<u>Jeff [signature]</u> ANII Reviewed By: Date: <u>3/19/08</u>		

Page 3 of 9


	HITACHI	Ultrasonic Calibration and Examination Record Inner Radius Examinations																																																																																						
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-311</u>		Data Report Number: <u>20R19-093</u> Linearity Sheet: <u>L-006</u> Data Sheet Number: <u>D-089</u> Rev: <u>15</u> DRR: <u>N/A</u>																																																																																						
Calibration Data for Block: <u>99978AQC</u> <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>2225</u></td> <td></td> <td>Exam Start: <u>0255</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>0415</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultrage II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>0435</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255223</u></td> <td style="text-align: center;"><u>85° F</u></td> <td style="text-align: center;"><u>85° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp.</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Side</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>11.95"</u></td> <td><u>13.8"</u></td> <td><u>8.1</u></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </table> DAC @ 1X= <u>48.1dB</u> Sweep 0-10 = <u>17.0'</u> <u>Metal Path</u> Acceptable Linearity performed : <u>2/21/2008</u>		<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>2225</u>		Exam Start: <u>0255</u>	Cal Check: <u>N/A</u>		Exam End: <u>0415</u>	Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>07225</u>	Final Cal: <u>0435</u>	Couplant:	Batch	<u>255223</u>	<u>85° F</u>	<u>85° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp.	Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>11.95"</u>	<u>13.8"</u>	<u>8.1</u>			1X					Search Unit Data <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>KBA</u> Manufacturer:</td> <td style="text-align: center;"><u>01FRPD</u> Serial No.:</td> <td style="text-align: center;"><u>50"x1"/Rect.</u> Size/Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7 in.</u> Incident Point:</td> <td style="text-align: center;"><u>60°</u> Nominal Angle:</td> <td style="text-align: center;"><u>60°</u> Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>113-891-600</u> Model:</td> <td style="text-align: center;"><u>Shear</u> Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>9'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>Panametrics / Epoch 4</u> Manufacturer/Model:</td> <td style="text-align: center;"><u>031536006</u> Serial No.:</td> </tr> <tr> <td style="text-align: center;"><u>15.57 µs</u> Zero:</td> <td style="text-align: center;"><u>0.1291 in /µsec</u> Velocity:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u> Rep Rate:</td> <td style="text-align: center;"><u>Fullwave</u> Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u> Damping:</td> <td style="text-align: center;"><u>0%</u> Reject:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> DAC:</td> <td style="text-align: center;"><u>Off:</u> TVG:</td> </tr> <tr> <td style="text-align: center;"><u>17.0 in.</u> Range:</td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u> Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Sq. / Med</u> Pulser/Energy</td> <td style="text-align: center;"><u>1.0 MHz</u> Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>P/E</u> Mode:</td> <td style="text-align: center;"><u>Off:</u> DGS:</td> </tr> </table> Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>	<u>KBA</u> Manufacturer:	<u>01FRPD</u> Serial No.:	<u>50"x1"/Rect.</u> Size/Shape:	<u>0.7 in.</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:	<u>1.0 MHz</u> Frequency:	<u>113-891-600</u> Model:	<u>Shear</u> Mode:	<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031536006</u> Serial No.:	<u>15.57 µs</u> Zero:	<u>0.1291 in /µsec</u> Velocity:	<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>17.0 in.</u> Range:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	<u>Sq. / Med</u> Pulser/Energy	<u>1.0 MHz</u> Frequency:	<u>P/E</u> Mode:	<u>Off:</u> DGS:	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																						
Initial Cal: <u>2225</u>		Exam Start: <u>0255</u>																																																																																						
Cal Check: <u>N/A</u>		Exam End: <u>0415</u>																																																																																						
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>07225</u>																																																																																						
Final Cal: <u>0435</u>	Couplant:	Batch																																																																																						
<u>255223</u>	<u>85° F</u>	<u>85° F</u>																																																																																						
Thermometer	Initial Cal Temp.	Final Cal Temp.																																																																																						
Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																		
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>11.95"</u>	<u>13.8"</u>	<u>8.1</u>																																																																																		
		1X																																																																																						
<u>KBA</u> Manufacturer:	<u>01FRPD</u> Serial No.:	<u>50"x1"/Rect.</u> Size/Shape:																																																																																						
<u>0.7 in.</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:																																																																																						
<u>1.0 MHz</u> Frequency:	<u>113-891-600</u> Model:	<u>Shear</u> Mode:																																																																																						
<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:																																																																																						
<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031536006</u> Serial No.:																																																																																							
<u>15.57 µs</u> Zero:	<u>0.1291 in /µsec</u> Velocity:																																																																																							
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:																																																																																							
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:																																																																																							
<u>Off:</u> DAC:	<u>Off:</u> TVG:																																																																																							
<u>17.0 in.</u> Range:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:																																																																																							
<u>Sq. / Med</u> Pulser/Energy	<u>1.0 MHz</u> Frequency:																																																																																							
<u>P/E</u> Mode:	<u>Off:</u> DGS:																																																																																							
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																					
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																					
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																					
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																					
Exam Data for Component: <u>NSA NOZ</u> <u>VESSEL-NOZZLE (CORE SPRAY)</u> Configuration: <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>Plate</u> Exam Surface:</td> <td style="text-align: center;"><u>105° F</u> Component Temp.</td> </tr> </table> <table style="width:100%; border-collapse: collapse;"> <tr> <th>Examination Area</th> <th>Exam Angle</th> <th>Rotation Angle</th> <th>Wedge S/N</th> <th>Scan dB</th> <th>Recordable Indications</th> </tr> <tr> <td><u>0-7.0"</u></td> <td><u>60°</u></td> <td><u>±55°</u></td> <td><u>N/A</u></td> <td><u>66.7</u></td> <td><u>NRI</u></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>			<u>Plate</u> Exam Surface:	<u>105° F</u> Component Temp.	Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications	<u>0-7.0"</u>	<u>60°</u>	<u>±55°</u>	<u>N/A</u>	<u>66.7</u>	<u>NRI</u>																																																																								
<u>Plate</u> Exam Surface:	<u>105° F</u> Component Temp.																																																																																							
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications																																																																																			
<u>0-7.0"</u>	<u>60°</u>	<u>±55°</u>	<u>N/A</u>	<u>66.7</u>	<u>NRI</u>																																																																																			
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Exams performed to maintain a 20 - 30% FSH clad roll. Scanned CW and CCW. Calibration for nozzle to vessel weld (N/V).																																																																																								
<table style="width:100%; border: none;"> <tr> <td style="width:20%;"><u>Mark Hilborn</u> Initials: Examiner:</td> <td style="width:10%;"><u>III</u> Level:</td> <td style="width:20%;"><u>3/8/2008</u> Cal/Exam Date:</td> <td style="width:20%;"><u>[Signature]</u> Utility Reviewed By:</td> <td style="width:20%;"><u>3-15-08</u> Date:</td> </tr> <tr> <td><u>[Signature]</u> GE Reviewed By:</td> <td><u>III</u> Level:</td> <td><u>3/13/08</u> Date:</td> <td><u>[Signature]</u> ANII Reviewed By:</td> <td><u>3/19/08</u> Date:</td> </tr> </table>			<u>Mark Hilborn</u> Initials: Examiner:	<u>III</u> Level:	<u>3/8/2008</u> Cal/Exam Date:	<u>[Signature]</u> Utility Reviewed By:	<u>3-15-08</u> Date:	<u>[Signature]</u> GE Reviewed By:	<u>III</u> Level:	<u>3/13/08</u> Date:	<u>[Signature]</u> ANII Reviewed By:	<u>3/19/08</u> Date:																																																																												
<u>Mark Hilborn</u> Initials: Examiner:	<u>III</u> Level:	<u>3/8/2008</u> Cal/Exam Date:	<u>[Signature]</u> Utility Reviewed By:	<u>3-15-08</u> Date:																																																																																				
<u>[Signature]</u> GE Reviewed By:	<u>III</u> Level:	<u>3/13/08</u> Date:	<u>[Signature]</u> ANII Reviewed By:	<u>3/19/08</u> Date:																																																																																				

Quad Cities Unit-2 N5 - Core Spray

60° NS Exam Volume = 30.6 Sq. In.
60° FV S6 Exam Volume = 43.6 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 9.3 Sq. In.

60° NS T-Scan achieved = 1.8 Sq. In.
60° FV S6 T-Scan achieved = 31.5 Sq. In.
60° FV S4 T-Scan achieved = 9.3 Sq. In.

60° NS P-Scan achieved = 2.1 Sq. In.
60° FV S6 P-Scan achieved = 19.1 Sq. In.
Inner 15%T IRS-Scan achieved = 9.3 Sq. In. (By modeling.)



Quad Cities Unit-2, 2008


Page 5 of 9

REPORT NO. ZCR219-093

Quad Cities Unit-2 N5 - Core Spray

60° NS Exam Volume = 30.6 Sq. In.
60° FV S6 Exam Volume = 43.6 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 9.3 Sq. In.

60° FV S6 T-Scan achieved = 29.2 Sq. In.
60° FV S4 T-Scan achieved = 5.7 Sq. In.




Quad Cities Unit-2, 2008

Page 4 of 9

REPORT NO. ZQR14-093

Quad Cities Unit 2 N5A Core Spray



REPORT NO. 24219-093

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS									
PLANT		Quad 2							
PREPARED BY		S.C. MORTENSON				DATE		02/25/08	
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ	
MAIN STEAM									
N/V Weld (M)	PLATE	0 - 4.0"	60.0°	-	± 25° - 70°	FLAT	14.0"	1 MHz	
N/V Weld/Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 46°	FLAT	25.3"	1 MHz	
Zone 2a (M)	ODBR	60° - 90°	66.4°	-	24.1°	4.0"	16.3"	1 MHz	
CORE SPRAY									
N/V Weld/Zone 1 (M)	PLATE	0 - 7.0"	60.0°	-	± 55°	FLAT	14.0"	1 MHz	
Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 25°	FLAT	19.6"	1 MHz	
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	10.6"	1 MHz	
CRD									
N/V Weld (M)	PLATE	0 - 6.5"	45°	-	± 20.0° - 60.0°	FLAT	9.3"	1 MHz	
Zone 1 (M)	PLATE	0 - 7.5"	60.0°	-	± 15°	FLAT	13.9"	1 MHz	
Zone 2A (M)	PLATE	0 - 11.0"	70.0°	-	± 15°	FLAT	17.2"	1 MHz	
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	3.6"	1 MHz	
JET PUMP INSTRUMENT									
N/V Weld (M)	PLATE	5.0 - 10.0"	55.0°	-	± 20° - 60°	FLAT	11.8"	1 MHz	
Zone 1 (M)	PLATE	6.0 - 11.0"	60.0°	-	± 20°	FLAT	13.9"	1 MHz	
Zone 2A (M)	PLATE	0 - 14.0"	70.0°	-	± 25°	FLAT	17.2"	1 MHz	
Zone 2A (M)	PLATE	0 - 6.0"	80.0°	-	± 20°	FLAT	9.0"	1 MHz	
TOP HEAD VENT (N7) - 0° Offset									
N/V Weld (M)	PLATE	0 - 9.0"	60.0°	-	± 25.0° - 55.0°	FLAT	8.4"	1.0 MHz	
ZONE 2A (M)	PLATE	0 - 8.0"	70.0°	-	± 20°	FLAT	13.6"	1.0 MHz	
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	-	± 17°	FLAT	13.0"	1.0 MHz	
ZONE 2A (M)	ODBR	40° - 90°	50.0°	-	26°	1.9"	2.5"	1.0 MHz	
TOP HEAD SPRAY (N6) - 48° Offset									
N/V Weld (M)	PLATE	0 - 8.0"	45.0°	-	± 15.0° - 85.0°	FLAT	5.7"	1.0 MHz	
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	-	± 15.0° - 90.0°	FLAT	8.4"	1.0 MHz	
ZONE 1 (M)	PLATE	0 - 7.5"	70.0°	-	± 45°	FLAT	13.6"	1.0 MHz	
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	-	± 21°	FLAT	17.0"	1.0 MHz	
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	13°	1.9"	6.8"	1.0 MHz	
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	30°	1.9"	6.4"	1.0 MHz	
ZONE 2A (M)	ODBR	45° - 70°	50.0°	-	26°	1.9"	9.4"	1.0 MHz	
SBLC N10									
N/V Weld (M)	PLATE	4.5° - 9.0°	45.0°	-	± 17° - 51°	FLAT	9.1"	1 MHz	
NOTES: M MANUAL XXX° (XXX°) WEDGE / (FIXTURE) ROTATION ANGLE Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 577-3770									

W-039 ✓

W-031, W-032 ✓

W-031, W-032 ✓

W-131 ✓


W-180 ✓

W-132 ✓

W-131 ✓

Chris Minor
Digitally signed by Chris Minor
DN: cn=Chris Minor, o=CCI, email=chris.minor@cci.com
Reason: I am the Signer
Date: 2008.03.04 15:07:00 -0500

SME Review / Date


R. L. MAY
03/04/08
Site Review / Date

QUAD CITIES UNIT 2, Q2219

PAGE 8 OF 9

Quad Cities Unit 2 / Q2R19



GE Hitachi Nuclear Energy

Reactor Pressure Vessel Coverage Calculation Sheet

Quad Cities Unit 2 / Q2R19
N5A VES-NOZ (Core Spray)
Spring / 2008

Weld Length = 360. Exam Volume = 83.5		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° T-Scan (S4 UC)	A	9.3	9.3	11.1%	290	4.5%
60° T-Scan (S6 FV)	A	43.6	31.5	37.7%	290	15.2%
60° T-Scan (S6 NS)	A	30.6	1.8	2.2%	360	1.1%
IRS P-Scan (S4 UC)	A	9.3	9.3	11.1%	360	5.6%
60° P-Scan (S6 FV)	A	43.6	19.1	22.9%	360	11.4%
60° P-Scan (S6 NS)	A	30.6	2.1	2.5%	360	1.3%
60° T-Scan (S4 UC)	B	9.3	5.7	6.8%	70	0.7%
60° T-Scan (S6 FV)	B	43.6	29.2	35.0%	70	3.4%
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						

% Total Composite Coverage = 43.1%

Comments: A - Manual scanning was restricted due to the nozzle configuration.
Comments: B - 60° T-Scan S4 and S6 scans were restricted due to insulation support bracket.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in inches or degrees.

	HITACHI	EXAMINATION SUMMARY SHEET	Report No.: 2QR19-122				
Site: <u>Quad Cities</u> Component ID: <u>N5B NOZ</u> Outage: <u>Q2R19</u> <u>VESSEL-NOZZLE (CORE SPRAY)</u> System: <u>RPV</u> ASME Cat: <u>B-D</u> ASME Item <u>B3.90</u> Aug Req <u>N/A</u>							
Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Exam / Oper. Personnel	Cert Level	Date
60° Shear	D-082	N/A	GE-UT-311 Ver/Rev 15	99978AQC	Mark Hilborn	III	3/7/2008
60° RL	D-083	N/A	GE-UT-300 Ver/Rev 10	CAL-IIW2-045	Edward Fish	II	3/7/2008
60° RL	D-084	N/A	GE-UT-300 Ver/Rev 10	99978AQC	Edward Fish	II	3/7/2008
Examination Results: During the manual ultrasonic examination of the above referenced nozzle to vessel weld, no recordable indications were detected utilizing the above procedure. The inner 15%T examination volume as defined by 10 CFR 50 (Supplement 7) searching for flaws oriented perpendicular to the weld axis was performed per procedure GE-UT-311 V15, utilizing search units validated by modeling. This examination is acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda. Manual examinations were restricted due to the nozzle configuration and insulation support bracket. 43.1% code coverage was achieved.							
Previous examination results supplied by customer for review from ISI Program documents?					☒ Yes ☐ Change		
These examinations were performed under Work Order: 1025573					☐ No ☒ No Change		
This Summary and the following data sheets have been reviewed and accepted by the following personnel:						RWP: 8603 Dose: 138 mr.	
Prepared By: <u>J.H.C. A. [Signature]</u>	Level: <u>III</u>	Date: <u>3/12/08</u>	Utility Review: <u>[Signature]</u>	Date: <u>3/17/08</u>	Page <u>1</u> of <u>9</u>		
ANI Review: <u>Jeff [Signature]</u> Date: <u>3/19/08</u>							



HITACHI

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Outage: Q2R19

Procedure: GE-UT-311

Data Report Number: 20R19-122

Linearity Sheet: L-006

Data Sheet Number: D-082

Rev: 15

DRR: N/A

Calibration Data for Block: 99978AQC

<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>2140</u>	Exam Start: <u>0135</u>	
Cal Check: <u>N/A</u>	Exam End: <u>0250</u>	
Cal Check: <u>N/A</u>	<u>Ultracel II</u> Couplant:	<u>07225</u> Batch
Final Cal: <u>0340</u>		
<u>255223</u> Thermometer	<u>87° F</u> Initial Cal Temp.	<u>87° F</u> Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID Notch	<u>7.0"</u>	<u>1X</u>	<u>80%</u>	<u>11.95</u>	<u>13.8</u>	<u>8.1</u>
		<u>1X</u>				

DAC @ 1X= 48.1dB

Sweep 0-10 = 17.0"

Acceptable Linearity performed: 2/21/2008

Search Unit Data

<u>KBA</u> Manufacturer:	<u>01FRPD</u> Serial No.:	<u>.50"x1"/Rect.</u> Size/Shape:
<u>0.7 in.</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:
<u>1.0 MHz</u> Frequency:	<u>113-891-600</u> Model:	<u>Shear</u> Mode:

Search Unit Cable

<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:
------------------------------	----------------------	-------------------------

Instrument Settings

<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031536006</u> Serial No.:
<u>15.57 us</u> Zero:	<u>0.1291 in /user</u> Velocity:
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:
<u>Off:</u> DAC:	<u>Off:</u> TVG:
<u>17.0 in.</u> Range:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:
<u>Sq / Med</u> Pulser/Energy:	<u>1.0 MHz</u> Frequency:
<u>P/E</u> Mode:	<u>Off:</u> CSC:
	<u>Off:</u> DGS:

Exam Data for Component: N5B NOZ

VESSEL-NOZZLE (CORE SPRAY)

Configuration:

<u>Plate</u> Exam Surface:	<u>105° F</u> Component Temp.				
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications
<u>0 - 7.0"</u>	<u>60°</u>	<u>±55°</u>	<u>N/A</u>	<u>66.7</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.

Exams performed to maintain a 20 - 30% FSH clad roll.

Scanned CW and CCW.

Calibration for nozzle to vessel weld (N/A).

MRB Mark Hilborn

Initials: Examiner:

III

Level:

3/7/2008

Cal/Exam Date:

[Signature]

Utility Reviewed By:

3/17/08

Date:

[Signature]
Reviewed By:

III

Level:

3/11/08

Date:

[Signature]
ANII Reviewed By:

3/19/08

Date:

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components																																																																				
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-300</u>		Data Report Number: <u>20R19-122</u> Data Sheet Number: <u>D-083</u> Rev.: <u>10</u> Linearity Sheet: <u>L-005</u> DRR: <u>N/A</u>																																																																				
Calibration Block: <u>CAL-11W2-045</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>4.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>2215</u></td> <td></td> <td>Exam Start: <u>0715</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>0204</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultracel II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>0328</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255223</u> Thermometer</td> <td style="text-align: center;"><u>87° F</u> Initial Cal Temp.</td> <td style="text-align: center;"><u>87° F</u> Final Cal Temp.</td> </tr> </table>		<u>CS</u> Material	<u>N/A</u> Size	<u>4.0"</u> Thickness	Initial Cal: <u>2215</u>		Exam Start: <u>0715</u>	Cal Check: <u>N/A</u>		Exam End: <u>0204</u>	Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>07225</u>	Final Cal: <u>0328</u>	Couplant:	Batch	<u>255223</u> Thermometer	<u>87° F</u> Initial Cal Temp.	<u>87° F</u> Final Cal Temp.	<u>Search Unit Data</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u> Manufacturer:</td> <td style="text-align: center;"><u>228C-06006</u> Serial Number:</td> <td style="text-align: center;"><u>20.1"x6.2"/ Rect.</u> Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7</u> Incident Point:</td> <td style="text-align: center;"><u>60°</u> Nominal Angle:</td> <td style="text-align: center;"><u>60°</u> Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>SDC-3</u> Model:</td> <td style="text-align: center;"><u>RL</u> Mode:</td> </tr> </table>			<u>Sigma</u> Manufacturer:	<u>228C-06006</u> Serial Number:	<u>20.1"x6.2"/ Rect.</u> Size / Shape:	<u>0.7</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:	<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:																																							
<u>CS</u> Material	<u>N/A</u> Size	<u>4.0"</u> Thickness																																																																				
Initial Cal: <u>2215</u>		Exam Start: <u>0715</u>																																																																				
Cal Check: <u>N/A</u>		Exam End: <u>0204</u>																																																																				
Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>07225</u>																																																																				
Final Cal: <u>0328</u>	Couplant:	Batch																																																																				
<u>255223</u> Thermometer	<u>87° F</u> Initial Cal Temp.	<u>87° F</u> Final Cal Temp.																																																																				
<u>Sigma</u> Manufacturer:	<u>228C-06006</u> Serial Number:	<u>20.1"x6.2"/ Rect.</u> Size / Shape:																																																																				
<u>0.7</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:																																																																				
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:																																																																				
DAC Construction <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>SDH</td> <td>.6</td> <td>1X</td> <td>80%</td> <td>1.179</td> <td>0.681</td> <td>3.5</td> </tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> DAC 1X= <u>53.4</u> Sweep 0-10 = <u>2.0' Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee		Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	SDH	.6	1X	80%	1.179	0.681	3.5			1X							1X							1X							1X					<u>Search Unit Cable</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>12'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> <u>Instrument Settings</u> <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031574912</u></td> </tr> <tr> <td colspan="2" style="text-align: center;">Manufacturer/Model:</td> <td style="text-align: center;">Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>6.645 μs</u> Delay/Zero:</td> <td style="text-align: center;"><u>0.2120 in./μsec.</u> Velocity:</td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u> Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u> Rep Rate:</td> <td style="text-align: center;"><u>Fullwave</u> Rectification:</td> <td style="text-align: center;"><u>4.0 in.</u> Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u> Damping:</td> <td style="text-align: center;"><u>0%</u> Reject:</td> <td style="text-align: center;"><u>3.03 MHz</u> Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> DAC:</td> <td style="text-align: center;"><u>Off:</u> TVG:</td> <td style="text-align: center;"><u>Off:</u> CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Sq. / Med</u> Pulser:</td> <td style="text-align: center;"><u>Dual</u> Mode:</td> <td style="text-align: center;"><u>Off:</u> DGS:</td> </tr> </table>			<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u>		<u>031574912</u>	Manufacturer/Model:		Serial Number:	<u>6.645 μs</u> Delay/Zero:	<u>0.2120 in./μsec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>4.0 in.</u> Range:	<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:	<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:	<u>Sq. / Med</u> Pulser:	<u>Dual</u> Mode:	<u>Off:</u> DGS:
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																
SDH	.6	1X	80%	1.179	0.681	3.5																																																																
		1X																																																																				
		1X																																																																				
		1X																																																																				
		1X																																																																				
<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:																																																																				
<u>Panametrics / Epoch 4</u>		<u>031574912</u>																																																																				
Manufacturer/Model:		Serial Number:																																																																				
<u>6.645 μs</u> Delay/Zero:	<u>0.2120 in./μsec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:																																																																				
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>4.0 in.</u> Range:																																																																				
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:																																																																				
<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:																																																																				
<u>Sq. / Med</u> Pulser:	<u>Dual</u> Mode:	<u>Off:</u> DGS:																																																																				
Exam Data for Weld: <u>N5B NOZ</u> <u>VESSEL-NOZZLE (CORE SPRAY)</u> Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;"><u>OD Plate</u> Exam Surface:</td> <td style="text-align: center;"><u>105° F</u> Component Temperature</td> </tr> </table>		<u>OD Plate</u> Exam Surface:	<u>105° F</u> Component Temperature	<u>Calibration Verification</u> Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Reflector</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> <td style="text-align: center;"><u>N/A</u></td> </tr> </table>			Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																
<u>OD Plate</u> Exam Surface:	<u>105° F</u> Component Temperature																																																																					
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																			
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																			
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																			
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																			
Weld Examination Area: <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Plate</u></td> <td style="text-align: center;"><u>I</u></td> <td style="text-align: center;"><u>67.4</u></td> <td style="text-align: center;"><u>NRI</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td style="text-align: center;"><u>Plate CW/CCW</u></td> <td style="text-align: center;"><u>P</u></td> <td style="text-align: center;"><u>67.4</u></td> <td style="text-align: center;"><u>NRI</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> </table>		<u>Plate</u>	<u>I</u>	<u>67.4</u>	<u>NRI</u>	<u>60°</u>	<u>Plate CW/CCW</u>	<u>P</u>	<u>67.4</u>	<u>NRI</u>	<u>60°</u>	Acceptable Linearity performed: <u>2/21/2008</u>																																																										
<u>Plate</u>	<u>I</u>	<u>67.4</u>	<u>NRI</u>	<u>60°</u>																																																																		
<u>Plate CW/CCW</u>	<u>P</u>	<u>67.4</u>	<u>NRI</u>	<u>60°</u>																																																																		
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for near surface examination. Exams performed a minimum of 14 dB above reference. 45° Shear not used.																																																																						
<table style="width:100%;"> <tr> <td style="width:20%;"> <u>E.F.</u> Initials: Examiner </td> <td style="width:20%;"> <u>II</u> Level: </td> <td style="width:20%;"> <u>3/7/2008</u> Cal/Exam Date: </td> <td style="width:20%;"> <u>[Signature]</u> Utility Reviewed By: </td> <td style="width:20%;"> <u>3/17/08</u> Date: </td> </tr> <tr> <td> <u>N/A</u> Initials: Examiner </td> <td> <u>N/A</u> Level: </td> <td> <u>3/11/08</u> Date: </td> <td> <u>[Signature]</u> ANI Reviewed By: </td> <td> <u>3/19/08</u> Date: </td> </tr> </table>					<u>E.F.</u> Initials: Examiner	<u>II</u> Level:	<u>3/7/2008</u> Cal/Exam Date:	<u>[Signature]</u> Utility Reviewed By:	<u>3/17/08</u> Date:	<u>N/A</u> Initials: Examiner	<u>N/A</u> Level:	<u>3/11/08</u> Date:	<u>[Signature]</u> ANI Reviewed By:	<u>3/19/08</u> Date:																																																								
<u>E.F.</u> Initials: Examiner	<u>II</u> Level:	<u>3/7/2008</u> Cal/Exam Date:	<u>[Signature]</u> Utility Reviewed By:	<u>3/17/08</u> Date:																																																																		
<u>N/A</u> Initials: Examiner	<u>N/A</u> Level:	<u>3/11/08</u> Date:	<u>[Signature]</u> ANI Reviewed By:	<u>3/19/08</u> Date:																																																																		



HITACHI

**Ultrasonic Calibration and Examination Record
RPV Components**

Site/Unit: Quad Cities / 2

Data Report Number: 20R19-122

Linearity Sheet: L-005

Outage: Q2R19

Data Sheet Number: D-084

Procedure: GE-UT-300

Rev.: 10

DRR: N/A

Calibration Block: 99978AQC

<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness
Initial Cal: <u>2214</u>		Exam Start: <u>0115</u>
Cal Check: <u>N/A</u>		Exam End: <u>0204</u>
Cal Check: <u>N/A</u>	<u>Ultrage II</u> Couplant	<u>07225</u> Batch
Final Cal: <u>0328</u>		
<u>255223</u> Thermometer	<u>87° F</u> Initial Cal Temp.	<u>87° F</u> Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID Notch	<u>7.0</u>	<u>1X</u>	<u>80%</u>	<u>11.99</u>	<u>6.92</u>	<u>6.9</u>
		<u>1X</u>				
		<u>1X</u>				
		<u>1X</u>				
		<u>1X</u>				

DAC 1X= 69.5

Sweep 0-10 = 10.0" Depth

Note: N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: N5B NOZ

VESSEL-NOZZLE (CORE SPRAY)

Configuration:

OD Plate

Exam Surface:

105° F

Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>69.5</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>69.5</u>	<u>NRI</u>	<u>60°</u>

Search Unit Data

<u>Sigma</u> Manufacturer:	<u>22BC-06006</u> Serial Number:	<u>20.1"x6.2"/ Rect.</u> Size / Shape:
<u>0.7"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:

Search Unit Cable

<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

Instrument Settings

<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574912</u> Serial Number:
<u>6.645 μs</u> Delay/Zero:	<u>0.2119 in./μsec.</u> Velocity:
<u>0.8 - 3.0 MHz</u> Narrowband Filter:	
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:
<u>20.0 in.</u> Range:	<u>Sq. / Med</u> Pulser:
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:
<u>3.03 MHz</u> Frequency:	<u>Dual</u> Mode:
<u>Off:</u> DAC:	<u>Off:</u> TVG:
<u>Off:</u> CSC:	<u>Off:</u> DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 2/21/2008

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.

Exams performed to maintain a 10 - 20% clad roll.

Calibration for full volume examination.

Scanning limited due to insulation support.

45° Shear not used.

<u>EF</u> Initials:	<u>Edward Fish</u> Examiner	<u>II</u> Level:	<u>3/7/2008</u> Cal/Exam Date:
<u>N/A</u> Initials:	<u>N/A</u> Examiner	<u>N/A</u> Level:	<u>3/11/08</u> Date:
<u>GE</u> Reviewed By:			


<u>Kevin L. Hood</u> Utility Reviewed By:	<u>3/17/08</u> Date:
<u>Jeff Snyder</u> ANIR Reviewed By:	<u>3/15/08</u> Date:

Quad Cities Unit-2 N5 - Core Spray

60° NS Exam Volume = 30.6 Sq. In.
60° FV S6 Exam Volume = 43.6 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 9.3 Sq. In.

60° NS T-Scan achieved = 1.8 Sq. In.
60° FV S6 T-Scan achieved = 31.5 Sq. In.
60° FV S4 T-Scan achieved = 9.3 Sq. In.

60° NS P-Scan achieved = 2.1 Sq. In.
60° FV S6 P-Scan achieved = 19.1 Sq. In.
Inner 15%T IRS-Scan achieved = 9.3 Sq. In. (By modeling.)



Quad Cities Unit-2, 2008


Page 5 of 9

REPORT NO. 2008-122

Quad Cities Unit-2 N5 - Core Spray

60° NS Exam Volume = 30.6 Sq. In.
60° FV S6 Exam Volume = 43.6 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 9.3 Sq. In.

60° FV S6 T-Scan achieved = 29.2 Sq. In.
60° FV S4 T-Scan achieved = 5.7 Sq. In.




Quad Cities Unit-2, 2008

Page 4 of 9

Report No. 200819-122

Quad Cities Unit 2 N5B Core Spray



Quad Cities Unit 2, Q2R19

Page 7 of 9

REPORT NO. 20019-122

REPORT NO. 2Q2R19-122

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON				DATE 02/25/08		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
MAIN STEAM								
N/V Weld (M)	PLATE	0 - 4.0"	60.0°	-	± 25° - 70°	FLAT	14.0"	1 MHz
N/V Weld/Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 45°	FLAT	25.3"	1 MHz
Zone 2A (M)	ODBR	60° - 90°	66.4°	-	24.1°	4.0"	16.3"	1 MHz
CORE SPRAY								
N/V Weld/Zone 1 (M)	PLATE	0 - 7.0"	60.0°	-	± 55°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 25°	FLAT	19.6"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	10.6"	1 MHz
CRD								
N/V Weld (M)	PLATE	0 - 6.5"	45°	-	± 20.0° - 60.0°	FLAT	9.3"	1 MHz
Zone 1 (M)	PLATE	0 - 7.5"	60.0°	-	± 15°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 11.0"	70.0°	-	± 15°	FLAT	17.2"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	3.6"	1 MHz
JET PUMP INSTRUMENT								
N/V Weld (M)	PLATE	5.0 - 10.0"	55.0°	-	± 20° - 60°	FLAT	11.8"	1 MHz
Zone 1 (M)	PLATE	6.0 - 11.0"	60.0°	-	± 20°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 14.0"	70.0°	-	± 25°	FLAT	17.2"	1 MHz
Zone 2A (M)	PLATE	0 - 6.0"	80.0°	-	± 20°	FLAT	9.0"	1 MHz
TOP HEAD VENT (M7) - 0° Offset								
N/V Weld (M)	PLATE	0 - 9.0"	60.0°	-	± 25.0° - 55.0°	FLAT	8.4"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	70.0°	-	± 20°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	-	± 17°	FLAT	13.0"	1.0 MHz
ZONE 2A (M)	ODBR	40° - 90°	50.0°	-	26°	1.9"	2.5"	1.0 MHz
TOP HEAD SPRAY (M8) - 48° Offset								
N/V Weld (M)	PLATE	0 - 8.0"	45.0°	-	± 15.0° - 85.0°	FLAT	5.7"	1.0 MHz
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	-	± 15.0° - 90.0°	FLAT	8.4"	1.0 MHz
ZONE 1 (M)	PLATE	0 - 7.5"	70.0°	-	± 45°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	-	± 21°	FLAT	17.0"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	13°	1.9"	6.8"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	30°	1.9"	6.4"	1.0 MHz
ZONE 2A (M)	ODBR	45° - 70°	50.0°	-	26°	1.9"	9.4"	1.0 MHz
SBLC HOLD								
N/V Weld (M)	PLATE	4.5° - 9.0°	45.0°	-	± 17° - 51°	FLAT	9.1"	1 MHz

NOTES: M MANUAL
XOUT (XOUT) WEDGE / FIXTURE ROTATION ANGLE

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 577-3770

W-039 ✓

W-031, W-032 ✓

W-031, W-032 ✓

W-131 ✓

W-180 ✓

W-132 ✓

W-131 ✓

Chris Minor
SME Review / Date

Handwritten: LIT
P. L. RAY
03/04/08
SME Review / Date

Quad Cities Unit 2 / Q2R19



GE Hitachi Nuclear Energy

Reactor Pressure Vessel Coverage Calculation Sheet

**Quad Cities Unit 2 / Q2R19
N5B VES-NOZ (Core Spray)
Spring / 2008**

Weld Length = 360. Exam Volume = 83.5		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° T-Scan (S4 UC)	A	9.3	9.3	11.1%	290	4.5%
60° T-Scan (S6 FV)	A	43.6	31.5	37.7%	290	15.2%
60° T-Scan (S6 NS)	A	30.6	1.8	2.2%	360	1.1%
IRS P-Scan (S4 UC)	A	9.3	9.3	11.1%	360	5.6%
60° P-Scan (S6 FV)	A	43.6	19.1	22.9%	360	11.4%
60° P-Scan (S6 NS)	A	30.6	2.1	2.5%	360	1.3%
60° T-Scan (S4 UC)	B	9.3	5.7	6.8%	70	0.7%
60° T-Scan (S6 FV)	B	43.6	29.2	35.0%	70	3.4%
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						

% Total Composite Coverage = 43.1%

Comments: A - Manual scanning was restricted due to the nozzle configuration.
Comments: B - 60° T-Scan S4 and S6 scans were restricted due to insulation support bracket.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in inches or degrees.

Page 9 of 9

REPORT NO. 2012-19-122

		HITACHI		EXAMINATION SUMMARY SHEET				Report No: 2QR19-067	
Site: <u>Quad Cities</u>		Component ID: <u>N3B NOZ</u>							
Outage: <u>Q2R19</u>				VESSEL-NOZZLE (MAIN STEAM)					
System: <u>RPV</u>		ASME Cat.: <u>B-D</u>		ASME Item <u>B3.90</u>		Aug Req		<u>N/A</u>	

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Exam / Oper. Personnel	Cert Level	Date
60° RL	D-056	N/A	GE-UT-300 Ver/Rev 10	CAL-IIW2-045	Phillip Hopkins	II	3/5/2008
60° RL	D-057	N/A	GE-UT-300 Ver/Rev 10	99978AQC	Phillip Hopkins	II	3/5/2008
60° Shear	D-058	N/A	GE-UT-311 Ver/Rev 15	99978AQC	Wallace Reid	II	3/5/2008
70° Shear	D-059	N/A	GE-UT-311 Ver/Rev 15	99978AQC	Wallace Reid	II	3/5/2008

Examination Results:

During the manual ultrasonic examination of the above referenced nozzle to vessel weld, no recordable indications were detected utilizing the above procedure. The inner 15%T examination volume as defined by 10 CFR 50 (Supplement 7) searching for flaws oriented perpendicular to the weld axis was performed per procedure GE-UT-311 V15, utilizing search units validated by modeling.

This examination is acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda.

Manual examinations were restricted due to the nozzle configuration.

40.8% code coverage was achieved.

Previous examination results supplied by customer for review from ISI Program documents?		☒ Yes ☐ Change
These examinations were performed under Work Order: 1025573		☐ No ☒ No Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:				RWP: 8603 Dose: 61 mr.	
 Prepared By:		 Level: III Date: 3/19/08		Date: 3/17/08	
				 ANI Review: Date: 3/19/08	
				Page 1 of 8	

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components																																											
		Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-300</u>	Data Report Number: <u>2QR19-067</u> Data Sheet Number: <u>D-056</u> Rev.: <u>10</u>	Linearity Sheet: <u>L-007</u> DRR: <u>N/A</u>																																									
Calibration Block: <u>CAL-11W2-045</u>		<u>Search Unit Data</u>																																											
CS Material: <u>N/A</u> Initial Cal: <u>1030</u> Cal Check: <u>N/A</u> Cal Check: <u>N/A</u> Final Cal: <u>1515</u> Thermometer: <u>255562</u>	Size: <u>N/A</u> Thickness: <u>4.0"</u> Exam Start: <u>1200</u> Exam End: <u>1330</u> Couplant: <u>Ultragel II</u> Batch: <u>07225</u> Initial Cal Temp: <u>90° F</u> Final Cal Temp: <u>90° F</u>	Manufacturer: <u>Sigma</u> Serial Number: <u>228C-03009</u> Size / Shape: <u>21.1"x.62" / Rect.</u> Incident Point: <u>0.7"</u> Nominal Angle: <u>60°</u> Measured Angle: <u>60°</u> Frequency: <u>3.0 MHz</u> Model: <u>SDC-3</u> Mode: <u>RL</u>																																											
<u>DAC Construction</u>		<u>Search Unit Cable</u>																																											
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>SDH</td> <td><u>0.6"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>1.2"</u></td> <td><u>0.7"</u></td> <td><u>3.7</u></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.2"</u>	<u>0.7"</u>	<u>3.7</u>			1X							1X							1X							1X					Cable Type: <u>RG-174</u> Length: <u>9'</u> Connectors: <u>0</u>	
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																							
SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.2"</u>	<u>0.7"</u>	<u>3.7</u>																																							
		1X																																											
		1X																																											
		1X																																											
		1X																																											
DAC 1X= <u>61.3dB</u> Sweep 0-10 = <u>2.0" Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee		<u>Instrument Settings</u>																																											
Exam Data for Weld: <u>N3B NOZ</u> <u>VESSEL-NOZZLE (MAIN STEAM)</u> Configuration:		Manufacturer/Model: <u>Panametrics / Epoch 4</u> Serial Number: <u>031572811</u> Delay/Zero: <u>6.120 μs</u> Velocity: <u>0.2127 in./μsec.</u> Narrowband Filter: <u>0.8 - 3.0 MHz</u> Rep Rate: <u>Auto</u> Rectification: <u>Fullwave</u> Range: <u>4.0 in.</u> Pulse: <u>Sq. / Med</u> Damping: <u>400 Ohms</u> Reject: <u>0%</u> Frequency: <u>3.03 MHz</u> Mode: <u>Dual</u> DAC: <u>Off:</u> TVG: <u>Off:</u> CSC: <u>Off:</u> DGS: <u>Off:</u>																																											
OD Plate Exam Surface:		<u>Calibration Verification</u>																																											
Component Temperature: <u>100° F</u>		Field Simulator Block S/N: <u>N/A</u>																																											
Weld Examination Area:	Exam Access:	Scan dB:	Recordable Indications:																																										
<u>Plate</u>	<u>I</u>	<u>75.3</u>	<u>NRI</u>																																										
<u>Plate cw/ccw</u>	<u>P</u>	<u>75.3</u>	<u>NRI</u>																																										
Exam Angle:		Acceptable Linearity performed: <u>2/21/2008</u>																																											
<u>60°</u>																																													
<u>60°</u>																																													
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for near surface examination. Exams performed a minimum of 14 dB above reference. 45° S not used.																																													
Signature for Phillip Hopkins 6C Level II 3/5/2008 Initials: Examiner Level: Cal/Exam Date:																																													
Initials: Examiner Level: Date:																																													
Initials: Examiner Level: Date:																																													
GE Reviewed By: Level: Date:																																													
Utility Reviewed By:		Date:																																											
ANII Reviewed By:		Date:																																											

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components																																												
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-300</u>		Data Report Number: <u>2QR19-067</u> Data Sheet Number: <u>D-057</u> Rev.: <u>10</u>		Linearity Sheet: <u>L-007</u> DRR: <u>N/A</u>																																										
Calibration Block: <u>99978AQC</u>		<u>Search Unit Data</u>																																												
CS Material: <u>1052</u> Cal Check: <u>N/A</u> Cal Check: <u>N/A</u> Final Cal: <u>1520</u> 255562 Thermometer N/A Size: <u>7.0"</u> Exam Start: <u>1233</u> Exam End: <u>1330</u> Ultragel II Couplant: <u>07225</u> Batch: <u>1330</u> 91° F Initial Cal Temp. 7.0" Thickness Exam Start: <u>1233</u> Exam End: <u>1330</u> 07225 Batch 90° F Final Cal Temp.		Sigma Manufacturer: <u>22BC-03009</u> 0.7" Incident Point: <u>60°</u> 3.0 MHz Frequency: <u>SDC-3</u> RL Mode: <u>RL</u> 22BC-03009 Serial Number: <u>2(1.1"x.62") / Rect</u> Size / Shape: 60° Nominal Angle: <u>60°</u> Measured Angle: SDC-3 Model: <u>RL</u> Mode: <u>RL</u>																																												
DAC Construction <table border="1" style="width:100%; border-collapse: collapse; margin-top: 5px;"> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>12.3"</u></td> <td><u>6.5"</u></td> <td><u>6.5</u></td> </tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> </table>		Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.3"</u>	<u>6.5"</u>	<u>6.5</u>			1X							1X							1X							1X					<u>Search Unit Cable</u> RG-174 Cable Type: <u>9'</u> Length: <u>0</u> Connectors:		
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																								
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.3"</u>	<u>6.5"</u>	<u>6.5</u>																																								
		1X																																												
		1X																																												
		1X																																												
		1X																																												
DAC 1X= <u>72.9dB</u> Sweep 0-10 = <u>10.0" Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee		<u>Instrument Settings</u> Panametrics / Epoch 4 Manufacturer/Model: <u>031572811</u> Serial Number: 6.120 μs Delay/Zero: <u>0.2127 in./μsec.</u> Velocity: <u>0.8 - 3.0 MHz</u> Narrowband Filter: Auto Rep Rate: <u>Fullwave</u> Rectification: <u>20.0 in.</u> Range: <u>Sq. / Med</u> Pulser: 400 Ohms Damping: <u>0%</u> Reject: <u>3.03 MHz</u> Frequency: <u>Dual</u> Mode: Off: DAC: <u>Off:</u> TVG: <u>Off:</u> CSC: <u>Off:</u> DGS:																																												
Exam Data for Weld: <u>N3B NOZ</u> <u>VESSEL-NOZZLE (MAIN STEAM)</u> Configuration: OD Plate Exam Surface: 100° F Component Temperature <table border="1" style="width:100%; border-collapse: collapse; margin-top: 5px;"> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> <tr> <td><u>Plate</u></td> <td><u>I</u></td> <td><u>65.6</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> <tr> <td><u>Plate cw/ccw</u></td> <td><u>P</u></td> <td><u>65.6</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> </table>		Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>Plate</u>	<u>I</u>	<u>65.6</u>	<u>NRI</u>	<u>60°</u>	<u>Plate cw/ccw</u>	<u>P</u>	<u>65.6</u>	<u>NRI</u>	<u>60°</u>	<u>Calibration Verification</u> Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; margin-top: 5px;"> <tr><td>Reflector</td><td><u>N/A</u></td><td><u>N/A</u></td><td><u>N/A</u></td></tr> <tr><td>Amplitude</td><td><u>N/A</u></td><td><u>N/A</u></td><td><u>N/A</u></td></tr> <tr><td>Gain (dB)</td><td><u>N/A</u></td><td><u>N/A</u></td><td><u>N/A</u></td></tr> <tr><td>Sweep (SD)</td><td><u>N/A</u></td><td><u>N/A</u></td><td><u>N/A</u></td></tr> </table> Acceptable Linearity performed : <u>2/21/2008</u>			Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>											
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																										
<u>Plate</u>	<u>I</u>	<u>65.6</u>	<u>NRI</u>	<u>60°</u>																																										
<u>Plate cw/ccw</u>	<u>P</u>	<u>65.6</u>	<u>NRI</u>	<u>60°</u>																																										
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for full volume examination. Exams performed to maintain a 10 -20% clad roll. 45° S not used.																																														
<u>Scott R. Erickson for PHILLIP HOPKINS</u> <u>Phillip Hopkins</u> Initials: Examiner <u>N/A</u> GE Reviewed By: <u>II</u> Level: <u>N/A</u> <u>III</u> Level: <u>3/5/2008</u> Cal/Exam Date: <u>3/8/08</u> Date:																																														
<u>Kevin Zheoo</u> Utility Reviewed By: <u>Jeff Smayda</u> ANII Reviewed By: <u>03/17/08</u> Date: <u>3/19/08</u> Date:																																														

	HITACHI	Ultrasonic Calibration and Examination Record Inner Radius Examinations			
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u>		Data Report Number: <u>2QR19-067</u> Data Sheet Number: <u>D-058</u>		Linearity Sheet: <u>L-009</u>	
Procedure: <u>GE-UT-311</u>		Rev: <u>15</u>		DRR: <u>N/A</u>	

Calibration Data for Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>1040</u></td> <td></td> <td>Exam Start: <u>1200</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>1315</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultracel II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>1515</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255562</u></td> <td style="text-align: center;"><u>90° F</u></td> <td style="text-align: center;"><u>90° F</u></td> </tr> <tr> <td style="text-align: center;">Thermometer</td> <td style="text-align: center;">Initial Cal Temp.</td> <td style="text-align: center;">Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Side</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>12.0"</u></td> <td><u>13.9"</u></td> <td><u>8.2</u></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </table> DAC @ 1X= <u>51.2dB</u> Sweep 0-10 = <u>17.0"</u> <u>Metal Path</u> Acceptable Linearity performed: <u>2/21/2008</u>	<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>1040</u>		Exam Start: <u>1200</u>	Cal Check: <u>N/A</u>		Exam End: <u>1315</u>	Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>07225</u>	Final Cal: <u>1515</u>	Couplant:	Batch	<u>255562</u>	<u>90° F</u>	<u>90° F</u>	Thermometer	Initial Cal Temp.	Final Cal Temp:	Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.0"</u>	<u>13.9"</u>	<u>8.2</u>			1X					Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>KBA</u></td> <td style="text-align: center;"><u>01FRPD</u></td> <td style="text-align: center;"><u>.50"x1"/Rect.</u></td> </tr> <tr> <td>Manufacturer:</td> <td>Serial No.:</td> <td>Size/Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.75 in.</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td>Incident Point:</td> <td>Nominal Angle:</td> <td>Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u></td> <td style="text-align: center;"><u>113-891-600</u></td> <td style="text-align: center;"><u>Shear</u></td> </tr> <tr> <td>Frequency:</td> <td>Model:</td> <td>Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u></td> <td style="text-align: center;"><u>9'</u></td> <td style="text-align: center;"><u>0</u></td> </tr> <tr> <td>Cable Type:</td> <td>Length:</td> <td>Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u></td> <td style="text-align: center;"><u>031574011</u></td> </tr> <tr> <td colspan="2">Manufacturer/Model:</td> <td>Serial No.:</td> </tr> <tr> <td style="text-align: center;"><u>15.75 μs</u></td> <td style="text-align: center;"><u>0.1272 in / μsec</u></td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u></td> </tr> <tr> <td>Zero:</td> <td>Velocity:</td> <td>Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>Fullwave</u></td> <td style="text-align: center;"><u>17.0 in.</u></td> </tr> <tr> <td>Rep Rate:</td> <td>Rectification:</td> <td>Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> <td style="text-align: center;"><u>1.0 MHz</u></td> </tr> <tr> <td>Damping:</td> <td>Reject:</td> <td>Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td>DAC:</td> <td>TVG:</td> <td>CSC:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> <td style="text-align: center;"><u>Off:</u></td> </tr> <tr> <td></td> <td></td> <td>DGS:</td> </tr> </table> Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>	<u>KBA</u>	<u>01FRPD</u>	<u>.50"x1"/Rect.</u>	Manufacturer:	Serial No.:	Size/Shape:	<u>0.75 in.</u>	<u>60°</u>	<u>60°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>1.0 MHz</u>	<u>113-891-600</u>	<u>Shear</u>	Frequency:	Model:	Mode:	<u>RG-174</u>	<u>9'</u>	<u>0</u>	Cable Type:	Length:	Connectors:	<u>Panametrics / Epoch 4</u>		<u>031574011</u>	Manufacturer/Model:		Serial No.:	<u>15.75 μs</u>	<u>0.1272 in / μsec</u>	<u>0.8 - 3.0 MHz</u>	Zero:	Velocity:	Narrowband Filter:	<u>Auto</u>	<u>Fullwave</u>	<u>17.0 in.</u>	Rep Rate:	Rectification:	Range:	<u>400 Ohms</u>	<u>0%</u>	<u>1.0 MHz</u>	Damping:	Reject:	Frequency:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>	DAC:	TVG:	CSC:	<u>Off:</u>	<u>Off:</u>	<u>Off:</u>			DGS:	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																																																					
Initial Cal: <u>1040</u>		Exam Start: <u>1200</u>																																																																																																																					
Cal Check: <u>N/A</u>		Exam End: <u>1315</u>																																																																																																																					
Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>07225</u>																																																																																																																					
Final Cal: <u>1515</u>	Couplant:	Batch																																																																																																																					
<u>255562</u>	<u>90° F</u>	<u>90° F</u>																																																																																																																					
Thermometer	Initial Cal Temp.	Final Cal Temp:																																																																																																																					
Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																																																	
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.0"</u>	<u>13.9"</u>	<u>8.2</u>																																																																																																																	
		1X																																																																																																																					
<u>KBA</u>	<u>01FRPD</u>	<u>.50"x1"/Rect.</u>																																																																																																																					
Manufacturer:	Serial No.:	Size/Shape:																																																																																																																					
<u>0.75 in.</u>	<u>60°</u>	<u>60°</u>																																																																																																																					
Incident Point:	Nominal Angle:	Measured Angle:																																																																																																																					
<u>1.0 MHz</u>	<u>113-891-600</u>	<u>Shear</u>																																																																																																																					
Frequency:	Model:	Mode:																																																																																																																					
<u>RG-174</u>	<u>9'</u>	<u>0</u>																																																																																																																					
Cable Type:	Length:	Connectors:																																																																																																																					
<u>Panametrics / Epoch 4</u>		<u>031574011</u>																																																																																																																					
Manufacturer/Model:		Serial No.:																																																																																																																					
<u>15.75 μs</u>	<u>0.1272 in / μsec</u>	<u>0.8 - 3.0 MHz</u>																																																																																																																					
Zero:	Velocity:	Narrowband Filter:																																																																																																																					
<u>Auto</u>	<u>Fullwave</u>	<u>17.0 in.</u>																																																																																																																					
Rep Rate:	Rectification:	Range:																																																																																																																					
<u>400 Ohms</u>	<u>0%</u>	<u>1.0 MHz</u>																																																																																																																					
Damping:	Reject:	Frequency:																																																																																																																					
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																					
DAC:	TVG:	CSC:																																																																																																																					
<u>Off:</u>	<u>Off:</u>	<u>Off:</u>																																																																																																																					
		DGS:																																																																																																																					
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																				
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																				
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																				
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																																																				

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.

Exams performed to maintain a 20 - 30% FSH clad roll.
Scanned CW and CCW.
Calibration for nozzle to vessel weld (N/V).

<u>WWR</u> <u>Wallace Reid</u> Initials: Examiner:	<u>II</u> Level:	<u>3/5/2008</u> Cal/Exam Date:	<u>Jim L. Moore</u> Utility Reviewed By:	<u>3/7/08</u> Date:
<u>J.C. Reid</u> GE Reviewed By:	<u>III</u> Level:	<u>3/8/08</u> Date:	<u>Jeff Simpson</u> ANII Reviewed By:	<u>3/19/08</u> Date:

Page 4 of 8

Quad Cities Unit-2, 2008


Page 4 of 8

Quad Cities Unit-2 N3 - Main Steam

60° NS Exam Volume = 31.0 Sq. In.
60° FV S6 Exam Volume = 43.6 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 9.4 Sq. In.

60° NS T-Scan achieved = 1.8 Sq. In.
60° FV S6 T-Scan achieved = 28.5 Sq. In.
60° FV S4 T-Scan achieved = 9.4 Sq. In.

60° NS P-Scan achieved = 1.4 Sq. In.
60° FV S6 P-Scan achieved = 18.1 Sq. In.
Inner 15%T IRS-Scan achieved = 9.4 Sq. In. (By modeling.)



REPORT NO. ZCR19-061

REPORT NO. 20 R19-067

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON			DATE		02/25/08	
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
MAIN STEAM								
N/V Weld (M)	PLATE	0 - 4.0"	60.0°	-	± 25° - 70°	FLAT	14.0"	1 MHz
N/V Weld/Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 46°	FLAT	25.3"	1 MHz
Zone 2A (M)	ODBR	60° - 90°	66.4°	-	24.1°	4.0"	16.3"	1 MHz
CORE SPRAY								
N/V Weld/Zone 1 (M)	PLATE	0 - 7.0"	60.0°	-	± 55°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 25°	FLAT	19.6"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	10.6"	1 MHz
CRD								
N/V Weld (M)	PLATE	0 - 6.5"	45°	-	± 20.0° - 60.0°	FLAT	9.3"	1 MHz
Zone 1 (M)	PLATE	0 - 7.5"	60.0°	-	± 15°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 11.0"	70.0°	-	± 15°	FLAT	17.2"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	3.6"	1 MHz
JET PUMP INSTRUMENT								
N/V Weld (M)	PLATE	5.0 - 10.0"	55.0°	-	± 20° - 60°	FLAT	11.8"	1 MHz
Zone 1 (M)	PLATE	6.0 - 11.0"	60.0°	-	± 20°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 14.0"	70.0°	-	± 25°	FLAT	17.2"	1 MHz
Zone 2A (M)	PLATE	0 - 6.0"	80.0°	-	± 20°	FLAT	9.0"	1 MHz
TOP HEAD VENT (N7) - 0° Offset								
N/V Weld (M)	PLATE	0 - 9.0"	60.0°	-	± 25.0° - 55.0°	FLAT	8.4"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	70.0°	-	± 20°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	-	± 17°	FLAT	13.0"	1.0 MHz
ZONE 2A (M)	ODBR	40° - 90°	50.0°	-	26°	1.9"	2.5"	1.0 MHz
TOP HEAD SPRAY (N6) - 48° Offset								
N/V Weld (M)	PLATE	0 - 8.0"	45.0°	-	± 15.0° - 85.0°	FLAT	5.7"	1.0 MHz
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	-	± 15.0° - 90.0°	FLAT	8.4"	1.0 MHz
ZONE 1 (M)	PLATE	0 - 7.5"	70.0°	-	± 45°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	-	± 21°	FLAT	17.0"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	13°	1.9"	6.8"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	30°	1.9"	6.4"	1.0 MHz
ZONE 2A (M)	ODBR	45° - 70°	50.0°	-	26°	1.9"	9.4"	1.0 MHz
SBLC N10								
N/V Weld (M)	PLATE	4.5" - 9.0"	45.0°	-	± 17° - 51°	FLAT	9.1"	1 MHz

NOTES: (M) MANUAL
XXXX° (XXXX°) WEDGE / (FEATURE) ROTATION ANGLE

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 577-3770

W-039 ✓

W-031, W-032 ✓

W-031, W-032 ✓

W-131 /

W-180 ✓

W-132 ✓

W-131 ✓

Chris Minor
Digitally signed by Chris Minor
DN: cn=Chris Minor, o=CCN, email=
chris.minor@ccn.com, c=US
Date: 2008.02.28 10:05:47 -0500

SME Review / Date

Handwritten: HLT
P.L. MAY
03/04/08
Site Review / Date

Quad Cities Unit 2 / Q2R19



GE Hitachi Nuclear Energy

Reactor Pressure Vessel Coverage Calculation Sheet

Quad Cities Unit 2 / Q2R19
N3B VES-NOZ (Main Steam)
Spring / 2008

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 84.		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° T-Scan (S4 UC)	A	9.4	9.4	11.2%	360	5.6%
60° T-Scan (S6 FV)	A	43.6	28.5	33.9%	360	17.0%
60° T-Scan (S6 NS)	A	31	1.8	2.1%	360	1.1%
IRS P-Scan (S4 UC)	A	9.4	9.4	11.2%	360	5.6%
60° P-Scan (S6 FV)	A	43.6	18.1	21.5%	360	10.8%
60° P-Scan (S6 NS)	A	31	1.4	1.7%	360	0.8%
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						
% Total Composite Coverage =						40.8%

Rev. 0 9/23/05

Comments: A - Manual exam was restricted due to the nozzle configuration.
IRS P-Scan coverage validated by modeling.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in inches or degrees.

REF ID: A62419-2

	HITACHI	EXAMINATION SUMMARY SHEET	Report No.: 2QR19-083				
Site: <u>Quad Cities</u> Component ID: <u>N3D NOZ</u> Outage: <u>Q2R19</u> <u>VESSEL-NOZZLE (MAIN STEAM)</u> System: <u>RPV</u> ASME Cat.: <u>B-D</u> ASME Item <u>B3.90</u> Aug Req <u>N/A</u>							
Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Exam / Oper. Personnel	Cert Level	Date
60° RL	D-052	N/A	GE-UT-300 Ver/Rev 10	CAL-IIW2-045	Phillip Hopkins	II	3/5/2008
60° RL	D-053	N/A	GE-UT-300 Ver/Rev 10	99978AQC	Phillip Hopkins	II	3/5/2008
60° Shear	D-054	N/A	GE-UT-311 Ver/Rev 15	99978AQC	Wallace Reid	II	3/5/2008
70 Shear	D-055	N/A	GE-UT-311 Ver/Rev 15	99978AQC	Wallace Reid	II	3/5/2008
Examination Results: During the manual ultrasonic examination of the above referenced nozzle to vessel weld, no recordable indications were detected utilizing the above procedure. The inner 15%T examination volume as defined by 10 CFR 50 (Supplement 7) searching for flaws oriented perpendicular to the weld axis was performed per procedure GE-UT-311 V15, utilizing search units validated by modeling. This examination is acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda. Manual examinations were restricted due to the nozzle configuration. 40.8% code coverage was achieved.							
Previous examination results supplied by customer for review from ISI Program documents?					☒ Yes ☐ Change		
These examinations were performed under Work Order: 1025573					☐ No ☒ No Change		
This Summary and the following data sheets have been reviewed and accepted by the following personnel:						RWP: 8603 Dose: 61 mr.	
Prepared By: <u>J.C. Dief</u>	Level: <u>III</u>	Date: <u>3/19/08</u>	Utility Review: <u>Kevin J. Deo</u>	Date: <u>3/18/08</u>	Page <u>1</u> of <u>8</u>		
				ANII Review: <u>Jeff Snyder</u>		Date: <u>3/22/08</u>	

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components																																												
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-300</u>		Data Report Number: <u>2QR19-083</u> Data Sheet Number: <u>D-052</u> Rev.: <u>10</u>		Linearity Sheet: <u>L-007</u> DRR: <u>N/A</u>																																										
Calibration Block: <u>CAL-IIW2-045</u>		<u>Search Unit Data</u>																																												
<u>CS</u> Material Initial Cal: <u>1030</u> Cal Check: <u>N/A</u> Cal Check: <u>N/A</u> Final Cal: <u>1515</u> <u>255562</u> Thermometer <u>N/A</u> Size <u>Ultragel II</u> Couplant <u>90° F</u> Initial Cal Temp. <u>4.0"</u> Thickness Exam Start: <u>1332</u> Exam End: <u>1445</u> <u>07225</u> Batch <u>90° F</u> Final Cal Temp.		<u>Sigma</u> Manufacturer: <u>0.7"</u> Incident Point: <u>3.0 MHz</u> Frequency: <u>228C-03009</u> Serial Number: <u>60°</u> Nominal Angle: <u>SDC-3</u> Model: <u>21.1"X.62"/ Rect.</u> Size / Shape: <u>60°</u> Measured Angle: <u>RL</u> Mode:																																												
DAC Construction <table border="1" style="width:100%; border-collapse: collapse; margin-top: 5px;"> <thead> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>SDH</td> <td><u>0.6"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>1.2</u></td> <td><u>0.7</u></td> <td><u>3.7</u></td> </tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td>1X</td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.2</u>	<u>0.7</u>	<u>3.7</u>			1X							1X							1X							1X					<u>Search Unit Cable</u> <u>RG-174</u> Cable Type: <u>9'</u> Length: <u>0</u> Connectors:		
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																								
SDH	<u>0.6"</u>	1X	<u>80%</u>	<u>1.2</u>	<u>0.7</u>	<u>3.7</u>																																								
		1X																																												
		1X																																												
		1X																																												
		1X																																												
DAC 1X= <u>61.3dB</u> Sweep 0-10 = <u>2.0" Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee		<u>Instrument Settings</u> <u>Panametrics / Epoch 4</u> Manufacturer/Model: <u>6.120 µs</u> Delay/Zero: <u>0.2127 in./µsec.</u> Velocity: <u>0.8 - 3.0 MHz</u> Narrowband Filter: <u>031572811</u> Serial Number: <u>Auto</u> Rep Rate: <u>Fulwave</u> Rectification: <u>4.0 in.</u> Range: <u>Sq. / Med</u> Pulser: <u>400 Ohms</u> Damping: <u>0%</u> Reject: <u>3.03 MHz</u> Frequency: <u>Dual</u> Mode: <u>Off:</u> DAC: <u>Off:</u> TVG: <u>Off:</u> CSC: <u>Off:</u> DGS:																																												
Exam Data for Weld: <u>N3D NOZ</u> <u>VESSEL-NOZZLE (MAIN STEAM)</u> Configuration: <u>OD Plate</u> Exam Surface: <u>100° F</u> Component Temperature		<u>Calibration Verification</u> Field Simulator Block S/N: <u>N/A</u>																																												
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Weld Examination Area:</th> <th>Exam Access</th> <th>Scan dB</th> <th>Recordable Indications</th> <th>Exam Angle</th> </tr> </thead> <tbody> <tr> <td><u>Plate</u></td> <td><u>I</u></td> <td><u>75.3</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> <tr> <td><u>Plate CW/CCW</u></td> <td><u>P</u></td> <td><u>75.3</u></td> <td><u>NRI</u></td> <td><u>60°</u></td> </tr> </tbody> </table>		Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle	<u>Plate</u>	<u>I</u>	<u>75.3</u>	<u>NRI</u>	<u>60°</u>	<u>Plate CW/CCW</u>	<u>P</u>	<u>75.3</u>	<u>NRI</u>	<u>60°</u>	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th><u>N/A</u></th> <th><u>N/A</u></th> <th><u>N/A</u></th> </tr> </thead> <tbody> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </tbody> </table>			Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>											
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle																																										
<u>Plate</u>	<u>I</u>	<u>75.3</u>	<u>NRI</u>	<u>60°</u>																																										
<u>Plate CW/CCW</u>	<u>P</u>	<u>75.3</u>	<u>NRI</u>	<u>60°</u>																																										
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																											
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Calibration for near surface examination. Exams performed a minimum of 14 dB above reference. 45° Not used		Acceptable Linearity performed : <u>2/21/2008</u>																																												
Signature Section GE LUT for PHILLIP HOPKINS <u>Phillip Hopkins</u> Initials: Examiner <u>N/A</u> Initials: Examiner <u>Jh C. Dind</u> GE Reviewed By: <u>II</u> Level: Cal/Exam Date: <u>N/A</u> Level: <u>III</u> Level: <u>3/5/2008</u> Date: <u>3/8/08</u> Date:																																														
<u>John Lee</u> Utility Reviewed By: <u>Jeff Smyth</u> ANII Reviewed By: <u>3-18-08</u> Date: <u>3/27/08</u> Date:																																														

	HITACHI	Ultrasonic Calibration and Examination Record RPV Components		
Site/Unit: <u>Quad Cities / 2</u>		Data Report Number: <u>20R19-083</u>		Linearity Sheet: <u>L-007</u>
Outage: <u>Q2R19</u>		Data Sheet Number: <u>D-053</u>		
Procedure: <u>GE-UT-300</u>		Rev.: <u>10</u>	DRR: <u>N/A</u>	

Calibration Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>1052</u></td> <td></td> <td>Exam Start: <u>1332</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>1445</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultrage II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>1520</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255562</u> Thermometer</td> <td style="text-align: center;"><u>91° F</u> Initial Cal Temp.</td> <td style="text-align: center;"><u>90° F</u> Final Cal Temp.</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Reflector</th> <th>Hole Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> </thead> <tbody> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>12.3</u></td> <td><u>6.5</u></td> <td><u>6.5</u></td> </tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td>1X</td><td></td><td></td><td></td><td></td></tr> </tbody> </table> DAC 1X= <u>72.9dB</u> Sweep 0-10 = <u>10.0" Depth</u> Note: <u>N/A</u> dB difference between 3/8 and 5/8 Vee	<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>1052</u>		Exam Start: <u>1332</u>	Cal Check: <u>N/A</u>		Exam End: <u>1445</u>	Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>07225</u>	Final Cal: <u>1520</u>	Couplant:	Batch	<u>255562</u> Thermometer	<u>91° F</u> Initial Cal Temp.	<u>90° F</u> Final Cal Temp.	Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.3</u>	<u>6.5</u>	<u>6.5</u>			1X							1X							1X							1X					Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Sigma</u> Manufacturer:</td> <td style="text-align: center;"><u>22BC-03009</u> Serial Number:</td> <td style="text-align: center;"><u>20.1"x6.2" / Rect.</u> Size / Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.7"</u> Incident Point:</td> <td style="text-align: center;"><u>60°</u> Nominal Angle:</td> <td style="text-align: center;"><u>60°</u> Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>3.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>SDC-3</u> Model:</td> <td style="text-align: center;"><u>RL</u> Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>9'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td colspan="2" style="text-align: center;"><u>Panametrics / Epoch 4</u> Manufacturer/Model:</td> <td style="text-align: center;"><u>031572811</u> Serial Number:</td> </tr> <tr> <td style="text-align: center;"><u>6.120 µs</u> Delay/Zero:</td> <td style="text-align: center;"><u>0.2127 in./µsec.</u> Velocity:</td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u> Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u> Rep Rate:</td> <td style="text-align: center;"><u>Fulwave</u> Rectification:</td> <td style="text-align: center;"><u>20.0 in.</u> Range:</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u> Damping:</td> <td style="text-align: center;"><u>0%</u> Reject:</td> <td style="text-align: center;"><u>3.03 MHz</u> Frequency:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> DAC:</td> <td style="text-align: center;"><u>Off:</u> TVG:</td> <td style="text-align: center;"><u>Off:</u> CSC:</td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;"><u>Off:</u> DGS:</td> </tr> </table>	<u>Sigma</u> Manufacturer:	<u>22BC-03009</u> Serial Number:	<u>20.1"x6.2" / Rect.</u> Size / Shape:	<u>0.7"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:	<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:	<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u> Manufacturer/Model:		<u>031572811</u> Serial Number:	<u>6.120 µs</u> Delay/Zero:	<u>0.2127 in./µsec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	<u>Auto</u> Rep Rate:	<u>Fulwave</u> Rectification:	<u>20.0 in.</u> Range:	<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:	<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:			<u>Off:</u> DGS:
<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																									
Initial Cal: <u>1052</u>		Exam Start: <u>1332</u>																																																																																									
Cal Check: <u>N/A</u>		Exam End: <u>1445</u>																																																																																									
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>07225</u>																																																																																									
Final Cal: <u>1520</u>	Couplant:	Batch																																																																																									
<u>255562</u> Thermometer	<u>91° F</u> Initial Cal Temp.	<u>90° F</u> Final Cal Temp.																																																																																									
Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																					
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.3</u>	<u>6.5</u>	<u>6.5</u>																																																																																					
		1X																																																																																									
		1X																																																																																									
		1X																																																																																									
		1X																																																																																									
<u>Sigma</u> Manufacturer:	<u>22BC-03009</u> Serial Number:	<u>20.1"x6.2" / Rect.</u> Size / Shape:																																																																																									
<u>0.7"</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>60°</u> Measured Angle:																																																																																									
<u>3.0 MHz</u> Frequency:	<u>SDC-3</u> Model:	<u>RL</u> Mode:																																																																																									
<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:																																																																																									
<u>Panametrics / Epoch 4</u> Manufacturer/Model:		<u>031572811</u> Serial Number:																																																																																									
<u>6.120 µs</u> Delay/Zero:	<u>0.2127 in./µsec.</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:																																																																																									
<u>Auto</u> Rep Rate:	<u>Fulwave</u> Rectification:	<u>20.0 in.</u> Range:																																																																																									
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>3.03 MHz</u> Frequency:																																																																																									
<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:																																																																																									
		<u>Off:</u> DGS:																																																																																									

Exam Data for Weld: <u>N3D NOZ</u>				
<u>VESSEL-NOZZLE (MAIN STEAM)</u>				
Configuration:				
<u>OD Plate</u> Exam Surface:	<u>100° F</u> Component Temperature			
Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>65.6</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>65.6</u>	<u>NRI</u>	<u>60°</u>










Calibration Verification			
Field Simulator Block S/N: <u>N/A</u>			
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Acceptable Linearity performed : <u>2/21/2008</u>			

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off.
Calibration for full volume examination.
Exams performed to maintain a 10 -20% clad roll.
45° Not used

<u>Scott R. Erickson</u> GE with for <u>Phillip Hopkins</u> Initials: <u>Phillip Hopkins</u> Level: <u>II</u> Cal/Exam Date: <u>3/5/2008</u> Initials: <u>N/A</u> Level: <u>N/A</u> Initials: <u>Jh C. D. - S</u> Level: <u>III</u> Date: <u>3/8/08</u> GE Reviewed By: _____ Level: _____ Date: _____	<u>Kevin L. Looe</u> <u>03/18/08</u> Utility Reviewed By: _____ Date: _____ <u>Jeff Snyder</u> <u>3/22/08</u> ANII Reviewed By: _____ Date: _____
---	---

Page 3 of 8

	HITACHI	Ultrasonic Calibration and Examination Record Inner Radius Examinations																																																																																												
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-311</u>		Data Report Number: <u>2QR19-083</u> Linearity Sheet: <u>L-009</u> Data Sheet Number: <u>D-054</u> Rev: <u>15</u> DRR: <u>N/A</u>																																																																																												
Calibration Data for Block: <u>99978AQC</u> <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>CS</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>1040</u></td> <td></td> <td>Exam Start: <u>1200</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>1445</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultragel II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>1515</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255562</u> Thermometer</td> <td style="text-align: center;"><u>90° F</u> Initial Cal Temp.</td> <td style="text-align: center;"><u>90° F</u> Final Cal Temp.</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Side</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>12.0"</u></td> <td><u>13.9"</u></td> <td><u>8.2</u></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </table> DAC @ 1X= <u>51.2</u> Sweep 0-10 = <u>17.0" MP</u> Acceptable Linearity performed: <u>2/21/2008</u>		<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>1040</u>		Exam Start: <u>1200</u>	Cal Check: <u>N/A</u>		Exam End: <u>1445</u>	Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>07225</u>	Final Cal: <u>1515</u>	Couplant:	Batch	<u>255562</u> Thermometer	<u>90° F</u> Initial Cal Temp.	<u>90° F</u> Final Cal Temp.	Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.0"</u>	<u>13.9"</u>	<u>8.2</u>			1X					Search Unit Data <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>KBA</u> Manufacturer:</td> <td style="text-align: center;"><u>01FRPD</u> Serial No.:</td> <td style="text-align: center;"><u>50"x1"/Rect.</u> Size/Shape:</td> </tr> <tr> <td style="text-align: center;"><u>0.75 in.</u></td> <td style="text-align: center;"><u>60°</u></td> <td style="text-align: center;"><u>60°</u></td> </tr> <tr> <td>Incident Point:</td> <td>Nominal Angle:</td> <td>Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>113-891-600</u> Model:</td> <td style="text-align: center;"><u>Shear</u> Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>9'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>Panametrics / Epoch 4</u> Manufacturer/Model:</td> <td style="text-align: center;"><u>031574011</u> Serial No.:</td> </tr> <tr> <td style="text-align: center;"><u>15.75 µs</u> Zero:</td> <td style="text-align: center;"><u>0.1272 in /µsec</u> Velocity:</td> </tr> <tr> <td style="text-align: center;"><u>Auto</u></td> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u> Narrowband Filter:</td> </tr> <tr> <td style="text-align: center;"><u>Fullwave</u></td> <td style="text-align: center;"><u>17.0 in.</u></td> </tr> <tr> <td>Rep Rate:</td> <td>Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>Range:</u></td> <td style="text-align: center;"><u>Sq. / Med</u> Pulser/Energy</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u></td> <td style="text-align: center;"><u>0%</u></td> </tr> <tr> <td>Damping:</td> <td>Reject:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>P/E</u> Mode:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> DAC:</td> <td style="text-align: center;"><u>Off:</u> TVG:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> CSC:</td> <td style="text-align: center;"><u>Off:</u> DGS:</td> </tr> </table> Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>	<u>KBA</u> Manufacturer:	<u>01FRPD</u> Serial No.:	<u>50"x1"/Rect.</u> Size/Shape:	<u>0.75 in.</u>	<u>60°</u>	<u>60°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>1.0 MHz</u> Frequency:	<u>113-891-600</u> Model:	<u>Shear</u> Mode:	<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574011</u> Serial No.:	<u>15.75 µs</u> Zero:	<u>0.1272 in /µsec</u> Velocity:	<u>Auto</u>	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	<u>Fullwave</u>	<u>17.0 in.</u>	Rep Rate:	Rectification:	<u>Range:</u>	<u>Sq. / Med</u> Pulser/Energy	<u>400 Ohms</u>	<u>0%</u>	Damping:	Reject:	<u>1.0 MHz</u> Frequency:	<u>P/E</u> Mode:	<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:	<u>Off:</u> DGS:	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>CS</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																												
Initial Cal: <u>1040</u>		Exam Start: <u>1200</u>																																																																																												
Cal Check: <u>N/A</u>		Exam End: <u>1445</u>																																																																																												
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>07225</u>																																																																																												
Final Cal: <u>1515</u>	Couplant:	Batch																																																																																												
<u>255562</u> Thermometer	<u>90° F</u> Initial Cal Temp.	<u>90° F</u> Final Cal Temp.																																																																																												
Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																								
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>12.0"</u>	<u>13.9"</u>	<u>8.2</u>																																																																																								
		1X																																																																																												
<u>KBA</u> Manufacturer:	<u>01FRPD</u> Serial No.:	<u>50"x1"/Rect.</u> Size/Shape:																																																																																												
<u>0.75 in.</u>	<u>60°</u>	<u>60°</u>																																																																																												
Incident Point:	Nominal Angle:	Measured Angle:																																																																																												
<u>1.0 MHz</u> Frequency:	<u>113-891-600</u> Model:	<u>Shear</u> Mode:																																																																																												
<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:																																																																																												
<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574011</u> Serial No.:																																																																																													
<u>15.75 µs</u> Zero:	<u>0.1272 in /µsec</u> Velocity:																																																																																													
<u>Auto</u>	<u>0.8 - 3.0 MHz</u> Narrowband Filter:																																																																																													
<u>Fullwave</u>	<u>17.0 in.</u>																																																																																													
Rep Rate:	Rectification:																																																																																													
<u>Range:</u>	<u>Sq. / Med</u> Pulser/Energy																																																																																													
<u>400 Ohms</u>	<u>0%</u>																																																																																													
Damping:	Reject:																																																																																													
<u>1.0 MHz</u> Frequency:	<u>P/E</u> Mode:																																																																																													
<u>Off:</u> DAC:	<u>Off:</u> TVG:																																																																																													
<u>Off:</u> CSC:	<u>Off:</u> DGS:																																																																																													
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																											
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																											
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																											
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																											
Exam Data for Component: <u>N3D NOZ</u> <u>VESSEL-NOZZLE (MAIN STEAM)</u> Configuration: <table style="width:100%; border: none;"> <tr> <td style="text-align: center;"><u>OD Plate</u> Exam Surface:</td> <td style="text-align: center;"><u>100° F</u> Component Temp.</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Examination Area</th> <th>Exam Angle</th> <th>Rotation Angle</th> <th>Wedge S/N</th> <th>Scan dB</th> <th>Recordable Indications</th> </tr> <tr> <td><u>0-4.0"</u></td> <td><u>60°</u></td> <td><u>±25°-70°</u></td> <td><u>N/A</u></td> <td><u>63.2</u></td> <td><u>NRI</u></td> </tr> <tr> <td><u>0-4.0"</u></td> <td><u>60°</u></td> <td><u>±25°-70°</u></td> <td><u>N/A</u></td> <td><u>63.2</u></td> <td><u>NRI</u></td> </tr> </table>			<u>OD Plate</u> Exam Surface:	<u>100° F</u> Component Temp.	Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications	<u>0-4.0"</u>	<u>60°</u>	<u>±25°-70°</u>	<u>N/A</u>	<u>63.2</u>	<u>NRI</u>	<u>0-4.0"</u>	<u>60°</u>	<u>±25°-70°</u>	<u>N/A</u>	<u>63.2</u>	<u>NRI</u>																																																																								
<u>OD Plate</u> Exam Surface:	<u>100° F</u> Component Temp.																																																																																													
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications																																																																																									
<u>0-4.0"</u>	<u>60°</u>	<u>±25°-70°</u>	<u>N/A</u>	<u>63.2</u>	<u>NRI</u>																																																																																									
<u>0-4.0"</u>	<u>60°</u>	<u>±25°-70°</u>	<u>N/A</u>	<u>63.2</u>	<u>NRI</u>																																																																																									
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Exams performed to maintain a 20% - 30% FSH clad roll. (IRS, clad material) Scanned CW and CCW. Calibration for nozzle to vessel weld (N/V).																																																																																														
<table style="width:100%; border: none;"> <tr> <td style="width:33%;"> <u>WWR</u> <u>Wallace Reid</u> Initials: Examiner: </td> <td style="width:33%;"> <u>II</u> Level: </td> <td style="width:33%;"> <u>3/5/2008</u> Cal/Exam Date: </td> </tr> <tr> <td> <u>John C. Reid</u> GE Reviewed By: </td> <td> <u>III</u> Level: </td> <td> <u>3/8/08</u> Date: </td> </tr> </table> <table style="width:100%; border: none;"> <tr> <td style="width:33%;"> <u>Samuel Lee</u> Utility Reviewed By: </td> <td style="width:33%;"> <u>3/18/08</u> Date: </td> <td></td> </tr> <tr> <td> <u>Jeff Simpson</u> ANII Reviewed By: </td> <td> <u>3/22/08</u> Date: </td> <td></td> </tr> </table>			<u>WWR</u> <u>Wallace Reid</u> Initials: Examiner:	<u>II</u> Level:	<u>3/5/2008</u> Cal/Exam Date:	<u>John C. Reid</u> GE Reviewed By:	<u>III</u> Level:	<u>3/8/08</u> Date:	<u>Samuel Lee</u> Utility Reviewed By:	<u>3/18/08</u> Date:		<u>Jeff Simpson</u> ANII Reviewed By:	<u>3/22/08</u> Date:																																																																																	
<u>WWR</u> <u>Wallace Reid</u> Initials: Examiner:	<u>II</u> Level:	<u>3/5/2008</u> Cal/Exam Date:																																																																																												
<u>John C. Reid</u> GE Reviewed By:	<u>III</u> Level:	<u>3/8/08</u> Date:																																																																																												
<u>Samuel Lee</u> Utility Reviewed By:	<u>3/18/08</u> Date:																																																																																													
<u>Jeff Simpson</u> ANII Reviewed By:	<u>3/22/08</u> Date:																																																																																													

	HITACHI	Ultrasonic Calibration and Examination Record Inner Radius Examinations																																																																																											
Site/Unit: <u>Quad Cities / 2</u> Outage: <u>Q2R19</u> Procedure: <u>GE-UT-311</u>		Data Report Number: <u>2QR19-083</u> Linearity Sheet: <u>L-009</u> Data Sheet Number: <u>D-055</u> Rev: <u>15</u> DRR: <u>N/A</u>																																																																																											
Calibration Data for Block: <u>99978AQC</u> <table style="width:100%;"> <tr> <td style="text-align: center;"><u>CS/CL</u> Material</td> <td style="text-align: center;"><u>N/A</u> Size</td> <td style="text-align: center;"><u>7.0"</u> Thickness</td> </tr> <tr> <td>Initial Cal: <u>1042</u></td> <td></td> <td>Exam Start: <u>1:18:00 PM</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td></td> <td>Exam End: <u>2:45:00 PM</u></td> </tr> <tr> <td>Cal Check: <u>N/A</u></td> <td style="text-align: center;"><u>Ultragel II</u></td> <td style="text-align: center;"><u>07225</u></td> </tr> <tr> <td>Final Cal: <u>1518</u></td> <td style="text-align: center;">Couplant:</td> <td style="text-align: center;">Batch</td> </tr> <tr> <td style="text-align: center;"><u>255562</u> Thermometer</td> <td style="text-align: center;"><u>90° F</u> Initial Cal Temp.</td> <td style="text-align: center;"><u>90° F</u> Final Cal Temp:</td> </tr> </table> DAC Construction <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <th>Side</th> <th>Depth</th> <th>Gain @ 1X</th> <th>Max Amp</th> <th>"W" Dim.</th> <th>Sweep</th> <th>Screen Div.</th> </tr> <tr> <td>ID Notch</td> <td><u>7.0"</u></td> <td>1X</td> <td><u>80%</u></td> <td><u>1.93"</u></td> <td><u>20.7"</u></td> <td><u>6.7</u></td> </tr> <tr> <td></td> <td></td> <td>1X</td> <td></td> <td></td> <td></td> <td></td> </tr> </table> DAC @ 1X= <u>43.3</u> Sweep 0-10 = <u>31"</u> <u>MP</u> Acceptable Linearity performed : <u>2/21/2008</u>		<u>CS/CL</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness	Initial Cal: <u>1042</u>		Exam Start: <u>1:18:00 PM</u>	Cal Check: <u>N/A</u>		Exam End: <u>2:45:00 PM</u>	Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>07225</u>	Final Cal: <u>1518</u>	Couplant:	Batch	<u>255562</u> Thermometer	<u>90° F</u> Initial Cal Temp.	<u>90° F</u> Final Cal Temp:	Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.	ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>1.93"</u>	<u>20.7"</u>	<u>6.7</u>			1X					Search Unit Data <table style="width:100%;"> <tr> <td style="text-align: center;"><u>KBA</u> Manufacturer:</td> <td style="text-align: center;"><u>01FRPF</u> Serial No.:</td> <td style="text-align: center;"><u>50"x1"/Rect.</u> Size/Shape:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 in.</u></td> <td style="text-align: center;"><u>70</u></td> <td style="text-align: center;"><u>70°</u></td> </tr> <tr> <td>Incident Point:</td> <td>Nominal Angle:</td> <td>Measured Angle:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u></td> <td style="text-align: center;"><u>113-891-600</u></td> <td style="text-align: center;"><u>Shear</u></td> </tr> <tr> <td>Frequency:</td> <td>Model:</td> <td>Mode:</td> </tr> </table> Search Unit Cable <table style="width:100%;"> <tr> <td style="text-align: center;"><u>RG-174</u> Cable Type:</td> <td style="text-align: center;"><u>9'</u> Length:</td> <td style="text-align: center;"><u>0</u> Connectors:</td> </tr> </table> Instrument Settings <table style="width:100%;"> <tr> <td style="text-align: center;"><u>Panametrics / Epoch 4</u> Manufacturer/Model:</td> <td style="text-align: center;"><u>031574011</u> Serial No.:</td> </tr> <tr> <td style="text-align: center;"><u>17.13 µs</u> Zero:</td> <td style="text-align: center;"><u>0.1273 in / µsec</u> Velocity:</td> </tr> <tr> <td style="text-align: center;"><u>0.8 - 3.0 MHz</u> Narrowband Filter:</td> <td></td> </tr> <tr> <td style="text-align: center;"><u>Auto</u> Rep Rate:</td> <td style="text-align: center;"><u>Fullwave</u> Rectification:</td> </tr> <tr> <td style="text-align: center;"><u>31.0 in.</u> Range:</td> <td style="text-align: center;"><u>Sq. / Med</u> Pulser/Energy</td> </tr> <tr> <td style="text-align: center;"><u>400 Ohms</u> Damping:</td> <td style="text-align: center;"><u>0%</u> Reject:</td> </tr> <tr> <td style="text-align: center;"><u>1.0 MHz</u> Frequency:</td> <td style="text-align: center;"><u>P/E</u> Mode:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> DAC:</td> <td style="text-align: center;"><u>Off:</u> TVG:</td> </tr> <tr> <td style="text-align: center;"><u>Off:</u> CSC:</td> <td style="text-align: center;"><u>Off:</u> DGS:</td> </tr> </table> Calibration Verification Field Simulator Block S/N: <u>N/A</u> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr> <td>Reflector</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Amplitude</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Gain (dB)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> <tr> <td>Sweep (SD)</td> <td><u>N/A</u></td> <td><u>N/A</u></td> <td><u>N/A</u></td> </tr> </table>	<u>KBA</u> Manufacturer:	<u>01FRPF</u> Serial No.:	<u>50"x1"/Rect.</u> Size/Shape:	<u>1.0 in.</u>	<u>70</u>	<u>70°</u>	Incident Point:	Nominal Angle:	Measured Angle:	<u>1.0 MHz</u>	<u>113-891-600</u>	<u>Shear</u>	Frequency:	Model:	Mode:	<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:	<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574011</u> Serial No.:	<u>17.13 µs</u> Zero:	<u>0.1273 in / µsec</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:		<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>31.0 in.</u> Range:	<u>Sq. / Med</u> Pulser/Energy	<u>400 Ohms</u> Damping:	<u>0%</u> Reject:	<u>1.0 MHz</u> Frequency:	<u>P/E</u> Mode:	<u>Off:</u> DAC:	<u>Off:</u> TVG:	<u>Off:</u> CSC:	<u>Off:</u> DGS:	Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>CS/CL</u> Material	<u>N/A</u> Size	<u>7.0"</u> Thickness																																																																																											
Initial Cal: <u>1042</u>		Exam Start: <u>1:18:00 PM</u>																																																																																											
Cal Check: <u>N/A</u>		Exam End: <u>2:45:00 PM</u>																																																																																											
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>07225</u>																																																																																											
Final Cal: <u>1518</u>	Couplant:	Batch																																																																																											
<u>255562</u> Thermometer	<u>90° F</u> Initial Cal Temp.	<u>90° F</u> Final Cal Temp:																																																																																											
Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.																																																																																							
ID Notch	<u>7.0"</u>	1X	<u>80%</u>	<u>1.93"</u>	<u>20.7"</u>	<u>6.7</u>																																																																																							
		1X																																																																																											
<u>KBA</u> Manufacturer:	<u>01FRPF</u> Serial No.:	<u>50"x1"/Rect.</u> Size/Shape:																																																																																											
<u>1.0 in.</u>	<u>70</u>	<u>70°</u>																																																																																											
Incident Point:	Nominal Angle:	Measured Angle:																																																																																											
<u>1.0 MHz</u>	<u>113-891-600</u>	<u>Shear</u>																																																																																											
Frequency:	Model:	Mode:																																																																																											
<u>RG-174</u> Cable Type:	<u>9'</u> Length:	<u>0</u> Connectors:																																																																																											
<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574011</u> Serial No.:																																																																																												
<u>17.13 µs</u> Zero:	<u>0.1273 in / µsec</u> Velocity:																																																																																												
<u>0.8 - 3.0 MHz</u> Narrowband Filter:																																																																																													
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:																																																																																												
<u>31.0 in.</u> Range:	<u>Sq. / Med</u> Pulser/Energy																																																																																												
<u>400 Ohms</u> Damping:	<u>0%</u> Reject:																																																																																												
<u>1.0 MHz</u> Frequency:	<u>P/E</u> Mode:																																																																																												
<u>Off:</u> DAC:	<u>Off:</u> TVG:																																																																																												
<u>Off:</u> CSC:	<u>Off:</u> DGS:																																																																																												
Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																										
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																										
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																										
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>																																																																																										
Exam Data for Component: <u>N3D NOZ</u> <u>VESSEL-NOZZLE (MAIN STEAM)</u> Configuration: <table style="width:100%;"> <tr> <td style="text-align: center;"><u>OD Plate</u> Exam Surface:</td> <td style="text-align: center;"><u>100° F</u> Component Temp.</td> </tr> </table> <table style="width:100%;"> <tr> <th>Examination Area</th> <th>Exam Angle</th> <th>Rotation Angle</th> <th>Wedge S/N</th> <th>Scan dB</th> <th>Recordable Indications</th> </tr> <tr> <td><u>0-6.0"</u></td> <td><u>70°</u></td> <td><u>±46</u></td> <td><u>N/A</u></td> <td><u>64.3</u></td> <td><u>NRI</u></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>			<u>OD Plate</u> Exam Surface:	<u>100° F</u> Component Temp.	Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications	<u>0-6.0"</u>	<u>70°</u>	<u>±46</u>	<u>N/A</u>	<u>64.3</u>	<u>NRI</u>																																																																													
<u>OD Plate</u> Exam Surface:	<u>100° F</u> Component Temp.																																																																																												
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications																																																																																								
<u>0-6.0"</u>	<u>70°</u>	<u>±46</u>	<u>N/A</u>	<u>64.3</u>	<u>NRI</u>																																																																																								
Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations. 0% Reject = Off. Exams performed to maintain a 20% - 30% FSH clad roll. (IRS, clad material) Scanned CW and CCW. Calibration for nozzle to vessel weld (N/V).																																																																																													
<table style="width:100%;"> <tr> <td style="width:25%;"> <u>WWR</u> <u>Wallace Reid</u> Initials: Examiner: </td> <td style="width:10%;"> <u>II</u> Level: </td> <td style="width:15%;"> <u>3/5/2008</u> Cal/Exam Date: </td> <td style="width:20%;">  Utility Reviewed By: </td> <td style="width:30%;"> <u>3/18/08</u> Date: </td> </tr> <tr> <td>  GE Reviewed By: </td> <td> <u>III</u> Level: </td> <td> <u>3/18/08</u> Date: </td> <td>  ABRI Reviewed By: </td> <td> <u>3/22/08</u> Date: </td> </tr> </table>			<u>WWR</u> <u>Wallace Reid</u> Initials: Examiner:	<u>II</u> Level:	<u>3/5/2008</u> Cal/Exam Date:	 Utility Reviewed By:	<u>3/18/08</u> Date:	 GE Reviewed By:	<u>III</u> Level:	<u>3/18/08</u> Date:	 ABRI Reviewed By:	<u>3/22/08</u> Date:																																																																																	
<u>WWR</u> <u>Wallace Reid</u> Initials: Examiner:	<u>II</u> Level:	<u>3/5/2008</u> Cal/Exam Date:	 Utility Reviewed By:	<u>3/18/08</u> Date:																																																																																									
 GE Reviewed By:	<u>III</u> Level:	<u>3/18/08</u> Date:	 ABRI Reviewed By:	<u>3/22/08</u> Date:																																																																																									

REPORT NO. Q2R19-083

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS								
PLANT		Quad 2						
PREPARED BY		S.C. MORTENSON			DATE 02/25/08			
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	OFFSET	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
MAIN STEAM								
N/V Weld (M)	PLATE	0 - 4.0"	60.0°	-	± 25° - 70°	FLAT	14.0"	1 MHz
N/V Weld/Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 46°	FLAT	25.3"	1 MHz
Zone 2a (M)	ODBR	60° - 90°	66.4°	-	24.1°	4.0"	16.3"	1 MHz
CORE SPRAY								
N/V Weld/Zone 1 (M)	PLATE	0 - 7.0"	60.0°	-	± 55°	FLAT	14.0"	1 MHz
Zone 1 (M)	PLATE	0 - 6.0"	70.0°	-	± 25°	FLAT	19.6"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	10.6"	1 MHz
CRD								
N/V Weld (M)	PLATE	0 - 6.5"	45°	-	± 20.0° - 60.0°	FLAT	9.3"	1 MHz
Zone 1 (M)	PLATE	0 - 7.5"	60.0°	-	± 15°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 11.0"	70.0°	-	± 15°	FLAT	17.2"	1 MHz
Zone 2A (M)	ODBR	55° - 90°	66.3°	-	16.7°	3.1"	3.6"	1 MHz
JET PUMP INSTRUMENT								
N/V Weld (M)	PLATE	5.0 - 10.0"	55.0°	-	± 20° - 60°	FLAT	11.8"	1 MHz
Zone 1 (M)	PLATE	6.0 - 11.0"	60.0°	-	± 20°	FLAT	13.9"	1 MHz
Zone 2A (M)	PLATE	0 - 14.0"	70.0°	-	± 25°	FLAT	17.2"	1 MHz
Zone 2A (M)	PLATE	0 - 6.0"	80.0°	-	± 20°	FLAT	9.0"	1 MHz
TOP HEAD VENT (N7) - 0° Offset								
N/V Weld (M)	PLATE	0 - 9.0"	60.0°	-	± 25.0° - 55.0°	FLAT	8.4"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	70.0°	-	± 20°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	-	± 17°	FLAT	13.0"	1.0 MHz
ZONE 2A (M)	ODBR	40° - 90°	50.0°	-	26°	1.9"	2.5"	1.0 MHz
TOP HEAD SPRAY (N6) - 48° Offset								
N/V Weld (M)	PLATE	0 - 8.0"	45.0°	-	± 15.0° - 85.0°	FLAT	5.7"	1.0 MHz
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	-	± 15.0° - 90.0°	FLAT	8.4"	1.0 MHz
ZONE 1 (M)	PLATE	0 - 7.5"	70.0°	-	± 45°	FLAT	13.6"	1.0 MHz
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	-	± 21°	FLAT	17.0"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	13°	1.9"	6.8"	1.0 MHz
ZONE 2A (M)	ODBR	25° - 85°	50.0°	-	30°	1.9"	6.4"	1.0 MHz
ZONE 2A (M)	ODBR	45° - 70°	50.0°	-	26°	1.9"	9.4"	1.0 MHz
SBLIC N10								
N/V Weld (M)	PLATE	4.5" - 9.0"	45.0°	-	± 17° - 51°	FLAT	9.1"	1 MHz

NOTES: M4 MANUAL
 30X4" (60X4") WEDGE / FIXTURE ROTATION ANGLE

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ (704) 577-3770

W-039 ✓

W-031, W-032 ✓

W-031, W-032 ✓

W-131 /


W-180 ✓

W-132 ✓

W-131 ✓

Chris Minor
Digitally signed by Chris Minor
 DN: cn=Chris Minor, o=CCNPP, ou=CCNPP, email=Chris.Minor@ccnpp.com, c=US

SME Review / Date


 R. L. MAY
 03/04/08
 Site Review / Date

Quad Cities Unit-2, 2008


Page 7 of 8

Quad Cities Unit-2 N3 - Main Steam

60° NS Exam Volume = 31.0 Sq. In.
60° FV S6 Exam Volume = 43.6 Sq. In.
60° FV S4 / 15%T IRS Exam Volume = 9.4 Sq. In.

60° NS T-Scan achieved = 1.8 Sq. In.
60° FV S6 T-Scan achieved = 28.5 Sq. In.
60° FV S4 T-Scan achieved = 9.4 Sq. In.

60° NS P-Scan achieved = 1.4 Sq. In.
60° FV S6 P-Scan achieved = 18.1 Sq. In.
Inner 15%T IRS-Scan achieved = 9.4 Sq. In. (By modeling.)



REPORT NO. 20019-003

Quad Cities Unit 2 / Q2R19



GE Hitachi Nuclear Energy

Reactor Pressure Vessel Coverage Calculation Sheet

Quad Cities Unit 2 / Q2R19
N3D VES-NOZ (Main Steam)
Spring / 2008

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 84.		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° T-Scan (S4 UC)	A	9.4	9.4	11.2%	360	5.6%
60° T-Scan (S6 FV)	A	43.6	28.5	33.9%	360	17.0%
60° T-Scan (S6 NS)	A	31	1.8	2.1%	360	1.1%
IRS P-Scan (S4 UC)	A	9.4	9.4	11.2%	360	5.6%
60° P-Scan (S6 FV)	A	43.6	18.1	21.5%	360	10.8%
60° P-Scan (S6 NS)	A	31	1.4	1.7%	360	0.8%
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						
60° T-Scan (S4 UC)						
60° T-Scan (S6 FV)						
60° T-Scan (S6 NS)						
IRS P-Scan (S4 UC)						
60° P-Scan (S6 FV)						
60° P-Scan (S6 NS)						

% Total Composite Coverage = 40.8%

Rev. 0 9/23/05

Comments: A - Manual exam was restricted due to the nozzle configuration.
IRS P-Scan coverage validated by modeling.

Note - Rounding methods may affect calculated values. UC-Underclad, FV-Full volume, NS-Near Surface. Weld length in inches or degrees.

REPORT NO. 200219-083


GE NUCLEAR ENERGY
UT EXAMINATION SUMMARY SHEET
Report No: Q2R17-90
WO No: 580048, 573013

PROJECT: Quad Cities Unit-2, Q2R17
WELD ID: N4A NOZ, N4A IRS and N4A (NUREG 0619)
SYSTEM: Reactor Pressure Vessel

CALIBRATION ID: NOZ.IN, NOZ.IN.1, IRS.IN
GERIS DATA: Scan file types: P1, P2, P3, TL, Z1, Z2A, Z2B and Z3
MANUAL DATA: UT-063, UT-064, UT-065, UT-066
EXAMINERS: S. Gauthier Lv II, K. Montgomery Lv II, B. Dummer Lv III

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds and NUREG-0619.

Examination volumes were in accordance with Section XI, Figure IWB-2500-7 (a) and NUREG-0619.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-705 V4, using 0° L, 60° RL, and 45° S, search units. Nozzle Inner Radius and Inner 15%T examination volume parallel scans were performed using model validated shear wave search units.

Supplemental manual examinations from the ODBR surface (Zones 1 and 2A) were performed in accordance with procedure GE-UT-311 V10 to obtain additional coverage, in areas examined by the automated system, due to inadequate ID signal characteristics.

Scanning was performed from the vessel OD shell, OD Blend Radius and OD Nozzle Boss surfaces examining the nozzle to shell weld, nozzle inner radius section and NUREG 0619 specified bore regions.

No indications were recorded.

Previous data (QDC-001 and QDC-005 from 1995) was reviewed prior to completing this summary. No significant changes were noted.

Scanning was limited due to the nozzle configuration, thermocouple pad and bioshield interferences.

Coverage = 33% Nozzle to Shell weld.
 Coverage = 100% Nozzle Inner Radius Section
 Coverage = 100% NUREG-0619 Bore regions.

 PREPARED BY UT Level: <u>III</u>	3/10/04 DATE	 REVIEWED BY UT Level: <u>III</u>	3-12-04 DATE	 UTILITY REVIEW DATE	3/10/04 DATE	 ANII REVIEW DATE	3/19/04 DATE
---	-----------------	---	-----------------	----------------------------	-----------------	-------------------------	-----------------

Quad Cities Unit-2, 2004



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4A-NOZ

Report No.: Q2R17-90
Exam Data Sheet: N4A-01

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4a.p1.1	02B	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	1
n4a.p2.1	02B	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4a.p2.2	02B	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4a.p2.3	02B	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4a.p2.4	02B	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4a.p3.1	02B	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	1
n4a.p3.2	02B	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	1
n4a.p3.3	02B	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	1
n4a.tl.1	01B	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1
n4a.tl.2	01B	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1, 2
n4a.tl.3	01B	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1

Comments: (1) - Plate segregates observed in vessel plate.

Scanning performed with high profile triple pack, low profile tractor and 11" arm.

(2) - Poor contact / liftoff Ch. 1, 0° L-wave channel for indication characterization. Not required for detection.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CM

Level: III

Date: 2/29/04

Reviewed By: BIM

Level: III

Date: 3-10-04

Page 2 of 19

Quad Cities Unit-2, 2004

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4A-IRS

Report No.: Q2R17-90
Exam Data Sheet: N4A-02

File	Disk	Scan Type	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
n4a.z1.1	01B	Z1	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~	~	~
n4a.z2a.1	01B	Z2A	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~
n4a.z2a.2	01B	Z2A	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~
n4a.z2a.3	01B	Z2A	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~

Comments: None.

Scanning performed with ODBR package, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CPM

Level: III

Date: 2/29/04


Reviewed By: B/M D

Level: III

Date: 3-1-04

Page 3 of 19

Quad Cities Unit-2, 2004



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4A-IRS

Report No.: Q2R17-90
Exam Data Sheet: N4A-03

File	Disk	Scan Type															Remarks
			Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	
n4a.z2b.1	06A	Z2B	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4a.z3.1	06A	Z3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4a.z3.2	06A	Z3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4a.z3.3	06A	Z3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with NOZOD package, safe end tractor and safe end arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CP MT

Level: III

Date: 3/4/04

Reviewed By: B/M Dunn

Level: III

Date: 3-6-04

Page 4 of 19

Quad Cities Unit-2, Q2R17

Q2R17-90

Page 5 of 19

GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET				CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17								
PROCEDURE NO. : GE-UT-705 V4				REVISION : N/A				DRR : N/A				
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD
n4a.tl.1	N4A	01B	02/28/04	0056	0130	282°	166°	116°	92°	N/A	N/A	NOZ.IN
n4a.tl.2	N4A	01B	02/28/04	0754	0817	280°	4°	84°	92°	N/A	N/A	NOZ.IN
n4a.tl.3	N4A	01B	02/28/04	0850	0928	2°	168°	166°	92°	N/A	N/A	NOZ.IN
n4a.p3.1	N4A	02B	02/28/04	1001	1040	270°	110°	200°	92°	N/A	N/A	NOZ.IN
n4a.p3.2	N4A	02B	02/28/04	1045	1055	109°	141°	32°	92°	N/A	N/A	NOZ.IN
n4a.p3.3	N4A	02B	02/28/04	1733	1758	271°	141°	131°	92°	N/A	N/A	NOZ.IN
n4a.p1.1	N4A	02B	02/28/04	1822	1942	270°	271°	361°	92°	N/A	N/A	NOZ.IN
n4a.p2.1	N4A	02B	02/28/04	2008	2057	270°	23°	247°	92°	N/A	N/A	NOZ.IN
n4a.p2.2	N4A	02B	02/28/04	2115	2130	25°	340°	45°	92°	N/A	N/A	NOZ.IN
n4a.p2.3	N4A	02B	02/28/04	2207	2215	342°	329°	13°	92°	N/A	N/A	NOZ.IN
n4a.p2.4	N4A	02B	02/29/04	0611	0622	269°	330°	61°	92°	N/A	N/A	NOZ.IN
COMMENTS : * Rotation angles for TL and P exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached).						Search Unit Data:				Freq.	Rot.	
The GERIS 0° reference is located 90° CW of nozzle TDC.						No.	Model / Mode	S/N	Size	(MHz.)	Angle	
						1	RTD, 0° L2.25 / L	01-231	1.0 Dia	2.25	N/A	
						2	RTD, 45° T1-St / S	01-233	32x22mm	1.00	*	
						3	RTD, 60° L2-St / L	97-154	30x25mm	2.00	*	
Automated scanning was restricted due to the nozzle weld configuration.						4	RTD, 45° T1-St / S	04-8	32x22mm	1.00	*	
OPERATORS: SHANE GAUTHIER LvII KENT MONTGOMERY LvII				SOFTWARE REVISION: 5.26		6	RTD, 70° TRL2-St / L	96-228	2(12x25)mm	2.00	*	
				THERMOMETER S/N : 235018		13	RTD, 60° T1-St / S	01-234	32x18mm	1.00	*	
						14	RTD, 60° T1-St / S	01-235	32x18mm	1.00	*	
				COUPLANT : Demineralized Water								

Quad Cities Unit-2, Q2R17

				GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET						CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17			
PROCEDURE NO. : <u>GE-UT-705 V4</u>				REVISION : <u>N/A</u>		DRR : <u>N/A</u>							
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD	
n4a.z1.1	N4A IRS	01B	02/29/04	1135	1154	271°	272°	361°	92°	N/A	N/A	IRS.IN	
n4a.z2a.1	N4A IRS	01B	02/27/04	2301	2319	282°	178°	104°	92°	N/A	N/A	IRS.IN	
n4a.z2a.2	N4A IRS	01B	02/27/04	2337	2347	180°	59°	121°	92°	N/A	N/A	IRS.IN	
n4a.z2a.3	N4A IRS	01B	02/28/04	0913	0923	281°	61°	140°	92°	N/A	N/A	IRS.IN	
n4a.z2b.1	N4A IRS	06A	03/03/04	0834	0859	323°	35°	288°	98°	N/A	N/A	IRS.IN	
n4a.z3.1	N4A IRS	06A	03/04/04	0712	0725	35°	202°	167°	98°	N/A	N/A	IRS.IN	
n4a.z3.2	N4A IRS	06A	03/04/04	0729	0739	200°	310°	110°	98°	N/A	N/A	IRS.IN	
n4a.z3.3	N4A IRS	06A	03/04/04	0743	0745	308°	323°	15°	98°	N/A	N/A	IRS.IN	
COMMENTS : * Rotation angles for all exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached). The GERIS 0° reference is located 90° CW of nozzle TDC.						Search Unit Data:				Freq.	Rot.		
						No.	Model / Mode	S/N	Size	(MHz.)	Angle		
						9	KBA, 389-018-980 / S	00XL6V	0.5 x 1.0	2.25	N/A		
						10	KBA, 389-018-980 / S	00XL6Y	0.5 x 1.0	2.25	*		
Z1 and Z2A exams unrestricted. Z2B and Z3 scans limited by thermocouples and bioshield interference.						11	KBA, 389-018-980 / S	00XL6L	0.5 x 1.0	2.25	*		
						12	KBA, 389-018-980 / S	00XL6M	0.5 x 1.0	2.25	*		
OPERATORS: SHANE GAUTHIER LvII KENT MONTGOMERY LvII						13	RTD, 28° T2-St / S	98-1178	18 x 14mm	2.00	*		
						14	RTD, 28° T2-St / S	01-240	18 x 14mm	2.00	*		
COUPLANT : <u>Demineralized Water</u>													

Q2R17-90

Page 6 of 19



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Data Report Number: Q2R17-90

Linearity Sheet: L-008

Outage: Q2R17

Data Sheet Number: UT-063

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSC</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1520</u>		Exam Start <u>16:40</u>
Cal Check: <u>N/A</u>		Exam End <u>17:10</u>
Cal Check: <u>N/A</u>	<u>Ultracal II</u>	<u>01225</u>
Final Cal: <u>1725</u>	Couplant:	Batch
<u>255018</u>	<u>89° F</u>	<u>89° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>19.4</u>	<u>20.65</u>	<u>8.2</u>
		<u>1X</u>				

DAC @ 1X 58

Sweep 0-10 25 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>010HXL</u>	<u>0.5"x1.0"/Rect</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.0 in.</u>	<u>70°</u>	<u>68°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u>	<u>113-892-600</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>16.4 us</u>	<u>0.1283 in /usec</u>
Zero:	Velocity:
	<u>0.8 - 3.0 MHz</u>
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>25.0 in.</u>	<u>Sq. / Med</u>
Range:	Pulser/Energy
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>2.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off:</u>	<u>Off:</u>
DAC:	TVG:
<u>Off:</u>	<u>Off:</u>
CSC:	DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Exam Data for Component: N4A IRS

VESSEL-NOZZLE (FEEDWATER)

Configuration:

<u>ODBR</u>	<u>99° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>67.5</u>
<u>21.7</u>	<u>W-029A</u>
<u>70</u>	<u>NRI</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 2A CW

Exams performed to maintain a 5% FSH ID roll.

RD Brad Dummer

Initials: Examiner:

III

Level

3/5/04

Cal/Exam Date:

[Signature]

Utility Reviewed By:

3/14/04

Date:

CP MT

GE Reviewed By:

Level:

3/16/04

Date:

[Signature]

AMR Reviewed By:

3/19/04

Date:

Page 7 of 19



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Data Report Number: Q2R17-90

Linearity Sheet: L-008

Outage: Q2R17

Data Sheet Number: UT-084

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSC</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1520</u>		Exam Start: <u>16:40</u>
Cal Check: <u>N/A</u>		Exam End: <u>17:10</u>
Cal Check: <u>N/A</u>	<u>Ultracal II</u>	<u>01225</u>
Final Cal: <u>1725</u>	Couplant:	Batch
<u>255018</u>	<u>89° F</u>	<u>89° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>19.4</u>	<u>20.65</u>	<u>8.2</u>
		<u>1X</u>				

DAC @ 1X 61

Sweep 0-10 25 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>004NMY</u>	<u>0.5"x1.0" / Rect.</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.0 in.</u>	<u>70°</u>	<u>68°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u>	<u>113-292-600</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panometrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>16.4 us</u>	<u>0.1283 in /usec</u>
Zero:	Velocity:
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>25.0 in.</u>	<u>Sq. / Med</u>
Range:	Pulsar/Energy
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>2.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off:</u>	<u>Off:</u>
DAC:	TVG:
<u>Off:</u>	<u>Off:</u>
CSC:	DGS:

Exam Data for Component: N4A IRS

VESSEL-NOZZLE (FEEDWATER)

Configuration:

<u>ODBR</u>	<u>99° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>67.5</u>
<u>21.7</u>	<u>W-029B</u>
<u>70</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 2A CCW

Exams performed to maintain a 5% FSH ID roll.

RD Brad Dummer

Initials: Examiner:

III

Level:

3/5/04

Cal/Exam Date:

[Signature]

Utility Reviewed By:

3/10/04

Date:

CPM

GE Reviewed By:

[Signature]

Level:

3/16/04

Date:

[Signature]

AMII Reviewed By:

3/11/04

Date:



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2
Outage: Q2R17

Data Report Number: Q2R17-90 Linearity Sheet: L-008
Data Sheet Number: UT-085

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSC</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1520</u>		Exam Start: <u>16:40</u>
Cal Check: <u>N/A</u>		Exam End: <u>17:10</u>
Cal Check: <u>N/A</u>	<u>Ultracal II</u>	<u>01225</u>
Final Cal: <u>1725</u>	Couplant:	Batch
<u>255018</u>	<u>89° F</u>	<u>89° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	1X	<u>80</u>	<u>7.0</u>	<u>10.2</u>	<u>4.1</u>
		1X				

DAC @ 1X 47

Sweep 0-10 25 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>010HXJ</u>	<u>0.5"x1.0" / Rect</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.0 in.</u>	<u>45°</u>	<u>44°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u>	<u>113-892-600</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>12.3 us</u>	<u>0.1283 in / us</u>
Zero:	Velocity: ~
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>25.0 in.</u>	<u>Sq. / Med</u>
Range:	Pulsar/Energy
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>2.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off:</u>	<u>Off:</u>
DAC:	TVG:
<u>Off:</u>	<u>Off:</u>
CSC:	DGS:

Exam Data for Component: N4A IRS

VESSEL-NOZZLE (FEEDWATER)

Configuration:

<u>ODBR</u>	<u>98° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>43.8</u>
<u>40.3</u>	<u>W-027B</u>
<u>60</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 1 CCW.

Exams performed to maintain a 5% FSH ID roll.

BD Brad Dummer
Initials: Examiner:

III 3/5/04
Level Cal/Exam Date:

[Signature] 3/10/04
Utility Reviewed By: Date:

CD 15
GE Reviewed By:

IV 3/6/04
Level: Date:

[Signature] 3/10/04
AMR Reviewed By: Date:



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Data Report Number: Q2R17-90

Linearity Sheet: L-008

Outage: Q2R17

Data Sheet Number: UT-068

Procedure: GE-UT-311

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSCI</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1520</u>		Exam Start: <u>16:40</u>
Cal Check: <u>N/A</u>		Exam End: <u>17:10</u>
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>01225</u>
Final Cal: <u>1725</u>	Couplant:	Batch
<u>255018</u>	<u>89° F</u>	<u>89° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>7.0</u>	<u>0.2</u>	<u>4.1</u>
		<u>1X</u>				

DAC @ 1X 47

Sweep 0-10 25 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>0103X1</u>	<u>0.5"x1.0" / Rect</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.0 in.</u>	<u>45°</u>	<u>44°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u>	<u>113-892-600</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>12.3 us</u>	<u>0.1283 in /usec</u>
Zero:	Velocity:
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>25.0 in.</u>	<u>Sq. / Med</u>
Range:	Pulser/Energy
<u>400 Ohms</u>	<u>Full</u>
Damping:	Reject:
<u>2.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off.</u>	<u>Off.</u>
DAC:	TVG:
<u>Off.</u>	<u>Off.</u>
CSC:	DGS:

Exam Data for Component: N4A IRS

VESSEL-NOZZLE (FEEDWATER)

Configuration:

<u>ODBR</u>	<u>99° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>43.8</u>
<u>40.3</u>	<u>W-027A</u>
<u>80</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 1 CW

Exams performed to maintain a 5% FSH ID roll.

BD Brad Dummer

Initials: Examiner:

III

Level

3/5/04

Cal/Exam Date:

[Signature]

Utility Reviewed By:

3/10/04

Date:

CP MT

GE Reviewed By:

[Signature]

Level:

Date:

[Signature]

ANIR/Reviewed By:

3/10/04

Date:

Report No.: Q2R17-90

Feedwater N4A-NOZ Quad Cities Unit-2, 2004

Weld Length = 360. Exam Volume = 82.2		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
70° T-Scan	A	29.9	2.7	3.3%	360	1.6%
45° T-Scan	A	43.2	22.4	27.3%	360	13.6%
60° T-Scan	A	9.1	5.5	6.7%	360	3.3%
70° P-Scan	A	29.9	0	0.0%	360	0.0%
45° P-Scan	A	43.2	14.9	18.1%	360	9.1%
60° P-Scan	A	9.1	9.1	11.1%	360	5.5%
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						

% Total Composite Coverage = 33%


Comments: A - Examined accessible length. Scanning limited due to scanner access.

Note - Rounding methods may make calculated values appear in error.


Quad Cities Unit-2, Q2R17

Page 11 of 19

Quad Cities Unit-2 Feedwater N4A



Quad Cities Unit-2 Feedwater N4A



Guideline for Deciding when to Perform Manual UT Examination of Areas Not Covered by Automated Examinations

Component/Configuration: N4A NO2

A. DETERMINE

1. Percent coverage obtained with automated UT: 33 %
2. Approximate radiation dose received to complete automated UT: 1800 mR

B. ESTIMATE

1. Percent coverage increases if manual UT was performed: + 7 % *
2. Radiation dose expected if manual UT was performed: 2000 mR

Decision to Proceed: YES X NO Based On: DOSE

Prepared By: L.L. My Date: 03/05/04

* ALL UPPER WELD COVERAGE, NOT
WELD ON HAZ ON ID.

Q2R17-90
14 OF 19


Report No.: Q2R17-90

Feedwater N4A-IRS Quad Cities Unit-2, 2004

Weld Length = 360. Exam Volume = 100%		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area %	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Z1 CW	A	100%	100%	100.0%	360	50.0%
Z1 CCW	A	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2A CW	A	100%	100%	100.0%	360	50.0%
Z2A CCW	A	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2B CW	A	100%	100%	100.0%	285	39.6%
Z2B CCW	A	100%	100%	100.0%	285	39.6%
% Total Composite Coverage =						79.2%
Z3 CW	A	100%	100%	100.0%	285	39.6%
Z3 CCW	A	100%	100%	100.0%	285	39.6%
% Total Composite Coverage =						79.2%

Comments: A - Examined accessible length. Exam volume determined by modeling, 100% assigned volume.
Scanning limited due to bioshield interference at 320° CW to 35°.
100% Z2B and Z3 Coverage (Single side access) obtained throughout. See attached drawing. Non-PDI exam.
Note - Rounding methods may make calculated values appear in error.

Zone 2B and Zone 3 Scan Areas
100% Coverage (Single Side) Obtained Throughout.



Nir_PDI Qc2.XLS

MANUAL/GERIS 2000 DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Quad Cities 2					
PREPARED BY		S.C. MORTENSON			DATE		
					01/17/04		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld	PLATE	0 - 9.0"	66.0°	57.8° (52.4°) *	FLAT	18.5"	1 MHz
N/V Weld	PLATE	0 - 9.0"	70.0°	42.1° 37.0° *	FLAT	25.3"	1 MHz
Zone 1/NV (M)	ODBR	20° - 45°	35.0°	90.0°	5.5"	20.7"	1 MHz
Zone 2A	ODBR	45° - 90°	60.0°	35.0° (30.6°) **	5.5"	20.4"	1 MHz
RECIRC INLET							
N/V Weld	PLATE	0 - 8.0"	60.0°	38.0° (27.3°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.5"	80.0°	45.0° (35.5°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	PLATE	0 - 8.0"	68.0°	25.7° (16.0°) *	FLAT	21.2"	1 MHz
Zone 1	PLATE	0 - 9.0"	70.0°	15.6° (8.5°) *	FLAT	22.9"	1 MHz
Zone 2A	ODBR	55° - 90°	67.5°	18.1° (8.2°) **	3.3"	12.0"	1 MHz
FEEDWATER							
N/V Weld	PLATE	0 - 8.0"	60.0°	48.2° (39.2°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	60.0°	38.9° (28.3°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	40.3° (31.8°) **	3.5"	19.3"	2.25 MHz
Zone 2A	ODBR	50° - 90°	67.5°	21.7° (13.2°) **	3.5"	13.4"	2.25 MHz
Zone 2B	NOZOD	ALL	28.0°	68.0°	FLAT	7.5"	2 MHz
Zone 3	NOZOD	ALL	28.0°	90°	FLAT	6.7"	2 MHz

W-021, W-022
W-023, W-024

W-025, W-026

W-027, W-028
W-029, W-030

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0" PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45" PKG OFFSET
	--	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5" OFFSET
	---	DESIGN / (FIXTURE) ROTATION FOR 1.5" PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253

1/28/04
17 of 19
QUAD CITIES
REPORT NO. Q2R17-90
PAGE 16 OF 17



GE Nuclear Energy

GERIS 2000 OD Nozzle Examination Scan Plan

Quad Cities Unit-2, 2004
Nozzle Scanning Limits
Nozzle(s) N4

12.75 Weld CL Radius
18.10 ASME OD Radius
16.75 Outside Radius of ODBR
13.00 Outside Radius of NOZOD

125.50 Vessel ID Radius
6.38 Vessel Nom. Thickness
131.88 Vessel OD Radius
1.0 Overscan Distance

Package Configuration: Triple Pack and ODBR Package.

Channel	Beam Angle	CPU Angle	Fixture Angle	Type	Delay	SU Parameters Velocity	X-Off	Y-Off	Scan Area	Scanner Min	Scanner Max	A-Gate Start	A-Gate Stop	A-Gate Max MP	C-Gate Start	C-Gate Stop
N4 T-Scan. Supplement 4 and 6 radial scans. Step → 0.25 Index → 0.4°																
1	0	0.0	0.0	WM	4	0.233	0.0	0.0	N/A	Note 1	19.25	0	75	8.3	18	54
2	45	-9.0	9.0	T	15	0.128	3.0	0.0	N/A	Note 1	13.25	0	230	13.8	37	191
3	60	7.2	352.8	T	15	0.233	-3.0	0.0	N/A	Note 1	19.25	0	180	19.2	32	152
N4 P1. 45° S for outer 85%T volume. Step → 0.25 Index → 0.5°																
2	45	51.3	308.7	P	15	0.128	3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
4	45	-51.3	51.3	P	15	0.128	-3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
N4 P2. N/V Inner 15%T P-scan examination from PLATE with 70T-scan. Step → 0.15 Index → 0.5°																
13	60	39.2	320.8	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
6	70	0.0	0.0	T	10	0.233	0.0	0.0	N/A	Note 1	9.30	0	50	4.7	10	48
14	60	-39.2	39.2	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 P3. N/V Inner 15%T P-scan examination from PLATE. Step → 0.15 Index → 0.5°																
13	60	28.3	331.7	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
14	60	-28.3	28.3	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 Z1. Z1 Inner Radius Section examination from ODBR Step → 0.07 Index → 1.7°																
9	43.8	31.8	328.2	Z1	15	0.128	-2.5	0.0	N/A	50°	90°	0	410	19.3	165	335
10	43.8	-31.8	31.8	Z1	15	0.128	2.5	0.0	N/A	50°	90°	0	410	19.3	165	335

Scan Plan QC2-2004.xls Working N4

Channel	Beam	CPU	Fixture	Type	SU Parameters				Scan Area	Scanner		A-Gate			C-Gate	
	Angle	Angle	Angle		Delay	Velocity	X-Off	Y-Off		Min	Max	Start	Stop	Max MP	Start	Stop
N4 Z2A. Z2A Inner Radius Section examination from ODBR										Step →	0.07	Index →	1.7°			
11	67.5	13.2	346.8	Z2A	15	0.128	-2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
12	67.5	-13.2	13.2	Z2A	15	0.128	2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
N4 Z2B. Z2A Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	68.0	292.0	Z2B	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-68.0	68.0	Z2B	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
N4 Z3. Z3 Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	90.0	270.0	Z3	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-90.0	90.0	Z3	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
Notes: Vessel ID radius from B&W drawing Shell Course Subassembly 151825E-1.																
Vessel nominal thickness from B&W drawing Shell Forming Details 104186D-1 (ordered thickness).																
Note 1 - Scan into nozzle until onset of liftoff or limited by physical limitations.																
															Site Revision 0 2/22/04	

QUAD CITIES
REPORT NO. QC-R17-90
PAGE 19 OF 19



GE NUCLEAR ENERGY
UT EXAMINATION SUMMARY SHEET

Report No: Q2R17-91
WO No: 580046, 580047

PROJECT: Quad Cities Unit-2, Q2R17
WELD ID: N4B NOZ, N4B IRS and N4B (NUREG 0619)
SYSTEM: Reactor Pressure Vessel

CALIBRATION ID: NOZ.IN, NOZ.IN.1, IRS.IN
GERIS DATA: Scan file types: P1, P2, P3, TL, Z1, Z2A, Z2B and Z3
MANUAL DATA: N/A
EXAMINERS: S. Gauthier Lv II, K. Montgomery Lv II

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds and NUREG-0619.

Examination volumes were in accordance with Section XI, Figure IWB-2500-7 (a) and NUREG-0619.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-705 V4, using 0° L, 60° RL, and 45° S, search units. Nozzle Inner Radius and Inner 15%T examination volume parallel scans were performed using model validated shear wave search units.


Scanning was performed from the vessel OD shell, OD Blend Radius and OD Nozzle Boss surfaces examining the nozzle to shell weld, nozzle inner radius section and NUREG 0619 specified bore regions.

No indications were recorded.

Previous data (QDC-002 and QDC-006 from 1995) was reviewed prior to completing this summary. No significant changes were noted.

Scanning was limited due to the nozzle configuration and bioshield interferences.

Coverage = 33% Nozzle to Shell weld.
Coverage = 100% Nozzle Inner Radius Section
Coverage = 100% NUREG-0619 Bore regions.

 PREPARED BY UT Level: <u>III</u>	<u>3/14/04</u> DATE	 REVIEWED BY UT Level: <u>III</u>	<u>3-7-04</u> DATE	 UTILITY REVIEW	<u>3/11/04</u> DATE	 AMI REVIEW	<u>3/19/04</u> DATE
---	-------------------------------	---	------------------------------	---	-------------------------------	--	-------------------------------

Quad Cities Unit-2, 2004

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4B-NOZ

Report No.: Q2R17-91
Exam Data Sheet: N4B-01

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4b.p1.1	01A	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	1
n4b.p1.2	01A	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	1
n4b.p2.1	01A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4b.p2.2	01A	P2	~	~	~	~	~	Void	~	~	~	~	~	~	Void	Void	Void
n4b.p2.3	01A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4b.p2.4	01A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4b.p2.5	01A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4b.p2.6	01A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4b.p2.7	01A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1

Comments: Scan file n4b.p2.2 voided.

Scanning performed with high profile triple pack, low profile tractor and 11" arm.

(1) - Plate segregates observed in vessel plate.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst

CM

Reviewed By:

R/M D

Level:

III

Date:

2/27/04

Level:

III

Date:

2-28-04

Quad Cities Unit-2, 2004

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4B-NOZ

Report No.: Q2R17-91
Exam Data Sheet: N4B-02

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4b.p3.1	02A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	1
n4b.p3.2	02A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	1
n4b.tl.1	02A	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1
n4b.tl.2	02A	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1

Comments: Scanning performed with high profile triple pack, low profile tractor and 11" arm.

(1) - Plate segregates observed in vessel plate.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CO M

Reviewed By: RPM

Level: III

Date: 2/28/04

Level: III

Date: 2-28-04

Page 3 of 16

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4B-IRS

Report No.: Q2R17-91
Exam Data Sheet: N4B-03

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4b.z1.1	03A	Z1	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~	~	~
n4b.z1.2	03A	Z1	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~	~	~
n4b.z2a.1	01B	Z2A	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with ODBR package, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CDM

Reviewed By: B. M. D.

Level: III Date: 3/2/04

Level: III Date: 3-3-04

Quad Cities Unit-2, 2004



GE Nuclear Energy

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4B-IRS

Report No.: Q2R17-91
Exam Data Sheet: N4B-04

File	Disk	Scan		Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type																
n4b.z2b.1	08A	Z2B		~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4b.z2b.2	08A	Z2B		~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4b.z3.1	08A	Z3		~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4b.z3.2	08A	Z4		~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~		~	~	~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with NOZOD package, safe end tractor and safe end arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CA NT

Reviewed By: BLM Dunn

Level: III

Date: 3/5/04

Level: III

Date: 3-6-04

Page 5 of 16

Quad Cities Unit-2, Q2R17

Q2R17-91

Page 6 of 16

				GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET						CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17			
PROCEDURE NO. : GE-UT-705 V4				REVISION : N/A		DRR : N/A							
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD	
n4b.p1.1	N4B	01A	02/27/04	1036	1140	270°	251°	341°	92°	N/A	N/A	NOZ.IN	
n4b.p1.2	N4B	01A	02/27/04	1146	1152	249°	271°	22°	92°	N/A	N/A	NOZ.IN	
n4b.p2.1	N4B	01A	02/27/04	0134	0146	337°	28°	51°	92°	N/A	N/A	NOZ.IN	
n4b.p2.2	~	~	~	~	~	~	~	~	~	~	~	~	
n4b.p2.3	N4B	01A	02/27/04	0524	0533	27°	64°	37°	92°	N/A	N/A	NOZ.IN	
n4b.p2.4	N4B	01A	02/27/04	0911	0939	224°	126°	98°	92°	N/A	N/A	NOZ.IN	
n4b.p2.5	N4B	01A	02/27/04	0945	0948	127°	113°	14°	92°	N/A	N/A	NOZ.IN	
n4b.p2.6	N4B	01A	02/27/04	1230	1251	222°	339°	117°	92°	N/A	N/A	NOZ.IN	
n4b.p2.7	N4B	01A	02/27/04	1308	1318	62°	116°	54°	92°	N/A	N/A	NOZ.IN	
n4b.p3.1	N4B	02A	02/27/04	1403	1510	270°	272°	358°	92°	N/A	N/A	NOZ.IN	
n4b.p3.2	N4B	02A	02/27/04	1531	1532	273°	269°	4°	92°	N/A	N/A	NOZ.IN	
n4b.tl.1	N4B	02A	02/27/04	1608	1646	270°	77°	167°	92°	N/A	N/A	NOZ.IN	
n4b.tl.2	N4B	02A	02/27/04	1702	1747	76°	271°	195°	92°	N/A	N/A	NOZ.IN	
COMMENTS : * Rotation angles for TL and P exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached).						Search Unit Data:				Freq.	Rot.		
						No.	Model / Mode	S/N	Size	(MHz.)	Angle		
The GERIS 0° reference is located 90° CW of nozzle TDC.						1	RTD, 0° L2.25 / L	01-231	1.0 Dia	2.25	N/A		
						2	RTD, 45° T1-St / S	01-233	32x22mm	1.00	*		
						3	RTD, 60° L2-St / L	97-154	30x25mm	2.00	*		
Automated scanning was restricted due to the nozzle weld configuration.						4	RTD, 45° T1-St / S	04-8	32x22mm	1.00	*		
OPERATORS: SHANE GAUTHIER LvII				SOFTWARE REVISION: 5.26		6	RTD, 70° TRL2-St / L	96-228	2(12x25)mm	2.00	*		
KENT MONTGOMERY LvII				THERMOMETER S/N : 235018		13	RTD, 60° T1-St / S	01-234	32x18mm	1.00	*		
						14	RTD, 60° T1-St / S	01-235	32x18mm	1.00	*		
				COUPLANT : Demineralized Water									

Page 895 of 945

Report No.: Q2R17-91

Feedwater N4B-NOZ Quad Cities Unit-2, 2004

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 82.2		Required Exam Area Sq. In.	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
70° T-Scan	A	29.9	2.7	3.3%	360	1.6%
45° T-Scan	A	43.2	22.4	27.3%	360	13.6%
60° T-Scan	A	9.1	5.5	6.7%	360	3.3%
70° P-Scan	A	29.9	0	0.0%	360	0.0%
45° P-Scan	A	43.2	14.9	18.1%	360	9.1%
60° P-Scan	A	9.1	9.1	11.1%	360	5.5%
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						


% Total Composite Coverage = 33%

Comments: A - Examined accessible length. Scanning limited due to scanner access.

Note - Rounding methods may make calculated values appear in error.

Quad Cities Unit-2, Q2R17


Quad Cities Unit-2 Feedwater N4B



Quad Cities Unit-2 Feedwater N4B

70° Exam Volume = 29.9 Sq. In.
45° Exam Volume = 43.2 Sq. In.
Inner 15%T Exam Volume (IRS & 60°T) = 9.1 Sq. In.

70° P-Scan achieved = N/A Sq. In.
45° P-Scan achieved = 14.9 Sq. In.
IRS P-Scan achieved = 9.1 Sq. In. (By model)



Guideline for Deciding when to Perform Manual UT Examination of Areas Not Covered by Automated Examinations

Component/Configuration: N4B NO2

A. DETERMINE

1. Percent coverage obtained with automated UT: 33 %
2. Approximate radiation dose received to complete automated UT: 1800 mR

B. ESTIMATE

1. Percent coverage increases if manual UT was performed: + 7 % *
2. Radiation dose expected if manual UT was performed: 2000 mR

Decision to Proceed: YES X NO Based On: Dose

Prepared By: L. L. May Date: 03/05/04

* ALL UPPER WELD COVERAGE, NOT
WELD ON HAZ ON I.D.

Q2R17-91
" OF 16


Report No.: Q2R17-91

Feedwater N4B-IRS Quad Cities Unit-2, 2004

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area %	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Weld Length = 360. Exam Volume = 100%						
Z1 CW	A/B	100%	100%	100.0%	360	50.0%
Z1 CCW	A/B	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2A CW	A/B	100%	100%	100.0%	360	50.0%
Z2A CCW	A/B	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2B CW	A/B	100%	100%	100.0%	226	31.4%
Z2B CCW	A/B	100%	100%	100.0%	226	31.4%
% Total Composite Coverage =						62.8%
Z3 CW	A/B	100%	100%	100.0%	226	31.4%
Z3 CCW	A/B	100%	100%	100.0%	226	31.4%
% Total Composite Coverage =						62.8%

Comments: A/B - Examined accessible length. Exam volume determined by modeling, 100% assigned volume.
Scanning limited due to bioshield interference at 316° CW to 37° and thermocouple at 145° CW to 198°.
100% Z2B and Z3 Coverage (Single side access) obtained throughout. See attached drawing. Non-PDI exam.
Note - Rounding methods may make calculated values appear in error.

Zone 2B and Zone 3 Scan Areas 100% Coverage (Single Side) Obtained Throughout.



Nir_PDI Qc2.XLS

MANUAL/GERIS 2000 DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Quad Cities 2					
PREPARED BY		S.C. MORTENSON			DATE		
					01/17/04		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld	PLATE	0 - 9.0"	66.0°	57.8° (52.4°) *	FLAT	18.5"	1 MHz
N/V Weld	PLATE	0 - 9.0"	70.0°	42.1° 37.0°) *	FLAT	25.3"	1 MHz
Zone 1/NV (M)	ODBR	20° - 45°	35.0°	90.0°	5.5"	20.7"	1 MHz
Zone 2A	ODBR	45° - 90°	60.0°	35.0° (30.6°) **	5.5"	20.4"	1 MHz
RECIRC INLET							
N/V Weld	PLATE	0 - 8.0"	60.0°	38.0° (27.3°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.5"	60.0°	45.0° (35.5°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	PLATE	0 - 8.0"	68.0°	25.7° (16.0°) *	FLAT	21.2"	1 MHz
Zone 1	PLATE	0 - 9.0"	70.0°	15.6° (8.5°) *	FLAT	22.9"	1 MHz
Zone 2A	ODBR	55° - 90°	67.5°	18.1° (8.2°) **	3.3"	12.0"	1 MHz
FEEDWATER							
N/V Weld	PLATE	0 - 8.0"	60.0°	48.2° (39.2°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	80.0°	38.9° (28.3°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	40.3° (31.8°) **	3.5"	19.3"	2.25 MHz
Zone 2A	ODBR	50° - 90°	67.5°	21.7° (13.2°) **	3.5"	13.4"	2.25 MHz
Zone 2B	NOZOD	ALL	28.0°	68.0°	FLAT	7.5"	2 MHz
Zone 3	NOZOD	ALL	28.0°	90°	FLAT	6.7"	2 MHz

W-021, W-022
W-023, W-024

W-025, W-026

W-027, W-028
W-029, W-030

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0" PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45" PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5" OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5" PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253



GE Nuclear Energy

GERIS 2000 OD Nozzle Examination Scan Plan

Quad Cities Unit-2, 2004
Nozzle Scanning Limits
Nozzle(s) N4

12.75 Weld CL Radius
18.10 ASME OD Radius
16.75 Outside Radius of ODBR
13.00 Outside Radius of NOZOD

125.50 Vessel ID Radius
6.38 Vessel Nom. Thickness
131.88 Vessel OD Radius
1.0 Overscan Distance

Package Configuration: Triple Pack and ODBR Package.

Beam CPU Fixture					SU Parameters				Scan	Scanner		A-Gate			C-Gate	
Channel	Angle	Angle	Angle	Type	Delay	Velocity	X-Off	Y-Off	Area	Min	Max	Start	Stop	Max MP	Start	Stop
N4 T-Scan. Supplement 4 and 6 radial scans.									Step →	0.25	Index →	0.4°				
1	0	0.0	0.0	WM	4	0.233	0.0	0.0	N/A	Note 1	19.25	0	75	8.3	18	54
2	45	-9.0	9.0	T	15	0.128	3.0	0.0	N/A	Note 1	13.25	0	230	13.8	37	191
3	60	7.2	352.8	T	15	0.233	-3.0	0.0	N/A	Note 1	19.25	0	180	19.2	32	152
N4 P1. 45° S for outer 85%T volume.									Step →	0.25	Index →	0.5°				
2	45	51.3	308.7	P	15	0.128	3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
4	45	-51.3	51.3	P	15	0.128	-3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
N4 P2. N/V Inner 15%T P-scan examination from PLATE with 70T-scan.									Step →	0.15	Index →	0.5°				
13	60	39.2	320.8	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
6	70	0.0	0.0	T	10	0.233	0.0	0.0	N/A	Note 1	9.30	0	50	4.7	10	48
14	60	-39.2	39.2	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 P3. N/V Inner 15%T P-scan examination from PLATE.									Step →	0.15	Index →	0.5°				
13	60	28.3	331.7	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
14	60	-28.3	28.3	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 Z1. Z1 Inner Radius Section examination from ODBR									Step →	0.07	Index →	1.7°				
9	43.8	31.8	328.2	Z1	15	0.128	-2.5	0.0	N/A	50°	90°	0	410	19.3	165	335
10	43.8	-31.8	31.8	Z1	15	0.128	2.5	0.0	N/A	50°	90°	0	410	19.3	165	335

QUAD CITIES
REPORT NO. QC2R17-91
PAGE 15 OF 16

Channel	Beam	CPU	Fixture	Type	SU Parameters				Scan	Scanner		A-Gate			C-Gate	
	Angle	Angle	Angle		Delay	Velocity	X-Off	Y-Off	Area	Min	Max	Start	Stop	Max MP	Start	Stop
N4 Z2A. Z2A Inner Radius Section examination from ODBR										Step →	0.07	Index →	1.7°			
11	67.5	13.2	346.8	Z2A	15	0.128	-2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
12	67.5	-13.2	13.2	Z2A	15	0.128	2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
N4 Z2B. Z2A Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	68.0	292.0	Z2B	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-68.0	68.0	Z2B	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
N4 Z3. Z3 Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	90.0	270.0	Z3	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-90.0	90.0	Z3	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
Notes: Vessel ID radius from B&W drawing Shell Course Subassembly 151825E-1.																
Vessel nominal thickness from B&W drawing Shell Forming Details 104186D-1 (ordered thickness).																
Note 1 - Scan into nozzle until onset of liftoff or limited by physical limitations.																
Side Revision 0 2/22/04																

Site Revision 0 2/22/04

QUAD CITIES
REPORT NO. QC2-R17-91
PAGE 16 OF 16



GE NUCLEAR ENERGY
UT EXAMINATION SUMMARY SHEET

Report No: Q2R17-92
WO No: 580044, 580045

PROJECT Quad Cities Unit-2, Q2R17
WELD ID: N4C NOZ, N4C IRS and N4C (NUREG 0619)
SYSTEM: Reactor Pressure Vessel

CALIBRATION ID: NOZ.IN, NOZ.IN.1, IRS.IN
GERIS DATA: Scan file types: P1, P2, P3, TL, Z1, Z2A, Z2B and Z3
MANUAL DATA: UT-067, UT-068
EXAMINERS: S. Gauthier Lv II, K. Montgomery Lv II, B. Dummer Lv III

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds and NUREG-0619.

Examination volumes were in accordance with Section XI, Figure IWB-2500-7 (a) and NUREG-0619.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-705 V4, using 0° L, 60° RL, and 45° S, search units. Nozzle Inner Radius and Inner 15%T examination volume parallel scans were performed using model validated shear wave search units.

Supplemental manual examinations from the ODBR surface (Zones 2A and 3) were performed in accordance with procedure GE-UT-311 V10 to obtain additional coverage, in areas examined by the automated system, due to inadequate ID signal characteristics.

Scanning was performed from the vessel OD shell, OD Blend Radius and OD Nozzle Boss surfaces examining the nozzle to shell weld, nozzle inner radius section and NUREG 0619 specified bore regions.

Two (2) acceptable indications were recorded.

Previous data (QDC-003 and QDC-007 from 1995) was reviewed prior to completing this summary. No significant changes were noted.

Scanning was limited due to the nozzle configuration, thermocouple pad and bioshield interferences.

Coverage = 33% Nozzle to Shell weld.
Coverage = 100% Nozzle Inner Radius Section
Coverage = 100% NUREG-0619 Bore regions.

 PREPARED BY UT Level: <u>III</u>	3/6/04 DATE	 REVIEWED BY UT Level: <u>III</u>	3-6-04 DATE	 UTILITY REVIEW	3/19/04 DATE	 AMT REVIEW	3/19/04 DATE
--	-----------------------	--	-----------------------	---------------------------	------------------------	-----------------------	------------------------

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4C-NOZ

Report No.: Q2R17-92
Exam Data Sheet: N4C-01

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4c.p1.1	04A	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	1
n4c.p2.1	05A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1, 2
n4c.p2.2	05A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	1
n4c.p3.1	04A	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	1
n4c.tl.1	05A	TL	NRI	001	NRI	~	~	~	~	~	~	~	~	~	~	~	1
n4c.tl.2	05A	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	1

Comments: 1 - Plate segregates observed in vessel plate.

2 - Poor contact channel 14, coverage obtained from the opposite direction and P3 channel 14 scans.

Scanning performed with high profile triple pack, low profile tractor and 11" arm. Indication sheet numbers preceeded by "N4C-".

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CP MT

Level: III

Date: 3/4/04

Reviewed By: BLM D

Level: III

Date: 3-4-04



Report No.: Q2R17-92
Exam Data Sheet: N4C-01
Ind. Data Sheet: N4C-001

[illegible]

Date: 3-4-09



GE Nuclear Energy

GERIS 2000 Indication Evaluation Data Sheet

Project : Quad Cities Unit-2
Weld ID : N4C NOZ
Indication : 1

Report No.: Q2R17-92
Exam Data Sheet : N4C-01
Indication Data Sheet : N4C-001

Flaw Through Wall = 0.13
Flaw Length "l" = 1.21
Surface Separation "S" = 1.0

"T" nominal = 6.38
"T" measured = N/A
Clad "T" nominal = 0.1875

ASME Section XI, 1995 Edition, 1996 Addenda TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	-	-
0.05	2.0	2.2	2.01	2.22 Y
0.10	2.2	2.5	-	-
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	-	-
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed 2.01	Allowed 2.22

a = 0.065
a/l value = 0.054
Y = 1.000

Flaw is Subsurface

Allowed a/t = 2.22%
ACTUAL a/t = 1.02%

Flaw is acceptable by Table IWB-3510-1.




Comments : Indication is a planar flaw aligned with the shell side fusion line, IWB-3510-1 used per IWB-3512.1(b).

Analyzed By: CDM




Reviewed By: RMD







Level: III Date: 3/4/04

Level: III Date: 3-6-04



QUAD CITIES
REPORT NO. Q2R17-92
PAGE 5 OF 21





QUAD CITIES
REPORT NO. Q2R17-92
PAGE 10 OF 71

GERIS 2000 Examination Data Sheet



Project : Quad Cities Unit-2, 2004
Component : N4C-IRS

Report No.: Q2R17-92
Exam Data Sheet: N4C-02

Scan			Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
File	Disk	Type															
n4c.z1.1	04A	Z1	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~	~	~
n4c.z1.2	04A	Z1	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~	~	~
n4c.z2a.1	04A	Z2A	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~
n4c.z2a.2	04A	Z2A	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~

Comments: Scanning performed with ODBR package, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CLM

Level: IV

Date: 3/3/04

Reviewed By: BIM D

Level: III

Date: 3-6-04

Quad Cities Unit-2, 2004

Page 8 of 21



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4C-IRS

Report No.: Q2R17-92
Exam Data Sheet: N4C-03

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4c.z2b.1	05A	Z2B	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4c.z2b.2	05A	Z2B	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4c.z2b.3	05A	Z2B	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4c.z3.1	06A	Z3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4c.z3.2	06A	Z3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~

Comments: Scanning performed with NOZOD package, safe end tractor and safe end.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: <u>CP MT</u> Level: <u>TIC</u> Date: <u>3/4/04</u>	Reviewed By: <u>BMD</u> Level: <u>III</u> Date: <u>3-6-04</u>
---	---

Quad Cities Unit-2, Q2R17

Q2R17-92

Page 9 of 21

				GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET						CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17			
PROCEDURE NO. : <u>GE-UT-705 V4</u>				REVISION : <u>N/A</u>		DRR : <u>N/A</u>							
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD	
n4c.p3.1	N4C NOZ	04A	02/03/04	0232	0340	270°	271°	361°	102°	N/A	N/A	NOZ.IN	
n4c.p1.1	N4C NOZ	04A	02/03/04	0433	0539	270°	269°	361°	102°	N/A	N/A	NOZ.IN	
n4c.p2.1	N4C NOZ	05A	02/03/04	0620	0647	270°	51°	141°	102°	N/A	N/A	NOZ.IN	
n4c.p2.2	N4C NOZ	05A	02/03/04	0753	0850	340°	271°	291°	102°	N/A	N/A	NOZ.IN	
n4c.tl.1	N4C NOZ	05A	02/03/04	0951	1126	270°	291°	339°	102°	N/A	N/A	NOZ.IN.1	
n4c.tl.2	N4C NOZ	05A	02/03/04	1132	1136	285°	268°	17°	102°	N/A	N/A	NOZ.IN.1	
COMMENTS : * Rotation angles for TL and P exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached). The GERIS 0° reference is located 90° CW of nozzle TDC. Recalibration due to Ch. 3, 60°L, 97-154 failing, replaced with 97-153 after recalibration						Search Unit Data:				Freq.	Rot.		
						No.	Model / Mode	S/N	Size	(MHz.)	Angle		
						1	RTD, 0° L2.25 / L	01-231	1.0 Dia	2.25	N/A		
						2	RTD, 45° T1-St / S	01-233	32x22mm	1.00	*		
						3	RTD, 60° L2-St / L	97-153	30x25mm	2.00	*		
Automated scanning was restricted due to the nozzle weld configuration.						4	RTD, 45° T1-St / S	04-8	32x22mm	1.00	*		
OPERATORS: SHANE GAUTHIER LvII KENT MONTGOMERY LvII				SOFTWARE REVISION: 5.26 THERMOMETER S/N : 235018		6	RTD, 70° TRL2-St / L	96-228	2(12x25)mm	2.00	*		
						13	RTD, 60° T1-St / S	01-234	32x18mm	1.00	*		
						14	RTD, 60° T1-St / S	01-235	32x18mm	1.00	*		
COUPLANT : <u>Demineralized Water</u>													

Page 914 of 945



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Outage: Q2R17

Procedure: GE-UT-311

Data Report Number: Q2R17-92

Data Sheet Number: UT-087

Linearity Sheet: L-008

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSCI</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1520</u>		Exam Start: <u>16:10</u>
Cal Check: <u>N/A</u>		Exam End: <u>16:30</u>
Cal Check: <u>N/A</u>	<u>Ultracel II</u>	<u>01225</u>
Final Cal: <u>1725</u>	Couplant:	Batch
<u>255019-215019</u>	<u>89° F</u>	<u>89° F</u>
Thermometer <u>3/14/04</u>	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>19.4</u>	<u>20.65</u>	<u>8.2</u>
		<u>1X</u>				

DAC @ 1X 61

Sweep 0-10 25 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>004NMY</u>	<u>0.5"x1.0" / Rect.</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.0 in.</u>	<u>70°</u>	<u>68°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u>	<u>113-292-800</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>16.4 us</u>	<u>0.1283 in / us</u>
Zero:	Velocity:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>Off</u>	<u>Off</u>
DAC:	TVG:
<u>Off</u>	<u>Off</u>
	CSC:
	DGS:

Exam Data for Component: N4C IRS

VESSEL-NOZZLE (FEEDWATER)

Configuration:

<u>ODBR</u>	<u>89° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
<u>360°</u>	<u>67.5</u>
	<u>21.7</u>
	<u>W-029B</u>
	<u>70</u>
	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 2A CCW.

Exams performed to maintain a 5% FSH ID roll.

BD Brad Dummer

Initials: Examiner:

III

Level

3/5/04

Cal/Exam Date:

Dan K. Chitt

Utility Reviewed By:

3/10/04

Date:

CPM

GE Reviewed By:

IV

Level:

3/6/04

Date:

John Smith

AMR Reviewed By:

3/19/04

Date:

Page 11 of 21



GE NUCLEAR ENERGY

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Quad Cities / 2

Outage: Q2R17

Procedure: GE-UT-311

Data Report Number: Q2R17-92

Data Sheet Number: UT-068

Linearity Sheet: L-008

Rev: V10

DRR: N/A

Calibration Data for Block: 99978 AQC

<u>CSCI</u>	<u>N/A</u>	<u>7.3"</u>
Material	Size	Thickness
Initial Cal: <u>1520</u>		Exam Start <u>16:10</u>
Cal Check: <u>N/A</u>		Exam End <u>16:30</u>
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>01225</u>
Final Cal: <u>1725</u>	Couplant:	Batch
<u>3-M-01 255048 285018</u>	<u>89° F</u>	<u>89° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>7.3</u>	<u>1X</u>	<u>80</u>	<u>19.4</u>	<u>20.65</u>	<u>8.2</u>
		<u>1X</u>				

DAC @ 1X 58

Sweep 0-10 25 Metal Path

Acceptable Linearity performed : 2/10/2004

Search Unit Data

<u>KBA</u>	<u>010HXL</u>	<u>0.5"x1.0" / Rect</u>
Manufacturer:	Serial No.:	Size/Shape:
<u>0.0 in.</u>	<u>70°</u>	<u>68°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u>	<u>113-892-800</u>	<u>Shear</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573711</u>
Manufacturer/Model:	Serial No.:
<u>16.4 us</u>	<u>0.1283 in / us</u>
Zero:	Velocity:
	<u>0.8 - 3.0 MHz</u>
	Narrowband Filter:
<u>Auto</u>	<u>Full</u>
Rep Rate:	Rectification:
<u>25.0 in.</u>	<u>Sq. / Med</u>
Range:	Pulser/Energy
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>2.0 MHz</u>	<u>P/E</u>
Frequency:	Mode:
<u>Off:</u>	<u>Off:</u>
DAC:	TVG:
<u>Off:</u>	<u>Off:</u>
CSC:	DGS:

Exam Data for Component: N4C IRS

VESSEL-NOZZLE (FEEDWATER)

Configuration:

<u>ODBR</u>	<u>99° F</u>
Exam Surface:	Component Temp.
Examination Area	Exam Angle
Rotation Angle	Wedge S/N
Scan dB	Recordable Indications
<u>360°</u>	<u>67.5</u>
<u>21.7</u>	<u>W-029A</u>
<u>70</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration.

Calibration for Zone 2A CW.

Exams performed to maintain a 5% FSH ID roll.

BD Brad Dummer

Initials: Examiner:

III

Level

3/3/04

Cal/Exam Date:

[Signature]

Utility Reviewed By:

3/14/04

Date:

CP MR

GE Reviewed By:

[Signature]

Level:

3/14/04

Date:

[Signature]

AMR Reviewed By:

3/19/04

Date:

Page 12 of 21

Report No.: Q2R17-92

Feedwater N4C-NOZ Quad Cities Unit-2, 2004

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 82.2		Required Exam Area Sq. In.	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
70° T-Scan	A	29.9	2.7	3.3%	356	1.6%
45° T-Scan	A	43.2	22.4	27.3%	356	13.5%
60° T-Scan	A	9.1	5.5	6.7%	356	3.3%
70° P-Scan	A	29.9	0	0.0%	360	0.0%
45° P-Scan	A	43.2	14.9	18.1%	360	9.1%
60° P-Scan	A	9.1	9.1	11.1%	360	5.5%
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						

% Total Composite Coverage = 33%


Comments: A - Examined accessible length. Scanning limited due to scanner access.
N4C TL scans lost 4° coverage due to position error.

Note - Rounding methods may make calculated values appear in error.


Quad Cities Unit-2 Feedwater N4C

70° Exam Volume = 29.9 Sq. In.
45° Exam Volume = 43.2 Sq. In.
Inner 15%T Exam Volume (IRS & 60°T) = 9.1 Sq. In.

70° T-Scan achieved = 2.7 Sq. In.
45° T-Scan achieved = 22.4 Sq. In.
60° T-Scan achieved = 5.5 Sq. In.



Quad Cities Unit-2 Feedwater N4D



Guideline for Deciding when to Perform Manual UT Examination of Areas Not Covered by Automated Examinations

Component/Configuration: N4C No2

A. DETERMINE

1. Percent coverage obtained with automated UT: 33 %
2. Approximate radiation dose received to complete automated UT: 1800 mR

B. ESTIMATE

1. Percent coverage increases if manual UT was performed: +7 % *
2. Radiation dose expected if manual UT was performed: 2000 mR

Decision to Proceed: YES X NO Based On: DOSE

Prepared By: R. L. May Date: 03/05/04

* ALL UPPER WELD COVERAGE, NOT
WELD ON HAZ ON I.D.

Q2R17-92

16 of 21


Report No.: Q2R17-92

Feedwater N4C-IRS Quad Cities Unit-2, 2004

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area %	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Weld Length = 360.						
Exam Volume = 100%						
Z1 CW	A/B	100%	100%	100.0%	360	50.0%
Z1 CCW	A/B	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2A CW	A/B	100%	100%	100.0%	360	50.0%
Z2A CCW	A/B	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2B CW	A/B	100%	100%	100.0%	230	31.9%
Z2B CCW	A/B	100%	100%	100.0%	230	31.9%
% Total Composite Coverage =						63.9%
Z3 CW	A/B	100%	100%	100.0%	230	31.9%
Z3 CCW	A/B	100%	100%	100.0%	230	31.9%
% Total Composite Coverage =						63.9%

Comments: A/B - Examined accessible length. Exam volume determined by modeling, 100% assigned volume.
Scanning limited due to bioshield interference at 321° CW to 36° and thermocouple at 138° CW to 193°.
100% Z2B and Z3 Coverage (Single side access) obtained throughout. See attached drawing. Z2A and Z3 are non-PDI exams.
Note - Rounding methods may make calculated values appear in error.

Zone 2B and Zone 3 Scan Areas 100% Coverage (Single Side) Obtained Throughout.



Nir_PDI Qc2.XLS

MANUAL/GERIS 2000 DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Quad Cities 2					
PREPARED BY		S.C. MORTENSON			DATE 01/17/04		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld	PLATE	0 - 9.0"	66.0°	57.8° (52.4°) *	FLAT	18.5"	1 MHz
N/V Weld	PLATE	0 - 9.0"	70.0°	42.1° 37.0°) *	FLAT	25.3"	1 MHz
Zone 1/NV (M)	ODBR	20° - 45°	35.0°	90.0°	5.5"	20.7"	1 MHz
Zone 2A	ODBR	45° - 90°	60.0°	35.0° (30.6°) **	5.5"	20.4"	1 MHz
RECIRC INLET							
N/V Weld	PLATE	0 - 8.0"	60.0°	38.0° (27.3°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.5"	60.0°	45.0° (35.5°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	PLATE	0 - 8.0"	68.0°	25.7° (16.0°) *	FLAT	21.2"	1 MHz
Zone 1	PLATE	0 - 9.0"	70.0°	15.6° (8.5°) *	FLAT	22.9"	1 MHz
Zone 2A	ODBR	55° - 90°	67.5°	18.1° (8.2°) **	3.3"	12.0"	1 MHz
FEEDWATER							
N/V Weld	PLATE	0 - 8.0"	60.0°	48.2° (39.2°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	60.0°	38.9° (28.3°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	40.3° (31.8°) **	3.5"	19.3"	2.25 MHz
Zone 2A	ODBR	50° - 90°	67.5°	21.7° (13.2°) **	3.5"	13.4"	2.25 MHz
Zone 2B	NOZOD	ALL	28.0°	68.0°	FLAT	7.5"	2 MHz
Zone 3	NOZOD	ALL	28.0°	90°	FLAT	6.7"	2 MHz

W-021, W-022
W-023, W-024

W-025, W-026

W-027, W-028
W-029, W-030

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0° PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45° PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5° OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5° PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253



GE Nuclear Energy

GERIS 2000 OD Nozzle Examination Scan Plan

Quad Cities Unit-2, 2004
Nozzle Scanning Limits
Nozzle(s) N4

12.75 Weld CL Radius
18.10 ASME OD Radius
16.75 Outside Radius of ODBR
13.00 Outside Radius of NOZOD

125.50 Vessel ID Radius
6.38 Vessel Nom. Thickness
131.88 Vessel OD Radius
1.0 Overscan Distance

Package Configuration: Triple Pack and ODBR Package.

Channel	Beam	CPU	Fixture	Type	SU Parameters				Scan	Scanner		A-Gate			C-Gate	
	Angle	Angle	Angle		Delay	Velocity	X-Off	Y-Off	Area	Min	Max	Start	Stop	Max MP	Start	Stop
N4 T-Scan. Supplement 4 and 6 radial scans.										Step →	0.25	Index →	0.4°			
1	0	0.0	0.0	WM	4	0.233	0.0	0.0	N/A	Note 1	19.25	0	75	8.3	18	54
2	45	-9.0	9.0	T	15	0.128	3.0	0.0	N/A	Note 1	13.25	0	230	13.8	37	191
3	60	7.2	352.8	T	15	0.233	-3.0	0.0	N/A	Note 1	19.25	0	180	19.2	32	152
N4 P1. 45° S for outer 85%T volume.										Step →	0.25	Index →	0.5°			
2	45	51.3	308.7	P	15	0.128	3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
4	45	-51.3	51.3	P	15	0.128	-3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
N4 P2. N/V Inner 15%T P-scan examination from PLATE with 70T-scan.										Step →	0.15	Index →	0.5°			
13	60	39.2	320.8	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
6	70	0.0	0.0	T	10	0.233	0.0	0.0	N/A	Note 1	9.30	0	50	4.7	10	48
14	60	-39.2	39.2	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 P3. N/V Inner 15%T P-scan examination from PLATE.										Step →	0.15	Index →	0.5°			
13	60	28.3	331.7	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
14	60	-28.3	28.3	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 Z1. Z1 Inner Radius Section examination from ODBR										Step →	0.07	Index →	1.7°			
9	43.8	31.8	328.2	Z1	15	0.128	-2.5	0.0	N/A	50°	90°	0	410	19.3	165	335
10	43.8	-31.8	31.8	Z1	15	0.128	2.5	0.0	N/A	50°	90°	0	410	19.3	165	335

QUAD CITIES
REPORT NO. QC2-R17-92
PAGE 21

Channel	Beam Angle	CPU Angle	Fixture Angle	Type	SU Parameters				Scan Area	Scanner		A-Gate			C-Gate	
					Delay	Velocity	X-Off	Y-Off		Min	Max	Start	Stop	Max MP	Start	Stop
N4 Z2A. Z2A Inner Radius Section examination from ODBR										Step →	0.07	Index →	1.7°			
11	67.5	13.2	346.8	Z2A	15	0.128	-2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
12	67.5	-13.2	13.2	Z2A	15	0.128	2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
N4 Z2B. Z2A Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	68.0	292.0	Z2B	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-68.0	68.0	Z2B	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
N4 Z3. Z3 Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	90.0	270.0	Z3	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-90.0	90.0	Z3	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
Notes: Vessel ID radius from B&W drawing Shell Course Subassembly 151825E-1. Vessel nominal thickness from B&W drawing Shell Forming Details 104186D-1 (ordered thickness). Note 1 - Scan into nozzle until onset of liftoff or limited by physical limitations.																
															Site Revision 0 2/22/04	

QUAD CITIES
REPORT NO. QC2R17-92
PAGE 21 OF 21



GE NUCLEAR ENERGY
UT EXAMINATION SUMMARY SHEET

Report No: Q2R17-93
WO No: 580042, 580043

PROJECT Quad Cities Unit-2, Q2R17
WELD ID: N4D NOZ, N4D IRS and N4D (NUREG 0619)
SYSTEM: Reactor Pressure Vessel

CALIBRATION ID: NOZ.IN, NOZ.IN.1, IRS.IN
GERIS DATA: Scan file types: P1, P2, P3, TL, Z1, Z2A, Z2B and Z3
MANUAL DATA: N/A
EXAMINERS: S. Gauthier Lv II, K. Montgomery Lv II

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds and NUREG-0619.

Examination volumes were in accordance with Section XI, Figure IWB-2500-7 (a) and NUREG-0619.

Automated transverse and parallel scans were performed in accordance with procedure GE-UT-705 V4, using 0° L, 60° RL, and 45° S, search units. Nozzle Inner Radius and Inner 15%T examination volume parallel scans were performed using model validated shear wave search units.

Scanning was performed from the vessel OD shell, OD Blend Radius and OD Nozzle Boss surfaces examining the nozzle to shell weld, nozzle inner radius section and NUREG 0619 specified bore regions.

No indications were recorded.

Previous data (QDC-004 and QDC-008 from 1995) was reviewed prior to completing this summary. No significant changes were noted.

Scanning was limited due to the nozzle configuration and bioshield interferences.

Coverage = 33% Nozzle to Shell weld.
Coverage = 100% Nozzle Inner Radius Section
Coverage = 100% NUREG-0619 Bore regions.

 PREPARED BY UT Level: III	3/6/04 DATE	 REVIEWED BY UT Level: III	3-6-04 DATE	 UTILITY REVIEW	3/11/04 DATE	 ANTI REVIEW	3/19/04 DATE
----------------------------------	----------------	----------------------------------	----------------	--------------------	-----------------	-----------------	-----------------

Quad Cities Unit-2, 2004



GE Nuclear Energy

GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4D-NOZ

Report No.: Q2R17-93
Exam Data Sheet: N4D-01

Scan			Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
File	Disk	Type															
n4d.p1.1	03B	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	~
n4d.p1.2	03B	P1	~	NRI	~	NRI	~	~	~	~	~	~	~	~	~	~	~
n4d.p2.1	03A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n4d.p2.2	03A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n4d.p2.3	03A	P2	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n4d.p3.1	03B	P3	~	~	~	~	~	NRI	~	~	~	~	~	~	NRI	NRI	~
n4d.p3.2	Void	Void	~	~	~	~	~	~	~	~	~	~	~	~	Void	Void	~
n4d.p3.3	03B	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4d.p3.4	03B	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4d.p3.5	03B	P3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4d.tl.1	04A	TL	NRI	NRI	NRI	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Scan file n4dp3.2 void.

Scanning performed with high profile triple pack, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CM

Reviewed By: RLM Dunn

Level: III


Date: 3/8/03

Level: III

Date: 3-6-04

Page 2 of 15

Quad Cities Unit-2, 2004



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4D-IRS

Report No.: Q2R17-93
Exam Data Sheet: N4D-02

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4d.z1.1	03A	Z1	~	~	~	~	~	~	~	~	~	Void	Void	~	~	~	Void
n4d.z1.2	03A	Z1	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~	~	~
n4d.z2a.1	03A	Z2A	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~
n4d.z2a.2	03A	Z2A	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with ODBR package, low profile tractor and 11" arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CP MR

Reviewed By: R/M Dm

Level: III

Date: 3/2/04

Level: III

Date: 3-6-04

Page 3 of 15

Quad Cities Unit-2, 2004



GERIS 2000 Examination Data Sheet

Project : Quad Cities Unit-2, 2004
Component : N4D-IRS

Report No.: Q2R17-93
Exam Data Sheet: N4D-03

File	Disk	Scan	Ch. 1	Ch. 2	Ch. 3	Ch. 4	Ch. 5	Ch. 6	Ch. 7	Ch. 8	Ch. 9	Ch. 10	Ch. 11	Ch. 12	Ch. 13	Ch. 14	Remarks
		Type															
n4d.z2b.1	06A	Z2B	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4d.z2b.2	06A	Z2B	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
n4d.z3.1	06A	Z3	~	~	~	~	~	~	~	~	~	~	~	~	NRI	NRI	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~
~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~

Comments: Scanning performed with NOZOD package, safe end tractor and safe end arm.

The symbol ~ indicates "No entry required" or "Not Applicable". NRI indicates "No Recordable Indications".

Analyst: CPM

Reviewed By: BIMD

Level: III

Date: 3/4/04

Level: III

Date: 3-6-04

Page 4 of 15

Quad Cities Unit-2, Q2R17

Q2R17-93

Page 5 of 15

				GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET						CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17			
PROCEDURE NO. : GE-UT-705 V4				REVISION : N/A		DRR : N/A							
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD	
n4d.p1.1	N4D NOZ	03B	03/02/04	1337	1408	270°	120°	150°	92°	N/A	N/A	NOZ.IN	
n4d.p1.2	N4D NOZ	03B	03/02/04	1425	1453	121°	269°	212°	92°	N/A	N/A	NOZ.IN	
n4d.p2.1	N4D NOZ	03A	03/02/04	1113	1139	270°	326°	56°	92°	N/A	N/A	NOZ.IN	
n4d.p2.2	N4D NOZ	03A	03/02/04	1158	1253	325°	237°	272°	92°	N/A	N/A	NOZ.IN	
n4d.p2.3	N4D NOZ	03A	03/02/04	1308	1315	236°	271°	35°	92°	N/A	N/A	NOZ.IN	
n4d.p3.1	N4D NOZ	03B	03/02/04	1535	1614	270°	12°	102°	92°	N/A	N/A	NOZ.IN	
n4d.p3.2	Void	Void	Void	~	~	~	~	~	~	~	~	Void	
n4d.p3.3	N4D NOZ	03B	03/02/04	1803	1834	271°	137°	134°	92°	N/A	N/A	NOZ.IN	
n4d.p3.4	N4D NOZ	03B	03/02/04	1845	1854	150°	124°	26°	92°	N/A	N/A	NOZ.IN	
n4d.p3.5	N4D NOZ	03B	03/02/04	1946	2007	11°	120°	109°	92°	N/A	N/A	NOZ.IN	
n4d.tl.1	N4D NOZ	04A	03/02/04	2153	2318	270°	271°	361°	97°	N/A	N/A	NOZ.IN	
COMMENTS : * Rotation angles for TL and P exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached). The GERIS 0° reference is located 90° CW of nozzle TDC.						Search Unit Data:				Freq.	Rot.		
						No.	Model / Mode	S/N	Size	(MHz.)	Angle		
						1	RTD, 0° L2.25 / L	01-231	1.0 Dia	2.25	N/A		
						2	RTD, 45° T1-St / S	01-233	32x22mm	1.00	*		
						3	RTD, 60° L2-St / L	97-154	30x25mm	2.00	*		
Automated scanning was restricted due to the nozzle weld configuration.						4	RTD, 45° T1-St / S	04-8	32x22mm	1.00	*		
OPERATORS: SHANE GAUTHIER Lvii KENT MONTGOMERY Lvii						6	RTD, 70° TRL2-St / L	96-228	2(12x25)mm	2.00	*		
SOFTWARE REVISION: 5.26 THERMOMETER S/N : 235018 235074						13	RTD, 60° T1-St / S	01-234	32x18mm	1.00	*		
COUPLANT : Demineralized Water						14	RTD, 60° T1-St / S	01-235	32x18mm	1.00	*		

Quad Cities Unit-2, Q2R17

Q2R17-93

Page 6 of 15

				GERIS 2000 OD EXAMINATION SCAN FILES DATA SHEET						CUSTOMER: Exelon SITE: Quad Cities Unit-2 OUTAGE: Q2R17			
PROCEDURE NO. : GE-UT-705 V4				REVISION : N/A		DRR : N/A							
FILE NAME	WELD	DISK NO.	DATE	EXAM START TIME	EXAM STOP TIME	SCAN START	SCAN STOP	SCAN AREA	VESSEL TEMP. (°F)	CAL RECHECK IN OUT		CAL RECORD	
n4d.z1.1	N4D IRS	~	~	~	~	~	~	~	~	~	~	~	
n4d.z1.2	N4D IRS	03A	03/03/04	0817	0850	271°	272°	360°	92°	N/A	N/A	IRS.IN	
n4d.z2a.1	N4D IRS	03A	03/02/04	0919	0937	270°	119°	151°	92°	N/A	N/A	IRS.IN	
n4d.z2a.2	N4D IRS	03A	03/02/04	1034	1047	120°	269°	211°	92°	N/A	N/A	IRS.IN	
n4d.z2b.1	N4D IRS	Void	Void	~	~	~	~	~	~	~	~	Void	
n4d.z2b.2	N4D IRS	05A	03/04/04	0454	0520	323°	33°	290°	98°	N/A	N/A	IRS.IN	
n4d.z3.1	N4D IRS	05A	03/04/04	0534	0553	323°	33°	290°	98°	N/A	N/A	IRS.IN	
COMMENTS : * Rotation angles for all exams per the GERIS 2000 nozzle to vessel scan-plan sheet (attached).						Search Unit Data:					Freq.	Rot.	
						No.	Model / Mode	S/N	Size	(MHz.)	Angle		
The GERIS 0° reference is located 90° CW of nozzle TDC.						9	KBA, 389-018-980 / S	00XL6V	0.5 x 1.0	2.25	N/A		
						10	KBA, 389-018-980 / S	00XL6Y	0.5 x 1.0	2.25	*		
Z1 and Z2A exams unrestricted. Z2B and Z3 scans limited by bioshield interference.						11	KBA, 389-018-980 / S	00XL6L	0.5 x 1.0	2.25	*		
						12	KBA, 389-018-980 / S	00XL6M	0.5 x 1.0	2.25	*		
OPERATORS: SHANE GAUTHIER LvII				SOFTWARE REVISION: 5.26		13	RTD, 28° T2-St / S	98-1178	18 x 14mm	2.00	*		
KENT MONTGOMERY LvII				THERMOMETER S/N : 235018		14	RTD, 28° T2-St / S	01-240	18 x 14mm	2.00	*		
				235074									
				COUPLANT : Demineralized Water									

Report No.: Q2R17-93

Feedwater N4D-NOZ Quad Cities Unit-2, 2004


Weld Length = 360. Exam Volume = 82.2		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
70° T-Scan	A	29.9	2.7	3.3%	360	1.6%
45° T-Scan	A	43.2	22.4	27.3%	360	13.6%
60° T-Scan	A	9.1	5.5	6.7%	360	3.3%
70° P-Scan	A	29.9	0	0.0%	360	0.0%
45° P-Scan	A	43.2	14.9	18.1%	360	9.1%
60° P-Scan	A	9.1	9.1	11.1%	360	5.5%
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						
70° T-Scan						
45° T-Scan						
60° T-Scan						
70° P-Scan						
45° P-Scan						
60° P-Scan						

% Total Composite Coverage = 33%


Comments: A - Examined accessible length. Scanning limited due to scanner access.

Note - Rounding methods may make calculated values appear in error.

Quad Cities Unit-2 Feedwater N4D



Quad Cities Unit-2 Feedwater N4D



Guideline for Deciding when to Perform Manual UT Examination of Areas Not Covered by Automated Examinations

Component/Configuration: N4D NO2

A. DETERMINE

1. Percent coverage obtained with automated UT: 33 %
2. Approximate radiation dose received to complete automated UT: 1800 mR

B. ESTIMATE

1. Percent coverage increases if manual UT was performed: + 7 % *
2. Radiation dose expected if manual UT was performed: 2000 mR

Decision to Proceed: YES X NO Based On: Dose

Prepared By: R.L. My Date: 03/05/04

* ALL UPPER WELD COVERAGE, NOT
WELD ON HAZ ON I.D.

Q2R17-93
10 of 15

Report No.: Q2R17-93

Feedwater N4D-IRS Quad Cities Unit-2, 2004

Weld Length = 360. Exam Volume = 100%		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area %	Area Scanned Auto	Percent of Area Auto	Weld Length Auto	Percent Auto
Z1 CW	A	100%	100%	100.0%	360	50.0%
Z1 CCW	A	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2A CW	A	100%	100%	100.0%	360	50.0%
Z2A CCW	A	100%	100%	100.0%	360	50.0%
% Total Composite Coverage =						100.0%
Z2B CW	A	100%	100%	100.0%	290	40.3%
Z2B CCW	A	100%	100%	100.0%	290	40.3%
% Total Composite Coverage =						80.6%
Z3 CW	A	100%	100%	100.0%	290	40.3%
Z3 CCW	A	100%	100%	100.0%	290	40.3%
% Total Composite Coverage =						80.6%


Comments: A - Examined accessible length. Exam volume determined by modeling, 100% assigned volume.

Scanning limited due to bioshield interference at 323° CW to 33°.

100% Z2B and Z3 Coverage (Single side access) obtained throughout. See attached drawing. Z2A and Z3 are non-PDI exams.

Note - Rounding methods may make calculated values appear in error.

Zone 2B and Zone 3 Scan Areas
100% Coverage (Single Side) Obtained Throughout.



Q2R17-93

Nir_PDI Qc2.XLS

MANUAL/GERIS 2000 DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Quad Cities 2					
PREPARED BY		S.C. MORTENSON			DATE		
					01/17/04		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld	PLATE	0 - 9.0"	66.0°	57.8° (52.4°) *	FLAT	18.5"	1 MHz
N/V Weld	PLATE	0 - 9.0"	70.0°	42.1° (37.0°) *	FLAT	25.3"	1 MHz
Zone 1/NV (M)	ODBR	20° - 45°	35.0°	90.0°	5.5"	20.7"	1 MHz
Zone 2A	ODBR	45° - 90°	60.0°	35.0° (30.6°) **	5.5"	20.4"	1 MHz
RECIRC INLET							
N/V Weld	PLATE	0 - 8.0"	60.0°	38.0° (27.3°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.5"	60.0°	45.0° (35.5°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	PLATE	0 - 8.0"	68.0°	25.7° (16.0°) *	FLAT	21.2"	1 MHz
Zone 1	PLATE	0 - 9.0"	70.0°	15.6° (8.5°) *	FLAT	22.9"	1 MHz
Zone 2A	ODBR	55° - 90°	67.5°	18.1° (8.2°) **	3.3"	12.0"	1 MHz
FEEDWATER							
N/V Weld	PLATE	0 - 8.0"	60.0°	48.2° (39.2°) *	FLAT	14.0"	1 MHz
N/V Weld	PLATE	0 - 8.0"	60.0°	38.9° (28.3°) *	FLAT	14.0"	1 MHz
N/V Weld / Zone 1	ODBR	50° - 90°	43.8°	40.3° (31.8°) **	3.5"	19.3"	2.25 MHz
Zone 2A	ODBR	50° - 90°	67.5°	21.7° (13.2°) **	3.5"	13.4"	2.25 MHz
Zone 2B	NOZOD	ALL	28.0°	68.0°	FLAT	7.5"	2 MHz
Zone 3	NOZOD	ALL	28.0°	90°	FLAT	6.7"	2 MHz

W-021, W-022
W-023, W-024

W-025, W-026

W-027, W-028
W-029, W-030

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0" PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45" PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5" OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5" PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253



GE Nuclear Energy

GERIS 2000 OD Nozzle Examination Scan Plan

Quad Cities Unit-2, 2004
Nozzle Scanning Limits
Nozzle(s) N4

12.75 Weld CL Radius
18.10 ASME OD Radius
16.75 Outside Radius of ODBR
13.00 Outside Radius of NOZOD

125.50 Vessel ID Radius
6.38 Vessel Nom. Thickness
131.88 Vessel OD Radius
1.0 Overscan Distance

Package Configuration: Triple Pack and ODBR Package.

Channel	Beam	CPU	Fixture	Type	SU Parameters				Scan Area	Scanner		A-Gate			C-Gate	
	Angle	Angle	Angle		Delay	Velocity	X-Off	Y-Off		Min	Max	Start	Stop	Max MP	Start	Stop
N4 T-Scan. Supplement 4 and 6 radial scans.										Step →	0.25	Index →	0.4°			
1	0	0.0	0.0	WM	4	0.233	0.0	0.0	N/A	Note 1	19.25	0	75	8.3	18	54
2	45	-9.0	9.0	T	15	0.128	3.0	0.0	N/A	Note 1	13.25	0	230	13.8	37	191
3	60	7.2	352.8	T	15	0.233	-3.0	0.0	N/A	Note 1	19.25	0	180	19.2	32	152
N4 P1. 45° S for outer 85%T volume.										Step →	0.25	Index →	0.5°			
2	45	51.3	308.7	P	15	0.128	3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
4	45	-51.3	51.3	P	15	0.128	-3.0	0.0	N/A	Note 1	11.50	0	230	13.8	37	191
N4 P2. N/V Inner 15%T P-scan examination from PLATE with 70T-scan.										Step →	0.15	Index →	0.5°			
13	60	39.2	320.8	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
6	70	0.0	0.0	T	10	0.233	0.0	0.0	N/A	Note 1	9.30	0	50	4.7	10	48
14	60	-39.2	39.2	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 P3. N/V Inner 15%T P-scan examination from PLATE.										Step →	0.15	Index →	0.5°			
13	60	28.3	331.7	N/V	15	0.128	-3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
14	60	-28.3	28.3	N/V	15	0.128	3.0	0.0	8.0	Note 1	13.05	0	300	14.0	120	250
N4 Z1. Z1 Inner Radius Section examination from ODBR										Step →	0.07	Index →	1.7°			
9	43.8	31.8	328.2	Z1	15	0.128	-2.5	0.0	N/A	50°	90°	0	410	19.3	165	335
10	43.8	-31.8	31.8	Z1	15	0.128	2.5	0.0	N/A	50°	90°	0	410	19.3	165	335

Scan Plan QC2-2004.xls Working N4

QUAD CITIES
REPORT NO. QC2-2004-93
PAGE 14 OF 15

Channel	Beam Angle	CPU Angle	Fixture Angle	Type	SU Parameters				Scan Area	Scanner		A-Gate			C-Gate	
					Delay	Velocity	X-Off	Y-Off		Min	Max	Start	Stop	Max MP	Start	Stop
N4 Z2A. Z2A Inner Radius Section examination from ODBR										Step →	0.07	Index →	1.7°			
11	67.5	13.2	346.8	Z2A	15	0.128	-2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
12	67.5	-13.2	13.2	Z2A	15	0.128	2.5	0.0	N/A	50°	90°	0	290	13.4	115	240
N4 Z2B. Z2A Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	68.0	292.0	Z2B	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-68.0	68.0	Z2B	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
N4 Z3. Z3 Inner Radius Section examination from NOZOD.										Step →	0.07	Index →	2.2°			
13	28	90.0	270.0	Z3	15	0.128	-2.5	0.0	N/A	All	All	0	170	7.5	70	150
14	28	-90.0	90.0	Z3	15	0.128	2.5	0.0	N/A	All	All	0	170	7.5	70	150
Notes: Vessel ID radius from B&W drawing Shell Course Subassembly 151825E-1. Vessel nominal thickness from B&W drawing Shell Forming Details 104186D-1 (ordered thickness). Note 1 - Scan into nozzle until onset of liftoff or limited by physical limitations.																

Site Revision 0 2/22/04

QUAD CITIES
REPORT NO. QC2-R17-93
PAGE 15 OF 15

HITACHI		EXAMINATION SUMMARY SHEET				Report No.: Q2R21-010	
Site: <u>Quad Cities</u>		Component ID: <u>0200-W-178</u>					
Outage: <u>Q2R21</u>		RPV SKIRT					
System: <u>RPV</u>		ASME Cat.: <u>F-A</u>		ASME Item <u>F1.40</u>		Aug Req <u>N/A</u>	

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Exam / Oper. Personnel	Cert Level	Date
VT-3	VT-042	N/A	ER-AA-335-016 Ver/Rev 7	N/A	Steve Snyder	II	3/24/2012

Examination Results:

During the visual examination of the above referenced component, no recordable indications were observed.

Examination was limited due to permanent insulation.
 RPV Skirt is approximately 230" long by 72" high. 730" long by 72" high
 Total area = 16,560 sq. inches 52,560 sq. inches
 Area examined = 230" x 7.5" + 216" x 12" = 1869 sq. inches 730" x 7.5" + 216" x 12" = 5619 sq. inches *SE Erickson 4/2/12*
 $1869 / 16,560 = 0.113 \times 100 = 11.3\%$ $5619 / 52,560 = 0.106 \times 100 = 10.6\%$
~~11.3% of the required area was examined.~~
 10.6% of the required ID area was examined. 0% of the required ID area was examined.
 This examination meets the requirements of ASME Section XI, 1995 Edition through 1996 addenda.

Examination results were compared to Data Report <u>N/A</u> from: <u>N/A</u>		☐ Change
These examinations were performed under Work Order: <u>1356987</u>		☐ No Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:					RWP: <u>10012939</u>	
Prepared By: <u>Scott Erickson</u>	Level: <u>III</u>	Date: <u>03/25/12</u>	Utility Review: <u>[Signature]</u>	Date: <u>3-29-12</u>	Dose: <u>10</u> mr.	
ANII Review: <u>[Signature]</u>					Date: <u>4/1/12</u>	Page <u>1</u> of <u>2</u>

Note: IR 0134 7632 generated to document coverage.

17 NOL 3-29-12

Note: IR 0134 7660 generated for drawing revision level *Scott Erickson 4-1-12*



ER-AA-335-016
Revision 7
Page 18 of 18

ATTACHMENT 2
VT-3 Visual Examination NDE Report for Component Supports,
Attachments and Interiors of Reactor Vessels
Page 1 of 1

VT-042

STATION: Quad Cities		UNIT: 2		DATE: 3/24/12		REPORT NO: Q2R21-010	
SYSTEM: RPV		COMP. NO.: 0200-W-178				WO. NO.: 1356987	
VT-3	☒	LIMITED VT-3	☐	DIRECT	☒	REMOTE	☐
DRAWING(S): 149900 E		REV.: 5		DESIGN C.S.: N/A		DESIGN H.S. N/A	
AIDS: FLASHLIGHT		☒	MIRROR	☒	TEST CARD	☒	OTHER: N/A
ATTRIBUTE				RI	NRI	IO	EXPLANATIONS/ COMMENTS
1	CRACK/LINEAR/ROUNDED/PITTING/SEVERED				X		
2	ARC STRIKES/WELD SPATTER/SCORING/ROUGHNESS						N/A
3	EROSION/CORROSION/WEAR/GOUGING/SCRAPING				X		Light Surface Rust
4	DEFORMED/BENT/LOOSE/DETACHED/MISSING PARTS				X		
5	THREAD ENGAGEMENT/BOLT ELONGATION/WELDMENT				X		
6	SPALLED CONCRETE OR GROUT/ANCHORS/IMBED						N/A
7	CLEARANCES/TRAVEL STOPS/PINS						N/A
8	DRAWINGS/ENVIRONMENT				X		
9	LOCKNUT/PIN/TACKWELD SECURING CAN SETTING						N/A
10	NON-INTEGRAL ATTACHMENT LOOSE/INSUL. DAMAGED				X		
11	SPRINGS/ROLLERS/BEARINGS						N/A
12	FLUID LEVEL/FLUID LEAKS/WEEPAGE/INDICATOR STUD						N/A
14	OTHER						N/A
15	• SUPPORT SETTING WITHIN TOLERANCE OF DESIGN			INCHES	N/A	LBS.	N/A
* THESE ITEMS NEED NOT BE EVALUATED WHEN EXAM PERFORMED IS A STATION APPLICABLE LIMITED VT-3.							
RESULTS: RI = RECORDABLE INDICATION NRI = NO RECORDABLE INDICATION IO = INFO ONLY							
COMMENTS: Examination of SKIRT to bottom head weld was limited to the upper 7.5" and 2-6"x12" inspection ports. One at approximately 57° and the other at 300°.							
DOCUMENTATION OF LIMITATIONS/OBSTRUCTIONS Permanently attached insulation from the bottom of the skirt up to 7.5" below the skirt to bottom head weld.							
ISI Interval: 4 th		ISI Period: 3 rd					
EXAMINER: Steve Snyder						LEVEL: II	DATE: 3/24/2012
Further Evaluation Required: ☐ Yes ☒ No							
Additional Actions: N/A							
(Action Request, Work Order, Issue Report, etc. initiated for Corrective Action)							
REVIEWER:						DATE: 3-28-12	
ANII:						DATE: 4/1/12	

 Create another New Issue

 Create another Issue from '01347632'

Print Close window

****AS REQUIRED, PRINT ISSUE REPORT AND PROVIDE TO YOUR SUPERVISOR******Note: This is your only notice. You will not have an opportunity to print this confirmation later.****Exelon Nuclear Issue - Statement of Confirmation**

Issue #: 01347632

Originator: JAY MILLER

Submit Date: March 29, 2012

Basic Information

Affected Facility: Quad Cities

Dscv Date: 03/29/2012 18:00

How Discovered Code: H02

Event Date: 03/29/2012 18:00

Affected Unit: 02

Affected Sys: RX

Subject: COVERAGE LESS THAN 90% FOR ISI COMPONENT 0200-W-178

Work Against: N

Name: COVERAGE LESS THAN 90% FOR ISI COMPONENT 0200-W-178

Equipment Location: Quad Cities Unit 2

Required Information

Condition Description: During Q2R21 an ISI examination was scheduled to be performed on component 200-W-178 for the Unit 2 RPV Skirt. A VT-3 examination was performed in accordance with ER-AA-335-016 Revision 7 on the examination area specified in ASME Section XI, IWF-2500. Due to the physical limitations of the permanent insulation only 11.3% coverage could be obtained. ASME Section XI requires a minimum of 90% coverage. If 90% coverage can not be achieved a relief request will be required to document the coverage achieved. It was also determined that no other examination methods could have been used to obtain additional coverage. This IR is being generated as required by ER-AA-335-010 to document the coverage achieved during this examination – No indications were discovered and there are no operability issues.

Immediate actions taken: Notified the ISI Program Owner
Wrote IR

Recommendation for action: Generate an AT for the Engineering ISI Program Owner to update the ISI database and ISI Program with the actual coverage achieved.

Supervisor Verbally Contacted: Mac Rice

Optional Additional Information**Routing**

Owed To Group: ACAPALL

Routed to Group: CR-OSC

 Go Back

[Print](#) | [New Search](#) | [Home](#)

AR 01347660 Report

Aff Fac:	Quad Cities	AR Type:	CR	Status:	APPROVED
Aff Unit:	00	Owed To:	A8450ENCAP	Due Date:	04/28/2012
Aff System:	--			Event Date:	03/29/2012
CR Level/Class:	4/D			Disc Date:	03/29/2012
How Discovered:	H02			Orig Date:	03/29/2012
WR/PIMS AR:		Equip Tag:	-		

Action Request Details

Subject: PASSPORT DRAWING REVISION LEVEL DOES NOT MATCH OLE

Description: Originator: DAVID J KNOX Supv Contacted: J. Campagna

Condition Description:

In Passport, the controlled documents panel (C010) for Babcock & Wilcox vendor drawing 1499900E shows revision level 006. The drawing viewed via the OLE is revision level 5.

Immediate actions taken:

Wrote IR.

Recommended Actions:

Update Passport to show correct revision level of the drawing

Operable Basis:

Reportable Basis:

Functional Basis:

SOC Reviewed by: MICHAEL A GRAHAM 03/31/2012 08:38:30 CDT

SOC Comments:

The apcard image was imported in 2006.

*

From Mike Stephenson: Current practice is to start vendor drawings at Rev A, regardless of what the vendor revision is. This is because the vendors can and do revise their own drawings. This does not mean our installed equipment has changed, therefore our drawing revisions remain the same until we alter the equipment such that a revision is necessary to our drawing. Records Management added Mike Stephensons notes to passport as it is an old legacy issue. Close to actions taken and information provided. (Finks 3/30/12) (SOC 3/31/12)

Assignments

Assign #:	Assigned To:	Status:	COMPLETE
------------------	---------------------	----------------	----------

<u>01</u>			
Aff Fac:	Quad Cities	Prim Grp:	ACAPALL
Assign Type:	TRKG	Sec Grp:	
Priority:		Due Date:	04/03/2012
Schedule Ref:		Orig Due Date:	
Unit Condition:			
Subject/Description:	PASSPORT DRAWING REVISION LEVEL DOES NOT MATCH OLE		