

NORTHEAST NUCLEAR ENERGY COMPANY  
MILLSTONE NUCLEAR POWER STATION  
UNITS NO. 1 & NO. 2

Docket # 50-245  
Control # 8003040509  
Date 2-29-80 of Document  
**REGULATORY DOCKET FILE**

SEMIANNUAL RADIOACTIVE EFFLUENTS  
RELEASE REPORT

July 1, 1979 - December 31, 1979

Operating License No's. DPR-21 & DPR-65

Docket No's. 50-245 & 50-336

February 29, 1980

8003040509

NORTHEAST NUCLEAR ENERGY COMPANY  
MILLSTONE NUCLEAR POWER STATION  
UNITS NO. 1 & NO. 2

SEMIANNUAL RADIOACTIVE EFFLUENTS  
RELEASE REPORT

July 1, 1979 - December 31, 1979

Operating License No's. DPR-21 & DPR-65

Docket No's. 50-245 & 50-336

February 29, 1980

## INTRODUCTION

1.0 This report is being submitted for Northeast Nuclear Energy Company's, Millstone Nuclear Power Station, Units No. 1 and No. 2 in accordance with the requirements of 10CFR50.36a, and the Technical Specifications and in the format outlined by U. S. NRC Regulatory Guide 1.21.

During the period covered by this report, Unit No. 1 operated with a unit capacity factor of 96% and Unit No. 2 with a unit capacity factor of 70%.

Unit No. 1 was shutdown for refueling from N/A to \_\_\_\_\_.

Unit No. 2 was shutdown for refueling from N/A to \_\_\_\_\_.

A single report is being submitted for both units as the two units share a number of items related to this report. However, release data and dose calculations are presented separately for each unit.

## RADIOACTIVE EFFLUENT RELEASES

2.0 The plants were operated in accordance with the Technical Specifications. The liquid and airborne radioactive effluents are given in the attached tables as follows:

Table 2.1-1	Unit 1 Liquid Effluents-Summation
Table 2.1-2	Unit 1 Liquid Effluents-Batch Mode
Table 2.1-3	Unit 1 Gaseous Effluents-Summation
Table 2.1-4	Unit 1 Gaseous Effluents-Elevated Continuous
Table 2.2-1	Unit 2 Liquid Effluents-Summation
Table 2.2-2	Unit 2 Liquid Effluents-Continuous Mode
Table 2.2-3	Unit 2 Liquid Effluents-Batch Mode
Table 2.2-4	Unit 2 Gaseous Effluents-Summation
Table 2.2-5	Unit 2 Gaseous Effluents-Mixed Continuous - Unit 2 Ventilation
Table 2.2-6	Unit 2 Gaseous Effluents Elevated or Mixed Batch - Unit 2 Containment Purges
Table 2.2-7	Unit 2 Gaseous Effluents-Elevated Batch - Unit 2 Waste Gas Tanks
Table 2.3-1	Supplemental Information

Table 2.1-1

MILLSTONE NUCLEAR POWER STATION - UNIT No. 1EFFLUENT AND WASTE DISPOSAL REPORT  
LIQUID EFFLUENTS - SUMMARY OF ALL RELEASESYear 1979

Units	JULY	AUG.	SEPT.	QUARTERLY TOTALS	Est. Total Error, %
-------	------	------	-------	------------------	---------------------

## A. Fission and Activation Products

1. Total released(not including H-3,Gases, Alpha)	Ci	4.46E-03	1.44E-03	2.92E-03	8.82E-03	1.50E+01
2. Average diluted concentration during period	µCi/ml	3.81E-09	1.69E-09	1.90E-09	2.48E-09	
3. Percent of applicable limit **	%	-	-	-	** 0.09	

\*\* Based on limit of 10.0 curies per quarter - E.T.S., 2.4.1.2.E

## B. Tritium

1. Total Released	Ci	1.37E-02	3.41E-01	5.81E-01	9.36E-01	1.50E+01
2. Average diluted concentration during period	µCi/ml	1.17E-08	4.00E-07	3.77E-07	2.63E-07	

## C. Dissolved and Entrained Gases

1. Total Released	Ci	≤ 1.24E-05	4.84E-02	4.02E-02	8.86E-02	1.50E+01
2. Average diluted concentration during period	µCi/ml	≤ 1.06E-11	5.68E-08	2.61E-08	2.4E-08	-

## D. Gross Alpha Radioactivity

1. Total Released	Ci	3.21E-06	≤ 1.42E-05	≤ 1.51E-05	3.21E-06	1.50E+01
-------------------	----	----------	------------	------------	----------	----------

E. Volume of waste released(Prior to dilution)	liters	9.58E+03	2.84E+05	3.01E+05	5.95E+05	1.00E+01
--	--------	----------	----------	----------	----------	----------

F. Volume of dilution water used during period	liters	1.17E+09	8.52E+08	1.54E+09	3.56E+09	1.00E+01
--	--------	----------	----------	----------	----------	----------

Table 2.1-1 (cont.)

WINDYBROOK NUCLEAR POWER STATION - UNIT No. 1

EFFLUENT AND WASTE DISPOSAL REPORT  
 LIQUID EFFLUENTS - SUBMISSION OF ALL EFFLUENTS

Year 1979

Units	OCT	NOV	DEC	QUARTERLY TOTALS	Est. Total Error, %
-------	-----	-----	-----	------------------	---------------------

A. Fission and Activation Products

1. Total released(not including H-3,Gases, Alpha)	Ci	4.47E-03	4.29E-03	1.31E-03	1.01E-02	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.46E-09	8.22E-10	8.85E-10	1.51E-09	
3. Percent of applicable limit **	%	---	---	---	** 0.10	

\*\* Based on limit of 10.0 curies per quarter - E.T.S., 2.4.1.2.E

B. Tritium

1. Total Released	Ci	1.01E+00	8.11E-01	5.51E-01	2.37E+00	1.50E+01
2. Average diluted concentration during period	uCi/ml	3.30E-07	3.75E-07	3.72E-07	3.54E-07	

C. Dissolved and Entrained Gases

1. Total Released	Ci	1.41E-02	2.49E-01	6.76E-03	2.70E-01	1.50E+01
2. Average diluted concentration during period	uCi/ml	4.61E-09	1.15E-07	4.57E-09	4.03E-08	

D. Gross Alpha Radioactivity

1. Total Released	Ci	≤2.31E-05	≤2.30E-05	≤1.99E-05	≤6.60E-05	1.50E+01
-------------------	----	-----------	-----------	-----------	-----------	----------

E. Volume of waste released(Prior to dilution)	liters	4.61E+05	5.75E+05	3.91E+05	1.43E+06	1.00E+01
--	--------	----------	----------	----------	----------	----------

F. Volume of dilution water used during period	liters	3.06E+09	2.16E+09	1.48E+09	6.70E+09	1.00E+01
--	--------	----------	----------	----------	----------	----------



Table 2.1-2 (cont.)

MILLSTONE NUCLEAR POWER STATION UNIT No. 1

## EFFLUENT AND WASTE DISPOSAL REPORT

YEAR 1979

## LIQUID EFFLUENTS - BATCH MODE

Nuclides Released	Unit	OCT	NOV	DEC	Quarterly Total
I-131	Ci	2.56E-04	4.83E-04	1.34E-04	8.72E-04
Ba,La-140	Ci	1.10E-03	7.68E-04	1.09E-05	1.88E-03
Cs-134	Ci	---	---	6.29E-05	6.29E-05
Cs-137	Ci	---	---	2.70E-04	2.70E-04
Co-58	Ci	---	1.88E-05	6.01E-06	2.48E-05
Co-60	Ci	1.13E-03	1.04E-03	6.71E-04	2.84E-03
Mn-54	Ci	4.36E-04	2.48E-04	9.97E-05	7.83E-04
Mo-99	Ci	2.38E-05	---	---	2.38E-05
Ce-141	Ci	5.32E-05	7.16E-05	---	1.25E-04
Cr-51	Ci	1.31E-03	1.40E-03	---	2.71E-03
I-133	Ci	7.24E-05	2.28E-04	2.46E-06	3.02E-04
I-132	Ci	---	---	1.13E-05	1.13E-05
Ru-105	Ci	7.63E-05	---	---	7.63E-05
Sr-89	Ci	≤2.31E-05	≤2.88E-05	≤1.37E-05	≤6.56E-05
Sr-90	Ci	7.84E-06	2.42E-05	≤2.54E-06	3.20E-05
Nb-95	Ci	---	1.04E-05	---	1.04E-05
Mn-56	Ci	---	---	1.63E-05	1.63E-05
I-134	Ci	---	---	2.11E-05	2.11E-05
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
Total for period(above)	Ci	4.47E-03	4.29E-03	1.31E-03	1.01E-02
xenon-133	Ci	6.70E-03	7.69E-02	3.22E-03	8.68E-02
xenon-135	Ci	7.38E-03	1.72E-01	3.54E-03	1.83E-01
	Ci				



Table 2.1-3

MILLSTONE NUCLEAR POWER STATION - UNIT No. 1EFFLUENT AND WASTE DISPOSAL REPORT  
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASESYear 1979

Units	JULY	AUG.	SEPT.	QUARTERLY TOTALS	Est. Total Error, %
-------	------	------	-------	---------------------	------------------------

## A. Fission and Activation Gases

1. Total Released	Ci	1.54E+03	1.41E+03	2.15E+03	5.10E+03	2.50E+01
2. Average Release Rate For Period	uCi/sec	5.75E+02	5.26E+02	8.30E+02	6.42E+02	
3. Percent of Technical Specification Limit	%	-	-	-	* 0.243	

\* Limit as per E.T.S. Equation 2.4.2.2.B.1

## B. Iodines

1. Total Iodine - 131	Ci	1.06E-02	1.57E-02	1.67E-02	4.30E-02	2.50E+01
2. Average Release Rate For Period	uCi/sec	3.96E-03	5.86E-03	6.45E-03	5.41E-03	

## C. Particulates

1. Particulates With Half-lives > 8 Days	Ci	1.09E-02	1.11E-02	9.12E-03	3.11E-02	2.50E+01
2. Average Release Rate For Period	uCi/sec	4.07E-03	4.14E-03	3.52E-03	3.91E-03	
3. Percent of Technical Specification Limit	%	-	-	-	** 1.17	
4. Gross Alpha Radioactivity	Ci	1.60E-06	1.80E-06	2.08E-06	5.48E-06	

\*\* Limit as per E.T.S. Equation 2.4.2.2.B.2

## D. Tritium

1. Total Released	Ci	3.48E+00	1.20E+01	8.75E+00	2.42E+01	2.50E+01
2. Average Release Rate For Period	uCi/sec	1.30E+00	4.48E+00	3.38E+00	3.04E+00	

Table 2.1-3 (cont.)  
MILLSTONE NUCLEAR POWER STATION - UNIT No. 1

EFFLUENT AND WASTE DISPOSAL REPORT  
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Year 1979

Units	OCT	NOV	DEC	QUARTERLY TOTALS	Est. Total Error, %
-------	-----	-----	-----	------------------	---------------------

A. Fission and Activation Cases

1. Total Released	Ci	1.72E+03	8.91E+02	7.16E+02	3.33E+03	2.50E+01
2. Average Release Rate For Period	uCi/sec	6.42E+02	3.44E+02	2.67E+02	4.19E+02	
3. Percent of Technical Specification Limit	%	_____	_____	_____	*0.711	

\* Limit as per E.T.S. equation 2.4.2.2.B.1

B. Iodines

1. Total Iodine - 131	Ci	1.66E-02	2.41E-02	1.67E-02	5.74E-02	2.50E+01
2. Average Release Rate For Period	uCi/sec	6.20E-03	9.30E-03	6.24E-03	7.22E-03	

C. Particulates

1. Particulates With Half-lives > 8 Days	Ci	9.21E-03	1.69E-02	1.09E-02	3.70E-02	2.50E+01
2. Average Release Rate For Period	uCi/sec	3.44E-03	5.60E-03	4.07E-03	4.65E-03	
3. Percent of Technical Specification Limit	%	_____	_____	_____	**1.17E+00	
4. Gross Alpha Radioactivity	Ci	8.57E-07	1.56E-06	1.62E-06	4.04E-06	

\*\* Limit as per E.T.S. equation 2.4.2.2.B.2

D. Tritium

1. Total Released	Ci	2.86E+00	2.79E+00	3.57E+00	9.22E+00	2.50E+01
2. Average Release Rate For Period	uCi/sec	1.07E+00	1.08E+00	1.33E+00	1.16E+00	

Table 2.1-4  
MILLSTONE NUCLEAR POWER STATION - UNIT No. 1

EFFLUENT AND WASTE DISPOSAL REPORT

YEAR 1979 GASEOUS EFFLUENTS-ELEVATED RELEASE - CONTINUOUS MODE

Nuclides Released	Unit	JULY	AUG.	SEPT.	Quarterly Total
-------------------	------	------	------	-------	-----------------

1. Fission gases

Xe-135	Ci	3.17E+02	3.69E+02	3.60E+02	1.05E+03
Kr-87	Ci	6.23E-01	2.01E+01	-	2.07E+01
Kr-88	Ci	-	-	-	-
Kr-85m	Ci	3.35E+01	1.69E+01	-	5.04E+01
Xe-135	Ci	2.98E+02	3.58E+02	4.22E+02	1.08E+03
Xe-133	Ci	5.21E+01	1.32E+01	1.36E+02	2.01E+02
Kr-89	Ci	-	-	-	-
Xe-137	Ci	4.66E+02	7.50E+01	7.69E+02	1.31E+03
Xe-135m	Ci	3.69E+02	5.56E+02	4.64E+02	1.39E+03
Kr-83m	Ci	-	-	-	-
Xe-133m	Ci	-	-	-	-
Xe-131m	Ci	-	-	-	-
Kr-85	Ci	-	-	-	-
Ar-37	Ci	-	-	-	-
Total For Period	Ci	1.54E+03	1.41E+03	2.15E+03	5.10E+03

2. Iodines

iodine-131	Ci	1.04E-02	1.51E-02	1.62E-02	4.17E-02
iodine-133	Ci	5.94E-02	7.39E-02	8.90E-02	2.22E-01
iodine-135	Ci	7.61E-02	7.69E-02	1.04E-01	2.57E-01
Total for period	Ci	1.46E-01	1.66E-01	2.09E-01	5.21E-01

3. Particulates

I-131	Ci	1.71E-04	5.72E-04	4.99E-04	1.24E-03
Ba,La-140	Ci	8.80E-03	8.30E-03	6.62E-03	2.37E-02
Mn-54	Ci	2.92E-04	2.30E-04	2.32E-04	7.54E-04
Co-58	Ci	1.98E-05	3.54E-05	4.38E-05	9.90E-05
Co-60	Ci	4.30E-04	5.24E-04	5.28E-04	1.48E-03

Cs-134	Ci	1.25E-05	2.58E-05	1.38E-05	5.21E-05
Cs-137	Ci	1.11E-04	1.38E-04	7.94E-05	3.28E-04
Fe-59	Ci	1.40E-05	2.79E-05	2.05E-05	6.24E-05
	Ci				
	Ci				

Sr-89	Ci	* 1.02E-03	1.28E-03	1.07E-03	3.37E-03
Sr-90	Ci	7.33E-06	9.17E-06	6.98E-06	2.35E-05
	Ci				
	Ci				
	Ci				

\* Particulate samples for July were lost during analysis for Strontium. Since the unit was shutdown for all of June, July strontium releases were calculated using

Table 2.1-4 (cont.)  
 HILLSTONE NUCLEAR POWER STATION - UNIT No. 1

EFFLUENT AND WASTE DISPOSAL REPORT

YEAR 1979 GASEOUS EFFLUENTS-ELEVATED RELEASE - CONTINUOUS MODE

Nuclides Released	Unit	OCT	NOV	DEC	Quarterly Total
-------------------	------	-----	-----	-----	-----------------

1. Fission gases

Xe-133	Ci	3.48E+02	3.49E+02	3.66E+02	1.06E+03
Kr-87	Ci	2.81E+01	---	1.10E+01	3.91E+01
Kr-88	Ci	---	---	1.03E+01	1.03E+01
Kr-85m	Ci	9.64E+00	3.16E+01	3.10E+00	4.43E+01
Xe-135	Ci	5.01E+01	5.27E+01	3.58E+01	1.39E+02
Xe-133	Ci	1.14E+01	---	---	1.14E+01
Kr-89	Ci	---	---	---	---
Xe-137	Ci	1.15E+03	---	---	1.15E+03
Xe-135m	Ci	1.25E+02	1.06E+02	1.26E+02	3.57E+02
Kr-83m	Ci	---	---	---	---
Xe-133m	Ci	---	---	---	---
Xe-131m	Ci	---	3.52E+02	1.64E+02	5.16E+02
Kr-85	Ci	---	---	---	---
Ar-37	Ci	---	---	---	---
Total For Period	Ci	1.72E+03	8.91E+02	7.16E+02	3.33E+03

2. Iodines

iodine-131	Ci	1.57E-02	2.26E-02	1.52E-02	5.35E-02
iodine-133	Ci	8.15E-02	1.20E-01	9.14E-02	2.93E-01
iodine-135	Ci	7.05E-02	1.56E-01	1.23E-01	3.50E-01
Total for period	Ci	1.68E-01	2.99E-01	2.30E-01	6.97E-01

3. Particulates

I-131	Ci	9.49E-04	1.50E-03	1.50E-03	3.95E-03
Ba,La-140	Ci	6.99E-03	1.33E-02	7.74E-03	2.80E-02
Mn-54	Ci	1.16E-04	2.68E-04	2.47E-04	6.31E-04
Co-58	Ci	4.36E-06	2.96E-05	3.51E-05	6.01E-05
Co-60	Ci	2.04E-04	4.21E-04	2.48E-04	8.73E-04

Cs-134	Ci	2.21E-06	7.01E-06	2.62E-05	3.54E-05
Cs-137	Ci	4.15E-05	7.32E-05	1.23E-04	2.38E-04
Fe-59	Ci	7.83E-05	---	3.71E-06	2.70E-05
	Ci				
	Ci				

Sr-89	Ci	8.75E-04	1.32E-03	9.25E-04	3.12E-03
Sr-90	Ci	5.03E-06	7.98E-06	1.49E-05	1.79E-05
	Ci				
	Ci				
	Ci				

Table 2.2-1

MILLSTONE NUCLEAR POWER STATION - UNIT No. 2EFFLUENT AND WASTE DISPOSAL REPORT  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASESYear 1979

Units	JULY	AUGUST	SEPTEMBER	QUARTERLY TOTALS	Est. Total Error, %
-------	------	--------	-----------	------------------	---------------------

## A. Fission and Activation Products

1. Total released(not including H-3,Gases, Alpha)	Ci	1.30E-01	8.17E-02	1.19E-01	3.31E-01	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.61E-09	1.59E-09	1.48E-09	1.56E-09	
3. Percent of applicable limit **	%	1.30E+00	8.17E-01	1.19E+00	3.31E+00	

\*\* Based on limit of 10.0 curies per quarter - E.T.S., 2.4.1.2.E

## B. Tritium

1. Total Released	Ci	1.51E+01	2.41E+01	2.92E+01	6.84E+01	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.87E-10	4.70E-07	3.65E-07	3.23E-07	

## C. Dissolved and Entrained Gases

1. Total Released	Ci	1.24E-02	6.82E-03	6.18E-03	2.54E-02	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.54E-10	1.33E-10	7.72E-11	1.20E-10	

## D. Gross Alpha Radioactivity

1. Total Released	Ci	≤ 3.56E-04	≤ 2.71E-04	3.34E-04	---	1.50E+01
-------------------	----	------------	------------	----------	-----	----------

E. Volume of waste released(Prior to dilution)	liters	7.11E+06	5.36E+06	6.40E+06	1.89E+07	1.00E+01
--	--------	----------	----------	----------	----------	----------

F. Volume of dilution water used during period	liters	8.35E+10	5.13E+10	8.01E+10	2.12E+11	1.00E+01
--	--------	----------	----------	----------	----------	----------

Table 2.2-1 (cont.)  
MILLSTONE NUCLEAR POWER STATION - UNIT No. 2

EFFLUENT AND WASTE DISPOSAL REPORT  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

Year 1979

Units	OCTOBER	NOVEMBER	DECEMBER	QUARTERLY TOTALS	Est. Total Error, %
-------	---------	----------	----------	------------------	---------------------

A. Fission and Activation Products

1. Total released(not including H-3,Gases, Alpha)	Ci	1.79E-01	9.62E-02	1.36E-01	4.11E-01	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.89E-09	2.27E-08	1.89E-09	2.40E-09	
3. Percent of applicable limit **	%	1.79E+00	9.62E-01	1.36E+00	4.11E+00	

\*\* Based on limit of 10.0 curies per quarter - E.T.S., 2.4.1.2.E

B. Tritium

1. Total Released	Ci	1.69E+01	5.40E+01	2.21E+01	9.30E+01	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.79E-07	1.27E-05	3.09E-07	5.44E-07	

C. Dissolved and Entrained Gases

1. Total Released	Ci	1.60E-02	1.96E-01	3.92E-02	2.51E-01	1.50E+01
2. Average diluted concentration during period	uCi/ml	1.69E-10	4.62E-08	5.47E-10	1.47E-09	

D. Gross Alpha Radioactivity

1. Total Released	Ci	≤ 3.50E-04	≤ 5.68E-05	≤ 3.61E-05	- - - -	1.50E+01
-------------------	----	------------	------------	------------	---------	----------

E. Volume of waste released(Prior to dilution)	liters	6.78E+06	7.10E+05	5.70E+06	1.32E+07	1.00E+01
--	--------	----------	----------	----------	----------	----------

F. Volume of dilution water used during period	liters	9.46E+10	4.24E+09	7.17E+10	1.71E+11	1.00E+01
--	--------	----------	----------	----------	----------	----------

Table 2.2-2

HILLSTONE NUCLEAR POWER STATION - UNIT No. 2

## EFFLUENT AND WASTE DISPOSAL REPORT

YEAR 1979

LIQUID EFFLUENTS-CONTINUOUS MODE

STEAM GENERATOR BLOWDOWN

Nuclides Released	Unit	JULY	AUGUST	SEPTEMBER	Quarterly Total
I-131	Ci	$\leq 9.74E-03$	$\leq 3.51E-03$	$4.17E-04$	$4.17E-04$
Ba,La-140	Ci	$\leq 2.69E-03$	$\leq 1.00E-03$	$\leq 9.17E-04$	-- --
Co-60	Ci	$2.88E-03$	$1.36E-03$	$1.96E-03$	$6.20E-03$
Cs-137	Ci	$2.58E-04$	-- --	-- --	$2.58E-04$
I-133	Ci	-- --	-- --	$5.14E-04$	$5.14E-04$
Sr-89	Ci	$\leq 1.34E-04$	$\leq 2.51E-04$	$\leq 2.43E-04$	-- --
Sr-90	Ci	$\leq 3.36E-05$	$\leq 4.02E-04$	$\leq 3.04E-04$	-- --
	Ci				
	Ci				
TOTALS FOR PERIOD	Ci	$3.14E-03$	$1.36E-03$	$2.89E-03$	$7.39E-03$
	Ci				
	Ci				
	Ci				
	Ci				
H-3	Ci	$3.24E-02$	$3.88E-02$	$1.02E-01$	$1.73E-01$
	Ci				
GROSS ALPHA	Ci	$\leq 3.36E-04$	$\leq 2.51E-04$	$\leq 3.04E-04$	-- --
	Ci				
	Ci				
	Ci				
	Ci				
Total for period (above)	Ci				
xenon-133	Ci	$\leq 3.88E-03$	$\leq 2.73E-04$	$\leq 5.09E-04$	-- --
xenon-135	Ci	$\leq 9.66E-04$	$\leq 9.67E-05$	$\leq 1.42E-04$	-- --
	Ci				

Table 2.2-2 (cont.)

MILLSTONE NUCLEAR POWER STATION - UNIT No. 2

EFFLUENT AND WASTE DISPOSAL REPORT

Steam Generator Blowdown

YEAR 1979

LIQUID EFFLUENTS-CONTINUOUS MODE

Nuclides Released	Unit	October	November	December	Quarterly Total
-------------------	------	---------	----------	----------	-----------------

I-131	Ci	≤ 2.49E-04		≤ 6.22E-04	-----
Ba, La-140	Ci	≈ 4.36E-04		≈ 6.22E-04	-----
Co-60	Ci	2.30E-03		-----	2.30E-03
Mn-54	Ci	7.74E-04		-----	7.74E-04
Cs-137	Ci	-----		5.35E-04	5.35E-04

Na-24	Ci	-----		2.70E-02	2.70E-02 ***
Sr-89	Ci	≈ 3.41E-04		≈ 1.99E-04	-----
Sr-90	Ci	≈ 3.90E-05		≈ 3.49E-05	-----
Total For Period	Ci	3.07E-03		2.75E-02	3.06E-02
	Ci				

\*\*\* Discharged During Special Flow Test of Secondary System

	Ci				
H-3	Ci	3.71E-02	12-05-79	2.23E-02	6.68E-02
	Ci				
Gross Alpha	Ci	≈ 3.25E-04		≈ 2.49E-04	-----
	Ci				

	Ci				
	Ci				
	Ci				
	Ci				
	Ci				

	Ci				
	Ci				
	Ci				
	Ci				
	Ci				

Total for period (above)	Ci				
--------------------------	----	--	--	--	--

xenon-133	Ci	≈ 2.10E-03		≈ 9.90E-04	-----
xenon-135	Ci	≈ 5.16E-04		≈ 3.03E-04	-----
	Ci				

UNIT OFF LINE 11-01-79



Table 2.2-3

MILLSTONE NUCLEAR POWER STATION UNIT No. 2

## EFFLUENT AND WASTE DISPOSAL REPORT

YEAR 1979LIQUID EFFLUENTS - BATCH MODE  
LIQUID RAD WASTE

Nuclides Released	Unit	JULY	AUGUST	SEPTEMBER	Quarterly Total
I-131	Ci	$\leq 2.32E-04$	$5.92E-05$	-- --	$5.92E-05$
Ba,La-140	Ci	$\leq 5.11E-04$	$1.49E-05$	$\leq 4.85E-04$	$1.49E-05$
Cs-134	Ci	$4.35E-03$	$6.95E-03$	$9.29E-03$	$2.06E-02$
Cs-137	Ci	$4.69E-03$	$8.81E-03$	$1.13E-02$	$2.48E-02$
Co-58	Ci	$3.12E-02$	$1.81E-02$	$2.36E-02$	$7.29E-02$
Co-60	Ci	$5.50E-02$	$3.67E-02$	$5.97E-02$	$1.51E-01$
Mn-54	Ci	$4.99E-03$	$3.52E-03$	$5.32E-03$	$1.38E-02$
Cr-51	Ci	$7.66E-04$	$6.30E-04$	$5.41E-05$	$1.45E-03$
Ag-110m	Ci	$2.68E-03$	$1.75E-05$	$1.19E-03$	$3.89E-03$
Nb-97	Ci	$3.27E-03$	$2.14E-03$	$1.40E-03$	$6.81E-03$
W-187	Ci	$1.34E-02$	$1.39E-04$	$3.48E-04$	$1.39E-02$
Ru-105	Ci	$1.42E-03$	$7.41E-04$	$8.19E-04$	$2.98E-03$
Zr-95	Ci	$1.01E-03$	$2.94E-04$	$6.39E-04$	$1.94E-03$
Nb-95	Ci	$2.99E-03$	$1.47E-03$	$1.55E-03$	$6.01E-03$
Cs-136	Ci	$1.61E-04$	$1.15E-04$	$1.54E-04$	$4.30E-04$
Fe-59	Ci	$6.05E-04$	$3.46E-04$	$9.30E-05$	$1.04E-03$
Na-24	Ci	$2.53E-04$	$1.58E-04$	-- --	$4.11E-04$
Sr-92	Ci	$3.38E-05$	-- --	-- --	$3.38E-05$
I-132	Ci	-- --	$8.15E-05$	-- --	$8.15E-05$
Mn-56	Ci	-- --	$8.88E-06$	-- --	$8.88E-06$
I-134	Ci	-- --	$1.14E-05$	-- --	$1.14E-05$
Zn-65	Ci	-- --	$1.07E-05$	-- --	$1.07E-05$
Ce-144	Ci	-- --	-- --	$1.97E-04$	$1.97E-04$
Mo-99	Ci	-- --	-- --	$5.58E-06$	$5.58E-06$
Ce-141	Ci	-- --	-- --	$1.07E-05$	$1.07E-05$
Sr-89	Ci	$\leq 2.33E-05$	$\leq 1.68E-05$	$\leq 1.32E-05$	-- --
Sr-90	Ci	$5.84E-05$	$\leq 3.36E-06$	$8.28E-06$	$6.67E-05$
TOTALS FOR PERIOD	Ci	$1.27E-01$	$8.03E-02$	$1.16E-01$	$3.23E-01$
GROSS ALPHA	Ci	$\leq 1.95E-05$	$\leq 2.02E-05$	$\leq 2.98E-05$	-- --
Xenon-133	Ci	$1.24E-02$	$6.81E-03$	$6.11E-03$	$2.53E-02$
Xenon-135	Ci	$8.65E-06$	$1.20E-05$	$7.38E-05$	$9.45E-05$
H-3	Ci	$1.51E+01$	$2.41E+01$	$2.91E+01$	$6.83E+01$

Table 2.2-3 (cont.)

MILLSTONE NUCLEAR POWER STATION UNIT No. 2

## EFFLUENT AND WASTE DISPOSAL REPORT

YEAR 1979

LIQUID EFFLUENTS - BATCH MODE

Liquid Rad Waste

Nuclides Released	Unit	October	November	December	Quarterly Total
I-131	Ci	1.26E-04	2.59E-04	6.87E-05	4.54E-04
Ba,La-140	Ci	4.68E-07	3.20E-05	1.46E-06	3.39E-05
Cs-134	Ci	1.23E-02	7.60E-03	1.23E-02	3.22E-02
Cs-137	Ci	1.34E-02	9.79E-03	1.44E-02	3.76E-02
Co-58	Ci	7.78E-02	1.15E-02	4.66E-02	1.36E-01
Co-60	Ci	5.67E-02	5.29E-02	2.50E-02	1.35E-01
Mn-54	Ci	6.79E-03	3.57E-03	1.66E-03	1.20E-02
Ag-110m	Ci	3.24E-03	3.31E-03	1.76E-03	8.31E-03
Nb-97	Ci	4.62E-03	3.80E-03	2.06E-03	1.05E-02
W-187	Ci	3.58E-04	2.39E-04	1.04E-04	7.01E-04
Ru-105	Ci	4.01E-05	2.10E-04	4.69E-04	7.19E-04
Zr-95	Ci	5.38E-05	1.67E-04	2.85E-04	5.06E-04
Nb-95	Ci	5.81E-04	9.70E-04	8.84E-04	2.44E-03
Cs-136	Ci	1.61E-04	1.24E-04	4.14E-06	2.89E-04
Fe-59	Ci	4.09E-05	4.63E-04	8.07E-04	1.31E-03
Sr-92	Ci	1.38E-04	7.51E-04	2.74E-04	1.16E-03
Cr-51	Ci	- - - -	3.85E-04	1.30E-03	1.69E-03
I-133	Ci	- - - -	1.37E-05	1.20E-05	2.57E-05
Zr-97	Ci	- - - -	1.45E-05	- - - -	1.45E-05
I-135	Ci	- - - -	4.05E-05	- - - -	4.05E-05
Na-24	Ci	- - - -	9.91E-05	4.10E-05	1.40E-04
Mo-99	Ci	- - - -	9.62E-06	- - - -	9.62E-06
Sr-89	Ci	≈ 1.10E-05	≈ 2.13E-05	≈ 2.89E-05	- - - -
Sr-90	Ci	7.45E-06	≈ 4.26E-06	≈ 7.22E-06	7.45E-06
Totals For Period	Ci	1.76E-01	9.62E-02	1.08E-01	3.81E-01
Gross Alpha		≈ 2.48E-05	≈ 5.68E-05	≈ 3.61E-05	- - - -
H-3		1.69E+01	5.40E+01	2.21E+01	9.30E+01
Total for period(above)	Ci				
xenon-133	Ci	1.59E-02	1.96E-01	3.90E-02	2.51E-01
xenon-135	Ci	1.07E-04	5.58E-05	1.63E-04	3.26E-04
	Ci				

Table 2.2-4

MILLSTONE NUCLEAR POWER STATION - UNIT No. 2  
 EFFLUENT AND WASTE DISPOSAL REPORT  
 GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Year 1979

Units	JULY	AUGUST	SEPTEMBER	QUARTERLY TOTALS	Est. Total Error, %
-------	------	--------	-----------	---------------------	------------------------

## A. Fission and Activation Gases

1. Total Released	Ci	1.42E+02	2.15E+01	2.21E+01	1.86E+02	2.50E+01
2. Average Release Rate For Period	uCi/sec	5.30E+01	8.02E+00	8.55E+00	2.33E+01	
3. Percent of Technical Specification Limit	%	---	---	---	---	

## B. Iodines

1. Total Iodine - 131	Ci	8.45E-05	6.13E-04	6.13E-05	7.59E-04	2.50E+01
2. Average Release Rate For Period	uCi/sec	3.15E-05	2.29E-04	2.37E-05	9.54E-05	

## C. Particulates

1. Particulates With Half-lives > 8 Days	Ci	2.24E-04	1.22E-03	8.71E-05	1.53E-03	2.50E+01
2. Average Release Rate For Period	uCi/sec	8.37E-05	4.57E-04	3.36E-05	1.93E-04	
3. Percent of Technical Specification Limit	%	---	---	---	---	
4. Gross Alpha Radioactivity	Ci	$\leq 6.01E-08$	$\leq 6.21E-08$	$\leq 3.50E-08$	---	

## D. Tritium

1. Total Released	Ci	5.29E+01	2.62E+00	1.89E+00	5.74E+01	2.50E+01
2. Average Release Rate For Period	uCi/sec	1.97E+01	9.78E-01	7.30E-01	7.22E+00	

Table 2.2-4 (cont.)  
 MILLSTONE NUCLEAR POWER STATION - UNIT No. 2

EFFLUENT AND WASTE DISPOSAL REPORT  
 GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Year 1979

Units	OCTOBER	NOVEMBER	DECEMBER	QUARTERLY TOTALS	Est. Total Error, %
-------	---------	----------	----------	------------------	---------------------

A. Fission and Activation Gases

1. Total Released	Ci	1.29E+01	7.59E+01	8.60E+00	9.74E+01	2.50E+01
2. Average Release Rate For Period	uCi/sec	4.81E+00	2.93E+01	3.21E+00	1.22E+01	
3. Percent of Technical Specification Limit	%	-----	-----	-----	-----	

B. Iodines

1. Total Iodine - 131	Ci	1.86E-04	2.43E-04	5.46E-05	4.84E-04	2.50E+01
2. Average Release Rate For Period	uCi/sec	6.94E-05	9.38E-05	2.04E-05	6.07E-05	

C. Particulates

1. Particulates With Half-lives > 8 Days	Ci	1.51E-05	2.12E-05	1.91E-05	5.54E-05	2.50E+01
2. Average Release Rate For Period	uCi/sec	5.63E-06	8.19E-06	7.13E-06	6.95E-06	
3. Percent of Technical Specification Limit	%	-----	-----	-----	-----	
4. Gross Alpha Radioactivity	Ci	≤ 2.83E-08	≤ 5.45E-08	≤ 3.56E-08	-----	

D. Tritium

1. Total Released	Ci	7.64E+00	2.45E+00	3.45E+00	1.35E+01	2.50E+01
2. Average Release Rate For Period	uCi/sec	2.85E+00	9.46E-01	1.29E+00	1.70E+00	

MILLSTONE NUCLEAR POWER STATION - UNIT No. 2

## EFFLUENT AND WASTE DISPOSAL REPORT

UNIT 2 VENTILATION

YEAR 1979 GASEOUS EFFLUENTS - GROUND-LEVEL RELEASES - CONTINUOUS MODE

Nuclides Released	Unit	JULY	AUGUST	SEPTEMBER	Quarterly Total
-------------------	------	------	--------	-----------	-----------------

## 1. Fission gases

Xe-133	Ci	1.41E+02	2.06E+01	2.13E+01	1.83E+02
Kr-85	Ci	9.68E-01	6.85E-01	7.11E-01	2.36E+00
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
Total for period	Ci	1.42E+02	2.12E+01	2.20E+01	1.85E+02

## 2. Iodines

Iodine-131	Ci	8.45E-05	6.10E-04	3.46E-05	7.29E-04
Iodine-133	Ci	1.77E-05	3.48E-04	2.84E-05	3.94E-04
Iodine-135	Ci	3.97E-05	4.70E-04	8.30E-06	5.18E-04
Total for period	Ci	1.42E-04	1.43E-03	7.13E-05	1.64E-03

## 3. Particulates

I-131	Ci	-- -- --	3.38E-06	2.74E-06	6.12E-06
Ba, La-140	Ci	≤ 1.93E-07	≤ 4.17E-07	≤ 2.60E-07	-- -- --
Co-58	Ci	3.38E-07	3.90E-06	-- -- --	4.24E-06
Co-60	Ci	2.66E-05	2.99E-05	1.05E-05	6.70E-05
Mn-54	Ci	1.69E-06	3.50E-06	9.26E-07	6.12E-06

Cs-137	Ci	5.66E-06	3.14E-06	1.96E-06	1.08E-05
Sr-89	Ci	≤ 8.33E-08	≤ 8.73E-08	≤ 5.60E-08	-- -- --
Sr-90	Ci	2.41E-08	≤ 1.94E-08	2.03E-08	4.44E-08
	Ci				
TOTALS FOR PERIOD	Ci	3.43E-05	4.38E-05	1.61E-05	9.42E-05

H-3	Ci	5.29E+01	2.62E+00	1.89E+00	5.74E+01
GROSSALPHA	Ci	≤ 6.01E-08	≤ 6.21E-08	≤ 3.50E-08	-- -- --
	Ci				
	Ci				

Table 2.2-5 (cont.)  
MILLSTONE NUCLEAR POWER STATION - UNIT No. 2

EFFLUENT AND WASTE DISPOSAL REPORT Unit No. 2 Ventilation

YEAR 1979 GASEOUS EFFLUENTS - GROUND-LEVEL RELEASES - CONTINUOUS MODE

Nuclides Released	Unit	October	November	December	Quarterly Total
-------------------	------	---------	----------	----------	-----------------

1. Fission gases

Xe-133	Ci	1.29E+01	7.42E+01	7.91E+00	9.50E+01
Kr-85	Ci	2.35E-02	9.92E-01	1.06E-01	1.12E+00
Xe-135	Ci	- - - -	- - - -	5.86E-01	5.86E-01
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
Total for period	Ci	1.29E+01	7.52E+01	8.60E+00	9.67E+01

2. Iodines

Iodine-131	Ci	6.01E-05	1.48E-05	3.71E-05	2.45E-04
Iodine-133	Ci	6.61E-05	3.40E-05	6.68E-06	1.07E-04
Iodine-135	Ci	6.01E-05	6.07E-05	1.08E-05	1.32E-04
Total for period	Ci	1.86E-04	2.43E-04	5.46E-05	4.84E-04

3. Particulates

I-131	Ci	4.44E-06	6.47E-06	3.65E-06	1.46E-05
Ba,La-140	Ci	≤ 2.15E-07	≈ 3.60E-07	9.79E-07	9.79E-07
Co-58	Ci	2.18E-07	- - - -	1.99E-06	2.21E-06
Co-60	Ci	9.06E-06	1.14E-05	9.32E-06	2.98E-05
Mn-54	Ci	9.79E-07	1.22E-06	1.20E-06	3.40E-06

Cs-137	Ci	3.81E-07	1.74E-06	2.01E-06	4.13E-06
Cs-134	Ci	- - - -	3.57E-07	- - - -	3.57E-07
Sr-89	Ci	≈ 6.36E-07	≈ 7.63E-08	≈ 6.40E-08	- - - -
Sr-90	Ci	≈ 1.41E-07	≈ 2.18E-08	≈ 7.11E-09	- - - -
Total For Period	Ci	1.51E-05	2.12E-05	1.91E-05	5.54E-05

	Ci				
	Ci				
	Ci				
H-3	Ci	7.64E+00	2.45E+00	3.45E+00	1.35E+01
Gross Alpha	Ci	≤ 2.83E-08	≈ 5.45E-08	≈ 3.56E-08	- - - -







Table 2.2-7

## MILLSTONE NUCLEAR POWER STATION - UNIT No. 2

EFFLUENT AND WASTE DISPOSAL REPORT WASTE GAS DECAY TANKS  
GASEOUS EFFLUENTS-ELEVATED RELEASE - BATCH MODE

YEAR 1979

Nuclides Released	Unit	JULY	AUGUST	SEPTEMBER	Quarterly Total
-------------------	------	------	--------	-----------	-----------------

## 1. Fission gases

Xe-133	Ci	1.54E-03	9.00E-04	-- -- --	2.44E-03
Xe-135	Ci	1.40E-05	2.20E-05	7.00E-06	4.30E-05
Xe-131m	Ci	-- -- --	1.30E-03	-- -- --	1.30E-03
Xe-135m	Ci	-- -- --	-- -- --	-- -- --	-- -- --
Kr-85	Ci	9.64E-03	2.85E-01	1.45E-01	4.40E-01
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				
Total for period	Ci	1.12E-02	2.87E-01	1.45E-01	4.43E-01

## 2. Iodines

iodine-131	Ci	-- -- --	-- -- --	2.40E-05	2.40E-05
iodine-133	Ci	-- -- --	-- -- --	1.10E-05	1.10E-05
iodine-135	Ci	-- -- --	-- -- --	-- -- --	-- -- --
Total for period	Ci	-- -- --	-- -- --	3.50E-05	3.50E-05

## 3. Particulates

Cs-137	Ci	1.00E-06	2.00E-05	-- -- --	2.10E-05
Co-58	Ci	2.00E-06	-- -- --	-- -- --	2.00E-06
Mn-54	Ci	9.00E-06	3.80E-05	-- -- --	4.70E-05
Co-60	Ci	1.21E-04	2.88E-04	4.60E-05	4.55E-04
Cs-138	Ci	4.70E-05	8.29E-04	1.40E-05	8.90E-04

Rb-88	Ci	1.00E-05	-- -- --	-- -- --	1.00E-05
Cs-134	Ci	-- -- --	4.00E-06	1.10E-05	1.50E-05
	Ci				
	Ci				
TOTALS FOR PERIOD	Ci	1.90E-04	1.18E-03	7.10E-05	1.44E-03

H-3	Ci	5.00E-05	7.98E-04	1.92E-04	1.04E-03
	Ci				
	Ci				
	Ci				
	Ci				
	Ci				



TABLE 2.3-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT  
SUPPLEMENTAL INFORMATION

FACILITY: Millstone Unit No's. 1 and 2

1. REGULATORY LIMITS

a. Noble Gases

$$\sum_i Q_{is} [3.2 \bar{E}_{i\gamma} + 0.04 \bar{E}_{i\beta}] + Q_v [23 \bar{E}_{i\gamma} + 58 \bar{E}_{i\beta}] \leq 1$$

where,

$Q_{is}$  = release rate from the main stack of Unit 1 in Ci/sec  
(elevated releases)

$Q_v$  = release rate from unit 2 vent in Ci/sec (mixed release)

$i$  = the individual nuclide

$\bar{E}_{i\gamma}$  = the average gamma energy per disintegration (MeV)

$\bar{E}_{i\beta}$  = the average beta energy per disintegration (MeV)

b. All radioiodines and particulates with half lives greater than eight days.

$$7.9 \times 10^4 Q_s + 3.04 \times 10^6 Q_v \leq 1$$

c. Liquid effluents

10 Ci per calendar quarter per unit excluding tritium and dissolved gases.

2. MAXIMUM PERMISSIBLE CONCENTRATIONS

All maximum permissible concentrations for airborne and liquid releases are as specified in 10CFR20, Appendix B, Table II for the soluble form of the nuclide.

3. AVERAGE ENERGY

Millstone Environmental Technical Specifications, Table 2.4-5.

TABLE 2.3-1 (continued)

## 4. MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

a. Unit 1 Stack - Gaseous Releases(1) Fission and Activation Gases

Stack monitors continuously record the effluent activity and flow rate. During periods when the augmented off-gas system is not operable, the radiation monitor reading is related to  $\mu\text{Ci}$  by off-gas sampling at the steam jet air ejectors and subsequent isotopic analysis. The isotopic activity at the SJAE is mathematically decayed to establish the activity in the stack using the known holdup time. During periods of augmented off-gas system operation, samples are taken directly from the stack with a subsequent isotopic analysis. In both cases, the calculated activity in the stack is then correlated to the monitor reading. The isotopic concentrations at the release point are multiplied by the total stack flow to obtain total  $\mu\text{Ci}$  release for each isotope.

(2) Iodines and Particulates

Charcoal cartridges and particulate filters are used to collect iodines and particulates, respectively. The filters are then analyzed for isotopic content using a gamma spectrometer; particulate filters are also analyzed for strontium. Isotopic concentrations are multiplied by the release flow rate to determine the total amount of activity released.

b. Unit 1 & Unit 2 Liquid Effluents

There are eight tanks which are used to discharge liquids containing radioactivity to the environs; they are:

Unit 1 - Decontamination Solution Tank  
Unit 1 - Floor Drain Sample Tanks (2)  
Unit 1 - Waste Sample Tanks (2)  
Unit 2 - Clean Waste Monitor Tanks (2)  
Unit 2 - Aerated Waste Monitor Tank

Prior to release, a tank is recirculated for two equivalent tank volumes, a sample is drawn and analysed on the Ge(Li) gamma spectrometer for individual radionuclide composition. An aliquot of the sample is analyzed for tritium. Isotopic concentrations are multiplied by the volume released to obtain the total activity released.

A proportional aliquot of each discharge is retained for composite analysis for strontium and gross alpha.

TABLE 2.3-1 (continued)

c. Unit 2 Vent

Total cc's out the Unit 2 Vent per month is multiplied by the isotopic concentrations as measured by gamma spectrometer GE(Li) analysis of grab samples of gases, iodine and particulates to obtain total  $\mu\text{Ci}$  released from the Vent.

d. Unit 2 Containment Purges

Grab samples are taken for gaseous, particulate, and iodine. These are analyzed on GE(Li) gamma spectrometer and concentrations computed. Computed concentrations are then multiplied by the purge volume for total  $\mu\text{Ci}$  released.

Tritium collection is by the gas washing bottle method. The sample is counted on a liquid scintillation counter. Concentration is computed using worst possible case, 100% humidity. Concentration is multiplied by volume purged to give total  $\mu\text{Ci}$  released.

e. Estimates of Errors

Estimates of errors associated with radioactivity measurements were estimated using the following guidelines:

- (1) Sampling and Data Collection - 10% accounts for variation in personnel obtaining required data.
- (2) Calibration - 5% instrument calibration to NBS standards.
- (3) Counting of Samples - 10% maximum error due to counting statistics.
- (4) Flow and Level Measurements - 10% maximum errors on volumes released.

5. BATCH RELEASES

	Unit 1 Liquids	Unit 2 Liquids	Unit 2 Waste Gas Tanks	Unit 2 Cont. Purges
a. Number of Batch Releases	25	94	17	11
b. Total Time (Minutes)	6475	14,214	5865	4200
c. Maximum Time-One Batch (Minutes)	894	507	1156	1320
d. Average Time (Minutes)	259	151	345	382
e. Minimum Time-One Batch (Minutes)	85	45	85	30

Liquids - Average Stream Flow - Not Applicable - Ocean Site

6. ABNORMAL RELEASES

NONE

### 3.0 Radioactive Solid Waste

The units were operated in accordance with Environmental Technical Specification Section 2.4.3. Summaries of solid waste shipments for each unit are given in the attached Tables 3.1 and 3.2

TABLE 3.1

## EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1979)

## SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

MILLSTONE UNIT I (July 1, 1979 - December 31, 1979)

## A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated fuel)

1. Type of waste	Unit	6-month Period	Est. Total Error, %
a. Spent resins, filter sludges, evaporator bottoms, etc.	m <sup>3</sup> Ci	4.48 E 2 2.43 E 2	2.5 E 1
b. Dry compressible waste, contaminated equipment, etc.	m <sup>3</sup> Ci	3.47 E 2 5.01 E 0	3.0 E 1
c. Irradiated components, control rods, etc.	m <sup>3</sup> Ci	None	NA
d. Other (describe)	m <sup>3</sup> Ci	None	NA

## 2. Estimate of major nuclide composition (by type of waste)

	%	E
a. <sup>60</sup> Co	%	4.6 E 1
<sup>55</sup> Fe	%	1.9 E 1
<sup>54</sup> Mn	%	1.1 E 1
<sup>134</sup> Cs <sup>137</sup> Cs	%	7.9 E 0
<sup>131</sup> I <sup>58</sup> Co <sup>140</sup> La <sup>140</sup> Ba	%	9.8 E 0
<sup>141</sup> Ce <sup>95</sup> Nb <sup>59</sup> Fe <sup>90</sup> Sr <sup>63</sup> Ni	%	3.8 E 0
<sup>89</sup> Sr <sup>124</sup> Sb <sup>144</sup> Ce	%	2.5 E 0



b.	$^{60}\text{Co}$				%	5.1 E 1
	$^{54}\text{Mn}$				%	2.9 E 1
	$^{58}\text{Co}$	$^{144}\text{Ce}$	$^{51}\text{Cr}$	$^{59}\text{Fe}$	%	1.4 E 1
	$^{55}\text{Fe}$	$^{137}\text{Cs}$	$^{95}\text{Nb}$		%	5.0 E 0
	$^{89}\text{Sr}$	$^{90}\text{Sr}$	$^{63}\text{Ni}$		%	1.0 E 0

3. Solid Waste Disposition

Number of Shipments

62

Mode of Transportation

Truck (Sole Use Vehicle)

Destination

Barnwell, S. C.

4. Irradiated Fuel Shipments - NONE.

NOTE: Unit Two type (b.) waste is included in this report.

## EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1979)

## SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

MILLSTONE UNIT II (July 1, 1979 - December 31, 1979)

## A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated Fuel)

1. Type of waste	Unit	6-month Period	Est. Total Error, %
a. Spent resins, filter sludges, evaporator bottoms, etc.	m <sup>3</sup> Ci	1.19 E 02 2.33 E 00	2.5 E 01
b. Dry compressible waste, contaminated equipment, etc.	m <sup>3</sup> Ci	1.48 E 01 3.39 E 01	3.0 E 01
c. Irradiated components, control rods, etc.	m <sup>3</sup> Ci	None	N/A
d. Other (describe)	m <sup>3</sup> Ci	None	N/A

## 2. Estimate of major nuclide composition (by type of waste)

	%	E
a. <sup>60</sup> Co	%	3.6 E 01
<sup>58</sup> Co	%	3.6 E 01
<sup>55</sup> Fe	%	6.7 E 00
<sup>54</sup> Mn	%	5.8 E 00
<sup>134</sup> Cs, <sup>137</sup> Cs	%	5.4 E 00
<sup>124</sup> Sb, <sup>110m</sup> Ag, <sup>97</sup> Nb, <sup>95</sup> Nb, <sup>59</sup> Fe	%	8.1 E 00
<sup>95</sup> Zn, <sup>63</sup> Ni, <sup>57</sup> Co, <sup>41</sup> Ar, <sup>105</sup> Ru, <sup>24</sup> Na, <sup>89</sup> Sr, <sup>90</sup> Sr,	%	2.0 E 00
<sup>92</sup> Sr.		

	%	. E
b. $^{137}\text{Cs}$	%	3.7 E 01
$^{134}\text{Cs}$	%	2.9 E 01
$^{58}\text{Co}$ , $^{60}\text{Co}$	%	1.9 E 01
$^{144}\text{Ce}$ , $^{131}\text{I}$ , $^{133}\text{I}$ , $^{187}\text{W}$ , $^{24}\text{Na}$ , $^{54}\text{Mn}$	%	1.2 E 01
$^{95}\text{Nb}$ , $^{59}\text{Fe}$ , $^{140}\text{La}$ , $^{55}\text{Fe}$ , $^{63}\text{Ni}$ , $^{89}\text{Sr}$ , $^{90}\text{Sr}$	%	3.0 E 00

3. Solid Waste Disposition

Number of Shipments

14

Mode of Transportation

Truck (Sole Use Vehicle)

Destination

Barnwell, S.C.

4. Irradiated Fuel Shipments - NONE.

METEOROLOGY - JOINT FREQUENCY DISTRIBUTION

4.0 The joint-frequency distributions for the continuous and batch releases are given in the tables at the end of this report.

## OFFSITE DOSE ESTIMATES

5.0 In accordance with the requirements of the Technical Specifications and Regulatory Guide 1.21, the off-site dose to humans from the gaseous and liquid radioactive effluents of Millstone have been estimated.

These estimations are performed using measured effluent data, measured meteorological data, and calculational models developed by the U. S. Nuclear Regulatory Commission.

The dose estimates generally tend to be conservative due to the use of conservative assumptions in the calculational models. More realistic estimates of the off-site dose are obtained by analysis of the environmental monitoring data. A comparison of the doses estimated by each of the above methods will be presented in the Annual Radiological Environmental Monitoring Report due to be published April 1, 1980.

### 1. Dose Models

#### a. Airborne Effluents

Maximum individual doses and population doses due to the release of noble gases, radioiodines and particulates were calculated using the computer code GASPAR<sup>(1)</sup>, with the exception of Unit 1 noble gas doses. The maximum individual dose due to direct exposure from the Unit 1 noble gas plume was calculated using the computer code AIREM<sup>(2)</sup>.

The Gaspar code uses the semi-infinite cloud model to implement the dose models of U.S.N.R.C. Regulatory Guide 1.109 (October, 1977).

The values of average effluent concentration (X/Q) and average relative deposition (D/Q) used in the GASPARG code were generated using a meteorological computer code which implements the assumptions given in Section C of NRC Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors".

Releases from the Millstone Unit 1 375-foot stack are considered to be elevated at all times. The Pasquill stability classes were determined using the temperature gradient between the 33-foot and 447-foot levels of the meteorological tower.

Releases from the Unit 2, 145 foot vent stack were considered as a mixed mode release (partially elevated and partially ground). The Pasquill stability classes were determined using the temperature gradient between the 33 foot and 142 foot levels of the meteorological tower.

The GASPARG code was run separately for continuous releases from the MP2 vent (building ventilation), batch releases from the MP2 vent (containment purges) and MP2 batch releases from the MP1 stack (waste gas tanks). The resulting doses were then summed to determine the total Unit 2 dose.

The Unit 1 releases are from a 375 foot elevated stack and the use of the GASPARG semi-infinite cloud model would lead to an underestimate of the dose due to direct exposure from the plume at distances within 2 miles of the stack. Therefore, the AIREM code was implemented to determine the maximum individual exposure from an overhead finite gamma cloud.

The AIREM code uses a sector averaged Gaussian diffusion model and includes ground and inversion lid reflections, radionuclide decay, first daughter in-growth, ground deposition and cloud depletion, and contributions to dose from radionuclides in clouds at all azimuths. The finite cloud model used is a modified version of R. E. Cooper's EGAD code (3).

b. Liquid Effluents

Maximum individual and population doses due to the release of radioactive liquid effluents were calculated using the computer code LADTAP<sup>(4)</sup>.

The code implements the dose models and parameters given in Regulatory Guide 1.109 (October, 1977).

2. Results

a. Airborne Effluents

The calculated doses are presented in Tables 5.1.1 and 5.1.2.

For population doses, the GASPAR code calculates the dose to the whole body, GI-tract, bone, liver, kidney, thyroid, lung and skin from each of the following pathways: direct exposure from the plume, direct exposure from ground deposition, inhalation, vegetation, cow's milk and meat.

The values presented in the attached table are a total from all pathways, but only the whole body, skin and maximum organ dose are presented. The maximum organ dose in all cases was to the thyroid, and thus, the dose to all other organs was less than that shown for the thyroid.

For the dose to the maximum individual, the GASPAR program calculates the dose to the same organs listed above for the following pathways: direct exposure to the plume (except for Unit 1 finite cloud doses), exposure from ground deposition, inhalation, vegetation, meat, cow's milk and goat's milk. The doses are calculated for adults, teenagers, children and infants separately. Again, the maximum organ dose was to the thyroid.

For the ground deposition and inhalation pathways, the maximum individual dose is calculated at the off-site location of maximum decayed X/Q where a potential for dose exists.

For the vegetation pathway, the maximum individual dose is calculated at the vegetable garden of highest depleted X/Q. For the meat, cow's milk and goat's milk pathways, the calculated dose is included as the maximum individual's dose only at locations and times where these pathways actually exist. Doses were calculated at the cow farm and goat farm of maximum deposition. The doses presented in Tables 5.1.1 and 5.1.2, are the maximum doses observed.

The AIREM code calculates the individual whole body and skin dose for each sector-segment. The maximum individual dose is obtained by taking the maximum AIREM result at the off-site location where a potential for dose exists and multiplying by a factor of 0.7 to compensate for building shielding and occupancy.



No page 9 in  
Original document.

FOOTNOTES

- (1) GASPAR Dose Code, K. F. Eckerman, Radiological Assessment Branch, U. S. Nuclear Regulatory Commission, Washington, D. C., - Revised 2/20/76.
- (2) AIREM Program Manual - A computer Code for Calculating Doses, Population Doses; and Ground Depositions due to Atmospheric Emissions of Radionuclides, J. A. Marlin, Jr., C. B. Nelson and P. A. Cuny, U. S. EPA Office of Radiation Programs, Washington, D. C., May, 1974.
- (3) Cooper, R. E., EGAD - A Computer Program to Compute Dose Integrals from External Gamma Emitters, DP-1304. Mathematics and Computers (TID-4500, VC32), Savannah River Laboratory, Aiken, S. C., September, 1972.
- (4) LADTAP - U. S. Nuclear Regulatory Commission; Washington, D. C.

TABLE 5.1 .1  
Off-Site Dose Estimates  
Millstone Unit No. 1

		<u>1979</u>		
A.	<u>Airborne Effluents</u>	<u>Units</u>	<u>July-Sept</u>	<u>Oct-Dec</u>
1.	Maximum Individual Dose	Millirem		
	a. Whole Body		6.1(-2) <sup>a, b</sup>	2.4(-2) <sup>b</sup>
	b. Skin		6.1(-2) <sup>b</sup>	2.4(-2) <sup>b</sup>
	c. Thyroid		4.4(-1) <sup>c</sup>	3.7(-3) <sup>d</sup>
2.	Population Dose 0-50 Miles	Person-Rem		
	a. Whole Body		1.6(0)	1.2(0)
	b. Skin		9.0(0)	5.1(0)
	c. Thyroid		2.9(0)	4.1(0)
3.	Average Dose 0-50 Miles	Millirem		
	a. Whole Body		5.5(-4)	4.1(-4)
	b. Skin		3.1(-3)	1.7(-3)
	c. Thyroid		9.9(-4)	1.4(-3)
B.	<u>Liquid Effluents</u>			
1.	Maximum Individual Dose	Millirem		
	a. Whole Body		9.7(-5) <sup>e</sup>	4.6(-5) <sup>e</sup>
	b. Max Organ (GI-LLI)		9.0(-4)	2.1(-4)
	c. Thyroid		1.1(-4) <sup>e</sup>	1.1(-4) <sup>e</sup>
2.	Population Dose 0-50 Miles	Person-Rem		
	a. Whole Body		8.5(-4)	4.0(-4)
	b. Max Organ (GI-LLI)		3.8(-3)	7.3(-4)
	c. Thyroid		8.1(-4)	6.1(-4)
3.	Average Dose 0-50 Miles	Millirem		
	a. Whole Body		2.8(-7)	1.3(-7)
	b. Max Organ (GI-LLI)		1.3(-6)	2.4(-7)
	c. Thyroid		2.7(-7)	2.0(-7)

- a.  $6.1(-2) = 6.1 \times 10^{-2}$   
b. Location = 0.5 miles NE  
c. Infant thyroid dose at maximum goat farm - 2 miles ENE  
d. Child thyroid dose at maximum location - 1.6 miles E  
e. Teenager dose - all other doses are adult doses

TABLE 5.1.2

Off-Site Dose Estimates

Millstone Unit No. 2

		<u>1979</u>		
A.	<u>Airborne Effluents</u>	<u>Units</u>	<u>July-Sept</u>	<u>Oct-Dec</u>
1.	Maximum Individual Dose	Millirem		
	a. Whole Body		1.3(-2) <sup>a,b</sup>	5.2(-3) <sup>b</sup>
	b. Skin		3.7(-2) <sup>b</sup>	1.5(-2) <sup>b</sup>
	c. Thyroid		1.6(-1) <sup>c</sup>	5.5(-3) <sup>d</sup>
2.	Population Dose 0-50 Miles	Person-Rem		
	a. Whole Body		1.7(-1)	4.1(-2)
	b. Skin		2.8(-1)	8.4(-2)
	c. Thyroid		2.7(-1)	1.5(-1)
3.	Average Dose 0-50 Miles	Millirem		
	a. Whole Body		5.7(-5)	1.4(-5)
	b. Skin		9.7(-5)	2.9(-5)
	c. Thyroid		9.2(-5)	5.1(-5)
B.	<u>Liquid Effluents</u>			
1.	Maximum Individual Dose	Millirem		
	a. Whole Body		2.8(-3) <sup>e</sup>	3.0(-3) <sup>e</sup>
	b. Max Organ (GI-LLI)		1.8(-2)	1.6(-2)
	c. Thyroid		1.9(-3) <sup>e</sup>	1.8(-3) <sup>e</sup>
2.	Population Dose 0-50 Miles	Person-Rem		
	a. Whole Body		2.4(-2)	2.5(-2)
	b. Max Organ (GI-LLI)		6.9(-2)	6.8(-2)
	c. Thyroid		1.8(-2)	1.7(-2)
3.	Average Dose 0-50 Miles	Millirem		
	a. Whole Body		7.9(-6)	8.3(-6)
	b. Max Organ (GI-LLI)		2.3(-5)	2.2(-5)
	c. Thyroid		5.9(-6)	5.6(-6)

a.  $1.3(-2) = 1.3 \times 10^{-2}$

b. At the maximum location - 0.4 miles NE

c. Child thyroid dose at the maximum vegetable garden - 0.4 miles NE

d. Child thyroid dose at the maximum location - 0.4 miles NE

e. Teenager dose - all other doses are adult doses

MILLSTONE NO. 1

METEOROLOGICAL

JOINT FREQUENCY

DATA FOR

CONTINUOUS RELEASES

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY A -- DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	1	0	0	0	0	0	0	0	1
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	2	0	0	0	2
NNW	0	1	0	0	2	0	0	0	3
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	1	1	0	0	4	0	0	0	

NU. OF VALID OBSERVATION = 6

NU. OF CALMS (WS LT 0.5M/SEC) = 0

NU. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY B -- DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	1	0	0	0	0	1
S	0	1	1	0	0	0	0	0	2
SSW	0	1	1	0	0	0	0	0	2
SW	0	1	1	0	0	0	0	0	2
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	3	3	1	4	0	0	11
NNW	0	0	0	1	1	0	0	0	2
N	0	0	1	0	0	0	0	0	1
ALL SECTOR	0	3	7	5	2	4	0	0	

NO. OF VALID OBSERVATION = 21

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 1

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	1	0	3	0	0	0	0	5
NE	0	1	0	0	1	0	0	0	2
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	2	0	0	0	2
ESE	0	0	0	0	2	0	0	0	2
SE	0	0	1	0	0	0	0	0	1
SSE	0	1	1	1	2	0	0	0	5
S	0	1	1	1	0	0	0	0	3
SSW	1	2	4	0	0	0	0	0	7
SW	0	0	3	0	0	0	0	0	3
WSW	0	0	0	2	0	0	0	0	2
W	0	0	0	0	0	0	0	0	0
WNW	0	1	0	0	0	0	0	0	1
NW	0	1	5	8	5	2	0	0	21
NNW	0	2	6	1	0	0	0	0	9
N	0	0	1	0	0	0	0	0	1
ALL SECTOR	2	10	22	16	12	2	0	0	

NO. OF VALID OBSERVATION = 64

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 3



## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY D -- DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	2	3	12	24	23	0	0	0	64
NE	1	1	12	6	2	0	0	0	22
ENE	1	3	6	8	0	0	0	0	18
E	2	5	8	7	1	0	0	0	23
ESE	2	5	5	3	0	0	0	0	15
SE	3	10	12	4	5	0	0	0	34
SSE	0	12	21	1	1	0	0	0	35
S	3	16	19	9	2	0	1	0	50
SSW	2	11	9	12	14	3	1	2	54
SW	4	0	17	17	13	7	0	0	58
WSW	1	2	14	30	18	2	0	0	67
W	3	4	8	3	3	3	0	0	24
WNW	1	5	7	4	1	0	0	0	18
NW	1	5	7	15	10	0	0	0	38
NNW	1	4	8	9	4	0	0	0	26
N	0	4	10	6	1	0	0	0	21
ALL SECTOR	27	90	175	158	98	15	2	2	

NO. OF VALID OBSERVATION = 571

NO. OF CALMS (WS LT 0.5M/SEC) = 4

NO. OF MISSING WD/WS = 15

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.0	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	6	3	5	7	2	0	0	23
NE	3	0	4	3	0	0	0	0	10
ENE	0	3	3	8	1	0	0	0	15
E	3	3	9	4	0	0	0	0	19
ESE	2	8	5	6	0	0	0	0	21
SE	5	13	29	5	1	1	2	0	56
SSE	8	14	31	4	10	5	1	3	76
S	4	14	32	29	9	1	4	0	93
SSW	3	18	63	46	57	16	3	6	212
SW	5	24	62	76	19	9	2	1	198
WSW	10	24	40	52	11	4	1	1	143
W	2	10	19	23	8	2	0	0	64
WNW	5	14	9	7	3	0	0	0	38
NW	1	9	9	7	11	1	0	0	38
NNW	2	6	4	14	20	6	0	0	52
N	2	5	7	7	8	0	0	0	29
ALL SECTOR	55	171	329	296	165	47	13	11	

NU. OF VALID OBSERVATION = 1088

NU. OF CALMS (WS LT 0.5M/SEC) = 1

NU. OF MISSING WD/WS = 22

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY F -- DELTA T LESS THAN OR EQUAL TO 4.0 AND GREATER THAN 1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	1	0	0	0	1
NE	1	0	2	1	0	0	0	0	4
ENE	0	0	1	3	5	0	0	0	9
E	0	0	0	3	0	0	0	0	3
ESE	0	0	0	0	0	0	0	0	0
SE	0	2	2	0	0	0	0	0	4
SSE	1	3	4	1	1	0	0	0	10
S	5	6	2	3	0	0	0	0	16
SSW	0	6	9	5	0	0	0	0	20
SW	1	11	7	11	1	0	0	0	31
WSW	1	5	20	8	1	0	0	0	35
W	0	5	2	2	0	0	0	0	9
WNW	2	1	4	3	0	0	0	0	10
NW	1	0	4	2	0	0	0	0	7
NNW	0	1	0	2	2	0	0	0	5
N	0	0	0	1	4	0	0	0	5
ALL SECTOR	12	40	57	45	15	0	0	0	

NO. OF VALID OBSERVATION = 171

NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 1

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	1	0	0	0	0	0	1
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	1	1	0	0	0	0	0	2
NW	0	0	1	1	0	0	0	0	2
NNW	0	1	0	0	0	0	0	0	1
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	2	3	1	0	0	0	0	0

NO. OF VALID OBSERVATION = 6

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	3	10	15	32	31	2	0	0	93
NE	5	2	18	10	3	0	0	0	38
ENE	1	6	10	19	6	0	0	0	42
E	5	8	17	14	3	0	0	0	47
ESE	4	13	10	11	2	0	0	0	40
SE	8	26	48	12	6	1	2	0	103
SSE	9	31	63	8	14	5	1	3	134
S	12	38	56	43	11	1	5	0	166
SSW	6	38	86	63	71	19	4	8	295
SW	10	36	91	104	33	16	2	1	293
WSW	13	31	74	92	30	6	1	1	248
W	5	19	29	28	11	5	0	0	97
WNW	8	22	21	14	4	0	0	0	69
NW	3	15	29	36	29	7	0	0	119
NNW	3	15	18	27	29	6	0	0	98
N	2	9	19	14	13	0	0	0	57
ALL SECTOR	97	319	604	527	296	68	15	13	

NU. OF POSSIBLE OBSERVATIONS = 2208  
 NU. OF VALID OBSERVATIONS = 1946

NU. OF VALID NON-CALM CONCURRENT WD/WS/DT = 1920  
 NU. OF CALMS (WS LT 0.5M/SEC) = 7

NU. OF MISSING WD/WS = 262  
 NU. OF MISSING DELTA T = 239

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY A — DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	ALL
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION =

0

NO. OF CALMS (WS LT 0.5M/SEC) =

0

NO. OF MISSING WD/WS =

0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0615 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY B -- DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	1	0	1	0	0	2
WNW	0	0	0	0	3	1	0	0	4
NW	0	0	1	1	1	1	1	0	5
NNW	0	0	0	1	0	0	0	0	1
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	1	3	4	3	1	0	

NO. OF VALID OBSERVATION = 17

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	2	0	0	0	0	2
NE	0	0	5	2	0	0	0	0	7
ENE	0	0	0	0	0	0	0	0	0
E	1	0	0	0	0	0	0	0	1
ESE	0	0	1	0	0	0	0	0	1
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	2	0	0	0	0	2
SSW	0	0	0	0	2	0	0	0	2
SW	0	0	0	0	2	3	0	0	5
WSW	0	0	0	1	7	9	5	0	22
W	0	0	0	6	8	7	0	0	21
WNW	0	0	0	7	9	4	0	0	20
NW	0	0	2	20	21	22	6	0	71
NNW	0	0	4	4	3	3	0	0	14
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	1	0	12	44	52	48	11	0	

NO. OF VALID OBSERVATION = 163

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0



## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY D -- DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	5	11	50	31	3	0	0	100
NE	0	8	24	30	6	2	0	0	70
ENE	0	2	2	2	1	0	0	0	7
E	0	0	5	4	3	0	0	0	12
ESE	0	4	15	8	4	3	1	1	36
SE	0	4	19	5	2	1	2	0	33
SSE	1	5	19	3	3	1	0	0	32
S	0	5	15	24	12	5	0	0	61
SSW	1	7	18	26	21	14	4	0	91
SW	0	7	22	26	31	24	4	0	114
WSW	0	6	21	28	36	35	7	0	133
W	1	2	25	54	54	26	0	0	162
WNW	0	0	27	50	27	8	1	0	113
NW	3	7	17	47	52	21	0	0	147
NNW	0	3	17	38	39	10	1	0	108
N	1	1	5	22	20	0	0	0	49
ALL SECTOR	7	66	262	417	342	153	20	1	

NO. OF VALID OBSERVATION = 1268

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 1

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	4	6	3	4	0	0	0	18
NE	1	1	3	6	1	0	0	0	12
ENE	0	1	5	3	0	0	0	0	9
E	0	0	2	3	0	0	0	0	5
ESE	2	0	7	3	1	1	0	0	14
SE	0	4	0	2	2	1	5	0	14
SSE	0	3	4	6	7	12	5	5	42
S	1	1	8	6	6	16	1	0	39
SSW	2	6	10	27	17	17	8	1	88
SW	0	4	26	24	20	10	0	0	84
WSW	1	3	9	15	8	4	1	0	41
W	0	3	10	7	6	0	0	0	26
WNW	3	5	8	15	5	0	0	0	36
NW	1	3	11	3	2	0	0	0	20
NNW	1	2	8	9	11	4	0	0	35
N	3	1	7	5	5	0	0	0	21
ALL SECTOR	16	41	124	137	95	65	20	6	

NO. OF VALID OBSERVATION = 506

NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY F -- DELTA T LESS THAN OR EQUAL TO 4.0 AND GREATER THAN 1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0	0	0
E	0	0	2	2	0	0	0	0	4
ESE	0	0	2	1	0	0	0	0	3
SE	0	4	4	1	0	0	2	0	11
SSE	0	5	3	1	0	4	2	0	15
S	1	3	9	0	0	0	0	0	13
SSW	0	5	11	1	3	4	0	0	22
SW	0	4	3	1	1	0	0	0	9
WSW	1	0	1	1	2	0	0	0	5
W	0	1	1	0	0	0	0	0	2
WNW	0	1	3	1	0	0	0	0	5
NW	1	2	0	0	0	0	0	0	3
NNW	1	0	0	1	0	1	0	0	3
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	4	25	39	11	6	9	4	0	

NO. OF VALID OBSERVATION = 96

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	1	1	0	0	0	0	0	2
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	1	1	0	0	0	0	0	2
SW	0	0	1	0	0	0	0	0	1
WSW	0	0	1	0	0	0	0	0	1
W	0	2	0	0	0	0	0	0	2
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	4	4	0	0	0	0	0	0

NO. OF VALID OBSERVATION = 8

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
ENE	1	9	17	59	42	4	0	0	132
NE	1	9	32	39	7	2	0	0	90
ENE	0	4	7	5	1	0	0	0	17
E	1	0	9	9	3	0	0	0	22
ESE	2	5	25	12	5	4	1	1	55
SE	0	13	27	8	4	2	9	0	63
SSE	1	13	31	25	10	17	7	5	109
S	2	9	34	37	18	21	1	0	122
SSW	4	19	41	58	43	35	12	1	213
SW	0	16	54	53	54	37	4	0	218
WSW	3	9	32	50	53	48	13	0	208
W	1	9	37	70	68	34	0	0	219
WNW	3	6	38	73	44	13	1	0	178
NW	5	13	33	71	76	44	7	0	249
NNW	2	6	34	53	53	18	1	0	167
N	5	2	13	27	25	0	0	0	72
ALL SECTOR	31	142	464	649	506	279	56	7	

NO. OF POSSIBLE OBSERVATIONS = 2108  
 NO. OF VALID OBSERVATIONS = 2136

NO. OF VALID NON-CALM CONCURRENT WD/WS/DI = 2056  
 NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 72  
 NO. OF MISSING DELTA T = 149

MILLSTONE NO. 2  
METEOROLOGICAL  
JOINT FREQUENCY  
DATA FOR  
CONTINUOUS RELEASES

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY A -- DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	3	10	2	0	0	0	0	15
NE	2	3	1	2	0	0	0	0	8
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	3	3	0	0	0	0	0	6
SE	0	4	2	0	0	0	0	0	6
SSE	1	3	2	0	0	0	0	0	6
S	0	4	3	2	0	0	0	0	9
SSW	1	6	5	2	2	0	0	0	16
SW	1	1	12	1	0	0	0	0	15
WSW	0	3	2	5	0	0	0	0	10
W	1	0	0	0	0	0	0	0	1
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	3	6	1	0	0	0	10
NNW	0	1	11	6	1	0	0	0	19
N	0	5	3	1	0	0	0	0	9
ALL SECTOR	6	36	57	27	4	0	0	0	

NU. OF VALID OBSERVATION = 130

NU. OF CALMS (WS. LT 0.5M/SEC) = 0

NU. OF MISSING WD/WS = 5

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY B -- DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	3	3	1	0	0	0	0	8
NE	0	1	2	6	0	0	0	0	9
ENE	1	1	0	0	0	0	0	0	2
E	1	2	0	0	0	0	0	0	3
ESE	0	3	4	0	5	0	0	0	12
SE	0	0	2	0	0	0	0	0	2
SSE	1	1	3	3	0	0	0	0	8
S	2	5	3	0	1	0	0	0	11
SSW	0	2	3	1	0	0	0	0	6
SW	1	0	2	0	0	0	0	0	3
WSW	0	0	2	2	2	0	0	0	6
W	0	0	1	1	0	0	0	0	2
WNW	0	0	3	0	0	0	0	0	3
NW	1	4	8	2	2	0	0	0	17
NNW	0	1	7	2	2	0	0	0	12
N	1	3	3	0	0	0	0	0	7
ALL SECTOR	9	26	46	18	12	0	0	0	

NO. OF VALID OBSERVATION = 111

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 6



## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	2	2	1	0	0	0	0	6
NE	2	1	0	2	0	0	0	0	5
ENE	0	1	0	0	0	0	0	0	1
E	4	7	1	0	0	0	0	0	12
ESE	3	4	3	1	0	0	0	0	11
SE	1	6	8	8	0	0	0	0	23
SSE	1	5	5	5	0	0	0	0	16
S	0	4	6	1	0	0	0	0	11
SSW	1	8	4	1	3	0	0	0	17
SW	0	2	2	2	0	1	0	0	7
WSW	1	2	2	3	6	0	0	0	14
W	2	3	1	1	0	0	0	0	7
WNW	1	1	3	1	0	0	0	0	6
NW	0	3	5	3	0	0	0	0	11
NNW	0	1	12	0	0	0	0	0	13
N	0	2	3	1	0	0	0	0	6
ALL SECTOR	17	52	57	30	9	1	0	0	

NO. OF VALID OBSERVATION = 166

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 2

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY D -- DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	4	5	20	18	0	0	0	0	47
NE	1	8	11	10	0	0	0	0	30
ENE	6	6	11	0	0	0	0	1	24
E	4	13	12	5	0	0	0	0	34
ESE	3	6	8	4	0	0	0	0	21
SE	1	11	13	4	0	3	0	0	32
SSE	5	10	7	2	2	0	0	0	26
S	2	8	5	1	6	2	0	0	18
SSW	0	5	5	10	0	0	1	0	21
SW	3	5	8	17	11	1	0	0	45
WSW	1	6	13	25	10	0	0	0	55
W	2	13	11	4	3	0	0	0	33
WNW	4	6	13	1	0	0	0	0	24
NW	2	9	13	4	1	0	0	0	29
NNW	3	3	19	7	0	0	0	0	32
N	3	5	13	6	0	0	0	0	27
ALL SECTOR	44	119	182	118	27	6	1	1	

NO. OF VALID OBSERVATION = 501

NO. OF CALMS (WS LT 0.5M/SEC) = 3

NO. OF MISSING WD/WS = 5

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	4	2	7	3	0	0	0	0	16
NE	1	1	4	4	0	0	0	0	10
ENE	1	1	1	0	0	0	0	0	3
E	2	6	3	0	0	0	0	0	11
ESE	3	3	9	2	0	0	0	0	17
SE	4	8	11	0	0	1	0	0	24
SSE	2	10	10	1	3	0	2	0	28
S	2	12	9	4	2	3	0	0	32
SSW	6	18	10	27	15	1	7	0	84
SW	2	15	29	18	6	1	2	0	73
WSW	7	23	28	23	3	0	2	0	86
W	9	22	16	5	5	1	0	0	58
WNW	6	18	5	2	0	0	0	0	31
NW	2	2	3	0	0	0	0	0	7
NNW	3	6	14	5	0	0	0	0	28
N	1	2	3	2	0	0	0	0	6
ALL SECTOR	55	149	162	96	34	7	13	0	

NO. OF VALID OBSERVATION = 521

NO. OF CALMS (WS LT 0.5M/SEC) = 5

NO. OF MISSING WD/WS = 15

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY F -- DELTA T LESS THAN OR EQUAL TO 4.0 AND GREATER THAN 1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	1	1	0	0	0	0	0	2
NE	1	0	0	0	0	0	0	0	1
ENE	2	0	0	0	0	0	0	0	2
E	0	3	0	0	0	0	0	0	3
ESE	5	1	1	1	0	0	0	0	8
SE	3	5	8	7	0	0	0	0	23
SSE	4	5	17	6	0	0	0	0	32
S	2	7	12	6	0	0	0	0	27
SSW	3	14	28	14	7	1	2	0	69
SW	4	10	20	12	4	4	0	0	54
WSW	2	8	19	8	1	0	0	0	38
W	0	7	2	3	0	0	0	0	12
WNW	2	11	2	0	0	0	0	0	15
NW	2	1	1	0	0	0	0	0	4
NNW	4	3	2	0	0	0	0	0	9
N	3	0	1	2	0	0	0	0	6
ALL SECTOR	37	76	114	59	12	5	2	0	

NO. OF VALID OBSERVATION = 307

NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 8

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	0	0	0	0	0	0	0	1
NE	2	0	0	1	0	0	0	0	3
ENE	4	0	0	0	0	0	0	0	4
E	0	3	0	0	0	0	0	0	3
ESE	1	5	1	0	0	0	0	0	7
SE	1	1	2	0	0	0	0	0	4
SSE	1	2	6	7	0	0	0	0	16
S	0	5	6	2	0	0	0	0	13
SSW	3	6	15	11	6	0	0	0	41
SW	2	2	10	12	2	0	0	0	28
WSW	4	0	14	11	0	0	0	0	29
W	1	1	2	0	0	0	0	0	4
WNW	5	4	1	0	0	0	0	0	10
NW	4	8	3	0	0	0	0	0	15
NNW	1	3	0	0	0	0	0	0	4
N	2	0	0	0	0	0	0	0	2
ALL SECTOR	32	40	60	44	8	0	0	0	

NU. OF VALID OBSERVATION = 190

NU. OF CALMS (WS LT 0.5M/SEC) = 6

NU. OF MISSING WD/WS = 1

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 30 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	11	16	43	25	0	0	0	0	95
NE	9	14	18	25	0	0	0	0	66
ENE	14	9	12	0	0	0	0	1	36
E	11	34	16	5	0	0	0	0	66
ESE	15	26	29	10	5	0	0	0	85
SE	10	37	50	21	0	4	0	0	122
SSE	15	36	52	25	5	0	2	0	135
S	8	46	47	16	3	5	0	0	125
SSW	14	60	70	66	33	2	10	0	255
SW	14	35	83	62	23	7	2	0	226
WSW	15	42	80	77	22	0	2	0	238
W	15	46	33	14	8	1	0	0	117
WNW	18	40	27	4	0	0	0	0	89
NW	11	27	36	15	4	0	0	0	93
NNW	11	18	65	20	3	0	0	0	117
N	10	17	26	12	0	0	0	0	65
ALL SECTOR	201	503	687	397	106	19	16	1	

NO. OF POSSIBLE OBSERVATIONS = 2208

NO. OF VALID OBSERVATIONS = 1946

NO. OF VALID NON-CALM CONCURRENT WD/WS/UT = 1910

NO. OF CALMS (WS LT 0.5M/SEC) = 16

NO. OF MISSING WD/WS = 262

NO. OF MISSING DELTA T = 240

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT  
 DELTA T INTERVAL = 142 - 33 FT  
 PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T  
 DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315  
 DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY A — DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	1	3	1	0	0	0	0	5
NE	0	0	4	0	0	0	0	0	4
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	2	0	0	0	0	0	2
SE	0	0	0	0	0	1	0	0	1
SSE	0	0	0	0	0	1	0	0	1
S	0	0	0	2	1	1	0	0	4
SSW	0	0	0	0	2	0	0	0	2
SW	0	0	0	2	1	3	0	0	6
WSW	0	0	0	7	7	15	5	0	34
W	0	0	0	5	4	8	0	0	17
WNW	0	0	0	5	3	5	0	0	13
NW	0	0	0	5	6	2	0	0	13
NNW	0	0	4	8	3	1	0	0	16
N	0	0	3	4	0	0	0	0	7
ALL SECTOR	0	1	16	39	27	37	5	0	

NO. OF VALID OBSERVATION = 125      NO. OF CALMS (WS LT 0.5M/SEC) = 0      NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 1979/0015 - 31 DEC 1979/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY B — DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 UFG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNL	0	1	1	1	1	0	0	0	4
NE	0	0	3	9	2	0	0	0	14
ENE	0	1	0	0	0	0	0	0	1
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	2	0	0	0	0	0	2
SSE	0	0	0	0	0	0	0	0	0
S	0	0	1	2	0	0	0	0	3
SSW	0	0	3	6	0	0	0	0	9
SW	0	0	2	1	0	0	0	0	3
WSW	0	0	0	1	0	0	0	0	1
W	0	0	2	1	3	0	0	0	6
WNW	0	0	2	7	6	0	0	0	15
NW	0	1	4	1	4	1	0	0	11
NNW	0	1	17	1	0	3	0	0	22
N	0	0	3	0	0	0	0	0	3
ALL SECTOR	0	4	40	30	16	4	0	0	

NO. OF VALID OBSERVATION = 94

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WU/WS = 0



## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 35 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 JUL 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	2	11	10	0	0	0	0	23
NE	0	3	7	4	0	0	0	0	14
ENE	0	0	0	0	0	0	0	0	0
E	0	1	1	1	0	0	0	0	3
ESE	1	0	6	3	0	0	0	0	10
SE	0	1	3	1	0	0	0	0	5
SSE	0	1	8	5	1	1	0	0	16
S	0	2	7	11	4	6	0	0	24
SSW	1	1	7	10	2	1	0	0	22
SW	0	2	8	7	10	2	0	0	29
WSW	0	1	10	7	12	3	1	0	34
W	0	2	6	26	27	3	3	0	67
WNW	0	4	25	40	10	6	6	0	79
NW	0	5	22	19	4	7	0	0	57
NNW	0	1	33	21	12	0	0	0	67
N	0	0	13	5	4	0	0	0	22
ALL SECTOR	2	26	167	170	86	17	4	0	

NO. OF VALID OBSERVATION = 472

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 1

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASS / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	3	1	4	0	0	0	0	9
NE	0	1	3	1	0	0	0	0	5
ENE	0	1	2	0	0	0	0	0	3
E	0	1	3	1	0	0	0	0	5
ESE	0	0	4	3	0	0	0	0	7
SE	1	2	8	0	0	0	0	0	11
SSE	0	5	2	2	4	1	3	0	17
S	0	3	0	3	3	1	1	0	11
SSW	1	3	9	14	8	9	0	0	44
SW	3	7	11	14	9	4	0	0	48
WSW	0	9	12	9	2	0	0	0	32
W	0	9	5	3	0	0	0	0	17
WNW	1	2	10	0	0	0	0	0	13
NW	0	3	3	0	0	0	0	0	6
NNW	1	8	8	5	1	0	0	0	23
N	1	1	5	7	1	0	0	0	15
ALL SECTOR	9	58	86	66	28	15	4	0	

NO. OF VALID OBSERVATION = 260

NO. OF CALMS (WS LT 0.5M/SEC) = 6

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY F. -- DELTA T LESS THAN OR EQUAL TO 4.0 AND GREATER THAN 1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	3	0	0	0	0	0	0	3
NE	0	4	2	0	0	0	0	0	6
ENE	1	1	1	0	0	0	0	0	3
E	1	1	3	0	0	0	0	0	5
ESE	1	4	0	0	0	0	0	0	5
SE	0	1	1	1	2	2	0	0	7
SSE	0	3	1	4	5	4	0	0	17
S	5	4	5	0	2	0	0	0	16
SSW	1	3	9	6	8	6	1	0	34
SW	1	5	6	3	2	3	1	0	21
WSW	0	4	6	1	1	0	0	0	12
W	2	3	4	0	0	0	0	0	9
WNW	0	3	2	0	0	0	0	0	5
NW	0	3	3	0	0	0	0	0	6
NNW	1	0	0	1	0	0	0	0	2
N	1	2	6	1	0	0	0	0	10
ALL SECTOR	14	44	49	17	20	15	2	0	

NO. OF VALID OBSERVATION = 162

NO. OF CALMS (WS LT 0.5M/SEC) = 1

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 79/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND							ALL	
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0		GT 20.1
NNE	0	0	0	0	0	0	0	0	0
NE	2	0	2	0	0	0	0	0	4
ENE	2	1	1	0	0	0	0	0	4
E	0	6	5	0	0	0	0	0	11
ESE	1	4	0	0	0	0	0	0	5
SE	2	5	1	0	0	0	0	0	6
SSE	2	2	0	0	1	1	0	0	6
S	0	0	1	0	0	0	0	0	1
SSW	0	4	1	1	3	0	0	0	9
SW	4	4	1	0	0	0	0	0	9
WSW	4	1	2	3	0	1	0	0	11
W	2	2	1	0	0	0	0	0	5
WNW	0	1	1	0	0	0	0	0	2
NW	3	0	1	0	0	0	0	0	4
NNW	3	2	0	0	0	0	0	0	5
N	0	0	2	0	0	0	0	0	2
ALL SECTUR	25	30	19	4	4	2	0	0	

NO. OF VALID OBSERVATION = 65

NO. OF CALMS (WS LT 0.5M/SEC) = 1

NO. OF MISSING WD/WS = 6

## MILLSTONE NUCLEAR POWER STATION / UNIT 1

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 147 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 1 OCT 19/0015 - 31 DEC 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-15 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	2	21	61	62	2	0	0	0	148
NE	4	23	50	24	5	0	0	0	106
ENE	3	10	11	0	0	0	0	0	24
E	2	11	16	8	0	0	0	0	37
ESE	4	11	19	12	5	1	0	0	52
SE	4	13	31	8	2	6	1	0	65
SSE	4	17	32	19	12	9	3	0	96
S	7	14	35	23	13	3	1	0	96
SSW	5	25	37	50	31	21	1	0	170
SW	13	27	45	48	31	17	2	0	183
WSW	6	22	54	45	34	25	7	0	195
W	6	37	28	65	62	20	3	0	221
WNW	3	31	61	78	26	10	0	0	209
NW	3	29	64	65	41	15	0	0	217
NNW	6	18	102	56	24	6	0	0	212
N	2	10	54	33	6	0	0	0	105
ALL SECTOR	74	319	700	596	294	133	18	0	

NO. OF POSSIBLE OBSERVATIONS = 2208  
 NO. OF VALID OBSERVATIONS = 2156

NO. OF VALID NON-CALM CONCURRENT WD/WS/DI = 2133  
 NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 72  
 NO. OF MISSING DELTA T = 72

MILLSTONE NO. 2

METEOROLOGICAL

JOINT FREQUENCY

DATA FOR

CONTAINMENT PURGES

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

PASQUILL STABILITY A -- DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	3	4	0	0	0	0	0	8
NE	0	3	0	0	0	0	0	0	3
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	1	6	0	0	0	0	0	7
SE	0	7	4	0	0	0	0	0	11
SSE	1	0	2	2	0	0	0	0	5
S	1	5	10	6	1	0	0	0	23
SSW	0	0	9	1	0	0	0	0	10
SW	1	0	0	0	0	0	0	0	1
WSW	1	0	0	0	0	0	0	0	1
W	1	0	0	0	0	0	0	0	1
WNW	0	1	0	0	0	0	0	0	1
NW	0	1	0	0	0	0	0	0	1
NNW	0	1	3	0	0	0	0	0	4
N	1	2	5	0	0	0	0	0	8
ALL SECTOR	7	24	43	9	1	0	0	0	

NO. OF VALID OBSERVATION = 84

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 5

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

PASQUILL STABILITY B -- DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	4	2	0	0	0	0	0	7
NE	0	4	1	0	0	0	0	0	5
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	5	6	0	0	0	0	0	5
SE	2	5	8	1	0	0	0	0	16
SSE	3	3	11	10	0	0	0	0	27
S	3	9	6	0	2	0	0	0	20
SSW	1	1	2	1	0	0	0	0	5
SW	1	0	1	0	0	0	0	0	2
WSW	2	0	0	0	0	0	0	0	2
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	4	0	0	1	0	0	5
NNW	0	1	3	0	0	0	0	0	4
N	0	6	4	0	0	0	0	0	10
ALL SECTOR	13	38	42	12	2	1	0	0	

NO. OF VALID OBSERVATION = 108

NO. OF CALMS (MS LT 0.5M/SEC) = 0

NO. OF MISSING WD/MS = 4



## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	ALL
NNE	1	2	2	0	0	0	0	0	5
NE	1	1	0	0	0	0	0	0	2
ENE	2	0	0	0	0	0	0	0	2
E	2	3	0	0	0	0	0	0	5
ESE	1	2	3	0	0	0	0	0	6
SE	0	4	5	0	0	0	0	0	9
SSE	1	5	14	9	3	0	0	0	32
S	0	8	12	4	0	0	0	0	24
SSW	0	4	8	1	0	0	0	0	13
SW	0	4	1	0	0	0	0	0	5
WSW	0	3	0	0	0	0	0	0	3
W	0	0	0	0	0	0	0	0	0
WNW	1	0	1	0	0	0	0	0	2
NW	0	1	0	0	0	0	0	0	1
NNW	0	1	0	0	0	0	0	0	1
N	0	2	0	0	0	0	0	0	2
ALL SECTOR	9	40	46	14	3	0	0	0	

NO. OF VALID OBSERVATION = 112

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 3

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

PASQUILL STABILITY D -- DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	1	7	6	0	0	0	0	0	14
NE	1	3	0	0	0	0	0	0	4
ENE	0	0	0	0	0	0	0	0	0
E	4	0	0	0	0	0	0	0	4
ESE	0	1	1	0	0	0	0	0	2
SE	1	3	5	0	0	0	0	0	9
SSE	3	1	4	2	3	0	0	0	13
S	0	5	9	4	0	0	0	0	18
SSW	0	4	1	1	0	0	0	0	11
SW	1	2	2	0	0	0	0	0	5
WSW	1	5	9	7	0	0	0	0	22
W	3	10	3	2	6	0	0	0	24
WNW	2	4	2	0	0	0	0	0	13
NW	1	0	0	0	1	0	0	0	2
NNW	1	2	3	1	0	0	0	0	7
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	19	57	45	17	10	0	0	0	

NO. OF VALID OBSERVATION = 150

NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 6

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	4	0	0	0	0	0	0	0	4
NE	2	0	0	0	0	0	0	0	2
ENE	2	0	0	0	0	0	0	0	2
E	1	0	0	0	0	0	0	0	1
ESE	1	2	0	0	0	0	0	0	3
SE	0	0	1	0	0	0	0	0	1
SSE	4	1	2	2	4	0	0	0	13
S	1	1	10	11	2	0	0	0	25
SSW	2	3	2	50	31	2	0	0	90
SW	0	6	16	7	4	1	0	0	34
WSW	2	9	31	10	0	0	0	0	52
W	5	8	5	0	5	0	0	0	23
WNW	3	20	10	0	0	0	0	0	33
NW	3	3	0	0	0	0	0	0	6
NNW	1	3	2	0	0	0	0	0	6
N	1	0	0	0	0	0	0	0	1
ALL SECTOR	32	56	79	80	46	3	0	0	

NO. OF VALID OBSERVATION = 297

NO. OF CALMS (WS LT 0.5M/SEC) = 1

NO. OF MISSING WD/WS = 10

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	2	0	0	0	0	0	0	0	2
NE	2	0	0	0	0	0	0	0	2
ENE	2	0	0	0	0	0	0	0	2
E	3	1	0	0	0	0	0	0	4
ESE	3	5	0	0	0	0	0	0	8
SE	2	2	0	0	0	0	0	0	4
SSE	1	0	0	0	0	0	0	0	1
S	2	0	0	0	0	0	0	0	2
SSW	1	1	0	0	0	0	0	0	2
SW	1	1	2	0	0	0	0	0	4
WSW	0	1	1	5	0	0	0	0	7
W	0	0	0	0	0	0	0	0	0
WNW	3	0	0	0	0	0	0	0	3
NW	3	0	0	0	0	0	0	0	3
NNW	1	1	0	0	0	0	0	0	2
N	3	0	0	0	0	0	0	0	3
ALL SECTOR	29	12	3	5	0	0	0	0	

NU. OF VALID OBSERVATION = 60

NU. OF CALMS (WS LT 0.5M/SEC) = 11

NU. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 8 JUL 79/0245 - 6 SEP 79/2315

DATA ACQUISITION INTERVAL = MINUTES 00-45 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.6	10.9-15.0	15.1-20.0	GT 20.1	
NNE	10	17	14	0	0	0	0	0	41
NE	6	11	1	0	0	0	0	0	18
ENE	7	0	0	0	0	0	0	0	7
E	10	4	0	0	0	0	0	0	14
ESE	8	23	13	5	0	0	0	0	49
SE	5	27	42	9	0	0	0	0	83
SSE	13	11	46	29	10	0	0	0	109
S	9	32	56	27	6	0	0	0	130
SSW	5	22	24	68	39	5	0	0	163
SW	6	13	25	14	6	12	0	0	76
WSW	8	19	49	23	0	0	0	0	99
W	12	24	8	2	11	0	0	0	57
MNW	13	32	14	0	0	0	0	0	59
NW	11	6	4	0	1	1	0	0	23
NNW	6	10	11	1	0	0	0	0	28
N	7	11	9	0	0	0	0	0	27
ALL SECTOR	136	262	316	178	73	18	0	0	

NU. OF POSSIBLE OBSERVATIONS = 1513

NU. OF VALID OBSERVATIONS = 998

NU. OF VALID NON-CALM CONCURRENT WD/WS/DT = 903

NU. OF CALMS (WS LT 0.5M/SEC) = 15

NU. OF MISSING WD/WS = 515

NU. OF MISSING DELTA T = 567

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSLS / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY A -- DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	1	0	0	0	0	0	1
NL	0	3	7	0	0	0	0	0	10
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	3	0	0	0	3
WSW	0	0	0	11	4	27	1	0	43
W	0	0	0	3	2	14	0	0	19
WNW	0	0	0	11	2	0	0	0	13
NW	0	0	1	11	10	8	0	0	30
NNW	0	0	0	4	4	4	0	0	12
N	0	0	0	0	0	0	0	0	0
ALL SECTIK	0	3	9	40	25	53	1	0	

NU. OF VALID OBSERVATION = 131

NU. OF CALMS (WS LT 0.5M/SEC) = 0

NU. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY B — DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	1	2	1	0	0	0	0	4
NE	0	0	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	0	0	1
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	2	2	0	0	0	0	4
SSW	0	0	3	9	0	0	0	0	12
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	2	0	0	0	0	0	2
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	1	0	0	0	1	0	0	2
NNW	0	2	16	3	0	6	0	0	27
N	0	1	7	5	0	0	0	0	13
ALL SECTOR	0	6	32	20	0	7	0	0	

NO. OF VALID OBSERVATION = 62

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WU/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY C — DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.6	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	21	28	0	0	0	0	49
NE	0	3	12	16	0	0	0	0	31
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	4	1	0	0	0	0	5
SE	0	0	1	2	0	0	0	0	3
SSE	0	0	2	0	0	0	0	0	2
S	0	7	3	14	0	0	0	0	24
SSW	1	1	12	22	0	0	0	0	36
SW	1	0	17	6	6	0	0	0	30
WSW	1	2	18	12	15	8	0	0	56
W	1	6	8	35	21	5	0	0	76
WNW	0	0	26	55	2	0	0	0	83
NW	0	0	30	37	1	0	0	0	68
NNW	0	1	37	22	9	0	0	0	69
N	0	1	11	17	9	0	0	0	38
ALL SECTOR	4	21	202	267	63	13	0	0	

NU. OF VALID OBSERVATION = 570

NU. OF CALMS (WS LT 0.5M/SEC) = 0

NU. OF MISSING WU/WS = 3



## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 INT 79/1730 - 26 DEC 79/0515

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY D -- DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND							ALL	
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0		GT 20.1
NNE	0	8	59	92	0	0	0	0	159
NE	1	12	37	7	0	0	0	0	57
ENE	1	6	0	0	0	0	0	0	7
E	0	2	0	0	0	0	0	0	2
ESE	0	5	9	6	0	0	0	0	20
SE	4	6	16	18	0	0	0	0	44
SSE	2	0	43	9	2	0	0	0	56
S	4	11	14	7	6	0	0	0	42
SSW	3	5	8	6	3	0	0	0	25
SW	7	12	19	4	2	1	0	0	45
WSW	5	23	14	9	10	6	0	0	67
W	8	28	19	7	10	0	0	0	72
WNW	3	41	32	4	0	0	0	0	80
NW	1	14	28	10	0	0	0	0	53
NNW	1	3	46	11	1	0	0	0	62
N	0	3	39	18	5	0	0	0	65
ALL SECTOR	40	179	363	208	39	7	0	0	

NO. OF VALID OBSERVATION = 856

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY 1 -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNL	2	5	3	5	0	0	0	0	15
NE	0	5	5	0	0	0	0	0	10
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	2	1	1	0	0	0	0	4
SE	1	1	1	0	0	0	0	0	3
SSE	0	8	5	0	0	0	0	0	13
S	1	6	3	4	9	6	0	0	29
SSW	2	5	14	8	32	26	0	0	87
SW	2	11	20	19	15	10	0	0	77
WSW	0	12	11	8	3	2	0	0	36
W	0	14	13	1	1	0	0	0	29
WNW	3	8	11	0	0	0	0	0	22
NW	0	2	8	1	0	0	0	0	11
NNW	1	0	4	17	6	0	0	0	28
N	1	2	3	27	2	0	0	0	35
ALL SECTOR	13	81	102	91	68	44	0	0	

NO. OF VALID OBSERVATION = 399

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 35 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY F -- DELTA T LESS THAN OR EQUAL TO 4.0 AND GREATER THAN 1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	4	2	0	0	0	0	0	6
NE	0	1	10	0	0	0	0	0	11
ENE	1	1	0	0	0	0	0	0	2
E	2	1	1	0	0	0	0	0	4
ESE	1	5	0	0	0	0	0	0	6
SE	1	3	1	0	0	0	0	0	5
SSE	2	1	0	0	0	0	0	0	3
S	5	2	1	1	3	0	0	0	12
SSW	3	10	15	8	17	22	0	0	75
SW	2	11	6	11	6	7	0	0	43
WSW	0	7	1	1	0	1	0	0	10
W	2	1	1	0	2	0	0	0	6
WNW	4	4	3	0	0	0	0	0	11
NW	0	1	2	0	0	0	0	0	3
NNW	1	2	2	1	0	0	0	0	6
N	1	1	5	1	0	0	0	0	9
ALL SECTOR	25	55	50	23	28	30	0	0	

NO. OF VALID OBSERVATION = 211

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSHINE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 35 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.7	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	5	0	0	0	0	0	5
ENE	0	7	1	0	0	0	0	0	8
E	1	22	13	0	0	0	0	0	36
ESE	3	2	0	0	0	0	0	0	5
SE	1	2	0	0	0	0	0	0	3
SSE	4	5	0	0	0	0	0	0	9
S	2	4	1	0	0	0	0	0	7
SSW	0	8	4	7	11	0	0	0	30
SW	7	11	1	0	0	0	0	0	19
WSW	8	4	0	0	0	0	0	0	12
W	4	1	1	2	0	0	0	0	8
WNW	1	0	2	0	0	0	0	0	3
NW	1	2	1	0	0	0	0	0	4
NNW	4	6	1	0	0	0	0	0	11
N	1	2	1	0	0	0	0	0	4
ALL SECTOR	37	76	31	9	11	0	0	0	

NO. OF VALID OBSERVATION = 160

NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 1

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 142 FT

DELTA T INTERVAL = 142 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 10 OCT 79/1730 - 26 DEC 79/0315

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	2	18	88	126	0	0	0	0	234
NE	1	24	76	23	0	0	0	0	124
ENE	2	15	1	0	0	0	0	0	18
E	3	25	14	0	0	0	0	0	42
ESE	4	14	14	8	0	0	0	0	40
SE	7	12	19	20	0	0	0	0	58
SSE	8	14	50	9	2	0	0	0	83
S	12	30	24	28	18	6	0	0	118
SSW	9	29	56	60	63	48	0	0	265
SW	19	45	63	40	32	18	0	0	217
WSW	14	48	46	41	32	44	1	0	226
W	15	50	42	48	36	19	0	0	210
WNW	11	53	74	70	4	0	0	0	212
NW	2	20	70	59	11	9	0	0	171
NNW	7	14	106	58	20	10	0	0	215
N	3	10	66	68	16	0	0	0	163
ALL SECTOR	119	421	809	658	234	154	1	0	

NO. OF POSSIBLE OBSERVATIONS = 2441  
 NO. OF VALID OBSERVATIONS = 2398

NO. OF VALID NON-CALM CONCURRENT WD/WS/DI = 2396  
 NO. OF CALMS (WS LT 0.5M/SEC) = 2

NO. OF MISSING WD/WS = 43  
 NO. OF MISSING DELTA T = 40

MILLSTONE NO. 2

METEOROLOGICAL

JOINT FREQUENCY

DATA FOR

WASTE GAS TANK RELEASES

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

PASQUILL STABILITY A -- DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION = 0

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

PASQUILL STABILITY B -- DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION = 0

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0



## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	4	0	0	0	4
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	2	3	0	0	0	0	5
SSE	0	1	4	0	0	0	0	0	5
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	1	6	3	4	0	0	0	0

NO. OF VALID OBSERVATION = 14

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WU/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

PASQUILL STABILITY D -- DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	12	2	0	0	0	14
E	0	0	0	4	5	0	0	0	9
ESE	0	0	0	0	0	0	0	0	0
SE	0	4	4	1	5	0	0	0	14
SSE	0	5	5	4	1	0	0	0	15
S	0	3	1	6	5	0	0	0	15
SSW	0	0	4	8	8	0	0	0	20
SW	0	1	0	2	0	0	0	0	3
WSW	0	5	0	0	0	0	0	0	5
W	0	1	0	0	0	0	0	0	1
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	19	14	37	26	0	0	0	

NO. OF VALID OBSERVATION = 96

NO. OF CALMS (MS LT 0.5M/SEC) = 0

NO. OF MISSING WD/MS = 2

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND							GT 20.1	ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0		
MNE	0	2	0	0	3	0	0	0	5
NE	0	2	0	0	0	0	0	0	2
ENE	0	1	1	1	0	0	0	0	3
E	0	0	2	0	0	0	0	0	2
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	2	2	2	0	0	0	0	0	6
S	0	11	0	4	0	0	0	0	15
SSW	0	0	3	9	6	0	0	0	18
SW	1	4	15	9	0	0	0	0	29
WSW	2	9	0	0	0	0	0	0	11
W	1	2	0	0	0	0	0	0	3
WNW	0	4	0	0	0	0	0	0	4
NW	2	0	0	0	0	0	0	0	2
NNW	0	0	0	0	0	0	0	0	0
N	0	0	3	2	0	0	0	0	5
ALL SECTOR	8	37	26	25	9	0	0	0	

NO. OF VALID OBSERVATION = 105

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 11

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

PASQUILL STABILITY G -- DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND							ALL	
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0		GT 20.1
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION =

0

NO. OF CALMS (WS LT 0.5M/SEC) =

0

NO. OF MISSING WD/WS =

0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 16 JUL 79/1800 - 24 SEP 79/2215

DATA ACQUISITION INTERVAL = MINUTES 00-00 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	2	0	0	3	0	0	0	5
NE	0	2	0	0	0	0	0	0	2
ENE	0	1	1	13	2	0	0	0	17
E	0	0	2	4	9	0	0	0	15
ESE	0	0	0	0	0	0	0	0	0
SE	0	4	6	4	5	0	0	0	19
SSE	2	8	11	4	1	0	0	0	26
S	0	14	1	10	5	0	0	0	30
SSW	0	1	7	17	14	0	0	0	39
SW	1	12	15	13	0	0	0	0	41
WSW	4	19	0	0	0	0	0	0	23
W	1	12	0	0	0	0	0	0	13
WNW	0	5	0	0	0	0	0	0	5
NW	2	0	0	0	0	0	0	0	2
NNW	0	0	0	0	0	0	0	0	0
N	0	0	3	2	0	0	0	0	5
ALL SECTOR	10	80	46	67	39	0	0	0	

NO. OF POSSIBLE OBSERVATIONS = 286

NO. OF VALID OBSERVATIONS = 242

NO. OF VALID NON-CALM CONCURRENT WD/WS/DT = 242

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 44

NO. OF MISSING DELTA T = 31

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY A -- DELTA T LESS THAN OR EQUAL TO -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNL	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION = 0

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY B — DELTA T LESS THAN OR EQUAL TO -1.7 AND GREATER THAN -1.9 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNL	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	1	0	0	1
NW	0	0	0	0	0	0	2	0	2
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	1	2	0	

NO. OF VALID OBSERVATION = 5

NO. OF CALMS (WS. LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY C -- DELTA T LESS THAN OR EQUAL TO -1.5 AND GREATER THAN -1.7 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	1	0	0	1
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	9	0	0	9
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	10	0	0	0

NO. OF VALID OBSERVATION = 10

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0



## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY D — DELTA T LESS THAN OR EQUAL TO -0.5 AND GREATER THAN -1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND							ALL	
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0		GT 20.1
NNE	0	0	0	11	29	0	0	0	40
NE	0	0	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	8	6	0	0	14
WSW	0	0	0	9	2	0	0	0	11
W	0	0	0	0	0	0	0	0	0
WNW	0	0	2	2	1	0	0	0	5
NW	0	0	0	12	14	0	0	0	26
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	8	12	0	0	0	20
ALL SECTOR	0	0	2	43	66	6	0	0	

NO. OF VALID OBSERVATION = 117

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY E -- DELTA T LESS THAN OR EQUAL TO 1.5 AND GREATER THAN -0.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION = 0

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY F — DELTA T LESS THAN OR EQUAL TO 4.0 AND GREATER THAN 1.5 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION =

0

NO. OF CALMS (WS LT 0.5M/SEC) =

0

NO. OF MISSING WU/WS =

0

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

PASQUILL STABILITY G — DELTA T GREATER THAN 4.0 DEG C PER 100 METERS

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	0	0	0	0	0	0
ALL SECTOR	0	0	0	0	0	0	0	0	0

NO. OF VALID OBSERVATION = 0

NO. OF CALMS (WS LT 0.5M/SEC) = 0

NO. OF MISSING WD/WS = 0

## MILLSTONE NUCLEAR POWER STATION / UNIT 2

## WIND SPEED/WIND DIRECTION/STABILITY JOINT FREQUENCY DISTRIBUTION

WIND LEVEL = 447 FT

DELTA T INTERVAL = 447 - 33 FT

PASQUILL STABILITY CLASSES / CLASS DETERMINATION METHOD = DELTA T

DATA PERIOD = 13 NOV 79/1130 - 16 NOV 79/1415

DATA ACQUISITION INTERVAL = MINUTES 00-30 OF EACH HOUR

## ALL STABILITY CLASSES

DIRECTION	SPEED IN METERS PER SECOND								ALL
	0.5-1.5	1.6-3.3	3.4-5.5	5.6-8.2	8.3-10.8	10.9-15.0	15.1-20.0	GT 20.1	
NNE	0	0	0	11	29	0	0	0	40
NE	0	0	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0	0	0
SW	0	0	0	0	8	7	0	0	15
WSW	0	0	0	9	2	0	0	0	11
W	0	0	0	0	0	0	0	0	0
WNW	0	0	2	2	1	1	0	0	6
NW	0	0	0	12	14	9	2	0	37
NNW	0	0	0	0	0	0	0	0	0
N	0	0	0	8	12	0	0	0	20
ALL SECTOR	0	0	2	43	66	17	2	0	

NU. OF POSSIBLE OBSERVATIONS = 130  
 NU. OF VALID OBSERVATIONS = 130

NU. OF VALID NON-CALM CONCURRENT WD/WS/UT = 130  
 NU. OF CALMS (WS LT 0.5M/SEC) = 0

NU. OF MISSING WD/WS = 0  
 NU. OF MISSING DELTA T = 0