

## PMFermiCOLPEm Resource

---

**From:** Govan, Tekia  
**Sent:** Thursday, August 14, 2014 8:56 AM  
**To:** FermiCOL Resource  
**Subject:** FW: Fermi 3 Draft ACRS Presentations (Email #1)  
**Attachments:** Section 3.7 & 3.8\_Draft.pdf; Opening Remarks\_Draft.pdf

---

**From:** Nicholas A Latzy [<mailto:latzyn@dteenergy.com>]  
**Sent:** Wednesday, August 13, 2014 3:11 PM  
**To:** Govan, Tekia  
**Subject:** Fw: Fermi 3 Draft ACRS Presentations (Email #1)

Tekia,

Attached to this email and the next email (email #2) are the DRAFT Fermi 3 ACRS Presentations for the August 20, 2014 meeting.

If you have any questions concerning these presentations, please feel free to contact me.

Thank you

Nicholas A. Latzy  
Principal Engineer - Nuclear Engineering  
Major Enterprise Projects  
DTE Energy  
(313)235-9226

*(See attached file: Section 3.7 & 3.8\_Draft.pdf)(See attached file: Opening Remarks\_Draft.pdf)*

**Hearing Identifier:** Fermi\_COL\_Public  
**Email Number:** 1448

**Mail Envelope Properties** (F5A4366DF596BF458646C9D433EA37D7017822539172)

**Subject:** FW: Fermi 3 Draft ACRS Presentations (Email #1)  
**Sent Date:** 8/14/2014 8:56:16 AM  
**Received Date:** 8/14/2014 8:56:25 AM  
**From:** Govan, Tekia

**Created By:** Tekia.Govan@nrc.gov

**Recipients:**  
"FermiCOL Resource" <FermiCOL.Resource@nrc.gov>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	652	8/14/2014 8:56:25 AM
Section 3.7 & 3.8_Draft.pdf	1607976	
Opening Remarks_Draft.pdf	989455	

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**



**DTE Energy**<sup>®</sup>

**Fermi 3 COLA  
Presentation to ACRS Subcommittee  
Section 3.7 and 3.8**



## Background



- Fermi 3 site-specific Soil-Structure Interaction (SSI) was performed to address:
  - Partial embedment of Seismic Category I structures
  - Evaluate side backfill for Seismic Category I structures as permitted by DCD
- Initial SSI (2011-2012) analysis used the subtraction method
- In 2012, Fukushima Near Term Task force Recommendation 2.1 required evaluation of the Central and Eastern US Seismic Source Characterization (CEUS SSC) model
- DTE Energy elected to re-perform all prior Fermi 3 site-specific SSI analysis using CEUS SSC based inputs
- Resulted in a coherent set of analyses which demonstrate the Fermi 3 site is well enveloped by the ESBWR standard plant design

## Discussion Topics:

- 3.7 Seismic Design
  - Seismic Design Parameters: Design ground motion with compare to Certified Seismic Design Response Spectra (CSDRS)
  - Seismic System Analysis: SSI
- 3.8 Seismic Category I Structures
  - Other Seismic Category I Structures
  - Foundations

## Section 3.7 – Seismic Design

Site-Specific SSI and Structure-Soil-Structure Interaction (SSSI) analyses were performed to demonstrate the Fermi 3 site is well enveloped by the ESBWR standard plant design

- Updated site-specific seismic inputs based on CEUS SSC model
- Accounted for partial embedment of the Reactor Building/Fuel Building (RB/FB) and Control Building (CB) into the Bass Islands Group bedrock
- Evaluated side backfill for Seismic Category I structures as permitted by DCD

## Section 3.7.1 – Seismic Design Inputs


### Seismic Design Parameters:

- Computed site-specific amplification functions to develop Foundation Input Response Spectra (FIRS)
- Determined horizontal and vertical FIRS for the RB/FB and CB
- Enhanced the FIRS to satisfy minimum ground motion requirements specified in 10 CFR Part 50, Appendix S and to satisfy ISG-17 recommendations for hazard consistent spectra
- Developed ground motion time histories and subsurface material properties for SSI analyses

## Section 3.7.1 – Seismic Design Inputs (continued)



### Fermi 3 RB/FB FIRS compared to ESBWR CSDRS (5 percent damping)




FIRS for Fermi 3 RB/FB are enveloped by the ESBWR  
horizontal and vertical CSDRS



## Section 3.7.1 – Seismic Design Inputs (continued)



### Fermi 3 CB FIRS compared to ESBWR CSDRS (5 percent damping)



FIRS for Fermi 3 CB are enveloped by the ESBWR  
horizontal and vertical CSDRS

## Section 3.7.1 – Seismic Design Inputs (continued)





- Fire Water Service Complex (FWSC) is a surface founded structure on fill concrete above bedrock
- FWSC FIRS is well enveloped by ESBWR CSDRS x 1.35
- All FWSC requirements are satisfied

## Section 3.7.1 – Seismic Design Inputs (continued)



Fermi 3 FWSC FIRS compared to 1.35 times ESBWR  
CSDRS (5 percent damping)



FIRs for Fermi 3 FWSC are enveloped by the ESBWR  
horizontal and vertical CSDRS

## Section 3.7.1 – Conclusion



Site-specific FIRS are enveloped by ESBWR CSDRS design motions

## Section 3.7.2 – Soil-Structure Interaction



### Seismic System Analysis:

Fermi 3 site-specific SSI analyses were performed to evaluate partial embedment and to address ESBWR requirements for side backfill

- Followed methodology presented in DCD Appendix 3A with the ESBWR structural models for the RB/FB and CB
- Fermi 3 site-specific SSI and SSSI analyses were performed using SASSI2010:
  - Used the direct method of analysis wherever possible
  - The modified subtraction method of analysis was used where the number of Interaction Nodes exceeded the capacity of SASSI2010 using the direct method
  - Benchmarked the modified subtraction method against the direct method

## Section 3.7.2 – Conclusion




- Analyses for RB/FB and CB were performed with and without the engineered granular backfill
- Results from the Fermi 3 SSI and SSSI analyses show the seismic forces in members, accelerations, and floor response spectra are well enveloped by the ESBWR standard plant design for both the RB/FB and CB

## Section 3.7.2 – Conclusion (continued)



### DCD-Fermi 3 Comparison - RB/FB



The Fermi 3 RB/FB is well enveloped by the  
ESBWR RB/FB standard plant design

## Section 3.7.2 – Conclusion (continued)



### Governing Comparison for Response Spectra




The Fermi 3 RB/FB is well enveloped by the ESBWR RB/FB standard plant design



## Section 3.7.2 – Conclusion (continued)



### DCD-Fermi 3 Comparison - CB




The Fermi 3 CB is well enveloped by the ESBWR CB standard plant design

## Section 3.7.2 – Conclusion (continued)



### Governing Comparison for Response Spectra



The Fermi 3 CB is well enveloped by the ESBWR CB standard plant design

## Section 3.7.4 – Commitment



### Seismic Instrumentation:

- The seismic monitoring program described in this subsection, including the necessary test and operating procedures, will be implemented prior to the receipt of fuel on site. (COM 3.7-001)

## Section 3.8.4 – Purpose and Conclusion



### Other Seismic Category I Structures:

- Lateral soil pressures from the applicable SSI and SSSI analyses were evaluated
- A quantitative assessment of the sidewall design was performed
- The induced out-of-plane bending moments and shear forces in the walls are enveloped by the ESBWR standard plant design

## Section 3.8.5 - Conclusion



### Foundations:


- Results from the Fermi 3 site-specific foundation stability evaluations demonstrated that the minimum factors of safety for sliding, overturning, and flotation meet SRP 3.8.5 requirements
- The Fermi 3 site-specific soil dynamic bearing demands are considerably below the allowable dynamic bearing capacities of the bedrock



**DTE Energy**®

Fermi 3 COLA

Presentation to ACRS Subcommittee  
Opening Remarks



## Presentation Overview



### Presenting summary information for Sections:

- 2.5 Geology, Seismology, and Geotechnical Engineering
- 3.7 Seismic Design
- 3.8 Seismic Category I Structures

### Section 2.5

- Basic Geology and Seismic Information
- Vibratory Ground Motion (Central and Eastern U.S. Seismic Source Characterization [CEUS SSC] applied to establish site seismic response)
- Surface Faulting
- Stability of Subsurface Materials and Foundations
- Stability of Slopes

### Section 3.7

- Developed Fermi 3 seismic inputs to support Soil-Structure Interaction (SSI) and Structure-Soil-Structure Interaction (SSSI) Analyses:
  - Partial Embedment of Seismic Category I Structures
  - Evaluate side backfill for Seismic Category I Structures as permitted by DCD
  - Used Direct Method where possible
- Discuss results of SSI and SSSI

### Section 3.8


- Discuss foundation stability and lateral soil pressures



# Conclusion



Fermi 3 GMRS compared to ESBWR CSDRS (5 percent damping)





GMRS for Fermi 3 site is well enveloped by the ESBWR horizontal and vertical Certified Seismic Design Response Spectra (CSDRS)

# Conclusion



Fermi 3 RB/FB FIRS compared to ESBWR CSDRS (5 percent damping)




FIRS for Fermi 3 RB/FB, CB, and FWSC are enveloped by the ESBWR horizontal and vertical CSDRS

# Conclusion



## Governing Comparison for Response Spectra



Response spectra for Fermi 3 RB/FB and CB are enveloped by the ESBWR design response spectra

## Conclusion



The Fermi 3 site is well enveloped by the ESBWR standard plant design