

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9205120099 DOC. DATE: 92/04/30 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 GROOMS, J. Carolina Power & Light Co.
 CHAMBERS, R.H. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for April 1992 for Robinson Unit 2.
 W/920508 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD2-1	LA	3	3		PD2-1	PD	1	1
	LO,	R	1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR/DLPO/LPEB10		1	1		NRR/DOEA/OEAB		1	1
	<u>REG FILE</u> 01		1	1		RGN2		1	1
EXTERNAL:	EG&G BRYCE, J.H		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

R
I
D
S
/
A
D
S
/
A
D
D
S

MR
JHP



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

MAY 08 1992

Robinson File: 15505

Serial: RNP/92-1321

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.4 for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of April, 1992.

Very truly yours,

R. H. Chambers
General Manager
H. B. Robinson S. E. Plant

SAB/dwm

Enclosure

cc: Mr. S. D. Ebnetter
Mr. L. W. Garner

120006

9205120099 920430
PDR ADCK 05000261
R PDR

RUN DATE 05/05/92
RUN TIME 09:35:22

DOCKET NO. 050-0261
COMPLETED BY JACKIE GROOMS
TELEPHONE (803)383-4524

OPERATING STATUS

- | | |
|---|---|
| <ol style="list-style-type: none"> 1. UNIT NAME: ROBINSON UNIT 2 2. REPORTING PERIOD: APRIL 92 3. LICENSED THERMAL POWER (MWT): 2300 4. NAMEPLATE RATING (GROSS MWE): 739.0 5. DESIGN ELECTRICAL RATING (NET MWE): 700.0 6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0 7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0 | <p>NOTES There are 409 assemblies and one (1) skeleton assembly in the Spent Fuel Pool with 100 fuel rods. There are 56 assemblies in the Dry Fuel Storage.</p> |
|---|---|

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS: N/A

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): 0
10. REASONS FOR RESTRICTION IF ANY: Unit shutdown for refueling.

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	719.00	2903.00	185567.00
12. NUMBER OF HOURS REACTOR CRITICAL	.00	2089.40	130478.66
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	.00	2087.27	127608.47
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	.00	4741889.76	258615819.84
17. GROSS ELEC. ENERGY GEN. (MWH)	.00	1594322.00	83852559.00
18. NET ELEC. ENERGY GENERATED (MWH)	-2559.00	1517119.00	79202056.00
19. UNIT SERVICE FACTOR	.00	71.90	68.77
20. UNIT AVAILABILITY FACTOR	.00	71.90	68.78
21. UNIT CAP. FACTOR (USING MDC NET)	-.52	76.52	64.07
22. UNIT CAP. FACTOR (USING DER NET)	-.51	74.66	60.97
23. UNIT FORCED OUTAGE RATE	.00	.00	14.72
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):	None		

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: 06/19/92
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY	-----	-----
INITIAL ELECTRICITY	-----	-----
COMMERCIAL OPERATION	-----	-----

CP&L CO
RUN DATE 05/05/92
RUN TIME 09:29:38

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

DOCKET NO. 050-0261
COMPLETED BY JACKIE GROOMS
TELEPHONE (803) 383-4524

APRIL 1992

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-15	17	-2
2	-10	18	-2
3	-10	19	-2
4	-7	20	-2
5	-4	21	-2
6	-4	22	-2
7	-4	23	-2
8	-4	24	-1
9	-3	25	-1
10	-3	26	-2
11	-4	27	-2
12	-3	28	-2
13	-3	29	-1
14	-3	30	-1
15	-2		
16	-2		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH April

DOCKET NO. 050-0261
 UNIT NAME H. B. Robinson
 DATE 05/05/92
 COMPLETED BY J. W. Grooms
 TELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0306*	040192	S	719	C	1	-----	ZZ	ZZZZZZ	Continuation of Cycle #14 Refueling Outage. This outage will continue into May. *Continued from previous month.

1 F: Forced
S: Scheduled

2 Reason:
A-Equipment Failure (Explain)
B-Maintenance of Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3 Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5 Exhibit I - Same Source

(9/77)