

PRIORITY 1
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9501170128 DOC. DATE: ~~94/12/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 KRICH, R.M. Carolina Power & Light Co.
 SCARBOROUGH, J. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Dec 1994 for H B Robinson Steam Electric Plant, Unit 2, W/950109 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFARI, B	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DISP/PIPB	1 1	NRR/DOPS/OECB	1 1
	RGN2	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

NR

P
R
I
O
R
I
T
Y

1
D
O
C
U
M
E
N
T



TS 6.9.1.4

Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29551

Robinson File No: 15505
Serial: RNP-RA/95-0002

JAN 09 1995

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261 / LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specifications Section 6.9.1.4 for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Carolina Power & Light Company submits the enclosed report of operation statistics and shutdown experience for the month of December 1994.

Very truly yours,

R. M. Krich
Manager - Regulatory Affairs

SAB:sb

Enclosures

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP

9501170128 941231
PDR ADOCK 05000261
R PDR



Highway 151 and SC 23 Hartsville SC

IE24
11

CP&L CO
 RUN DATE 01/05/95
 RUN TIME 12:56:50

PLANT PERFORMANCE DATA SYSTEM
 OPERATING DATA REPORT
 ROBINSON UNIT 2

PAGE 1
 RPD36-000

DOCKET NO. 050-0261
 COMPLETED BY: J. S. SCARBOROUGH
 TELEPHONE (803)857-1000

OPERATING STATUS

1. UNIT NAME: ROBINSON UNIT 2
2. REPORTING PERIOD: DECEMBER 94
3. LICENSED THERMAL POWER (MWT): 2300
4. NAMEPLATE RATING (GROSS MWE): 739.0
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 683.0
8. IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: None
9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): None
10. REASONS FOR RESTRICTION, IF ANY: None

NOTES: There are 238 assemblies and 1 assembly with 100 rods in the Spent Fuel Pool. There are 157 assemblies in the Reactor and 56 assemblies in the Dry Fuel Storage.

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	744.00	8760.00	208968.00
12. NUMBER OF HOURS REACTOR CRITICAL	744.00	6963.67	147411.53
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	744.00	6847.34	144319.18
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	1697449.68	15185845.68	295495320.72
17. GROSS ELEC. ENERGY GEN. (MWH)	561971.00	4908541.00	95862549.00
18. NET ELEC. ENERGY GENERATED (MWH)	536120.00	4646412.00	90579355.00
19. UNIT SERVICE FACTOR	100.00	78.17	69.06
20. UNIT AVAILABILITY FACTOR	100.00	78.17	69.07
21. UNIT CAP. FACTOR (USING MDC NET)	105.50	77.66	64.89
22. UNIT CAP. FACTOR (USING DER NET)	102.94	75.77	61.92
23. UNIT FORCED OUTAGE RATE	.00	21.83	15.20
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH): Refueling Outage 16 scheduled April 29, 1995, with a duration of 39 days.			
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: N/A			
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION: FORECAST ACHIEVED			
INITIAL CRITICALITY	----	----	
INITIAL ELECTRICITY	----	----	
COMMERCIAL OPERATION	----	----	

CP&L CO
RUN DATE 01/05/95
RUN TIME 12:56:49

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

DOCKET NO. 050-0261
COMPLETED BY: J. S. SCARBOROUGH
TELEPHONE (803)857-1000

DECEMBER 1994

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	723	17	720
2	722	18	637
3	723	19	726
4	722	20	726
5	722	21	726
6	721	22	726
7	720	23	726
8	720	24	727
9	718	25	727
10	719	26	726
11	720	27	725
12	722	28	726
13	722	29	726
14	724	30	724
15	725	31	724
16	724		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 050-0261

UNIT NAME H. B. Robinson

DATE 12/05/94

COMPLETED BY J. S. Scarborough

TELEPHONE (803) 857-1000

REPORT MONTH DECEMBER

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ²	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
01	121794	F	-----	B	N/A	-----	TA	VALVEX	Ramp Down From 100% to 70% power for Turbine Valve Test, OST-551.

1 F: Forced
S: Scheduled

2 Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3 Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵ Exhibit 1 - Same Source

SUMMARY: With the exception of the power reduction listed above, the plant operated at 100% power during the month of December.