# CATEGORY 1

### REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9909140065 DOC.DATE: 99/08/31 NOTARIZED: NO DOCKET #
FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
AUTH.NAME AUTHOR AFFILIATION
FREEMAN,T. Carolina Power & Light Co.
WARDEN,R.L. Carolina Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1999 for HB Robinson Steam Electric Plant, Unit 2. With 990910 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR | ENCL | SIZE: | TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT	COPIES		RECIPIENT	COP	IES
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
	SUBBARATNAM	1 .	1			
T. T		- 1	-	06/551/515	-	3
INTERNAL	FILE CENTER 01	~ <u>T</u>	T	OC/DBA/PAD		<b>-</b>
	RES/DRAA/OERAB	1	1	RGN2	1	1
			_	•	_	_
EXTERNAL:	LMITCO MARSHALL	1	1	NOAC	1	1
	NRC PDR	1	1	·		

THE WALL STREET

G

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR



Carolina Power & Light Company

Robinson Nuclear Plant 3581 West Entrance Road Hartsville SC 29550

Serial: RNP-RA/99-0186

SEP 1 0 1999

United States Nuclear Regulatory Commission Attn: Document Control Desk

Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2 DOCKET NO. 50-261/LICENSE NO. DPR-23

# MONTHLY OPERATING REPORT

Sir or Madam:

In accordance with Technical Specifications (TS) Section 5.6.4 for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Carolina Power & Light (CP&L) Company submits the enclosed report of operating statistics and shutdown experience for the month of August, 1999. In accordance with TS Section 5.6.4, this report is being submitted to the NRC by the 15th day of the month following the calendar month covered by the report.

If you have any questions concerning this matter, please contact Mr. H. K. Chernoff.

Sincerely,

R. L. Warden

Manager - Regulatory Affairs

PMY/pmy Attachments

c: NRC Resident Inspector, HBRSEP

L. A. Reyes, NRC, Region II

R. Subbaratnam, NRC, NRR

9909140065 990831 PDR ADDCK 05000261 R PDR 11 JE24 Attachment I to Serial: RNP-RA/99-0186

CP&L CO RUN DATE 09/Q1/99 RUN TIME 18:03:58

### PLANT PERFORMANCE DATA SYSTEM OPERATING DATA REPORT H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PAGE 1 of 1

RPD36-000

**OPERATING STATUS** 

1.

7.

**DOCKET NO. 050-0261** COMPLETED BY THOMAS FREEMAN TELEPHONE (843)857-1403

NOTES:

UNIT NO. 2	
REPORTING PERIOD: AUGUST 1999	
LICENSED THERMAL POWER (MWT): 2300	
NAMEPLATE RATING (GROSS MWE): 739.0	
DESIGN ELECTRICAL RATING (NET MWE): 700.0	
MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0	
	REPORTING PERIOD: AUGUST 1999 LICENSED THERMAL POWER (MWT): 2300 NAMEPLATE RATING (GROSS MWE): 739.0 DESIGN ELECTRICAL RATING (NET MWE): 700.0

- IF CHANGES OCCUR IN CAPACITY RATING (ITEMS 3 THROUGH 7) SINCE LAST REPORT, 8. **GIVE REASONS:**
- POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): NONE 9.

MAX DEPENDABLE CAPACITY (NET MWE): 683.0

UNIT NAME: H. B. ROBINSON STEAM ELECTRIC PLANT (HBRSEP),

10. REASONS FOR RESTRICTION, IF ANY:

		THIS MONTH	YR TO DATE	CUMUL ATIVE
11.	HOURS IN REPORTING PERIOD NUMBER OF HOURS REACTOR CRITICAL REACTOR RESERVE SHUTDOWN HRS HOURS GENERATOR ON LINE UNIT RESERVE SHUTDOWN HOURS GROSS THERMAL ENERGY GEN. (MWH)	744.00	5831.00	249863.00
12.		744.00	5801.28	184873.49
13.		.00	.00	3314.65
14.		744.00	5796.68	181633.81
15.		.00	.00	23.20
16.		1694601.36	13306567.20	380349180.24
17.	GROSS ELEC. ENERGY GEN. (MWH) NET ELEC. ENERGY GENERATED (MWH) UNIT SERVICE FACTOR	541728.00	4365849.00	123663299.00
18.		516038.00	4166293.00	117061041.00
19.		100.00	99.41	72.69
20. 21. 22. 23.	UNIT AVAILABILITY FACTOR UNIT CAP. FACTOR (USING MDC NET) UNIT CAP. FACTOR (USING DER NET) UNIT FORCED OUTAGE RATE	100.00 101.55 99.09	99.41 104.61 102.07 .00	72.70 69.88 66.93 12.60

- SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE DATE AND DURATION OF EACH): Refueling Outage 19 scheduled to begin September 25, 1999, with a scheduled duration of 28 days. 24.
- IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: N/A 25.
- 26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

**INITIAL CRITICALITY** INITIAL ELECTRICITY COMMERCIAL OPERATION Attachment II to Serial: RNP-RA/99-0186

CP&L CO RUN DATE 09/01/99 RUN TIME 18:03:58 PLANT PERFORMANCE DATA SYSTEM APPENDIX B - AVERAGE DAILY POWER LEVEL H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PAGE 1 of 1 RPD39-000

DOCKET NO. 050-0261 COMPLETED BY: THOMAS FREEMAN TELEPHONE (843)857-1403

### AUGUST 1999

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	693*	17	700*
2	692*	18	699*
3	696*	19	698*
4	698*	20	700*
5	698*	21	700*
6	698*	22	698*
7	699*	23	700*
8	700*	24	701*
9	699*	25	697*
10	699*	26	691*
11	700*	27	685*
12	697*	28	666*
13	699*	29	667*
14	700*	30	669*
15	700*	31	665*
16	698*		

<sup>\*</sup> The maximum dependable capacity is 683 MWE. The Plant operated above the Max Dependable Capacity (MDC) due to the condenser water inlet temperature  $< 95^{\circ}$  F.

#### UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: AUGUST 1999

DOCKET NO. <u>050-0261</u>
UNIT NAME <u>HBRSEP, UNIT NO. 2</u>
DATE <u>09/01/99</u>
COMPLETED BY <u>THOMAS FREEMAN</u>
TELEPHONE (843) 857-1403

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code⁴	Component Code⁵	Cause & Corrective Action to Prevent Recurrence
									·

F: Forced

S: Scheduled

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

**D-Regulatory Restriction** 

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

Exhibit G - Instructions

For Preparation of Data

Entry Sheets for Licensee

Event Report (LER) File

(NUREG-0161)

<sup>5</sup> Exhibit 1 - Same Source

SUMMARY: The unit operated at near 100% power until 8/25/99, when coast down for Refueling Outage 19 began. There were no challenges to the pressurizer power operated relief valves or the pressurizer safety valves during the month. There were no steam generator inspections during the month.