Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Fukushima Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, September 16, 2014

Work Order No.: NRC-1084 Pages 1-112

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	+ + + +
7	FUKUSHIMA SUBCOMMITTEE
8	+ + + +
9	OPEN SESSION
10	+ + + +
11	TUESDAY
12	SEPTEMBER 16, 2014
13	+ + + +
14	ROCKVILLE, MARYLAND
15	+ + + +
16	The Subcommittee met at the Nuclear
17	Regulatory Commission, Two White Flint North, Room
18	T2B1, 11545 Rockville Pike, at 8:30 a.m., Charles H.
19	Brown, Jr., Chairman, presiding.
20	
21	
22	
23	
24	
25	

1	COMMITTEE MEMBERS:
2	CHARLES H. BROWN, JR., Chairman
3	DENNIS C. BLEY, Member
4	RONALD G. BALLINGER, Member
5	JOY REMPE, Member
6	STEPHEN P. SCHULTZ, Member
7	GORDON R. SKILLMAN, Member
8	JOHN W. STETKAR, Member
9	
10	DESIGNATED FEDERAL OFFICIAL:
11	CHRISTINA ANTONESCU
12	
13	STAFF PRESENT:
14	MAITRI BANERJEE
15	MIKE CASE
16	DAVID RAHN
17	RICH STATTEL
18	RUSS SYDNOR
19	
20	
21	
22	
23	
24	

1	
2	T-A-B-L-E O-F C-O-N-T-E-N-T-S
3	<u>PAGE</u>
4	Call to order and opening statement
5	by Chairman Charles Brown4
6	Opening Comments and Overview by Mike Case6
7	Presentation of Tasks
8	by Russ Sydnor10
9	by David Rahn28
LO	Member Comments74
L1	
L2	
L3	
L 4	
L5	
L 6	
L7	
L8	
L9	
20	
21	
22	
23	
24	

P-R-O-C-E-E-D-I-N-G-S

2.1

2 (8:34 a.m.)

CHAIRMAN BROWN: The meeting will now come to order. Please excuse me if I sound a little raspy, I want to make sure everybody enjoys, maybe I can pass on the goodies here.

This is a meeting of the Fukushima Subcommittee, I am Charles Brown, Chairman of this subcommittee meeting. ACRS members in attendance are John Stetkar, Dennis Bley, Joy Rempe, Steve Schultz, Dick Skillman and Harold Ray. Christina Antonescu of the ACRS is the designated federal official for this meeting, however, filling in for her at this time is Mairtri Banerjee.

The purpose of this briefing is to review the staff's planned activities and discuss progress made to date on Reactor and Containment Instrumentation for Severe Accident Monitoring. Specifically the staff is working on the Enhanced Reactor and Containment Instrumentation, NRC Fukushima Tier 3 Item, which is a comment from the Advisory Committee.

The subcommittee will gather information, analyze relevant issues and facts and formulate proposed positions and actions as appropriate for

deliberation by the Full Committee.

2.1

The rules for participation in today's meeting have been announced as part of this notice for the meeting previously published in the Federal Register on September 3rd, 2014. We have received no written comments or requests for time to make oral comments from members, statements from members of the public regarding today's meeting.

Also we have some people on the bridge phone line listening to the discussions. To preclude interruption of the meeting the phone line will be placed on listen in mode during the discussion and presentations and Committee discussions. Also the bridge line will be opened at the end of the meeting to see if anyone listening would like to make any comments. At that time everyone should identify themselves by name during that period if they desire to make comments.

A transcript of the meeting is being kept and will be made available as stated in the Federal Register notice. Therefore, we request that participants in this meeting use the microphones located throughout the meeting room when addressing the Subcommittee. The participants should first identify

themselves and speak with sufficient clarity and volume 1 2 so they may be readily heard. 3 We will now proceed with the meeting. call upon Mr. Mike Case director of the Division of 4 5 Engineering in the Office of Nuclear Regulatory 6 Research to make an opening statement. 7 MEMBER REMPE: Mr. Chairman, before the 8 opening statement occurs --9 CHAIRMAN BROWN: I was about to call --10 Fine, go ahead. Joy Rempe has an announcement that she 11 must make. 12 MEMBER REMPE: I need to announce that I 13 must recuse myself from some of the topics discussed 14 today because of conflict of interest from other 15 activities Ι do. Thank you, sorry for the 16 interruption. 17 MR. CASE: Okay. Great. Thank you. 18 you said, my name is Mike Case. I'm really the, I'm 19 still in the Office of Research but now I'm the Director 20 of the Division of Safety Analysis. So I moved over 2.1 to a different division. I was formerly the Director 22 of the Division of Engineering and that's where I got involved in this particular issue. 2.3 24 So I'm what they call the SES Lead for this

issue. And the issue, as you said, is the Fukushima
Tier 3 Item on enhancing accident instrumentation
during beyond design basis events.

And to tell you the truth it's been somewhat of an interesting assignment in that it's different in that this is not really a staff-generated issue, at least from the staff on our side. The Fukushima Task Force looked at this and didn't identify this as a particular issue. And the ACRS identified this issue in your considerations of the Fukushima event.

And I am really quite impressed with what I call the safety ethic of Russ and his team, because they didn't really make a distinction that this is an ACRS issue or this is a staff issue. They took it on as a safety issue. And so they have been really diligent of moving the issue forward and sort of taking ownership of the issue as a safety issue and saying hey, let's understand this and let's see what we can do in regulatory space.

The approach we were asked to take by the Steering Committee of the Fukushima Task Force was interesting as well in that, you know, unlike maybe other issues, they didn't give us a bundle of FTE and

2.1

a bundle of contract dollars and say go out there team and create this technical basis for this safety issue.

What they asked us to do was to really go out and to work with others to pull together information that would support a technical basis for this issue. And so, once again, Russ and his team I think really did an admirable job.

So we're in the process of pulling that technical information together and so what they've gone out and did, they've gone both domestically and internationally to pull together information on this issue. So they've been out with IAEA, NEA, Department of Energy, DOE, they've been out with EPRI. They've been working with the Tier 1 activities that are related to this. And they've been working with the standard development organizations.

So what you'll hear today is really a status update. So they'll be telling you about the various progress they have made with those particular endeavors.

And since the purpose of the meeting is a status update I don't think we need any formal feedback from the Committee so, you know, you don't have to write a letter or anything. This is more informal so

2.1

obviously we're interested in your feedback on the particular issues.

So as they go through the status if you have insights we of course want to hear those. Probably for me the larger issue right now is how do all these pieces fit together to get to a regulatory resolution of this issue. And quite frankly we haven't got to that point yet. So we're still collecting information.

But I thought I'd share a little bit of, at least, my overarching thoughts. And so, as I said before, we really haven't reached this point but we want to get to this point.

Quite frankly, you know, when I look at this issue and sort of the information that I have to date I don't see this resulting in a new requirement in this area, driven a lot by, you know, in order to get like to a rule or some sort of a durable requirement like that you would have to pass backfit tests so when you look at this it's very difficult to see how this, you know, how what we're finding will result in a significant safety improvement.

So I'm not thinking that it's going to result in a new regulatory requirement but it may. I think this issue will have a lot of positive impact on

2.1

the Tier 1 issues because it sort of has driven us to 1 2 ask a lot of those, in those Tier 1 environment, a lot 3 of good questions of how they're resolving some of these instrumentation related issues. 4 5 And then I think there's good the standards development 6 potential in and the 7 regulatory guide area that we can use some of the 8 information that we've developed to sort of at least 9 set out a future staff position on some of these issues. 10 And so, once again, after you hear the 11 status updates it might be valuable to us as a team to 12 maybe listen to your insights as to how do you all see 13 the pieces fitting together, because that will help us 14 focus some of our remaining activities. 15 And SO that's all Τ have for an 16 introduction. Once again, thanks, it's always great 17 to be here. And I think I'll turn it over Dave or to 18 Russ? 19 MALE PARTICIPANT: To Russ. 20 MR. SYDNOR: I'll start out. 2.1 MR. CASE: If you will start us out. 22 The first thing I'll do is MR. SYDNOR: just describe what we told the Commission and the 23 24 Steering Committee we were going to do for this, and we also told that to the ACRS too.

2.1

I'm going to reiterate something Mike said about this is primarily a status report. We've been working this a couple of years so we have some preliminary opinions but we're not going to necessarily share those today because we don't have all our technical basis to back those up yet. But we're in the process of deriving that.

We are interested in, or going to try to,
Dave and I will try to explain all the various things
we've been doing and what we've been looking at. And
it's, you know, it's from an international perspective,
it's quite extensive how much information is out there
in this area. And how much interest there is in this
area.

But we're interested in feedback from the Committee today if you think we're missing something. You know, if there's something else that you think we ought to be looking at. So just to go --

CHAIRMAN BROWN: Excuse me, when you say there's interest, after looking at the plethora of, you know, meetings and things you all have attended and the joint discussions, et cetera, and you just made a conclusion relative to what you saw that there was a

lot of interest. But what does that mean?

2.1

Are they going down a path to actually do something? Are they identifying parameters how they would do it? And you're all just kind of back here looking at what they're doing? I mean, what is the -
MR. SYDNOR: There's some of all of that I think in what you'll see. I think that will come out in the discussion but in general you'll see a lot of different entities, U.S. entities, national entities, that are looking at the same issues. Some perhaps more

And so we're looking at that and trying to discern why. What are the strategies or what are the assumptions that are driving some of those differences.

thoroughly than others.

CHAIRMAN BROWN: Okay, let me phrase it a little -- Mike made the comment that he didn't really see this leading to any particular efforts, either a new rule or a change in rules or regulation, or whatever you want to call it, in terms of what utilities or power providers might be required to implement. He didn't see that coming based on the comments he just made.

Is that perception shared in these other entities that you all talked to in the international community? Are they thinking that yes we really ought

to have something and you all are kind of on a different 1 2 path? 3 MR. RAHN: I can answer that a little bit because I've been participating in a lot of the 4 international work. Almost all of the work that we've 5 6 seen done so far is in the form of guidance, not 7 So they're leaning towards development requirements. 8 of how to develop a good monitoring system. Or how to 9 identify the requirements that go into specifying a 10 appropriate set of information needed by the operators 11 to manage severe accidents. 12 We haven't seen a lot in the way of 13 rulemaking. We haven't seen a lot in the way of finished standards yet either. 14 15 CHAIRMAN BROWN: So they may develop some quidance and/or standards, but yet there would be no, 16 17 they would be just be pieces of paper laying out there 18 on the table that if some of their providers wanted to 19 do that or felt it was important enough that they could 20 go use those but there would be no execution directed 2.1 by the --22 The regulatory agencies. MR. RAHN: 23 CHAIRMAN BROWN: the regulatory 24 agencies.

And I'd say that first you have 1 MR. RAHN: 2 to have something out there to endorse and then once 3 it's out there and has been, you know, absorbed by the industry and by the regulatory agencies in other 4 5 countries, that that's the point at which they would 6 identify it's something that must be done. But first 7 I think they have to be led toward what it is first. MR. CASE: You know, I think that's a great 8 9 question. You know, like IEEE. IEEE has a standard 10 on accident instrumentation so they're looking at the 11 experience at Fukushima and saying hey what changes do 12 I need to make to my standards. 13 I've got to look at that from a regulatory 14 perspective. You know, once they make their changes 15 need to understand are any of those changes 16 significant enough to pass a regulatory test. 17 And so I, you know, right now maybe I'm not 18 seeing that but once again they're not done yet. 19 people are looking at it sort of from their perspective 20 and they're looking at it from a safety perspective, 2.1 which is great. 22 And so what we're really searching for is are any of those changes changes that will trip a 23

So that's

sort

regulatory threshold.

24

of

1	difference in perspective.
2	CHAIRMAN BROWN: David, go ahead.
3	MEMBER SCHULTZ: David?
4	MR. RAHN: Yes.
5	MEMBER SCHULTZ: At the same time you're
6	going to be discussing today, and it's been mentioned
7	already, that there is a connection to Tier 1 activities
8	here and you're not only working with or toward those
9	activities but are really following them closely.
10	MR. RAHN: Yes.
11	MEMBER SCHULTZ: And providing input to
12	them.
13	MR. RAHN: Correct.
13 14	MR. RAHN: Correct. MEMBER SCHULTZ: And those activities are
14	MEMBER SCHULTZ: And those activities are
14 15	MEMBER SCHULTZ: And those activities are moving directly to rulemaking?
14 15 16	MEMBER SCHULTZ: And those activities are moving directly to rulemaking? MR. RAHN: Yes. We're participating in
14 15 16 17	MEMBER SCHULTZ: And those activities are moving directly to rulemaking? MR. RAHN: Yes. We're participating in rulemaking activities.
14 15 16 17	MEMBER SCHULTZ: And those activities are moving directly to rulemaking? MR. RAHN: Yes. We're participating in rulemaking activities. MEMBER SCHULTZ: And so in some
14 15 16 17 18	MEMBER SCHULTZ: And those activities are moving directly to rulemaking? MR. RAHN: Yes. We're participating in rulemaking activities. MEMBER SCHULTZ: And so in some complimentary fashion could there not be either an
14 15 16 17 18 19	MEMBER SCHULTZ: And those activities are moving directly to rulemaking? MR. RAHN: Yes. We're participating in rulemaking activities. MEMBER SCHULTZ: And so in some complimentary fashion could there not be either an opportunity or a need to apply requirements related to
14 15 16 17 18 19 20 21	MEMBER SCHULTZ: And those activities are moving directly to rulemaking? MR. RAHN: Yes. We're participating in rulemaking activities. MEMBER SCHULTZ: And so in some complimentary fashion could there not be either an opportunity or a need to apply requirements related to instrumentation moving forward?

1 MEMBER SCHULTZ: Okay. Thank you. 2 MEMBER STETKAR: You mentioned, you know, 3 people that you've discussed things with, which is a broad term, and interests, which is a pretty broad term, 4 5 and quidance, which is a pretty broad term. Thumbing 6 through your slides here I see that you've had meetings 7 with OECD, NEA, MDEP, IAEA. Those folks don't 8 promulgate any regulations, they only, if at all, 9 promulgate general guidance and recommendations. 10 Standards groups promulgate standards. 11 Regulators promulgate regulations. Have you had any 12 discussions with organizations like WENRA to see what 13 the regulators in Europe are actually planning? 14 MR. RAHN: In the Committee, for IAEA for 15 example, adopted some language from WENRA we 16 categorizations. You know, so in that sense we are 17 using information from WENRA but we haven't had direct 18 contact. 19 MEMBER STETKAR: Okay. What I'm probing 20 is to see, you know, I think Charlie was trying to probe 2.1 feet on the ground in terms of individual country 22 regulators both in Europe and in Asia perhaps. So like 23 what they're planning. 24 MR. RAHN: I suspect that eventually the

Japanese will have something along these lines. 1 2 MEMBER REMPE: That was a question I 3 wanted to ask you of the various countries, are you seeing that the Japanese regulators are a bit more 4 5 aggressive about it these than we are --6 MR. RAHN: Yes. We have seen that the 7 Japanese are more aggressive. Yes. 8 MEMBER BLEY: We have a couple of slides 9 that touch on their R&D plan for this area, which is 10 the most extensive work that we've found in this 11 particular --12 MEMBER STETKAR: From the Japanese? 13 MR. SYDNOR: Yes. 14 MEMBER BLEY: All right. I have 15 different direction I'd like to ask about. When you 16 read the testimony of the guys in the plant and their 17 frustration at how the instruments worked, it kind of 18 Especially if you have ever operated a moves you. 19 plant. Have you had any interactions with INPO, WANO 20 or any other operator-linked organizations to hear what 2.1 they're thinking and if anything's coming this way? 22 Under our MOU with EPRI we MR. SYDNOR: interface, I'll talk about that on one of our slides, 23 24 and the initiative they're doing. And some of the

1	members of that working group are the leads for the
2	owner's groups that are writing the SAMGs. And we've
3	had some detailed discussions of instrumentation
4	issues.
5	My opinion is industry appreciates this
6	issue, now how far they're, you know, willing to go with
7	the issue obviously the industry doesn't necessarily
8	consider regulation as a necessary step in this regard.
9	But they are interested in the technical
10	aspects of the issue that the strategies they put in
11	place are tested and I will talk about, there's some
12	new work that they're doing with simulators and
13	simulating severe accident conditions that I wanted to
14	mention during this presentation. But the EPRI
15	project is probably our closest link with the industry.
16	(Simultaneous speaking.)
17	MEMBER BLEY: So you haven't had any
18	interactions with INPO or WANO?
19	MR. SYDNOR: Not INPO or WANO.
20	MEMBER STETKAR: So you don't know what
21	the operators would really like to have in these
22	situations?
23	MR. CASE: Well, we do. Dave and Russ do,
24	they used to be operators.

The issue that we see is that 1 MR. RAHN: 2 the operator needs to have as much reliable information 3 as he can to execute the planned mitigating strategies for all types of events. And so the more reliable set 4 of instrumentation he has the better, obviously. 5 6 So the issue is that -- The closest we've 7 gotten to is when we kicked off the IAEA consultency meetings in Japan, they brought in a few folks from 8 TEPCO to help inform us as to what the operators were 9 10 dealing with. They actually I&C folks. 11 But some of those folks were actually at 12 the plant during the event and had to deal with some 13 of the problems they had with the loss of power and loss of available instrumentation. So we did get to talk 14 to those folks. But I can understand the frustration 15 16 that the operators must have felt. 17 probably MEMBER STETKAR: Ι 18 understand the frustration that they must have felt. 19 MEMBER BLEY: Yes. Folks writing procedures sometimes and folks laying out requirements 20 2.1 sometimes really don't focus on the instrumentation and 22 what really will people be able to do at the times they're planning for them to do them. And I'm hoping 23

there's more effort on that now, more focus on that.

But go ahead, you're probably going to cover all these topics anyway.

MR. SYDNOR: Yes, I think every question would have come up in later slides anyway. I just want to briefly go over what we told the Commission, what we told ACRS that we were going to do for this activity, the Tier 3 activity. There are three major tasks.

The first one really started several years ago and was working with the other Tier 1 teams. We had meetings, we communicated with them. Reviewed orders, what they were doing, what they were proposing. Tried to influence them to ask questions when they were dealing with the industry about instrumentation needs and uses.

And so most of that task is done, although in a later slide there's still some that's ongoing because the rulemaking is still ongoing.

And Task 2 was really probably the broader area that we didn't realize how broad it was going to be when we proposed it, because we didn't know the scope and breadth of efforts that were going to be undertaken worldwide on this specific to this issue. And so this was to review previous and ongoing research efforts and other coordinate with international and domestic

2.1

entities and standards organizations.

2.1

And so we thought we could make some inroads there and I think, you know, we have a good story to tell in that area.

And, finally, Task 3 was to, once most of Tier 1 activities were done was evaluate what had been done in this area and use this as part of our GAP analysis. We would gather information from Task 2, compare to what had been done in Task 1, or not done, through some type of GAP analysis.

We have started some work on that this year. And we'll talk about it briefly, we don't have our final results or come to conclusions yet but we're making some headway on that.

CHAIRMAN BROWN: Before you go on, back up a second. On the Task 1, I'm just going to take this as an example. When you say ensure that licensees and NRC staff appropriately considering instrumentation needs when implementing site-specific actions for Tier 1.

And then you look at Task 2, which talks about information available for severe accident management analyses and stuff like that. In looking through the various documents and paperwork and stuff

like that it was difficult to see where there was a focus on, as opposed to process, where there was a focus on more specific things.

For instance, instrumentation needs have to define what are the parameters you need. What's the range of the parameters you need? What was the experience we had at Fukushima of the instrumentation they had and what were their qualifications? And none of that information was in any of the, at least in the half a dozen documents that I looked at.

And it seems if you're going to provide input to the Tier 1 activities in terms of severe accident management instrumentation that you have to address more than what's the realm of research that's going on in the world in terms of stuff and what are the specifics that should be addressed. So that seemed to be a missing part of this overall project.

Didn't have any real big problem with trying to find out information. That was, you know, obviously you want to try to get as much information as to what's available and what people know. But you also have to identify what you want to know and about those specific parameters and stuff that you're going to need.

2.1

1	And it was a question I raised a little bit
2	earlier, I asked the question in one of your earlier
3	meetings, I mean if you're going to manage, we've got
4	all these SAMGs and severe accident management stuff
5	which is supposed to enable us to deal with these
6	circumstances of the beyond design basis type functions
7	or situations.
8	But if we don't have information from the
9	plant to tell us how to use those what good are they,
10	if you don't know what to address?
11	And so it just seemed to me some of this
12	stuff was missing. If I've got the wrong picture and
13	there's really something in there I'm
14	MR. RAHN: Yes, you really have to get to
15	the specific guidance documents that are being
16	developed right now. So for example the
17	CHAIRMAN BROWN: That from the IEEE
18	standard was it 497?
19	MR. RAHN: 497, yes.
20	CHAIRMAN BROWN: Seemed to not really have
21	a lot of detail in it. I mean there was a little
22	PowerPoint presentation written on it.
23	MR. RAHN: Yes, the IEEE standard
24	CHAIRMAN BROWN: Is sparse.

Well in the area of a severe 1 MR. RAHN: 2 accident -- Actually the purpose of the IEEE standard 3 isn't to specify what those ranges are. You know, there's been a evolution in the IEEE standard that has 4 5 gone away from the approach that was taken in Reg Guide 6 1.97 Rev 2, which where the staff specified the ranges. 7 You know, so those ranges and the ambient environmental conditions and so forth do need to be 8 9 specified before you can identify the right 10 requirements for designing а severe accident 11 monitoring instrumentation program. 12 However, a lot of the guidance documents 13 that are currently being developed require that to be So even though the staff itself is not doing that 14 15 the guidance documents specify a methodology by which 16 you would get that information. And then it would be 17 up to the people who implement the system to follow that 18 quidance. 19 CHAIRMAN BROWN: Okay. Go on. 20 MR. SYDNOR: As part of our Task 2.1 evaluation that we've done we are putting together much 22 more detailed information. From all these documents 23 we've found were extracting instrumentation

requirements that these various entities have proposed

or analyzed the need for. And so we are taking those 1 and building kind of a matrix of instrumentation that 2 3 we're analyzing and trying to understand differences. Trying to understand gaps. 4 5 Some of that's driven by what accident 6 mitigation strategy you propose. And there are 7 differences between different countries and different pieces of the puzzle, whether you're talking SAMGs or 8 9 you're talking FLEX equipment, there's whether 10 different strategies. Some of that we'll talk about 11 briefly when we get to the later slide. 12 But we are, I think when we're done we're 13 going to have much more detail. It's in there, you have 14 to dig it out. 15 CHAIRMAN BROWN: Okay. You can tell I'm 16 struggling. 17 It's a status report, not --MR. SYDNOR: 18 CHAIRMAN BROWN: I come from the make it 19 and break it school of thought where you take a direct experience that we had, which is probably the most 20 2.1 experience, setting aside the Russian severe 22 Chernobyl, experience where have а lot of we 23 information relative to the actual conditions, both 24 radiation temperatures and pressures. The ability to

know whether you had water levels in certain places, et cetera, et cetera, for the BWR standpoint.

And yet that all just seems to be lying

fallow, it's all just spread around the ground and

laying there, it's just not being utilized to develop

6 at least a go forward thought process of where do we

think we about where we should be.

1

2

3

4

5

7

8

9

10

11

12

13

14

15

16

17

18

19

20

2.1

22

23

24

And you can always do more to confirm some of that but that was a pretty severe downstream, you know, long-term effect type event. And instead we have a ten-year process maybe to get to some idea of what we may do post ten years from now, which is like an eternity.

So it's just a little difficult for me to see where we're going to end up with anything in what I would call, and I don't mean tomorrow or the next year, but within a reasonable timeframe in terms of giving people -- Even if we only make it guidance as to what they should be considering for their plants.

So that gives you a little flavor of what I'm, it probably sounds like the earlier discussions we had in the previous meetings. So, okay, you can -
MR. SYDNOR: Okay. Under Task 1 I had

mentioned some of the stuff we had done earlier, one

to two years ago. We're still communicating with Tier 1 teams, primarily the new consolidated Rulemaking Team.

In addition we have, Dave's actually on one of those teams and I have another member on my staff who's from a station blackout standpoint, is on that rulemaking team also.

We've reviewed the Tier 1 activities, I already mentioned that. We've reviewed the guidance documents that were put out. Dave was, and a number of people in his organization and some in mine, supported the spent fuel order. And so that gave us a lot of direct experience in dealing with the industry and with licensing of the order and the guidance and development there.

And some of that got into qualification of the new equipment that we were, new level indicators we were requiring to be installed under that order.

And so we can apply some of that experience to what we're doing here.

And in the last bullet I think I mentioned a couple of times, Dave is on the consolidated rulemaking team and we are lobbying them, and it remains to be seen how successful that is. Or, you know, if

2.1

1	it, as Mike was saying, whether it can pass the backfit
2	requirements.
3	I'm going to let Dave talk about what he's
4	been doing. We have a number of slides on
5	international activities because there's really quite
6	a bit going on there.
7	This one is one where we think there's been
8	a lot gained out of this activity and this slide and
9	a later slide will talk about that in relation to how
10	we believe we can take what we learned from this and
11	roll it into hard regulatory guidance.
12	MR. RAHN: So the IAEA
13	MEMBER RAY: Excuse me. I've been
14	thinking about something you just said and it took me
15	a second to decide whether I needed to ask a question
16	and I do.
17	You're talking about backfit requirements
18	for beyond design basis accident mitigation, is that
19	what we're talking about? That's what I heard you say.
20	MR. RAHN: I think it's more for severe
21	accident management, severe accident monitoring
22	capabilities in
23	MEMBER RAY: And we have a way to apply
24	backfit rules to that?

1 MR. RAHN: Yes.

2.1

MEMBER RAY: Okay.

MR. RAHN: So the IAEA effort was to develop a technical document that's going to be used. Initially its purpose was to help new agencies, new regulators and new member countries to identify a path for identifying the appropriate set of information that could used by the operators for a range, a broad range, of postulated events, starting with anticipated operational occurrences, going through transients and design basis events. And then into what they call design extension conditions, some of which include fuel damage. Some do not, some do.

And over that broad range the IAEA Team had set up a committee that was made up of members of accident management strategy folks as well as instrumentation design folks. And together they identified a path toward determining the appropriate set of instrumentation that operators would refer to while dealing with the broad range of events that could occur.

In the area of severe accident monitoring they specifically identified the need for back up power for those instruments. And the approach they took is

that that backup power and the categorization of severe 1 2 accident instruments should be treated special, different from the design basis event equipment. 3 So it would have an independent power 4 supply from the design basis event equipment and as well 5 6 have better qualification from a ability to withstand 7 harsh environments. So the guidance was put into that document 8 leads one toward specifying that range 9 that 10 parameters that would be needed to be monitored. Ιt 11 didn't have the numbers in there but it talks about, 12 in qualitative terms, the range that would be needed. 13 And then there's also guidance put in there 14 as for how to determine that, through modeling or 15 through evaluation of other events that have occurred. So the kind of documentation that should 16 17 be sought after by someone who's designing a new accident monitoring system would involve evaluating 18 19 things like you were mentioning from the accident 20 monitoring information that was available in Fukushima 2.1 and from TMI and other types of events. 22 So a lot of folks have interest in the Fukushima data that INL is maintaining. 23 And there's 24 been a lot of interest in qualifying and quantifying

1	the parameters needed to determine the range
2	requirements for those instruments and the
3	survivability for those instruments.
4	MEMBER STETKAR: Okay, what is the
5	timeline on the publication of that tech doc?
6	MR. RAHN: Well, yes, as soon as this
7	document is published, which it's to be published
8	within a month or so.
9	MEMBER STETKAR: Oh, okay. So it's
10	close.
11	MR. RAHN: It's been in the publishing
12	mode for a long time.
13	MEMBER STETKAR: It's in published
14	locations over there?
15	MR. RAHN: It's in that stage, right.
16	CHAIRMAN BROWN: That's the first line up
17	there? That's the "Accident Monitoring Systems for
18	Nuclear" this next one at the bottom is a separate
19	document, right?
20	MR. RAHN: Yes, a new one. Yes, that's a
21	new document that just got started, actually the first
22	meeting is going on right now as we speak. They met
23	yesterday and they're going to meet all this week. And
24	they're talking about methods for identifying a better

way of qualifying equipment that must survive in order 1 2 to provide the information to the operators. 3 That is being more focused toward equipment qualification. But my personal opinion is 4 5 I think in order to solve this issue it's going to take 6 combination of qualifying equipment and maybe 7 thinking outside the boxes how something should be 8 monitored. 9 But I think the approaches that they're 10 taking is as a follow-on to the first document that I 11 pointed out that survivability analyses need to be 12 performed. MEMBER SCHULTZ: 13 That first document --Wait a minute, let me try here 14 MEMBER RAY: 15 for a second. Let me ask my colleagues a question 16 because I'm missing something here. 17 We're talking about establishing specific 18 this instrumentation. requirements for Those 19 requirements effect, ultimately, what the cost will be 20 of the systems we're talking about. After we've done 2.1 that then we apply cost benefit, I mean, a backfit rule 22 to determine whether to impose those requirements, is that the way it works? 2.3 24 Well I'm just, I thought maybe you guys

1	could talk about it and I wouldn't be badgering them
2	with a stupid question. But I don't understand how it
3	works to apply the, to do what you describe, which I
4	understand I believe. And then say well now we're done
5	but it won't pass the backfit test.
6	Well, what would happen if we went back and
7	did it over again and came up with something different,
8	might that pass the back How did you iterate between
9	that ultimate hurdle which the Chairman has talked
10	about recently, the Commission Chairman, and what
11	you're doing now to decide what is the right thing to
12	include in these guidance documents that you're talking
13	about? End of question.
14	MR. CASE: Is that to the Committee or to
15	us?
16	MEMBER RAY: That's to you now, because
17	they're
18	(Simultaneous speaking.)
19	MEMBER RAY: They don't seem to want to
20	answer, so maybe you can answer.
21	CHAIRMAN BROWN: I'll let them answer and
22	then I was going to make some comment relative, but I'm
23	not sure what their answer
24	MEMBER RAY: Wait. Let's get an answer

1 and then we can comment on how things --2 MR. SYDNOR: And vou've had some 3 discussions on this with the rulemaking team I'm sure? MR. RAHN: Yes I have. So first of all you 4 5 can't put something in a rule that's a requirement to 6 put something in that doesn't exist. You know, does 7 not have a commercial available and readily means to 8 be installed in a nuclear plant. 9 So, you know, what has to happen is that 10 research has to be performed and tests have to be 11 performed and suitability and survivability has to be 12 identified. And then you might find a specification 13 for equipment that will last. 14 But until that's done, you know, you can't 15 require something to be installed that doesn't exist 16 today. 17 Well, I mean, that's obvious. MEMBER RAY: 18 My real question, and I didn't make it very clear I 19 quess, is how do you iterate. Supposing we come up with a very neat, great system that will do everything we 20 2.1 want it to but it's too damn expensive. Does that mean 22 we do nothing? Under the backfit rule. 23 RAHN: Okay. I'll give you 24 In post-TMI timeframe there was several example.

items that were identified as part of 50.34. 1 They were 2 generic issues, generic safety issues, that all had 3 Roman numerals and numbers associated with them. And one of those items was Roman II.f.2 and 4 5 II.f.3. Those were requirements that were -- they 6 weren't requirements, they were generic safety issues 7 that were considered as potential for rules to install 8 instrumentation to monitor a core with significant core 9 damage. Okay? 10 So a generic safety issue was vetted by our 11 CRGR and the CRGR determined that there wasn't a 12 significant safety benefit enough to make 13 requirement because of its expense. 14 However, they determined that a set of nine 15 plants which were on hold, they had licenses on hold 16 for post-TMI, they should be required to install that 17 And these were plants for which there was 18 a construction permit on hold for TMI. 19 Now it turns out that none of those nine 20 plants ever got built. So it appears there's a 50.34.f 2.1 requirement for nine plants to put something in to 22 monitor for severe accidents but those nine plants 2.3 never got built. 24 However, in Part 52 they adopted and make

a reference to that clause such that new plants, such 1 2 as Summer and Vogtle, have to identify at least a 3 survivability analysis associated with the instruments that would be used by operators to manage severe 4 5 accidents. 6 So they have a section in there in Chapter 7 19 that requires them to perform a survivability 8 analysis of that instrumentation. So --9 MEMBER RAY: Well I think we should move 10 I appreciate the example you cited. I just, you on. 11 know, you brought up the issue of backfit and I was 12 trying to figure out how on earth that gets factored 13 into what you're describing you're doing. And I guess it doesn't. But once you're done with what you're 14 15 doing then any backfit consideration would apply to the 16 result. 17 Yes, we would have to make a MR. SYDNOR: 18 decision that we're recommending rulemaking and then 19 that undergo backfit would а analysis. 20 Simplistically, I mean we wouldn't be doing a backfit 2.1 analysis at this point. 22 MEMBER RAY: I understand. But on the other hand you're establishing requirements, or what 23

could become requirements, which would affect the

1	ability to impose it under the backfit rule. And, like
2	I say, I was sensitive to that because of the remarks
3	that Chairman just made. And so that's why I'm trying
4	to understand how you consider that because you
5	mentioned it, not me.
6	MEMBER BLEY: Harold, can I try to
7	rephrase your whole line of discussion?
8	MEMBER RAY: Yes, yes, go ahead. I'm
9	done.
10	MEMBER BLEY: Well I think what Harold was
11	getting at was, you lay out requirements, you take a
12	look and you say oh it doesn't meet the backfit analysis
13	but it's close. Can we modify the design a little bit
14	so that in fact the cost is in line and it would meet
15	the backfit requirements to get the safety gains that
16	we think would accrue from this?
17	And is there a process like that or is there
18	proposal, here it is. Doesn't meet it, we're done. Or
19	do you go through some iterative process to try to drive
20	the design to something that will accomplish your goals
21	and still be cost effective?
22	MEMBER SCHULTZ: Or the better question,
23	why don't you go through a process that would identify
24	a practical solution?

1	MR. CASE: Okay, well, here's my take on
2	that question. There's really two parts to the backfit
3	rule. First, I have to understand that it's a
4	significant safety improvement. That is the highest
5	hurdle to get through first. You know, then you can
6	assess the cost-benefit activity.
7	So the reason that I never get into this
8	iterative thing on the cost benefit is a lot of times
9	it will not pass a significant safety improvement.
10	So when I'm working in the beyond design
11	basis realm, you know, in order to get a quantified
12	significant safety improvement that is very, very, very
13	
14	MEMBER BLEY: Because the likelihood of the
15	core damage we're going to start with is so occasional.
16	MEMBER STETKAR: Because they use change
17	in core damage frequency and we're talking about things
18	after that. I mean the metric that is used is
19	ridiculous for these decisions. It's ridiculous.
20	And it's inappropriate.
21	MR. CASE: Correct.
22	MEMBER RAY: But that is what I had in mind
23	in sending the question your direction, was how the heck
24	do they do this

1	MEMBER STETKAR: They can't. Using the
2	current values.
3	MR. CASE: Well you can't do it
4	quantitatively. And so that's where the famous
5	qualitative factors come in. And so that's a big,
6	that's a heavy lift for the Agency to say hey I'm just
7	going to make up a bunch of qualitative factors and say
8	okay, that's a significant safety improvement.
9	MEMBER RAY: Okay, but I did think that's
10	what we were talking about here was something that was
11	in that domain, ultimately.
12	MR. CASE: It is.
13	MEMBER RAY: When you're talking about
14	MR. CASE: It's a hard domain to work with.
15	It's a hard domain to make new requirements.
16	MEMBER BALLINGER: Isn't there another
17	way, shouldn't it be the reverse? To establish a de
18	minimis set of instrumentation which is absolutely
19	required in order for the operator to make an assessment
20	of what's going on in the core. Period. Then where
21	do we go from there.
22	MR. CASE: Right, well we have that now in
23	the regulations.
24	MEMBER REMPE: But that's for design

1 basis. 2 MEMBER STETKAR: No, that's for No. 3 design basis. That's design basis. Go beyond that. Talk to the operators at Fukushima and ask them what 4 5 they would have really liked to have once they knew it 6 was a really bad day in the power plant. 7 Talk to the operators, the ones that 8 survived, at Chernobyl and ask them what they would 9 really liked to have had to let them know that it was 10 a really bad day at the power plant. 11 Don't start with what's required for the 12 design basis to prevent core damage. We're already 13 past that. It's irrelevant. What's in the 14 regulations to prevent core damage is irrelevant. 15 MEMBER SCHULTZ: If we try to approach 16 this with qualitative factors I don't think we'll ever 17 get to where we want to be. 18 When you're up to your MEMBER BALLINGER: 19 waist in seawater if you really want to know what's 20 going on that's the question to ask. What do I really 2.1 need to see? 22 MEMBER RAY: But, again, as I think John

said and as I felt before, when we're talking about the

domain we're talking about now, I don't know how to

23

1 apply backfit to that. Because presumably we meet the 2 hurdle that you're talking about in qualitative space. 3 This is something we're going to do because we want to have some capability in the beyond design 4 5 Not that we're going to subject that basis arena. 6 capability to the backfit rule. 7 Okay, I'll share MR. CASE: all my 8 I think the most critical part for our insights. 9 effort is really the Tier 1 activities. We should be 10 asking these, you know, I knew this since day one, we 11 ought to be asking these instrumentation questions in 12 the context of the Tier 1 issues. Because the Tier 1 13 issues are close enough to passing this significant 14 safety improvement. 15 So the things that, you know, when you talk 16 about Fukushima a lot of it was driven by the lack of 17 So we need to ask that question about 18 instrumentation specifically in the context of that 19 rule. And that's --20 MEMBER STETKAR: Mike, that's one issue. 2.1 But you could have 1,000 fully qualified power supplies 22 for something that fundamentally won't work. And it won't help the operators. So power is certainly a 23

source but having the instrumentation that indeed will

work in the environments that they were exposed to is a different issue.

could that Because you power instrumentation but if indeed it's not qualified for the temperatures, humidity, radiation fields, you could have an infinite amount of power but if the instrumentation is reliable not under those conditions, I mean, it might even be worse for the could operators because they be misled bу instrumentation that's providing faulty output.

So theoretically a lot of the Tier 1 issues will solve the power supply issue.

MR. CASE: Right, and the Tier 3 issue is for us to understand whether they fundamentally won't work. And so that's what I'm looking for. I'm looking, in all these studies, I'm looking for somebody to come up with the insight that hey we looked at this and it fundamentally won't work. Once I get, you know, once somebody puts their finger on that issue I've got something to work with. But right now I haven't seen that yet.

MEMBER SCHULTZ: Well that's why I asked the nexus between what's going on here in the Tier 1, because that's the way you need to develop that

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

2.1

22

23

integration. Not just a portion of it with regard to 1 2 the power supply issue, but to really put 3 instrumentation expectations in front in order to solve the problem or address the problem. 4 5 Dave, you mentioned Part 52 and 6 expectations associated with severe accident, at least 7 evaluations, that is now there as a result of TMI and 8 other things going forward. My question brings back 9 to the IAEA tech doc and I presume that NRC had a role 10 11 MR. RAHN: Yes. MEMBER SCHULTZ: -- associated with that 12 13 preparation. My question is, you know, you described 14 this as if it was bringing new processes and information 15 to the fore. I'm trying to understand how that, or in 16 what form that's being brought to table different from 17 what we already know? 18 MR. RAHN: Yes, I would say that --19 MEMBER SCHULTZ: I mean, you described 20 this as working to do, seems to me to be elements of 2.1 the problem direction that we have had dramatic 22 experience with and already know how to do this. 23 MR. RAHN: At TMI, right. 24 MEMBER SCHULTZ: Well not just TMI, but

all of the 32 that have come since. So I'm trying to 1 2 understand, I mean, we're not waiting for this. I mean 3 everything that I think is in that document NRC is quite familiar with and ought to be integrating already. 4 MR. RAHN: Right. But I wouldn't say it's 5 6 ever been captured in one document before. 7 MEMBER SCHULTZ: Okay. So that its 8 value. 9 MEMBER REMPE: So my impression of what's 10 in that IAEA document is, one of the things that's in 11 there, is that they're emphasizing plant-specific 12 evaluations. And I believe it's for a range, not just 13 one accident, of risk important events, which is 14 similar to what NRC and industry in the U.S., back in 15 the 90s perhaps, the SA-Keisou information emphasizes 16 one event, Diichi. And I'd like to hear your thoughts 17 on that and its impact. 18 Plus then talk a little bit more about 52 19 and what has been done with Summer and Vogtle. Are they 20 looking at a large number of risk important events based 2.1 on their PRAs from Westinghouse? What, you know, and 22 identified in what what exactly was types of conditions? 23

MR. RAHN: Well, so I'm not the expert in

Part 52, but I have read their proposed Chapter 19 1 And I'll tell you what, it's not as 2 information. 3 detailed as I would have liked. But it does require that the equipment be capable of beyond design basis 4 5 event type, not just design basis but extreme external 6 events. 7 MEMBER REMPE: But did they apply MAP for 8 three or four different scenarios and identify what 9 pressures, temperatures, radiation, conditions, et 10 cetera need to be submitted? 11 MR. RAHN: I'm not in the position to 12 answer that question. I don't know the specific list 13 of events that were considered. 14 MEMBER REMPE: Okay. 15 MEMBER STETKAR: Harold, do you know, I'm 16 going to put you on the spot since you asked this 17 I know when we've looked at the design 18 certifications to date, generally the identification 19 of that inventory of instruments is postponed to at 20 least the COL stage if not post-COL because the argument

Do you know, for Vogtle and Summer, did

is it's tied up with the human factors engineering and

the design of the control boards and you can't do all

of that stuff.

2.1

22

2.3

they actually develop a specific list at the COL stage 1 2 or was it punted to post-COL? 3 MEMBER RAY: I'll punt it to Charlie because he at the course. 4 5 (Simultaneous speaking.) 6 CHAIRMAN BROWN: I don't remember any 7 specifics at all in those discussions. I know it's been somewhat 8 MEMBER STETKAR: 9 frustrating, I think for the staff also, that they've 10 asked for these lists of key instrumentation for severe 11 accidents and, at least at the design certification 12 stage, it's generally been pushed forward with the 13 argument that well we can't specify the list of 14 instruments because it's tied up with human factors 15 engineering and I&C and all of the things that tend to 16 get pushed. 17 MEMBER RAY: Well we also need to remember 18 that those certifications were amendments of a prior 19 certification --20 MEMBER STETKAR: That's right. 2.1 eventually things come together at COL. You know, 22 they're building Vogtle and Summer and some of this line of questioning is do we know what the list of 23 24 instrumentations they have settled on. Do they have

1	a list? And how do we have assurance that they meet
2	the qualification requirements that you specified in
3	Chapter 19 of the design certification, which are, you
4	know, fairly broad requirements. But they're at least
5	requirements.
6	MR. SYDNOR: We looked at Chapter 19
7	design certs and COLs and it was not detailed. It
8	proposed a survivability analysis and gave an example
9	of one, as I recall it.
10	MEMBER STETKAR: Right.
11	MR. SYDNOR: It also had a list of, I'll
12	call it, my words, preliminary list of instrumentation.
13	I wouldn't call it a final. And when I asked questions
14	about that of the people in NRO it was an expectation
15	that the detailed engineering would execute all of
16	those requirements and they would develop that list.
17	They would do the survivability analysis.
18	MEMBER STETKAR: But I think that has
19	tended, at least to date I think in practice, to be a
20	post-COL activity.
21	MR. SYDNOR: I would agree with that.
22	MEMBER STETKAR: In theory it should be
23	ongoing I guess for Vogtle and Summer right now.
24	MR. SYDNOR: Or in new reactors, but going

back a year a half we looked at that. It was one of 1 2 the first things we looked at. Do we have anything else to 3 MR. SYDNOR: 4 say about the --5 No, let's move on. MR. RAHN: 6 addition we're looking at this interesting document 7 that was also put together by a team of folks that consisted of operators and I&C folks to put together 8 9 the task group on accident management of NEA. And it's 10 called Accident and Management Insights After the 11 Fukushima Daiichi Event. 12 And so this document was kind of developed 13 in parallel with the IAEA document with different But recommendations that came out of that 14 15 definitely identified that equipment and 16 instrumentation needed for handling severe accidents 17 need to account for the conditions and the time duration 18 that they need to function within. 19 So that's another independent, 20 independent from IAEA at least. Because I looked at 2.1 the list of the folks that were on both committees, the 22 IAEA Committee and NEA Committee, and there didn't seem to be any overlap so it seems like these were developed 23 24 independently.

In addition there's an MDEP effort 1 2 identify what would be a good set of requirements for, 3 primarily that's the EPR design containment pressure 4 management. And then as well as reliability 5 instrumentation. 6 MR. SYDNOR: We haven't seen the MDEP work 7 Just became aware of it recently. They have yet. 8 draft reports in progress, they hope to publish those. 9 The middle bullet there was one I thought was most 10 interesting to our effort and that they were going to 11 look at reliability and qualification of severe 12 accident instrumentation. 13 Just real quickly on the OECD/NEA report, this is one where, going back to Charlie's question 14 15 earlier. In that report is a listing of severe 16 accident instrumentation. And some of it is general, 17 you know, it's generic so it's not, it's very high level 18 but I feel we can extract that from that and use that 19 as one of our comparisons as part of our GAP analysis. 20 It's going to take some effort to do that 2.1 but it does have some lower level of detail about what 22 needed for accident thev think is severe 2.3 instrumentation.

I'll just talk about our -- The Office of

Research has a Memorandum of Understanding that allows 1 2 us to collaborate with EPRI, the industry's research And EPRI's actually done a lot of work in this 3 4 area. 5 The first two reports there have been done 6 quite awhile, but they were done very quickly after 7 And their main purpose was to support Fukushima. owner's groups severe accident management guideline 8 9 development. So they're like a technical document 10 which is a basis. 11 And they did something similar in the early 12 90s. Some of these are a rework of work that they did 13 in the early 90s, updating it with Fukushima lessons 14 learned. 15 MEMBER BLEY: Russ, related two 16 questions. One harks back to our other discussion 17 earlier. Let me ask them both first before you answer. 18 The first one is, and I don't remember, I 19 don't know if the SAMGs have an identified list of 20 important instruments for implementing the SAMGs. 2.1 know they talk about the parameters you're going to have 22 to look at. It strikes me that if in fact the NRC is 23 24 going to get involved in the SAMGs, and they have a

rulemaking about that, that that's the perfect place 1 2 to put in the other needs for -- If you're going to do 3 them how are you going to do them if you don't have the instruments to allow you to do them? 4 MEMBER SCHULTZ: And the understanding of 5 6 the accidents that you're trying to address. 7 That you're trying to MEMBER BLEY: 8 address. 9 MR. SYDNOR: One thing I wanted to stress 10 with this slide is I think the industry recognizes that. 11 And they funded, the third bullet there, the new EPRI 12 project, which is totally focused on instrumentation 13 control for beyond design basis events and severe 14 accidents. 15 The two bullets underneath that are past 16 work where they did something, some similar work in the 17 early 90s looking at severe accident instrumentation. 18 So right now they're still trying to figure 19 out how much to bite off off with this project. 20 There's, like I mentioned before, the owner's group 2.1 leads that are writing the severe accident management 22 quidelines, the generic ones that then the plants will then take and develop plant-specific procedures from, 23

are on this.

1	And they are participating in this
2	project. The project is far from any solutions on this
3	and quite frankly they're still talking about how far
4	to go with instrumentation. There is
5	MEMBER BLEY: These reports are out now?
6	The EPRI
7	MR. SYDNOR: Oh the two I mentioned are
8	old, all of these are out.
9	MEMBER BLEY: Right. I thought they
10	might have been too, but I don't remember.
11	MR. SYDNOR: One of them, more
12	interesting, in our last meeting with the working group
13	there, and by the way, Dave and I are both participating
14	with EPRI's technical advisory group for this effort
15	through our MOU.
16	One of the things that came out is that the
17	industry, several plants now are updating their
18	simulators with MELCOR and they're trying to develop
19	a capability of doing severe accident simulations.
20	And in fact the industry, the B&W Owner's
21	Group has done and initial study at Monticello and they
22	were pretty happy with
23	MEMBER STETKAR: BWR.
24	MR. SYDNOR: BWR. Did I say B&W? I meant

to say BWR. So it's very limited at this time. For instance one of the limitations of that early work they did was MELCOR would only simulate an in-vessel core aspects at this time. And so they don't have their full simulations but it was a major step forward in capability. And they were using it to essentially benchmark their severe accident management guidelines that they're developing with an actual simulation.

And the Sandia work has proven that MELCOR can actually do a pretty good job at simulating severe accidents. So I thought it was very encouraging and I wanted to mention that to the Committee. So I think there's a lot more to come out of this work.

And the one thing I wanted to stress is I think industry does understand the issue with instrumentation. You know, in our discussions on the technical group that comes out now, how they have They have time constraints. constraints. They have money constraints. They have constraints and they're still developing these procedures. They are not the plant-specific procedures are not developed. that's occurrent, just time limitation.

They have the generic guidelines, both the BWR Owner's Group Guideline and the PWR Owner's Group

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

2.1

22

23

Guideline are available and we're looking at those trying to extract what we see as instrumentation needs out of those.

We've been collaborating with DOE. DOE has actually done a lot of work and they're trying to do additional work. There's a couple of studies that have been done. The Sandia work that I already mentioned where they use MELCOR to simulate the accident.

Idaho and Oak Ridge have studies looking specifically at instrumentation performance. is -- One future project, actually they had started on it, they're currently experiencing some delays because, again, the plant-specific procedures were not available but the very last bullet there was intention to do these plant-specific studies for severe accident implementation using MELCOR and using the actual plant SAMGs, put the whole picture together and determine analysis from an standpoint what instrumentation would be useful.

And so there's some problems with continuing that work at this time. DOE was also trying to collaborate with the Japanese study. That Japanese study for severe accident instrumentation is actually

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

2.1

22

23

1	an Appendix through the IAEA doc. And, like I
2	mentioned, we find it a very broad thinking. It was
3	really a research and development plan and their
4	ultimate goal is to actually perhaps develop new
5	instrumentation that would support severe accidents.
6	But the front end of that study was an
7	analysis where we looked at, worldwide, at what others
8	were doing, lessons learned from Fukushima. And they
9	built a list of instrumentation needs from that
10	analysis. And we're kind of using that as a benchmark
11	for what we're looking at.
12	MEMBER REMPE: So to provide some
13	information on the DOE, for instance, I'm involved with
14	it, it being plant-specific evaluations would rely on
15	the results from the SOARCA evaluations.
16	CHAIRMAN BROWN: From the what
17	evaluations?
18	MEMBER REMPE: SOARCA evaluations. The
19	MELCOR analyses already exists. The decks already
20	exist. So the intent was to extract for the risk
21	important events identified in MELCOR to do
22	plant-specific evaluations.
23	The other point that it strikes me, I know
24	with some of the evaluations of the TMI events, it's

not just the conditions that the sensors are exposed 1 2 to, sometimes it's the sampling rate. 3 For example, if you look at the hydrogen burn 4 containment, the at TMI. The 5 temperatures in the containment never reflected that 6 there was a burn. There was one data point from the 7 pressure that said something happened there. And when 8 they went back in they saw phones melted and things like 9 that said maybe the temperatures weren't quite right. 10 And also there's more to think about too, 11 that the operators need, it's not just the sensor's 12 survivability. It's also the sampling rate and how the 13 data are provided to the operators. Well when you talk about 14 CHAIRMAN BROWN: 15 sampling rate are you talking milliseconds, seconds or minutes or half hour? 16 17 At TMI, and I'm sure it's MEMBER REMPE: 18 better now. I hope it is, every six minutes was how 19 often the data were, the operator saw it. 20 CHAIRMAN BROWN: You have to be kidding 2.1 me. 22 This MEMBER BLEY: wasn't accident This was done in the normal 23 monitoring stuff. 24 environment --

1 (Simultaneous speaking.) 2 MEMBER REMPE: Applications analysis need 3 to be done. MEMBER BLEY: It's like a log book. 4 5 Perfectly satisfactory for what its intended purpose 6 was. 7 MR. RAHN: And now we've also, we had a lot 8 of interest among our own staff of the output of the 9 National Academy's, so their report has several 10 recommendations in it, in Chapter 5 in particular, that 11 we've been paying attention to. I happened to provide 12 one excerpt here from that on the slide. 13 But in addition they're very strong in 14 making sure that DC power systems and backup power 15 systems are also looked at in a hard manner, in a couple 16 of ways. One way is just their ability to provide the, 17 you know, to last for the duration needed before 18 additional power can be brought in. 19 But, secondly, they highlighted a point 20 about the timing between failures of the AC system and 2.1 the DC system. So for example if you lose a DC system 22 you could also lose the breaker controls for the AC 23 system. 24 In other cases you also need to look at

sometimes we have a distribution of power where some 1 2 valves may be operated with DC power and other valves 3 may be operated with AC power and those valves may be on the same system. And so if they're in series, you 4 5 know, and you lose one and not the other you still can't 6 use the system. 7 MEMBER BLEY: From an electrical point of 8 view that's what they were talking about. 9 integrated performance point of view they noted that 10 a control signal that was there to protect you under, 11 I think it was a pipe break condition, was implemented 12 in a way that was identical to what would happen if you 13 lost power. Such that we had some hidden things in there and logic circuits put them in situations that 14 15 were unplanned because of that. 16 MR. RAHN: Right. 17 That seems a much broader MEMBER BLEY: 18 issue and I wonder if you've given that any thought. 19 I don't have, you know, that could be a very broad 20 ranging topic. 2.1 Yes, it's something that needs MR. RAHN: 22 to be considered when we look at this potential for a 2.3 race between the --

Yes.

MEMBER BLEY:

24

I mean the race was

set up by the electrical stuff but it was initiated by a phony signal back, by DC being the same thing as the signal they were looking for. So I don't know if you've thought about that, are there other places that we could ——

MR. RAHN: No, but when we read this, you know, it triggered stuff in our minds, is there something else we've got to look at. But, no, it was a very interesting report for us to evaluate. And I think it's just another data point that says hey, it's essential to have this equipment and it's got to be qualified for its use.

Other things that we're concerned with is what's happening here in the U.S. with regards to our own standards organization. And so IEEE is the standard that Reg Guide 1.97 refers to. It's IEEE 497. And there's a number in NRR here, Steve Weinman is our representative on working group 61 of the IEEE impact, which has to do with accident monitoring.

They currently have a draft of the next revision. And they're currently vetting that draft. Now there's an administrative issue associated that's holding that draft up from being published. They're trying to do a joint logo with IEC and IEEE and they're

2.1

having some difficulties in pulling that off.

2.1

2.3

But, regardless, by next year that draft standard should be released. It'll either be released as a joint logo or not. You know, so they'll be dealing with that in a meeting this next month and then in January again they're going to bring it up.

But currently they have identified what they call a Category F instrument, so we had types A, B, C, D and E that were initially, I guess they go all the way back to the ANS Standard, ANS 4.5, types of categories of instrumentation. And this new Category F is something that is used for accidents with significant fuel damage.

And so in there there are some criteria in there about determining whether or not they would actually survive, you know. So the standard says they must be able to at a minimum perform a survivability analysis, inform the operators when that information coming from those instruments is no longer reliable.

So that's something that, you know, we would hang our hats on if we were going to update Reg Guide 1.97, we would likely endorse that current revision of the IEEE Standard.

MEMBER SCHULTZ: David, what is SDO

1 please? Development 2 MR. Standards RAHN: 3 Organization, sorry. MEMBER SCHULTZ: 4 Thank you. 5 It's not good to use --MR. RAHN: Yes. 6 MEMBER SCHULTZ: Before we go on, because 7 we're going to leave Task 2 it looks like. 8 mentioned a wide number of organizations and activities 9 within those organizations that are happening to 10 address a number of different issues associated with 11 instrumentation severe accidents. And it's a lot of 12 information to both separate and then reintegrate 13 because that certainly seems what is needed to draw the type of conclusions. I mean, hopefully we're not going 14 15 to just update Reg Guide 1.97 by saying well there's 16 a new IEEE standard and we're going to adopt that within 17 the document. 18 MR. RAHN: No, we --19 MEMBER SCHULTZ: So I was wondering a couple of things. What is the plan, given all of what's 20 2.1 going on, for the NRC to integrate the information that

there an end point that is a focal point of when we think

has been generated and is being generated?

we're going to get there?

22

23

24

And is

And I would tie it into Reg Guide 1.97 1 2 because you say well we're going to update it, IEEE, 3 and so I'm trying to understand what that schedule might look like? And what the task is. 4 MEMBER STETKAR: The current version of 5 6 Rev 4 of 1.97 is actually really short. And all it does 7 is effectively inter-set that IEEE standard. not as meaty as Reg Guide 1.97 used to be in previous 8 9 incarnations. 10 MEMBER SCHULTZ: So I may just do this. 11 Let's go back to my original question then in terms of 12 integrating and drawing forward and a plan that can be 13 actualized or used. 14 MR. RAHN: Well, as Russ mentioned 15 earlier, we have as part of our Tier 1 activity is to 16 integrate that information as we develop our regulatory 17 tools. And so it's not beyond us, as John has pointed out, to endorse something with comments and with 18 19 clarifications. As a matter of fact I helped participate 20 2.1 in the development of Reg Guide 1.97 Revision 2 when 22 it came out. And we spent a lot of time developing the 23 information in tables that were attached as appendices

to that document. You know, I wouldn't say that's out

the realm of possibility for severe accident 1 2 instrumentation either. 3 MR. SYDNOR: But essentially what you're asking is what our Task 3 is all about. 4 It's to 5 integrate all of this, extract the information. 6 I said, you know, all of this has pertinent information, 7 some of it at different levels of detail. 8 MEMBER SCHULTZ: That's right. 9 MR. SYDNOR: And some of it yet to be done. 10 MEMBER SCHULTZ: Yes, and it's good, Russ, 11 as you said, that the organization is not totally 12 intertwined so that there is independence. But that 13 does then require Task 3 to have --14 MR. SYDNOR: The last slide I'll touch on 15 is our best guess at a current schedule based on what 16 this stuff progressing, how we see it 17 progressing. 18 MEMBER SKILLMAN: Let me just offer an add 19 on to Dr. Rempe's comment, for TMI, the sampling rate 20 to understand what happened in containment. 2.1 to really get the value of collaboration it would be useful to circle back around and touch some of the 22 people that were involved in a couple of these accidents 23 24 a long time ago, because these people have had a chance

to kind of distill what's important.

2.1

I'll give you an example. What pushed TMI-2 into natural circulation? We stopped the last reactor coolant pump. Why did we do that? Because we lost our last pressurizer level instrument. We didn't want to run dry in the pumps.

So a very obscure instrument drove us into a completely new operating realm, natural circulation. Personally that was very successful. But until that event that had never been tried. We didn't know whether it would go into natural circulation.

So, as Joy pointed out, the sampling rate for containment pressure, we're never going to, at least in my mind, never going to really be able to have probes deep in the core that will tell us exactly what the temperatures are. But the in-core detectors at TMI-2 did a pretty good job. They told us pretty much which direction that core was going.

So there may be, among the people that are still around who have been through a couple of these accidents, some information that might add to your new Category F that might not be as expensive as Harold is concerned about, although it may be, that might give those eight or ten practical items that will carry the

1 day. 2 I don't think you need 200 or 500. 3 containment conditions, reactor coolant conditions, how much water is in the basement. A couple of others 4 that are remarkable and obscure. 5 6 The automation of your waste disposal 7 system, they'll try to pump outside your boundary unless you block those, you can have offsite releases 8 9 that you hadn't anticipated. And from within the same 10 generators if you go up in your atmospheric pump valves 11 and you do have failed fuel and failed tubes you now 12 have an offsite release that you might not be able to 13 fully quantify. 14 So there are a couple of places where 15 talking to some of the folks who were around a long time 16 ago might bring fresh information to this. And I don't 17 believe it would be that difficult. I think these 18 folks would be able to say hey, these are the three or 19 four things that would have really helped us back when 20 that happened. 2.1 Thanks. MR. RAHN: Okay. 22 MEMBER SKILLMAN: Thank you.

DOE had done with Idaho and Oak Ridge was in that vein

MR. SYDNOR:

23

24

I'd just add I think the work

of looking back at TMI lessons learned and how to apply 1 2 that. 3 We looked, at least with MEMBER REMPE: the TMI, about 100 references that were around, we 4 5 didn't do the talking with the people because that 6 wasn't possible though it would have been the nice thing 7 to have done too. But that was part of the vein of it, to try 8 9 and see if we could identify certain sensors. What was 10 data qualification effort and the done, 11 survivability assessments. 12 MR. CASE: Maybe we can tease out the human 13 element of that. You know, maybe when we get to the final report we can use the final report to sort of 14 15 engage that. There's ways we can get to those, that 16 human intelligence. 17 MEMBER SKILLMAN: Thank you. 18 We'll move on to just, MR. SYDNOR: 19 there's three slides but this is really Task 3 effort. 20 It's something we've just started this year trying to 2.1 begin our analysis of looking at what has been done as 22 a result of Tier 1 activities and these other things. So these three slides here primarily talk 23 24 about what we're looking at in relation to specifically

Tier 1 activities, not necessarily what we extracted 1 2 from these other international efforts yet. So we've started an analysis of looking 3 back at mitigating strategies to understand what was 4 5 committed to there by the utilities. We're looking at 6 specific commitments. Specific lists of 7 instrumentation and what they've committed to do as 8 part of mitigating strategies. 9 I mentioned before Dave and others were 10 of the of fuel part review the spent pool 11 instrumentation implementation of that order. So 12 we've looked at what the utilities have responded to 13 those and we reviewed those in detail. Just, go ahead, for a quick, as a starting 14 15 point we took the licensee submittals and we took an 16 initial broad look at all the different BWR designs and 17 the different PWR designs and we're starting to put 18 together a comparison matrix. 19 And, like I mentioned before, one of the 20 sort of the benchmark we're using right now, because 2.1 we found it to be the most encompassing, is the 22 SA-Keisou analysis of what you ought to consider for severe accident instrumentation. 2.3

So we're benchmarking that against what

we're finding in these licensee submittals and trying 1 2 to understand the strategies behind the submittals. 3 MEMBER But., REMPE: Russ, ΜV understanding is the SA-Keisou -- did I say that 4 5 correctly, is only on another Fukushima event. And as 6 Dana pointed out, the next accident's going to be 7 different, it's something we didn't think about. so do you have any comment about that? 8 9 MR. SYDNOR: Do you know which accident is 10 going to occur? The only way I know to try 11 MEMBER REMPE: 12 and cover my bases is to look at a lot of different risk 13 important sequences, because no I don't. 14 MR. SYDNOR: I'm not sure how else to --15 MEMBER REMPE: Yes, I know. I just --16 MR. SYDNOR: I think in new reactors 17 that's exactly what the Chapter 19s are. They do the 18 external events and develop the risk significance. 19 MEMBER REMPE: That's the intent, but then 20 I actually have a copy of the Vogtle FSAR in Chapter 2.1 19 and, again, it's not clear to me from what I've read but I wasn't involved when this was done, but what's 22 the cutoff frequency, what's the duration time. 23 24 it's just not clear to me how that was implemented.

1	But if it were done in a very systematic
2	and methodical way then you have a difference between
3	the new plants and the existing plants that exists, but
4	it would be good to explore what's required to meet
5	those requirement is 10 CFR Part 52. And I'd be
6	interested in what you learn as you dig into that.
7	MEMBER RAY: Well of course both Vogtle
8	design certification amendments and the COLAs have all
9	preceded the developments that were to be imposed upon
10	them. So that we're not going to find, I don't believe,
11	in any of the material from that time, any of the
12	outcomes from the work that you're describing here now.
13	MEMBER REMPE: But they were required to
14	look at severe accident instrumentation.
15	MEMBER RAY: Yes.
16	MEMBER REMPE: And I just, it's not clear
17	to me what the process is that NRC instituted that they
18	had to follow.
19	MEMBER RAY: Or will have to follow.
20	MEMBER REMPE: Yes.
21	MEMBER RAY: That's the B
22	MALE PARTICIPANT: It hasn't been done
23	yet.
24	MEMBER RAY: That's the dilemma in this

case.

2.1

2.3

MR. SYDNOR: Another thing, in addition to mitigating strategies, we're looking at the BWR Owner's Group and the Westinghouse Owner's Group, which is the PWR Owner's Group, looking at their guidelines for emergency planning and severe accident management guidelines. And we're extracting from those what they're requiring for severe accident instrumentation.

We're reviewing also the purpose, assumption, approaches and considerations because there are different strategies one can take as far as accident management mitigation. And, again, we're using the SA-Keisou as sort of a benchmark comparison there.

But, for instance, mitigating strategies assumes, there's two main assumptions. That you've had the station blackout and the loss of ultimate heat sink and therefore it focuses on water injections, recovering DC power and hooking up portable equipment.

In looking at the severe accident management guidelines, we're reviewing those and we've identified a list of instrumentation that the operators are directed to use in those.

Now, again, these are not the

plant-specific ones, so these generic guidelines plants haven't taken those and populated all of that yet. But that's the next step, they're in the process of doing that. And some of that was why that previous benchmarking at the simulator was going on because they were trying to understand how difficult that is and understand how to do that adequately.

So, again, we're reviewing the purpose, assumption, approaches and considerations of that because it's not, what we've found so far is that we need to understand the strategy that they're utilizing because the strategy forms the basis for the instrumentation that they're specifying.

And in this case they consider, these are more aligned, the guidelines are more aligned, we find so far, more aligned with SA-Keisou analysis because it considers worst cases. It looks at various core melt sequences and damage to the reactor vessel, damage to containment and works through each of those events.

MEMBER SCHULTZ: So, to go back to Joy's question, or comment, about what is the next event. The question is is that sufficient. Is it sufficient to do a worst case approach and develop some sort of set of instrumentation that's going to handle worse

2.1

1 | cases?

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

2.1

22

23

24

Is that in fact going to be the best success path? And is it going to be successful from the comment that Harold had made earlier? Do you not derive a set of instrumentation that's so expensive that, well we're not going to go there.

MR. SYDNOR: Or I would propose, or are there other strategies you could implement as part of your prevention and mitigation procedures?

MEMBER SCHULTZ: All right, having said that, I'm not trying to discourage any of this from, this where the meat of it is. This is where the activity that you and Dave have identified as the real focus is the severe accident management guidelines and the mitigating strategies to pull together and to ask the questions over and over again, is the instrumentation considerations appropriate. got the right instrumentation that will support the severe accident management quidelines to support the mitigating strategies? And if not, what do --

MR. SYDNOR: I think we'd agree with -- MEMBER SCHULTZ: Okay.

MR. RAHN: I wanted to just add that it's not just the instrumentation but it's operator aids

1	that are used along with that instrumentation.
2	There's a lot of need for interpreting what the
3	instruments are saying. Even though, the instruments
4	will not be perfect, but you need to at least understand
5	the uncertainties associated with it and how those
6	uncertainties can increase as the accident progresses.
7	MEMBER SCHULTZ: Exactly. And that's
8	what Dennis and John were getting at earlier as well.
9	Is you have to understand, you have to know when the
10	instrumentation is helping and when it's not.
11	MR. RAHN: Right. So currently the
12	industry's EOPs, especially the BWR's group ones, have
13	pointers to where's the worst case number you can read
14	reliably on this particular water level instrument, for
15	example. So something like that needs to be
16	promulgated a little further into the SAMGs.
17	MEMBER BLEY: Is that on those big flow
18	charts?
19	MR. RAHN: Yes.
20	MEMBER BLEY: I don't recall ever seeing
21	that.
22	MR. RAHN: Oh yes. Yes, there's a bottom
23	range, bottom number. If you see a number on this
24	instrument below this you can't rely on it.

1	MEMBER BLEY: Okay.
2	MR. RAHN: Yes, before I came to the NRC
3	my company used to develop some of those operator aids.
4	And we automated some of ours, we had laptops with, you
5	know, maps of the, it had like a little diagram of the
6	containment and the reactor and we had all the water
7	level instrumentation on there, and reactor pressure
8	and temperature conditions.
9	And you could punch in whatever any one
10	instrument says and you put in the dry well temperature
11	and the containment temperature, I mean, say the
12	containment and the reactor building temperature it
13	will compute for you what the instrument ought to read.
14	MEMBER BLEY: Oh, okay, we used to have a
15	number graph. But that was a long time ago.
16	MEMBER STETKAR: That's when people knew
17	what a number graph was.
18	(Laughter.)
19	MALE PARTICIPANT: They don't require any
20	power, other than
21	(Simultaneous speaking.)
22	MR. SYDNOR: So the last thing I wanted to
23	talk about this morning was, you know, our timeline.
24	And this timeline hasn't changed. I think I added a

1	plus on somewhere on here because of some of the
2	unexpected delays. But this was the timeline that we
3	proposed in the SECY and in dealing with the steering
4	committee.
5	And it gives you sort of frame, I didn't
6	intend to go through all of these. But, you know, our
7	intention is to develop our recommendations next year.
8	Due to some of the delays in some of the research that
9	may stretch into 2016.
LO	MEMBER BLEY: But you are keeping touch
L1	with the Tier 1 folks?
L2	MR. SYDNOR: I don't know if it was issued
L3	yet but the latest SECY, every six months they give a
L 4	SECY to the Commission.
L5	MEMBER BLEY: Yes.
L6	MR. SYDNOR: One of the enclosures is
L7	MEMBER BLEY: Is that. Okay.
L 8	MR. SYDNOR: And so this is what we've been
L 9	working towards. And for the most part the schedule's
20	still pretty much holding up. And so, that's all we
21	had this morning unless there's any more questions,
22	comments. Appreciate the feedback that we've gotten
23	today.
24	CHAIRMAN BROWN: I guess I have one other,

not a new question, but just, I don't want to call it a take away either, but maybe a direction comment. And that's all of the stuff, and I'm going back to Ron's comment developing a de minimis set of instruments and their capabilities, specific capabilities.

I mean, we have a limited number of types of instrumentation that we're going to have to deal with. I mean it's either temperatures, pressures, levels, flows and that have to operate in some environment. Pressure, temperature, radiation environments.

And it would be, to me, this is me, not the Committee. This would be me for subsequent discussions would be to see where we start laying out what I would call some boundary conditions for these to say here's kind of a starting point to evaluate whether these conditions will give us value added relative to any subsequent regulations or guidance that we put out.

So to make that decision you need some type of analyses to see whether those boundary conditions that you can meet with instrumentation are going to satisfy the needs of the operators for some fairly critical, or what I would call very severe, something

2.1

similar to what we experienced in Japan. 1 2 That's pretty severe, I mean, that's hard 3 to envision, you know, melting and melting and melting and spreading stuff all over the place with very, very 4 5 high radiation. 6 That's got to be at least a consideration 7 for conditions environmental boundary for 8 qualification that these instruments would have -- And 9 what data, somebody else mentioned, what data did the 10 operators there feel that they were missing in terms of making decisions as to how they, what actions they 11 12 took. 13 We're going to be looking for some feedback 14 on where you are. And I guess I would like to have some 15 evaluation of that, of the specifics, as opposed to the 16 more general details that you've discussed so far. 17 That's my final, maybe final. If nobody else has 18 anything here I was going to go to the public comments 19 in the audience. Is there anybody in the audience that 20 2.1 MEMBER SCHULTZ: Well I have a comment I 22 wanted to make. 23 CHAIRMAN BROWN: Oh, Steve. I'm sorry. 24 Yes, thank you.

1 MEMBER SCHULTZ: Because I wanted to get 2 some more information if you can share it. We talked 3 about the nexus between the rulemaking activities that are upcoming or ongoing and this activity. 4 5 indicated you've written proposed language 6 rulemaking opportunities, they haven't yet been 7 adopted. And I guess I could leave it at that. 8 But 9 just to mention that with regard to the consolidated 10 rulemaking, we're going to hear a lot about that in 11 November and expect to write a letter in December 12 associated with that rulemaking activity. 13 So we ought to continue to talk in the near 14 term and know in the near term what is happening in 15 regard to your proposed language and the response that 16 you're getting to it. Because the Committee, I think, 17 will be very interested to understand where that's at 18 end of November, early December when we're about to 19 write our next letter associated with rulemaking in 20 this area. 2.1 CHAIRMAN BROWN: Thank you. 22 MEMBER SCHULTZ: Comes down to we need to find a way to keep us informed. 2.3 24 MR. RAHN: Yes. They did have, you know,

ago.
MEMBER SCHULTZ: Yes.
MR. RAHN: And, you know, at that point
there was an opportunity to talk about it. But maybe
it's time to revisit that.
MEMBER SCHULTZ: Yes. Well we have a full
meeting coming up with them, subcommittee with the
Fukushima Subcommittee in our subcommittee week in
November. It's a two day meeting and Mike Snodderly
is the staff member that's working on that meeting with
me. So we'll look to communicate with you and find out
status before we go into the Full Committee meeting.
CHAIRMAN BROWN: Steve, would you like to
have a brief discussion of this, where they are in the
severe accident management dispensation at that
meeting?
MEMBER SCHULTZ: That would be the right
time, yes. That's the right time to pull it in. So
I'm going to meet with Mike today on the objectives.
CHAIRMAN BROWN: Okay. So your take will
be on seeing whether the, what the scope of what we want
to incorporate in that meeting.
MEMBER STETKAR: It's Thursday/Friday of

1	that week.
2	MEMBER SCHULTZ: Right.
3	MEMBER STETKAR: It's November 20th and
4	21st. I saw you jotting down notes. You said that's
5	November, Full Committee?
6	MEMBER SCHULTZ: Said November
7	Subcommittee week, Thursday and Friday of that week we
8	have the subcommittee meeting but would then be
9	bringing it to the Full Committee, we expect to, in the
10	December week. The first week of December.
11	MR. RAHN: Thanks.
12	MEMBER SCHULTZ: Thank you.
13	MR. CASE: Thanks, those are good
14	insights.
15	CHAIRMAN BROWN: Okay. Any other member
16	comments or questions?
17	MEMBER RAY: What was the purpose of this
18	meeting, Charlie?
19	CHAIRMAN BROWN: Just to kind of see where
20	they were and what they were doing. It was an
21	information subcommittee meeting just to see what are
22	they planning, what have they done, who have they talked
23	to, where do they think they're going.
24	MEMBER RAY: I'm just laboring to connect

that with the what plants are ultimately obliged to do, you know.

CHAIRMAN BROWN: Yes, I got that flavor

quite clearly. And I agree with you. My concern is that we develop this so high level, overarching scope of what may be necessary whereas there may be some fairly simple approaches to providing some instruments that will provide information.

And we're going to bypass that in favor of complex systems that are costly. That if you make this stuff cost several million, a million dollars in order to do it it's not going to be very useful because it'll be rejected because of the low frequency aspects of these type of events.

MR. CASE: Right. I haven't seen that idea yet. You know, I am 100 percent interested in that idea. That low cost, this is the magic pill that really brings information to this area, we're looking for that. But so far --

CHAIRMAN BROWN: Well I made a comment in one of your -- There are high-temperature thermocouples available that you can use. There's mineral-insulated cable that's very resistant to radiation that provides temperature information. You can read these suckers

2.1

with a \$90 fluke instrument that you can connect to a pair of terminals that are running out into some remote operator station. And you can put 9 volt batteries in that, you can use it for about five years.

MEMBER BALLINGER: They're self-powered.

CHAIRMAN BROWN: Not all of them are self-powered. If you got self-powered you got to have stuff to generate the self, it depends on what you use. The point being that there are methods of measuring pressure and level that you can generate without all types of fancy instrumentation that are usable by folks.

You don't have to have something that, a computer that runs everything, you can use a piece of paper, graph paper, where you plot output voltages and then say okay this is what it ought to be over a calibration range and you can present that information out to operators in a remote location with cables that are capable of doing it.

And if you don't have high powered electronics in the radiation field it will work for a long time. Blacksmith technology is fairly good. Vacuum tubes actually work pretty well in these environments.

2.1

1	MEMBER BLEY: They're hard to find.
2	CHAIRMAN BROWN: I've got a whole box full
3	of vacuum tubes, okay?
4	MEMBER BALLINGER: It won't be long before
5	you will not be able to go to Radio Shack and get them.
6	CHAIRMAN BROWN: Yes. That's also the
7	case. So that is the point of the earlier comments I
8	made relative to we can make this thing so complicated
9	as to why not take a look at the information on what
10	are the boundary conditions and what are the simple
11	things that we can do to bring information to, the
12	operator is the key.
13	That was the key in Fukushima, what did the
14	operators need? And they ran out of not only power but
15	also the ability to get information because the
16	instruments were too suspect.
17	MR. RAHN: Yes, it's really the entire,
18	it's the instrument channel that has to be, it's not
19	just the instrument. You know, somehow you've got to
20	get that signal out of the containment. And right now
21	the limiting factor isn't the instrument if you're
22	talking about temperature. A lot of times it's the
23	inboard electrical penetration.
24	CHAIRMAN BROWN: Yes, exactly.

Charlie, I would add 1 MEMBER SKILLMAN: 2 I think you will find this to be this comment. 3 accurate. From the time of the accident to 10 days, 20 days, 50 days, 100 days after the accident, the 4 5 operator's line of vision will change. 6 Early on they're focused on core 7 temperature, hydraulics, heat transfer, decay heat 8 generation rate, reactor coolant system inventory, 9 inventory transfer from the reactor coolant system 10 pressure boundary to outside the boundary. if 11 on, there's As time goes 12 stabilization on the primary, their lens begins to 13 focus on other things. Where is the water going? 14 is it's specific activity? What are the radiological 15 consequences? What compartments can we get to? What 16 can't we get to? 17 So in the first 24, 48 and 72 hours there's 18

So in the first 24, 48 and 72 hours there's this blistering focus solely on RCS and some consideration about offsite. But as time goes on considerations for offsite for releases begins to come into view. And the instrumentation for that is commonly very, very simple. Not sophisticated. Sometimes neither durable nor robust.

So when we talk severe accident management

19

20

2.1

22

2.3

we've really had a major, major catastrophe in the reactor coolant system, whatever it might be. In the course of time some of the earlier considered not to important instrumentation begins to be very important, and you can't get to it.

And the reason you can't get to it is because the radiation level is just so high. And sometimes even your radiation instruments aren't functioning because they weren't qualified for the conditions that they saw during the course of the accident.

And so the river becomes how do you really make sure that you can steer your way through the 30 days after that accident when an awful lot of this secondary instrumentation is really not obvious to anybody. Can't get through the doors, you can't get to the compartments. Some pumps may not have functioned because the power for them was defeated and now you've got six inches of water on the floor. And what came up in the water was isotopes that were soluble from the core, so you're locked out of the building.

So there's more to this than just focusing on the sophistication in and around the reactor coolant system. The outer boundaries of the plant become

2.1

equally complicated in terms of how you steer your way 1 2 through the later days. MR. CASE: Okay. Well I need to think 3 We do not have a lot of thoughts out 4 about that one. in that area. You know, we're more focused on the sort 5 6 of the accident management part of it and not --7 MEMBER SKILLMAN: I know, and that's why I raised the comment. 8 9 The major accident management. MR. CASE: 10 MEMBER SKILLMAN: What happens is very 11 quickly the accident consumes the station footprint. 12 station is beside itself And the to prevent 13 radioisotopes from going on beyond what is 14 licensed boundary. And that becomes a real challenge. 15 You know, maybe one of the most important 16 sets of instrumentation you have is the meteorological 17 instrumentation so you can bring in the helicopters. 18 Where do they land? What's the wind direction? 19 What's the temperature? Things you really wouldn't 20 think of if you just focused on the core and the reactor 2.1 coolant system pressure valve. 22 That's why I say some of the folks that have been around these accidents might say you know there 23 24 are a couple of other things you might want to think

1	about.
2	MEMBER SCHULTZ: Certainly came up at
3	Fukushima.
4	MEMBER BLEY: And other places.
5	MEMBER SKILLMAN: Thank you.
6	CHAIRMAN BROWN: Okay. Any more member
7	comments? Turn to the
8	MEMBER REMPE: Dennis wanted
9	CHAIRMAN BROWN: Oh, Dennis?
10	MEMBER BLEY: No, I was
11	CHAIRMAN BROWN: Oh, I was going to check
12	out here first. Is there anybody out here that wanted
13	to make a comment?
14	MR. STATTEL: I'd like to make a comment
15	if you don't mind.
16	Hello. I'm Rich Stattel from I&C in the
17	NRR. My comment has to do with the, you had a
18	discussion regarding the prescriptive lists of
19	instrumentation. And it kind of reminds me back of
20	some of the discussions we've had when I was in the
21	industry and also when I worked in the New Reactors
22	realm. And we used the term minimum inventory.
23	Right?
24	In the New Reactors, when I was working on

the ESBWR project, we kind of ended up in a kind of hybrid situation where we put a minimum inventory list into our design certification with the understanding that there would be an analysis, a task analysis, and we'd HFE input and we would revise that list going forward. So that's my recollection. I believe most of the new reactor designs ended up in similar situations.

But there was mention of Reg Guide 1.97, the prescriptive lists that are in Reg Guide 1.97 initially. And I didn't hear any discussion about why those lists were pulled out. They were retracted from Reg Guide 1.97 and there was a couple of reasons for that.

One was the list, there are basically two lists in the original version. One applied to boiling water reactors and one applied to pressurized water reactors. And over the years we recognized that those lists weren't really a good fit because there were a lot of different versions of those reactors and we ended up imposing requirements for instrumentation that weren't necessary for a lot of the reactors. And there were also requirements that should have been necessary that weren't included in those lists.

2.1

1	So Reg Guide 1.97 over the years evolved
2	into let's perform the analysis. Let's get the input
3	from HFE and we'll get the right list. Basically we'll
4	develop the process for doing that.
5	MEMBER BLEY: For a plant.
6	MR. STATTEL: For a specific plant.
7	Right? So I just wanted to mention that because it
8	seems like every time an event occurs in the industry
9	there's always this push to put a prescriptive list.
10	If we get spent fuel pool level, if we get this, and
11	then apply that to the entire industry.
12	And I want to makes sure that the lessons
13	we learned over the last 15/20 years are considered
14	because there are truly plant-specific, unique inputs
15	that should be going into the development of those types
16	of lists. Right?
17	MEMBER BLEY: Thanks.
18	CHAIRMAN BROWN: Thank you, Rich. Are
19	there any other comments from the No one here? Okay.
20	Is there anyone on the phone lines? It is
21	open, if somebody's on the phone line would you probably
22	please just say something so we know it's open?
23	MEMBER STETKAR: I don't hear any of the
24	telltale noises to say that it's open.

1	CHAIRMAN BROWN: I don't hear any snap
2	crackle and pop. So hold on a minute we're checking.
3	He said it's on.
4	MEMBER BLEY: Nobody's there?
5	CHAIRMAN BROWN: Then nobody must be
6	there. So given that we don't hear any response from
7	the phone lines, if there's any other comments from the
8	staff or anyone else? Okay then we will close the
9	meeting. Thank you very much. We appreciate it.
10	(Whereupon, the above-entitled matter
11	went off the record at 10:21 a.m.)
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	



NRC Fukushima NTTF Tier 3 Item:

ACRS Recommendation 2(e)

ACRS Subcommittee Meeting September 16, 2014

Mike Case and Russ Sydnor, RES/DE David Rahn, NRR/DE



ACRS 2(e) – "Selected reactor and containment instrumentation should be enhanced to withstand beyond-design-basis accident conditions".

NRC Staff Team Members, Offices Represented:

Mike Case – Management Lead - RES

Russ Sydnor - RES

David Rahn - NRR

Paul Rebstock & Pong Chung - RES

Dinesh Taneja - NRO



Key Project Activities – (SECY-12-0095)

- Task 1 Ensure that licensees and NRC staff are appropriately considering instrumentation needs when implementing site specific actions for the NTTF Tier 1 Recommendations 2.3, 4.1, and 8, and Orders EA-12-049 and EA-12-051.
- Task 2 Obtain and review information from previous and ongoing research efforts for severe accident management analysis.

 Coordinate with and support international and domestic entities (e.g., IAEA & DOE) and standards organizations (e.g., IEEE/IEC, ANS).
- Task 3 Evaluate results of Tier 1 NTTF activities in coordination with the information obtained from applicable research efforts (international and domestic) to determine requirements for appropriate regulatory framework.



Task 1 – Activities

- Staff is still communicating with Tier 1 Teams.
- Reviewed Tier 1 activity orders and guidance documents, e.g. JLD-ISG-2012-01, NEI 12-06, NEI 14-01, and others.
- Directly supported related Tier 1 activities e.g. SFP Instrumentation order and guidance development, reviewing licensee overall integrated plans.
- Directly supporting Fukushima NTTF Consolidated Rulemaking team, and proposing rule language for consideration.



Task 2 - International Collaborations/Activities

- International Atomic Energy Agency (IAEA)
 - IAEA Technical Document, "Accident Monitoring Systems for Nuclear Power Plants"
 - Captures design practices for establishing design criteria to support the accomplishment of accident management strategies and to monitor post-accident conditions
 - Adds new recommended design criteria for monitoring design extension conditions (those with and without resulting significant fuel degradation)
 - Includes appendix for SA-Keisou (Severe Accident-Instrumentation and Monitoring Systems) R&D Plan
 - New Working Group- I&C Equipment Qualification Best Practices
 - Severe Accident I&C Equipment Qualification and Survivability
 Analysis for severe accident conditions will be addressed in a new IAEA TECDOC.



Task 2 - International Collaborations/Activities (continued)

OCED/NEA –

- Report of the CNRA Task Group on Accident Management, NEA/CNRA/R(2014)2, "Accident Management Insights after the Fukushima Daiichi NPP Accident"
 - "....., instrumentation that enables performing well-timed operator actions, surveying the effectiveness of the actions and monitoring their progress of the accident should be included. The systems, equipment and instrumentation should withstand the harsh conditions of the accident (e.g. very high temperatures, high radiation levels etc.), taking into account that it may be required to remain operable for a considerable period of time (several months or more). Consideration should be given to both fixed and mobile equipment."

MDEP –

- EPR Technical Experts Subgroup (TESG) for Severe Accident developing two reports;
 - Management of pressure in containment during a severe accident
 - Reliability and qualification of severe accident instrumentation
 - Final reports November 2014.



Task 2- US Collaborations/Activities

- EPRI Technical Report TR-1025295, Severe Accident Management Guidance Technical Basis Report, 2012:
 - Supports SAMG writers
 - Volume 1: Damage conditions, High-level Steps, and Effects
 - Volume 2: Accident progression physics and calculations
- EPRI Technical Report TR-1026539, Investigation of Strategies for Mitigating Radiological Releases in Severe Accidents; BWR Mark I and Mark II Studies, September 2012
- New EPRI Project Instrument and Control for Beyond Design Basis Events and Severe Accidents
 - EPRI Technical Report TR-103412, Assessment of Existing Plant Instrumentation for Severe Accident Management, 1993
 - EPRI Technical Report TR-102371, Instrument Performance Under Severe Accident Conditions: Ways to Acquire Information From Instruments Affected, 1993.



Task 2- US Collaborations/Activities

- DOE -
 - Sandia Report, SAND2012-6173, "Fukushima Daiichi Accident Study" (Status as of April 2012)
 - Idaho National Lab report INL/EXT-13-28043, "TMI-2 A Case Study for PWR Instrumentation Performance during a Severe Accident" March 2013
 - Oak Ridge report ORNL/TM-2013/154, "Fukushima Daiichi A Case Study for BWR Instrumentation and Control Systems Performance during a Severe Accident" April 2013
 - Future DOE research:
 - Research collaboration with NRC, EPRI
 - •Collaboration in a Japanese study on instrumentation performance at Fukushima
 - •Plant specific studies on severe accident instrumentation needs and performance



Task 2- US Collaborations/Activities

- NAS report- Lessons Learned from the Fukushima Nuclear Accident for Improving Safety of U.S. Nuclear Plants, 2014
 - Recommendation 5.1.A, excerpt:
 - Instrumentation for monitoring critical thermodynamic parameters in reactors, containments, and spent fuel pools.
 - "... robust and diverse monitoring instrumentation that can withstand severe accident conditions is essential for diagnosing problems; selecting, and implementing accident mitigation strategies; and monitoring their effectiveness".
- Interface with SDO -
 - Plan to Update RG 1.97, Criteria for Accident Monitoring Instrumentation for Nuclear Power Plants, based on the planned 2015 update to IEEE Standard 497, "IEEE Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations." Adds New Category "F" Instruments for accidents resulting in fuel damage. Category F provides the most direct indication of the parameters needed to execute the SAMGs. Requires a qualification process and a survivability analysis to determine the seismic and environmental constraints for reliable use.



Task 3 – Review of Tier 1 results

- NRC Order EA-12-049 on Mitigation Strategies (MS)
 - Requires a three-phased approach for maintaining and restoring core cooling, containment, and spent fuel pool (SFP) cooling
 - Completed no later than two (2) refueling cycles after submittal of the overall integrated plan or on 12/31/2016, whichever comes first.

Phase	Licensee may use
Initial	Installed equipment
Transition	Portable, onsite equipment
Final	Offsite resources & equipment



NRC Order EA-12-051 SFP Instrumentation



Task 3 -Reviewing Licensee submittals for Mitigation Strategies

- Review of BWR MS
 - Fermi-2 (BWR4, Mark I)
 - Nine Mile Point-2 (BWR5, Mark II)
 - Clinton-1 (BWR6, Mark III)
 - Hatch 1&2 (BWR4, Mark I)
- Review of PWR MS
 - North Anna 1&2 (W, 3 Loop)
 - Oconee 1,2&3 (B&W, 2 Loop)
 - Calvert Cliffs 1&2 (CE, 2 Loop)
 - Diablo Canyon 1&2 (W, 4 Loop)



Task 3 - Reviewing BWROG and WOG EPGs/SAMGs

- Currently evaluating different approaches Japanese SA-Keisou versus US NPPs' Mitigating Strategies (MS) instrumentation
 - Reviewing MS OIPs and 6-month status reports to identify the list of instrumentation and comparing those instruments with SA-Keisou list.
 - Reviewing purpose, assumptions, approaches, and considerations
 - SA-Keisou: assumes worst-case, various Core melt / RPV-damage / Containment-damage conditions
 - MS: assumes Station Blackout (SBO) and Loss of Ultimate Heat Sink (LUHS) and then considers successful water injections with available DC power, portable generators, and pumps from alternative heat sink.
- Currently evaluating BWROG and WOG EPGs/SAMGs instruments
 - Reviewing Owner Group's EPG/SAMGs to identify the list of SA instrumentation operators are directed to use to mitigate accident event.
 - Reviewing purpose, assumptions, approaches, and considerations
 - BWROG, WOG, and SA-Keisou all consider the worst cases with various Core melt/ RPV damage / Containment damage conditions



Project Plan Timelines:

Task 1 – Interface w/pertinent Tier 1 activities – Ongoing Task 2 – Research & Collaborations

- IAEA Tech Doc, Severe Accident Instrumentation: 2014-2015
- DOE & EPRI Fukushima Instrumentation studies: 2014-2015
- Tier 1 activities results for instrumentation: 2014-2015
- Provide input to SDO organizations (ANS, IEEE) 2015 (+)

Task 3 – Regulatory Framework determination

- Provide periodic updates to JLD and Commission
- Complete analysis of Tier 1-related research studies on instrumentation needs and environments – 2013 -2015
- Evaluate relative safety significance of implementing the research recommendations—use PRA methods, if appropriate
- Develop SECY for Tier 3 item resolution 2015 (+)



Acronyms

BWROG Boiling Water Reactor Owners Group

CNRA Committee on Nuclear Regulatory Activities

DOE Department of Energy

EPR European Pressurized Reactor

EPRI Electric Power Research Institute

IAEA International Atomic Energy Agency

LUHS Loss Ultimate Heat Sink

MDEP Multinational Design Evaluation Program

MS Mitigating Strategies

NAS National Academy of Sciences

OECD/NEA Organisation for Economic Co-Operation and Development /

Nuclear Energy Agency

OIP Overall Integrated Plan

PWROG Pressurized Water Reactor Owners Group (WOG, BWOG,

CEOG)



Acronyms (Continued)

RG Regulatory Guide

RPV Reactor Pressure Vessel

SA Severe accident

SAMG Severe accident management guideline

SBO Station Black Out

SDO Standards Developing Organization

WOG Westinghouse Owners Group



Back up Slides



Tier 1 Dependencies

- Seismic and Flooding Walkdowns RFI
- SBO Rulemaking (now combined with EOP/SAMG/EDMG Integration rulemaking)
- Mitigating Strategies Order
- Spent Fuel Pool Instrumentation Order
- EOPs/SAMGs/EDMGs Integration Rulemaking (now combined with SBO rulemaking)



Current Regulatory Framework

- 10 CFR 52.47(a)(8) –technically relevant portions of TMI-2 related requirements in 50.34(f), especially 50.34(f)(2)(ix)(c), 50.34(f)(2)(xvii), and 50.34(f)(2)(xix)
- 10 CFR 52.47(a)(23) and 10 CFR 52.79(a)(38) design features for the prevention and mitigation of severe accidents
- RG 1.97, Criteria for Accident Monitoring Instrumentation for Nuclear Power Plants



Major Accomplishments

- ✓ Reviewed Tier 1 Activities
- ✓ Reviewed DOE Modeling of Fukushima event
- ✓ Met with DOE and EPRI regarding research activities
- ✓ Participating in IAEA Tec Doc development
- ✓ Met with ANS Standards Board
- ✓ Interfacing with IEEE SC, (IEEE-497)

Plan/Path Forward

- Implement Program Plan
- Work with ANS SDO to identify criteria for Severe Accident Instrumentation
- Support IAEA issuing Tec Doc on Accident Monitoring Instrumentation
- Collaborate with EPRI and DOE
- Support IEEE SC on Accident Monitoring efforts
- Identify criteria arising from Tier 1 outcomes
- Determine need for Rulemaking (or alternative approach, e.g. Generic Communication)