

NorthAnnaRAIsPEm Resource

From: Buckberg, Perry
Sent: Monday, December 01, 2014 10:35 AM
To: 'na3raidommailbox@dom.com' (na3raidommailbox@dom.com)
(na3raidommailbox@dom.com)
Cc: NorthAnnaRAIsPEm Resource; Chien, Nan; McKirgan, John
Subject: Draft North Anna 3 RAI - 06.04 - Control Room Habitability System
Attachments: Draft RAI_7745 11-26-14.docx

Hello,

Please see attached draft RAI 7745 related to control room habitability for the North Anna 3 COLA.
Please let me know if you need clarification on this draft by CoB Wednesday.

Thanks,

Perry Buckberg

Senior Project Manager

phone: (301)415-1383

fax: (301)415-6406

perry.buckberg@nrc.gov

U.S. Nuclear Regulatory Commission

Office of New Reactors

Mail Stop T-06D38M

Washington, DC, 20555-0001

Hearing Identifier: NorthAnna3_eRAI
Email Number: 95

Mail Envelope Properties (44CD2E65B0FF0E499CB32BC30CF781F0018D155E0B62)

Subject: Draft North Anna 3 RAI - 06.04 - Control Room Habitability System
Sent Date: 12/1/2014 10:35:19 AM
Received Date: 12/1/2014 10:35:29 AM
From: Buckberg, Perry

Created By: Perry.Buckberg@nrc.gov

Recipients:

"NorthAnnaRAIsPEm Resource" <NorthAnnaRAIsPEm.Resource@nrc.gov>

Tracking Status: None

"Chien, Nan" <Nan.Chien@nrc.gov>

Tracking Status: None

"McKirgan, John" <John.McKirgan@nrc.gov>

Tracking Status: None

"na3raidommailbox@dom.com' (na3raidommailbox@dom.com) (na3raidommailbox@dom.com)"
<na3raidommailbox@dom.com>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	505	12/1/2014 10:35:29 AM
Draft RAI_7745 11-26-14.docx		36740

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

DRAFT Request for Additional Information - 7745

Issue Date: 12/1/2014

Application Title: North Anna, Unit 3 - Docket Number 52-017

Operating Company: Dominion

Docket No. 52-017

Review Section: 06.04 - Control Room Habitability System

Application Section: 6.4

QUESTION:

According to the applicant's chemical hazards analyses, when meteorological stability class F was selected, only a night time temperature of 71.5 F was used. During a public meeting held on October 30, 2014, the applicant explained that a temperature of 91.5 F, was not realistic to coexist with meteorological stability class F.

RG 1.78, Section C, 3.3, states, "Irrespective of the dispersion model or the analysis tool used, the value of the atmospheric dilution factor between the release point and the control room that is used in the analysis should be that value that is exceeded only 5% of the time."

Staff requests a clarification on whether the analysis relied upon by the applicant (as discussed in the first paragraph of this RAI) employs the RG 1.78, Section C, 3.3 provisions (quoted in the second paragraph of this RAI). Please provide technical basis and justification to support the explanation.