BWROG ECCS Suction Strainers Risk-Informed Solutions – NRC Public Meeting

Results Addendum


Larry Naron (Exelon) Ed Burns (ERIN Engineering) Bruce Letellier (Alion)



BWR Expertise – Proven Solutions


NRC Public Meeting

Acceptance Guidelines for Core Damage Frequency



NERS' GRI

Acceptance Guidelines for Core Damage Frequency Compared with Uncertainty



FRS' GR

Sensitivities for 2014 Proof of NERS' GRO Principle ACDF Case # Condition **Bed Density** Coatings (Per Rx Yr) 1 Baseline 65 lb/ft3 3.4 L/D topcoated ZOI 8.7E-9 (w/o defense-in-depth 7.4 L/D untopcoated ZOI mitigation measures) Break Dependent ZOI (Spherical ZOI) 65 lb/ft3 2 **Fixed Coating Fixed Qualified Coatings Addition** 2.5E-9 3 Lower Density 55 lb/ft³ 3.4 L/D topcoated ZOI 8.7E-10 7.4 L/D untopcoated ZOI **Break Dependent ZOI** (Spherical ZOI) Combined Cases 2 & 3 4 55 lb/ft³ **Fixed Qualified Coatings Addition** <1.0E-10 5 **Baseline including selected** 65 lb/ft³ 10 I /D auto 70I <1.0E-9 defense-in-depth measures(1) 65 lb/ft³ 6 4.0 L/D topcoated ZOI 1.2E-8 Baseline (w/o defense-in-depth 10 L/D untopcoated ZOI mitigation measures) Larger **Break Dependent ZOI** ZOI (Spherical ZOI)

- ⁽¹⁾ Defense-in-Depth measures included:
 - Strainer backflush
 - Alternate injection from external water source

December 4, 2014

Conclusion



- Demonstration of process and ability to display risk significance of ECCS suction strainer issues compared with established acceptance guidelines
- Deterministic inputs placed in a probabilistic framework provide a structure within which to discuss significance of issues
- Sensitivities and plant specific evaluations provide additional perspective on the safety significance of these issues across the fleet
- Phase 1 results are encouraging for the use of a riskinformed approach as input to decision makers in resolving phenomenological effects on strainer performance