

B 3.7 PLANT SYSTEMS

B 3.7.14 Spent Fuel Pool Boron Concentration

BASES

BACKGROUND In the two region poison fuel storage rack (References. 1 and 2) design, the spent fuel pool is divided into two separate and distinct regions. Region 1, with 286 storage positions, is designed and generally reserved for temporary storage of new or partially irradiated fuel. Region 2, with 1177 storage positions, is designed and generally used for normal, long term storage of permanently discharged fuel that has achieved qualifying burnup levels.

The McGuire spent fuel storage racks have been analyzed taking credit for soluble boron as allowed in Reference 3. The methodology ensures that the spent fuel rack multiplication factor, k_{eff} , is less than or equal to 0.95 as recommended in ANSI/ANS-57.2-1983 (Reference 4) and NRC guidance (Reference. 5). The spent fuel storage racks are analyzed to allow storage of fuel assemblies with enrichments up to a maximum nominal value of 5.00 weight percent Uranium-235 while maintaining $k_{\text{eff}} \leq 0.95$ including uncertainties, tolerances, biases, and credit for soluble boron. Soluble boron credit is used to offset off-normal conditions and to provide subcritical margin such that the spent fuel pool k_{eff} is maintained less than or equal to 0.95. The soluble boron concentration required to maintain k_{eff} less than or equal to 0.95 under normal conditions is 800 ppm. In addition, sub-criticality of the pool ($k_{\text{eff}} < 1.0$) is assured on a 95/95 basis, without the presence of the soluble boron in the pool. The criticality analysis performed shows that the regulatory subcriticality requirements are met for fuel assembly storage within an allowable storage configuration, when the criteria for fuel assembly type, initial enrichment, burnup, and post-irradiation cooling time, as specified in LCO 3.7.15, are satisfied.

APPLICABLE SAFETY ANALYSES Most accident conditions do not result in an increase in reactivity of the racks in the spent fuel pool. Examples of these accident conditions are the drop of a fuel assembly on top of a rack, the drop of a fuel assembly between rack modules (rack design precludes this condition), and the drop of a fuel assembly between rack modules and the pool wall. However, three accidents can be postulated which could result in an increase in reactivity in the spent fuel storage pools. The first is a drop or placement of a fuel assembly into the cask loading area. The second is a significant change in the spent fuel pool water temperature (either the loss of normal cooling to the spent fuel pool water which causes an increase in the pool water temperature or a large makeup to the pool with cold water which causes a decrease in the pool water temperature) and

APPLICABLE SAFETY ANALYSES (continued)

the third is the misloading of a fuel assembly into a location which the restrictions on location, enrichment, and burnup are not satisfied.

For an occurrence of these postulated accidents, the double contingency principle discussed in ANSI N-16.1-1975 and the April 1978 NRC letter (Reference. 6) can be applied. This states that one is not required to assume two unlikely, independent, concurrent events to ensure protection against a criticality accident. Thus, for these postulated accident conditions, the presence of additional soluble boron in the spent fuel pool water (above the 800 ppm required to maintain k_{eff} less than or equal to 0.95 under normal conditions) can be assumed as a realistic initial condition since not assuming its presence would be a second unlikely event.

Calculations were performed to determine the amount of soluble boron required to offset the highest reactivity increase caused by either of these postulated accidents and to maintain k_{eff} less than or equal to 0.95. It was determined that a spent fuel pool boron concentration of 1600 ppm was adequate to mitigate these postulated criticality related accidents and to maintain k_{eff} less than or equal to 0.95. Specification 3.7.14 ensures the spent fuel pool contains adequate dissolved boron to compensate for the increased reactivity caused by these postulated accidents.

Specification 4.3.1.1 c. requires that the spent fuel rack k_{eff} be less than or equal to 0.95 when flooded with water borated to 800 ppm. A spent fuel pool boron dilution analysis was performed which confirmed that sufficient time is available to detect and mitigate a dilution of the spent fuel pool before the 0.95 k_{eff} design basis is exceeded. The spent fuel pool boron dilution analysis concluded that an unplanned or inadvertent event which could result in the dilution of the spent fuel pool boron concentration to 800 ppm is not a credible event.

The concentration of dissolved boron in the spent fuel pool satisfies Criterion 2 of 10 CFR 50.36 (Reference. 5).

LCO

The spent fuel pool boron concentration is required to be within the limits specified in the COLR. The specified concentration of dissolved boron in the spent fuel pool preserves the assumptions used in the analyses of the potential criticality accident scenarios as described in Reference 4. This concentration of dissolved boron is the minimum required concentration for fuel assembly storage and movement within the spent fuel pool.

Bases

APPLICABILITY This LCO applies whenever fuel assemblies are stored in the spent fuel pool.

ACTIONS A.1 and A.2

The Required Actions are modified by a Note indicating that LCO 3.0.3 does not apply.

When the concentration of boron in the fuel storage pool is less than required, immediate action must be taken to preclude the occurrence of an accident or to mitigate the consequences of an accident in progress. This is most efficiently achieved by immediately suspending the movement of fuel assemblies. The concentration of boron is restored simultaneously with suspending movement of fuel assemblies. If the LCO is not met while moving irradiated fuel assemblies in MODE 5 or 6, LCO 3.0.3 would not be applicable. If moving irradiated fuel assemblies while in MODE 1, 2, 3, or 4, the fuel movement is independent of reactor operation. Therefore, inability to suspend movement of fuel assemblies is not sufficient reason to require a reactor shutdown.

SURVEILLANCE
REQUIREMENTS SR 3.7.14.1

This SR verifies that the concentration of boron in the spent fuel pool is within the required limit. As long as this SR is met, the analyzed accidents are fully addressed. The Surveillance Frequency is based on operating experience, equipment reliability, and plant risk and is controlled under the Surveillance Frequency Control Program.

Bases

- REFERENCES
1. UFSAR, Section 9.1.2.
 2. Issuance of Amendments, McGuire Nuclear Station, Units 1 and 2 (TAC NOS. MC0945 and MC0946), March 17, 2005.
 3. 10 CFR 50.68, "Criticality Accident Requirements"
 4. American Nuclear Society, "American National Standard Design Requirements for Light Water Reactor Fuel Storage Facilities at Nuclear Power Plants," ANSI/ANS-57.2-1983, October 7, 1983.
 5. Nuclear Regulatory Commission, Memorandum to Timothy Collins from Laurence Kopp, "Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light Water Reactor Power Plants," August 19, 1998.
 6. Double contingency principle of ANSI N16.1-1975, as specified in the April 14, 1978 NRC letter (Section 1.2) and implied in the proposed revision to Regulatory Guide 1.13 (Section 1.4, Appendix A).
 7. 10 CFR 50.36, Technical Specifications, (c)(2)(ii).
 8. UFSAR, Section 15.7.4.