



15	5/6/92	GEN. UPDATE REDRAWN ON CADD TO IMPROVE LEGIBILITY
14	5/7/12	INC. DUN 05-0255-001-006 REV. 00
13	01-18-03	INC. DCN E-31B-137 PER MOD 90-0002-02
9	5/6/92	GEN. UPDATE REDRAWN ON CADD TO IMPROVE LEGIBILITY

REVISIONS

CONTINUED FROM SH. 2

CONTINUED ON SH. 3A

SCHEME NO. GX01 - CHANNEL A
START-UP SYS. NO. 087/098

THIS DRAWING WAS REDRAWN ON CADD
& IN CONJUNCTION WITH DWG. E-31B SH. 3A
SUPERSEDES REV. 8.

GENERATOR - TRANSFORMER
A RELAY CKTS

NOTES:

- FOR GENERAL NOTES & LOCATION DESIGNATIONS SEE DRAWING INDEX E-31B.
- SEE SHT. 12 FOR 86 DEVICE CONTACT ASSIGNMENTS. SEE SHT. 14 FOR 74D/G CONTACTS 3-7.
- FOR SAFETY FEATURES ACTUATION SYSTEM SEE DRAWING 7749-E-16E.
- SEE DRAWING 7749-E-1-1 FOR $\frac{63FPX}{XT}$ RELAY COIL.
- *4 NOT USED - SEE GE INSTRUCTIONS GEI 10190G.
- FOR DETAILS OF TEST PUSHBUTTON SEE DRAWING E-30B SH. 17 FIG. 5.

SCALE NONE	DESIGNED TG	DRAWN JFS	DATE 03-23-92
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1 THE TOLEDO EDISON COMPANY			
ELEMENTARY WIRING DIAGRAMS GENERATOR AND TRANSFORMER PROTECTION TRIPPING AND LOCK-OUT RELAY CKTS			
DRAWING NO.			REV.
E-31B SH. 3			15