

# OPC Operability

**Robert Carritte**

MPR Associates

Open Phase Issue

January 14, 2015 • Three White Flint

# OPC Operability

- Offsite sources are considered Operable today without an open phase detection / isolation system.
- Modifying the Tech Spec Bases to identify the impact an open phase condition can have on the Operability of the offsite source and various site-specific means for verifying that an open phase condition does not exist seems like the right thing to do.
- We should not commit to declare the offsite source Inoperable just because the open phase detection / isolation system is unavailable.

# OPC Operability

**Robert Carritte**

MPR Associates

Open Phase Issue

January 14, 2015 • Three White Flint