



Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 479-858-4704

Stephenie L. Pyle
Manager, Regulatory Assurance
Arkansas Nuclear One

1CAN011503

January 15, 2015

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: License Amendment Request Supplemental
Technical Specification Change to Extend the
Type A Test Frequency to 15 Years
Arkansas Nuclear One, Unit 1
Docket No. 50-313
License No. DPR-51

Dear Sir or Madam:

Pursuant to 10 CFR 50.90, Entergy Operations, Inc. (Entergy) requested an amendment to Arkansas Nuclear One, Unit 1 (ANO-1) Technical Specifications (TS). Specifically the proposed change would allow for the extension to the ten-year frequency of the ANO-1 Type A or Integrated Leak Rate Test (ILRT) that is required by TS 5.5.16 to be extended to 15 years on a permanent basis (Reference 1).

Due to issuance of ANO-1 TS Amendment 250 on November 24, 2014 (ML14254A133) associated with adoption of TSTF-500, "DC Electrical Rewrite – Update to TSTF-360," the footer of the TS page associated with the ILRT extension request has changed, including the page number. A revised (clean) TS page for the ILRT amendment request is included in the attachment to this letter. No technical information is change on the affected TS page.

In accordance with 10 CFR 50.91(b)(1), a copy of this application is being provided to the designated Arkansas state official.

No new regulatory commitments are included in this letter. With respect to the original Entergy request (Reference 1), changes included in this letter do not invalidate the assessment of the no significant hazards consideration included in the reference letter.

If you have any questions or require additional information, please contact me.

Sincerely,

ORIGINAL SIGNED BY STEPHENIE L. PYLE

SLP/dbb

REFERENCE: 1. Entergy letter to NRC, "License Amendment Request Technical Specification Change to Extend the Type A Frequency to 15 Years," dated December 20, 2013 (1CAN121302) (ML13358A195)

Attachment: Replacement Revised (Clean) Technical Specification Page

cc: Mr. Marc L. Dapas
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
1600 East Lamar Boulevard
Arlington, TX 76011-4511

NRC Senior Resident Inspector
Arkansas Nuclear One
P. O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Ms. Andrea E. George
MS O-8B1
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. Bernard R. Bevill
Arkansas Department of Health
Radiation Control Section
4815 West Markham Street
Slot #30
Little Rock, AR 72205

Attachment to

1CAN011503

Replacement Revised (Clean) Technical Specification Page

5.0 ADMINISTRATIVE CONTROLS

5.5 Programs and Manuals

5.5.16 Reactor Building Leakage Rate Testing Program

A program shall be established to implement the leakage rate testing of the reactor building as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in NEI 94-01, Revision 2-A, "Industry Guideline for Implementing Performance-Based Option of 10 CFR 50, Appendix J," dated October 2008. The next Type A test performed after the December 16, 2005 Type A test shall be performed no later than December 16, 2020.

In addition, the reactor building purge supply and exhaust isolation valves shall be leakage rate tested once prior to entering MODE 4 from MODE 5 if not performed within the previous 92 days.

The peak calculated reactor building internal pressure for the design basis loss of coolant accident, P_a , is 54 psig.

The maximum allowable reactor building leakage rate, L_a , shall be 0.20% of containment air weight per day at P_a .

Leakage rate acceptance criteria are:

- a. Reactor Building leakage rate acceptance criteria is $\leq 1.0 L_a$. During the first unit startup following each test performed in accordance with this program, the leakage rate acceptance criteria are $< 0.60 L_a$ for the Type B and Type C tests and $< 0.75 L_a$ for Type A tests.
- b. Air lock testing acceptance criteria are:
 1. Overall air lock leakage rate is $\leq 0.05 L_a$ when tested at $\geq P_a$;
 2. For each door, leakage rate is $\leq 0.01 L_a$ when tested at ≥ 10 psig.

The provisions of SR 3.0.2 do not apply to the test frequencies specified in the Reactor Building Leakage Rate Testing Program.

The provisions of SR 3.0.3 are applicable to the Reactor Building Leakage Rate Testing Program.