

NRR-PMDAPEm Resource

From: Wiebe, Joel
Sent: Thursday, January 15, 2015 1:34 PM
To: Jessica Krejcie
Subject: Acceptance Review for License Amendment Regarding Request for Diesel Generator Load Rejection Surveillance Requirement

Jessica,

By letter dated December 18, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14352A204), Exelon Generation Company, LLC (Exelon), submitted a license amendment request for Braidwood Station, Units 1 and 2 and Byron Station, Units 1 and 2 to increase the voltage limit for the diesel generator (DG) full load rejection test specified by Technical Specification (TS) Surveillance Requirement (SR) 3.8.1.10. Additionally, the proposed amendment adds Note 3 to TS SR 3.8.1.10 for alignment with the Standard Technical Specifications documented in NUREG-1431. The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your request and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the request in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-6606.

Joel S. Wiebe, Sr. Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Hearing Identifier: NRR_PMDA
Email Number: 1815

Mail Envelope Properties (Joel.Wiebe@nrc.gov20150115133400)

Subject: Acceptance Review for License Amendment Regarding Request for Diesel
Generator Load Rejection Surveillance Requirement
Sent Date: 1/15/2015 1:34:04 PM
Received Date: 1/15/2015 1:34:00 PM
From: Wiebe, Joel

Created By: Joel.Wiebe@nrc.gov

Recipients:
"Jessica Krejcie" <Jessica.Krejcie@exeloncorp.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2119	1/15/2015 1:34:00 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: