

## ENCLOSURE 2

MFN 15-009

Comment Summary Table and Draft SE Markup

Non-Proprietary Information– Class I (Public)

### **IMPORTANT NOTICE**

This is a non-proprietary version of Enclosure 1, which has the proprietary information removed. Portions of the enclosure that have been removed are indicated by white space with an open and closed bracket as shown here [[ ]].

**Comment Summary for Draft Safety Evaluation for  
NEDE-33766P Revision 0,**

**“GEH Simplified Stability Solution (GS3)”**

**Note:** Page numbers shown in this table reflect the page numbers in this enclosure. Due to suggested changes in the Safety Evaluation (SE) and the addition of a change summary table, these page numbers differ from the page numbers in the draft SE sent to GEH for review.

Location	Comment
<p>Section 1.1 Background</p>	<p>Page 13: 2<sup>nd</sup> paragraph under the listed stability options: GEH suggests the following changes: “It is a solution licensed by GEH and based on Option III; it increases the likelihood of necessary scram when <del>an</del> growing power oscillations are <del>is</del> detected by setting all required solution parameters to its most sensitive limit when a rapid change of flow (indicating a recirculation pump trip) is detected. <del>To minimize the likelihood of spurious scrams, To provide a rigorous solution,</del> DSS-CD requires that a number of OPRM strings confirm with the determination that an oscillation is indeed occurring (thus the name confirmation density). <del>DSS-CD has been approved by the staff for use in MELLLA+.”</del></p> <p><i>This clarifies that DSS-CD does not increase the chance of scram, but rather increases the likelihood of necessary scram when growing oscillations are detected. Confirmation density is not only to minimize the likelihood of spurious scrams.</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 3.1 Overview of GS3 Methodology</p>	<p>Page 17: The paragraph starting with “Section 10 of the LTR describes...”: 3<sup>rd</sup> sentence: The link is broken in the parenthetical expression “(see Section 0)”. It should be changed to “(see Section 9)”.</p> <p><i>This is the section in the LTR that contains further discussion about the GS3 applicability envelope.</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 3.1 Overview of GS3 Methodology</p>	<p>Page 17: The paragraph starting with “Section 10 of the LTR describes...”: Last sentence: Change the section number from Section 4.4 to Section 10.</p> <p><i>This is the section in the LTR that contains further discussion about the procedure and checklist for plant-specific applications.</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 3.2 Technical Information</p>	<p>Page 18: Last paragraph in the section: 2<sup>nd</sup> to last sentence: Please provide a reference citation for the staff audit, which is Reference 8.</p> <p>Suggested changes shown in the markup.</p>

Location	Comment
<p>Section 4.2 Applicability of Proposed Envelope for Plants Using Stability Option III</p>	<p>Page 20: 1<sup>st</sup> paragraph in the section: GEH suggests the following changes: “As shown in that figure, the recirculation flow reduction at <math>t \approx 20</math> s results in a significant power-level reduction, which in turn increases the <b>available</b> CPR because, even though the power-to-flow ratio and void fraction remain essentially constant during the 2RPT, the lower power results in larger margins to <b>critical heat flux boiling transition</b>. If the transient is allowed to progress, large amplitude oscillations would occur (in the Figure 2 example, oscillations [[ ]] and grow exponentially). Eventually, the oscillations grow large enough to challenge SAFDLs (in the Figure 2 example, <b>critical heat flux boiling transition</b> is [[ ]]). The LTS setpoint must be reached and the scram must take place before margins to MCPR are depleted. In the Figure 2 example, a simulation of the Option III algorithm shows that the scram would have initiated [[ ]] and suppress the oscillations. <del>(Note that for a typical TRACG calculation, the Option III algorithm scram is not modeled and the transient is allowed to progress without scram; the Option III algorithm is applied as a post processing step to identify when the oscillations would have been mitigated).</del>”</p> <p><i>These changes were made to make the terminology consistent with BWRs, and the parenthetical expression pertaining to how the calculation is performed is unnecessary</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.2 Applicability of Proposed Envelope for Plants Using Stability Option III</p>	<p>Page 21: 3rd paragraph in the section: 2nd sentence: Change the reference number from “[Ref. 8]” to “[Ref. 9]”</p> <p><i>Reference 9 is the correct reference for the RAI responses.</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.4 Applicability of the Plant-Specific Applicability Checklist</p>	<p>Page 24: 2nd paragraph in the section: The link is broken in the parenthetical expression “(see Section 0)”. It should be changed to “(see Section 9)”.</p> <p><i>This is the section in the LTR that contains further discussion about the GS3 applicability envelope.</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.5 Applicability of [[ ]]</p>	<p>Page 24: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”</p> <p><i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i></p> <p>Suggested changes shown in the markup.</p>

Location	Comment
<p>Section 4.6 Legacy Fuel</p>	<p>Page 26: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”</p> <p><i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.6 Legacy Fuel</p>	<p>Page 27: 2<sup>nd</sup> paragraph in the section: GEH suggests the following change: “By the time a fuel bundle has been in the core for two or more cycles (twice- burned), the Gd has essentially been depleted and the U-235 content is relatively low, so that these bundles are not likely to have <del>neither</del> high powers <del>nor</del> or be close to safety limits.”</p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.6 Legacy Fuel</p>	<p>Page 27: 4th paragraph in the section: GEH suggests the following changes: This situation is also likely to occur with LTAs. By its very nature, test assemblies are never located at peak power positions, so that they burn slower than regular fuel. [[</p> <p style="text-align: right;">]]</p> <p><i>The intent that was discussed in the audit is not to explicitly model LUAs/LTAs in TRACG analyses, because of the few fuel bundles involved and because they are loaded in non-limiting core locations. This is a common practice in most reload analyses. The sentence seemed to indicate that the LUAs/LTAs needed to be explicitly modeled until they became "Legacy Fuel."</i></p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.6 Legacy Fuel</p>	<p>Page 27: Last paragraph in the section: GEH suggests the following change: “[[</p> <p style="text-align: center;">]]”</p> <p>Suggested changes shown in the markup.</p>
<p>Section 4.7 [[  ]]</p>	<p>Page 27: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”</p> <p><i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i></p> <p>Suggested changes shown in the markup.</p>

Location	Comment
Section 4.8 [[ ]]	Page 28: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”  <i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i> Suggested changes shown in the markup.
Section 4.8 [[ ]]	Page 28: 1st paragraph in the section: GEH suggests the following changes: “[[ ]] It is noteworthy, that for most cases, the final MCPR <del>is larger</del> at the moment of scram is larger than the IMCPR because of the margin increase provided by the pump trip and associated flow and power decrease.”  <i>The numerical value has been corrected to be consistent with Table 2 in the RAI response            package.</i> Suggested changes shown in the markup.
Section 4.9 [[ ]]	Page 29: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”  <i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i> Suggested changes shown in the markup.
Section 4.9 [[ ]]	Page 29: 2 <sup>nd</sup> paragraph in the section: GEH suggests the following changes: “[[ ]]” Suggested changes shown in the markup.
Section 4.10 [[ ]]	Page 31: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”  <i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i> Suggested changes shown in the markup.

Location	Comment
<p>Section 4.11 Mixed Cores Considerations</p>	<p>Page 33: Paragraph between Figure 12 and Figure 13: GEH suggests the following changes: Figures <del>12</del> 13 and <del>13</del> 14 show the [[</p> <p style="text-align: center;">]]</p> <p><i>The FMCP values were revised to be consistent with the response to RAI 4.</i> Suggested changes shown in the markup.</p>
<p>Section 4.12 Impact of LPRM Failures</p>	<p>Page 34: 1st paragraph in the section: Change the reference number from “[Ref. 7]” to “[Ref. 8]”</p> <p><i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i> Suggested changes shown in the markup.</p>
<p>Section 4.12 Impact of LPRM Failures</p>	<p>Page 34: 2nd paragraph in the section: 2nd sentence: Change the reference number from “[Ref. 8]” to “[Ref. 9]”</p> <p><i>Reference 9 is the correct reference for the RAI responses.</i> Suggested changes shown in the markup.</p>
<p>Section 4.13 Applicability of GS3 to Future Operating Conditions</p>	<p>Page 36: 3<sup>rd</sup> paragraph in the section: Last sentence: Change the reference number from “[Ref. 7]” to “[Ref. 8]”</p> <p><i>Reference 8 is the correct reference for the July 24, 2014 NRC staff audit.</i> Suggested changes shown in the markup.</p>
<p>Section 4.13 Applicability of GS3 to Future Operating Conditions</p>	<p>Page 37: 5th paragraph in the section: Item 3: GEH suggests adding a link for “Figure 3”.</p>

Location	Comment
Section 5.0 Conclusions	<p>Page 38: Item 5: GEH suggests the following change: “5. The use of TRACG04 for the GS3 flow reduction <del>calculations</del>-events is acceptable.”</p> <p>Suggested changes shown in the markup.</p>
Section 6.0 References	<p>Page 39: Reference 3: GEH suggests citing the -A version of this reference, as follows: “3. GE Hitachi Nuclear Energy, “Migration to TRACG04/PANAC11 from TRACG02/PANAC10 for Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications,” <del>NEDO</del> NEDE-32465 Supplement 1P-A, Revision 01, <del>September 2011</del> October 2014. (ADAMS Accession number <del>ML112550358</del> ML14304A306)”</p> <p>Suggested changes shown in the markup.</p>
Section 6.0 References	<p>Page 39: Reference 9: GEH suggests the following correction to the reference title: “9. GE Hitachi Nuclear Energy, “Response to Request for Additional Information Re: GEH Licensing Topical Report NEDE-33766P, <del>GEH Simplified Stability Solution (GS3)</del>,” September 19, 2014. (ADAMS Accession number ML14262A445)”</p> <p>Suggested changes shown in the markup.</p>
Section 6.0 References	<p>Pages 39 through 41: GEH suggests deleting References 10 through 37 since they are not cited in the draft SE. Suggested changes shown in the markup.</p>
Appendix A: Request for Additional Information Evaluation	<p>Page 42: RAI 1: 2<sup>nd</sup> paragraph of the evaluation: GEH suggests the following change: “GEH has committed to incorporate this modified pages in the approved “-A” version of the <del>ede</del> LTR.”</p> <p>Suggested changes shown in the markup.</p>
Appendix A: Request for Additional Information Evaluation	<p>Pages 42 and 43: RAIs 1 through 5: For the following sentence in each RAI evaluation: “The information requested was discussed during the July 2014 audit [Ref. 8], and was documented in the RAI response [Ref. 89].”</p> <p>GEH suggests changing the reference number from “[Ref. 8]” to “[Ref. 9]”</p> <p><i>Reference 9 is the correct reference for the RAI responses.</i></p> <p>Suggested changes shown in the markup.</p>

**Markup of Draft Safety Evaluation for  
NEDE-33766P Revision 0,  
“GEH Simplified Stability Solution (GS3)”**

The following markup illustrates the GEH proprietary content and suggestions per the comment summary table.



## TABLE OF CONTENTS

<b>TABLE OF CONTENTS</b> .....	<b>8</b>
<b>LIST OF FIGURES</b> .....	<b>9</b>
1.1 BACKGROUND .....	12
<b>2.0 REGULATORY EVALUATION</b> .....	<b>14</b>
<b>3.0 SUMMARY OF TECHNICAL INFORMATION</b> .....	<b>15</b>
3.1 OVERVIEW OF GS3 METHODOLOGY .....	15
3.2 TECHNICAL INFORMATION .....	17
<b>4.0 TECHNICAL EVALUATION</b> .....	<b>18</b>
4.1 APPLICABILITY OF TRACG04 FOR GS3 CALCULATIONS.....	20
4.2 APPLICABILITY OF PROPOSED ENVELOPE FOR PLANTS USING STABILITY OPTION III.....	20
4.3 APPLICABILITY OF GS3 TO PLANTS USING STABILITY OPTIONS I-D AND II .....	23
4.4 APPLICABILITY OF THE PLANT-SPECIFIC APPLICABILITY CHECKLIST.....	23
4.5 APPLICABILITY OF [[ .....	24
4.6 LEGACY FUEL.....	26
4.7 [[ .....	27
4.8 [[ .....	28
4.9 [ .....	29
4.10 [[ .....	31
4.11 MIXED CORES CONSIDERATIONS .....	32
4.12 IMPACT OF LPRM FAILURES .....	34
4.13 APPLICABILITY OF GS3 TO FUTURE OPERATING CONDITIONS .....	36
<b>6.0 REFERENCES</b> .....	<b>39</b>
<b>APPENDIX A: REQUEST FOR ADDITIONAL INFORMATION EVALUATION</b> .....	<b>42</b>
RAI-1 REVISED LTR .....	42
RAI-2 REALISTIC CPR LIMITS FOR GS3 APPLICATION.....	42
RAI-3 GS3 SENSITIVITY ANALYSES.....	42
RAI-4 MIXED CORE CONSIDERATIONS.....	42
RAI-5 IMPACT OF LPRM FAILURES ON GS3 RESULTS.....	43

## LIST OF FIGURES

<b>Figure 1. Typical stability exclusion region in the power-flow map.....</b>	<b>19</b>
<b>Figure 2. Typical CPR after a 2RPT that develops unstable oscillations (Fig 9-5, Ref. 1).22</b>	<b>22</b>
<b>Figure 3. CPR response to a 2RPT with unstable oscillations [[</b>	
<b>]].....</b>	<b>23</b>
<b>Figure 4. [[</b>	
<b>Figure 5. [[</b>	
<b>]].....</b>	<b>26</b>
<b>Figure 6. Sensitivity [[</b>	
<b>]].....</b>	<b>28</b>
<b>Figure 7. [[</b>	
<b>]] sensitivity results .....</b>	<b>29</b>
<b>Figure 8. Sensitivity [[</b>	
<b>]].....</b>	<b>30</b>
<b>Figure 9. Sensitivity to [[</b>	
<b>]].....</b>	<b>31</b>
<b>Figure 10. [[</b>	
<b>]] sensitivity.....</b>	<b>32</b>
<b>Figure 11. Mixed core loading [[</b>	
<b>]].....</b>	<b>33</b>
<b>Figure 12. Mixed core loading [[</b>	
<b>]].....</b>	<b>33</b>
<b>Figure 13. [[</b>	
<b>]].....</b>	<b>33</b>
<b>Figure 14. [[</b>	
<b>]].....</b>	<b>34</b>
<b>Figure 15. Typical LPRM to OPRM cell assignment .....</b>	<b>35</b>
<b>Figure 16. LPRM failure cases studied .....</b>	<b>35</b>
<b>Figure 17. Results of random LPRM failures .....</b>	<b>36</b>

**ACRONYMS**

2RPT	Two-Pump Recirculation Pump Trip
$\Delta$ CPR	Delta Critical Power Ratio
AOO	Anticipated Operational Occurrences
APRM	Average Power Range Monitor
BE	Best Estimate
BOC	Beginning of Cycle
BSP	Backup Stability Protection
BWROG	Boiling Water Reactor Owners Group
CPR	Critical Power Ratio
CSAU	Code Scaling Applicability and Uncertainty
D&S	Detect and Suppress
D&SS	Detect and Suppress Solution
DIVOM	Delta Over Initial MCPR Versus Oscillation Magnitude
DSS-CD	Detect and Suppress Solution - Confirmation Density
eDRF	Electronic Design Record File
EOC	End of Cycle
FMCP	Final Minimum Critical Power Ratio
FWHOOS	Feedwater Heater Out Of Service
Gd	Gadolinium
GDC	General Design Criteria
GEH	General Electric, Hitachi
GS3	GEH Simplified Stability Solution
ICPR	Initial Critical Power Ratio
LPRM	Local Power Range Monitor
LTA	Lead Test Assemblies
LTR	Licensing Topical Report
LTS	(Stability) Long Term Solution
MCPR	Minimum Critical Power Ratio
OLMCPR	Operating Limit Minimum Critical Power Ratio
OPRM	Oscillation Power Range Monitor
PBDA	Period Based Detection Algorithm

PHE	Peak Hot Excess
PIRT	Phenomena Identification and Ranking Table
RAI	Request for Additional Information
RPT	Recirculation Pump Trip
SAFDL	Specified Acceptable Fuel Design Limits
SER	Safety Evaluation Report
SLMCPR	Safety Limit Minimum Critical Power Ratio
SLO	Single Loop Operation
TER	Technical Evaluation Report
TH	Thermal Hydraulic
TLO	Two Loop Operation
U-235	Uranium-235

1                                    **SAFETY EVALUATION BY THE OFFICE OF NUCLEAR**  
2                                    **REACTOR REGULATION REGARDING**  
3                                    **LICENSING TOPICAL REPORT NEDE-33766P FOR**  
4                                    **GEH SIMPLIFIED STABILITY SOLUTION**  
5                                    **GE-HITACHI NUCLEAR ENERGY AMERICAS LLC**  
6

7    **1.0    INTRODUCTION**

8    By letter dated September 10, 2013 (Agencywide Documents Access and Management System  
9    (ADAMS) Accession No. ML13254A137), as supplemented on September 19, 2014 (ADAMS  
10    Accession No. ML14262A445), GE-Hitachi Nuclear Energy Americas LLC (GEH) submitted  
11    licensing topical report NEDE-33766P, “GEH Simplified Stability Solution (GS3),” Rev.0. The  
12    proposed topical report would allow an additional methodology for boiling water reactor (BWR)  
13    stability.

14    GS3 is a methodology to demonstrate the validity of stability-related scram setpoints. It does  
15    not require any hardware and/or software change for plants already implementing Options I-D,  
16    II, or III, to which GS3 applies. None of these options are approved for use in MELLLA+; thus  
17    GS3 is not applicable in the MELLLA+ domain. The implementation of the GS3 scram setpoint  
18    methodology does not alter any other plant limitations or restrictions such as SLO or FWHOOS.  
19    GS3 is intended to replace the TRACG DIVOM methodology described in NEDO-32465-A  
20    [Ref. 2] and NEDO-32465, Supplement 1 [Ref.3]. The GS3 methodology improvements are  
21    partly based on approved methodology concepts used in the DSS-CD methodology [Ref. 5].

22    The staff has reviewed the information provided in the LTR and accepted it without limitations.  
23    The main conclusion of the staff evaluation is that the proposed GS3 approach for Option I-D, II,  
24    and III plants provide ample margin for the conditions inside the envelope of applicability and is  
25    an acceptable approach to define scram setpoints.

26                    1.1    **BACKGROUND**

27    Following the March 1988 instability event in the LaSalle boiling water reactor, the Boiling Water  
28    Reactor Owners Group (BWROG) initiated a task to investigate actions that industry should take  
29    to resolve the stability issue as an operational concern. Through analysis, the BWROG found  
30    that the existing plant protection system, which was based on a scram on high average power  
31    range monitor (APRM) signal, may not provide enough protection against out-of-phase modes  
32    of instability; thus, the BWROG decided that a new automatic instability suppression function  
33    was required as a long-term solution and that this function should have a rapid and automatic  
34    response which does not rely on operator action.

1 The BWROG pursued and the staff approved three different long-term stability options, and it is  
2 up to the individual licensees to choose which solution will be implemented in their reactor.  
3 These options can be summarized as follows:

4 **I. Exclusion Region.** A region outside which instabilities are very unlikely is calculated  
5 for each representative plant type using well-defined procedures. If the reactor is  
6 operated inside this exclusion region, an automatic protective action is initiated to exit  
7 the region. This action is based exclusively on power and flow measurements, and the  
8 presence of oscillations is not required for its initiation. Two concepts of type I have  
9 been pursued by the BWROG:

10 **I-A** Immediate protection action (either scram or select rod insert) upon  
11 entrance to the exclusion region.

12 **I-D** Some small-core plants with tight inlet orifices have a reduced likelihood  
13 of out-of-phase instabilities. For these plants, the existing flow-biased high  
14 APRM scram provides a detect and suppress function to avoid safety limits  
15 violation for the expected instability mode. In addition, administrative controls are  
16 proposed to maintain the reactor outside the exclusion region.

17 **II. Quadrant-Based APRM Scram.** In a BWR/2, the quadrant-based  
18 average-power-range monitor is capable of detecting both in-phase and out-of-phase  
19 oscillations with sufficient sensitivity to initiate automatic protective action to suppress  
20 the oscillations before safety margins are compromised.

21 **III. LPRM-Based Detect and Suppress.** LPRM signals or combinations of a small  
22 number of LPRMs are analyzed on-line by using three diverse algorithms. If any of the  
23 algorithms detects unstable power oscillations, automatic protective action is taken to  
24 suppress the oscillations before safety margins are compromised.

25 All the above solutions have been implemented in the United States with some degree of  
26 success. Nevertheless, there are four significant areas of consideration, which merit a revisit of  
27 these long-term solutions. These areas are: (a) deficiencies identified in the CPR versus  
28 oscillation amplitude correlation used for detect and suppress solutions (i.e., the DIVOM  
29 correlation,) which resulted in a Part 21 notification, (b) proposed increases in power density,  
30 (c) the July 2003 Nine Mile Point 2 event, and (d) the December 2004 Perry event. For  
31 MELLLA+ applications, the staff has reviewed and approved two solutions: DSS-CD and EO3.

32 DSS-CD stands for detect and suppress solution – confirmation density. It is a solution licensed  
33 by GEH and based on Option III; it increases the likelihood of necessary scram when ~~an~~  
34 growing power oscillations ~~are~~ detected by setting all required solution parameters to its most  
35 sensitive limit when a rapid change of flow (indicating a recirculation pump trip) is detected. ~~To~~  
36 ~~minimize the likelihood of spurious scrams,~~ To provide a rigorous solution, DSS-CD requires  
37 that a number of OPRM strings confirm with the determination that an oscillation is indeed  
38 occurring (thus the name confirmation density). DSS-CD has been approved by the staff for  
39 use in MELLLA+.

1 EO3 stands for enhanced Option III. EO3 is a mixture of Option III and Option I-A. It sets an  
2 area in the power-flow map where a scram is enforced even if oscillations are not detected.  
3 This region is based on stability criteria for the hot channel, which allows for a well-defined  
4 calculation of the DIVOM slope. EO3 has been approved by the staff for use in MELLLA+.  
5  
6 The DIVOM methodology [Refs. 2, 3] is conservative by design. It was developed to avoid  
7 having to perform a large number of best estimate calculations to demonstrate compliance; thus  
8 a number of conservatisms were required. In the past, industry determined that these  
9 conservatisms were a good trade off when best-estimate calculations were very difficult and  
10 expensive to perform. However, experience over many years of implementation has shown that  
11 the scram setpoints developed using the DIVOM methodology were conservative and satisfied  
12 SAFDL requirements with large margins.

13 GS3 implementation does not require any hardware and software changes for plants licensed  
14 with Options I-D, II, or III, because it is used exclusively to demonstrate the acceptability of the  
15 solution setpoints or exclusion regions. The GS3 standard procedure for plant-specific  
16 confirmations of reload designs is applicable for the GEH BWR/2-6 product lines using TRACG  
17 methodology [Ref. 6], which has been qualified for stability analysis as part of DSS-CD licensing  
18 [Ref. 5].

19 The GS3 LTR [Ref. 1] describes a proposed methodology to replace the DIVOM methodology  
20 [Refs. 2, 3], which is used to demonstrate that LTS scram setpoints satisfy GDC criteria.  
21 Specifically, the GS3 methodology is designed to guarantee that SAFDLs are maintained should  
22 an LTS scram be required. The GS3 methodology is only applicable to D&S-type solutions  
23 where a reactor scram is required to ensure that SAFDLs are maintained. These LTS options  
24 are I-D, II, and III.

25 For plants implementing Option I-D, GS3 is applied to the flow-biased APRM scram line, which  
26 protects the reactor in case of core-wide oscillations. GS3 applies to the quadrant-based APRM  
27 scram in plants implementing Option II, which protects the reactor in case of both core-wide and  
28 regional oscillations. For plants implementing Option III, GS3 applies to the OPRM scram,  
29 which must protect the reactor for both core-wide and regional oscillations.

## 30 **2.0 REGULATORY EVALUATION**

31 The regulatory criteria for this review are based on relevant sections of the Standard Review  
32 Plan [Ref. 7]. Of specific relevance is SRP Section 15.9, "Boiling Water Reactor Stability."

33 The following GDC are applicable to this review:

34 Criterion 10, "Reactor design," requires that:

35 The reactor core and associated coolant, control, and protection systems shall be designed  
36 with appropriate margin to assure that specified acceptable fuel design limits are not  
37 exceeded during any condition of normal operation, including the effects of anticipated  
38 operational occurrences.

1 Criterion 12, "Suppression of reactor power oscillations," requires that:

2  
3 The reactor core and associated coolant, control, and protection systems shall be  
4 designed to assure that power oscillations which can result in conditions exceeding  
5 specified acceptable fuel design limits are not possible or can be reliably and readily  
6 detected and suppressed.

7 To ensure compliance with GDC 10 and 12, the NRC staff confirms that the thermal and  
8 hydraulic design of the core and the reactor coolant system has been accomplished using  
9 acceptable analytical methods, provides acceptable safety margins from conditions that could  
10 lead to fuel damage during normal reactor operation and anticipated operational occurrences,  
11 and is not susceptible to thermal-hydraulic instability or can be reliably and readily detected and  
12 suppressed.

13 Regulatory guidance for the review of the thermal and hydraulic design and the suppression of  
14 reactor power oscillations is provided in NUREG-0800, "Standard Review Plan for the Review of  
15 Safety Analysis Reports for Nuclear Power Plants" (SRP) Section 4.4, "Thermal and Hydraulic  
16 Design," and SRP Section 15.9, "BWR Core Stability." As prescribed in NUREG-0800,  
17 Chapter 4, the NRC staff will confirm that the licensee performs the plant-specific trip setpoint  
18 calculations using NRC-approved methodologies. SRP Section 15.9 describes review  
19 procedures to evaluate the possibility of thermal-hydraulic instability in BWRs, analytical  
20 methods and codes to predict the stability characteristics of BWRs, and the use of approved  
21 long-term stability solutions.

## 22 **3.0 SUMMARY OF TECHNICAL INFORMATION**

### 23 **3.1 OVERVIEW OF GS3 METHODOLOGY**

24

25 GS3 is only a methodology to demonstrate the validity of stability-related scram setpoints. It  
26 does not require any hardware and/or software change for plants already implementing Options  
27 I-D, II, III. The implementation of the GS3 methodology in these plant types does not change  
28 any aspect of the implemented BSP solutions, because the BSP exclusion regions are  
29 preventive in nature (i.e., the scram occurs before oscillations develop) and do not require to  
30 demonstrate additional margins to CPR other than the required steady state operation limits.

31 The DIVOM methodology [Refs. 2, 3] is conservative by design. It was developed to avoid  
32 having to perform a large number of best estimate calculations to demonstrate compliance; thus  
33 a number of conservatisms were required. In the past, industry determined that these  
34 conservatisms were a good trade off when best-estimate calculations were very difficult and  
35 expensive to perform. However, experience over many years of implementation has shown that  
36 the scram setpoints developed using the DIVOM methodology were conservative and satisfied  
37 SAFDL requirements with large margins. The results of these conservatisms in the DIVOM  
38 methodology have caused a significant increase in the stability-related OLMCPRs (for any given  
39 setpoint), making stability the limiting event setting the OLMCPR for several units operating  
40 cycles.



1 The proposed GS3 methodology is essentially a pre-calculation of the required OLMCPR as a  
2 function of either: (1) the selected OPRM scram setpoint for Option III plants, (2) the flow-biased  
3 APRM scram setpoints for each Option I-D plant, or (3) the quadrant based APRM scram  
4 setpoints for each Option II plant. In essence, the plant chooses  
5 [[ ]]] to prevent spurious scrams,  
6 and GS3 specifies the minimum OLMCPR the plant must operate under.

7 The implementation of GS3 for a reload application uses the following steps:

- 8 1. Verification of GS3 applicability. [The GS3 LTR](#) defines an envelope of applicability,  
9 which defines the type of plant, operating parameters and fuel loaded.
- 10 2. For Option III plants, definition of the OPRM scram setpoint that is necessary to avoid  
11 spurious scrams.
- 12 3. Table lookup (in Tables 9-5 to 9-9 of the GS3 LTR [Ref. 1]) to define the minimum  
13 OLMCPR that must be maintained during steady state operation.

14 Tables 9-5 through 9-9 in the GS3 LTR define [[ ]]] that is acceptable  
15 based on either the chosen setpoint (for Option III) or the existing flow-biased or quadrant based  
16 APRM scram (for Option I-D and Option II, respectively). [[ ]]]  
17 is the standard “delta-over-initial” CPR, which is customarily used in other approved  
18 applications (see Ref. 2 or Ref. 5 for other examples where delta-over-initial CPR is used) and  
19 has been demonstrated by example [[ ]]]

20  
21

22 [[ ]]]

23 Different acceptable OLMCPR values are calculated for rated conditions or for single loop  
24 operation because, for SLO, the initiating transient is a one-pump trip and the initial conditions  
25 are not full power, which allow for more operating flexibility, and thus, larger margins are  
26 required.

27 In cases that lay outside the applicability envelope (for example, introduction of new fuel lines),  
28 the GS3 LTR [[ ]]]

29  
30

]]

31 Section 10 of the LTR describes the procedure to implement the GS3 scram-setpoint  
32 methodology in plant-specific applications. Table 10-1 of the LTR defines the applicability  
33 checklist that is used [[ ]]]

34

1   ]] (see Section 09)). Further discussion about the procedure  
2 and checklist for plant-specific applications can be found in Section [4.4.10](#).

3 Table 10-3 of the GS3 LTR, defines the procedures to be followed for the introduction of new  
4 fuel types. The GS3 LTR specifies that [[

5  
6  
7   ]]

8 [[

9

10

11

12

13

14

15   ]] The full CSAU results are documented in Sections 3-7 of the GS3 LTR, and Section

16 8 shows an example application result.

### 17                 3.2     TECHNICAL INFORMATION

18 The LTR is divided into 12 sections. Sections 1 and 2 present an introduction to the report and  
19 the licensing requirements. They also define the scope of the TRACG04 application, which is  
20 limited to [[

21

]]

22 Sections 3, 4, 5, 6, and 7 document the application of the CSAU methodology to GS3  
23 calculations. This CSAU results form the basis for the uncertainty treatment applied to the GS3  
24 setpoints.

25 Section 8 provides an example demonstration analysis. [[

26

27

]]

28 Section 9 documents the generic methodology applicability envelope and  
29 [[   ]] (Section 9.5).

30 Section 10 documents the procedures to be followed for plant-specific applications to verify that  
31 the plant lies within the applicability envelope, and [[

32

]].


33 Sections 11 and 12 present the conclusions and list of references.

1 The information presented in the LTR has been reviewed by the staff along with the responses  
2 to additional information and the information presented during the staff audit [\[Ref. 8\]](#). This  
3 review is documented in Section 4, “**4.0 TECHNICAL EVALUATION**”.

#### 4 **4.0 TECHNICAL EVALUATION**

5 Long term stability (LTS) solutions are designed to protect the reactor for two different types of  
6 transients (See **Figure 1** for reference):

- 7 1. Slow transients associated with startup procedures, where the instability region is  
8 entered slowly and slightly because of control rod motion. These transients have been  
9 observed in the fleet and result in small amplitude oscillations that could be handled  
10 manually by the operator, but the LTS are designed to provide protection. Using **Figure**  
11 **1** as a reference, this type of event would start at low flow-low power, and slowly  
12 increase power by either withdrawing control rods or from an unexpected FW heater  
13 transient.
- 14 2. Fast transients associated with loss of recirculation flow. These transients occur when  
15 one or two recirculation pumps are tripped. The instability region may be entered fully  
16 and rapidly, resulting in large amplitude oscillations that would be hard to manage  
17 manually by the operator. For this event, the initial operating conditions would be a full  
18 power and the flow reduction (e.g., a recirculation pump trip) would force a trajectory  
19 parallel to the blue lines in **Figure 1**, which would enter the exclusion region.



1  
2

Figure 1. Typical stability exclusion region in the power-flow map

1 Fast RPT as described in the second transient above are, thus the most challenging transients  
2 from the point of view of instability and are used to verify the adequacy of the LTS scram  
3 setpoints. Experience has shown that the [[  
4  
5 ]] A 2-pump RPT (2RPT)  
6 [[ ]] is a reasonable transient to demonstrate  
7 performance of a LTS solution performance.

#### 8 4.1 APPLICABILITY OF TRACG04 FOR GS3 CALCULATIONS

9 The GS3 scram-setpoint methodology is based on TRACG04 calculations, which are similar to  
10 the calculations performed for DSS-CD [Ref. 4]. These calculations involve  
11 [[ ]] that results in unstable  
12 power oscillations. As part of the staff review of DSS-CD, TRACG04 was approved for these  
13 types of calculations [Ref.5]. The staff concludes that the use of TRACG04 for GS3 calculations  
14 is within the scope of the previous TRACG04 review [Ref.5]. Therefore, the use of TRACG04  
15 for the GS3 flow reduction calculations is acceptable.

#### 16 4.2 APPLICABILITY OF PROPOSED ENVELOPE FOR PLANTS USING STABILITY 17 OPTION III

18 Figure 2 shows a typical hot channel CPR following a 2RPT at  $t \approx 20$  s. As shown in that figure,  
19 the recirculation flow reduction at  $t \approx 20$  s results in a significant power-level reduction, which in  
20 turn increases the ~~available~~-CPR because, even though the power-to-flow ratio and void fraction  
21 remain essentially constant during the 2RPT, the lower power results in larger margins to ~~critical~~  
22 ~~heat flux~~boiling transition. If the transient is allowed to progress, large amplitude oscillations  
23 would occur (in the Figure 2 example, oscillations [[ ]] and grow exponentially).  
24 Eventually, the oscillations grow large enough to challenge SAFDLs (in the Figure 2 example,  
25 ~~critical heat flux~~boiling transition is [[ ]]). The LTS setpoint must be reached  
26 and the scram must take place before margins to MCPR are depleted. In the Figure 2 example,  
27 a simulation of the Option III algorithm shows that the scram would have initiated [[ ]]  
28 and suppress the oscillations. ~~(Note that for a typical TRACG calculation, the Option III~~  
29 ~~algorithm scram is not modeled and the transient is allowed to progress without scram; the~~  
30 ~~Option II algorithm is applied as a post-processing step to identify when the oscillations would~~  
31 ~~have been mitigated).~~

32 A key result of these simulations is that, for the typical 2RPT, the MCPR at the time of LTS  
33 scram is larger (i.e., safer) at the time of scram than at full-power steady state at  $t \approx 0$  s. This  
34 indicates that the LTS scram is effective. The large conservatisms in the DIVOM methodology  
35 assumptions tend to mask these results, and a best estimate (BE) calculation as presented in  
36 GS3 always presents a more complete picture of the real physics.

1 The 2RPT with instability transient of **Figure 2** is a particular example of the increase in CPR  
2 that results from an RPT. However, it is not unrepresentative. In the responses to request for  
3 additional information (RAI) [Ref. [89](#)], GEH submitted similar [[  
4  
5  
6 seen in this figure that ]] **Figure 3** shows the result of these calculations. It is  
7 [[

8  
9  
10  
11  
12  
13  
14 ]]

15 The results shown in Figure 3 are BE calculations performed at the real operating conditions  
16 expected [[  
17  
18  
19 ]]

20 It must be re-emphasized that the [[ ]] Under  
21 licensing conditions, the plant is allowed to operate just at the OLMCPR limit, [[  
22  
23  
24  
25  
26  
27 ]]

28 It can be concluded from this data that the scram setpoints calculated using the GS3 LTR  
29 methodology provide ample margin for conditions inside the envelope of applicability. Should  
30 [[  
31 ]]

[[

]]

**Figure 2. Typical CPR after a 2RPT that develops unstable oscillations (Fig 9-5, Ref. 1)**

1 [[

2 ]]

3 **Figure 3. CPR response to a 2RPT with unstable oscillations** [[

4 ]]

5  
6 4.3 APPLICABILITY OF GS3 TO PLANTS USING STABILITY OPTIONS I-D AND II

7 Because of the reduced number of US plants using Option I-D and II, the GS3 LTR proposes to  
8 use plant-specific calculations for each plant. GEH has performed these plant-specific  
9 calculations and they are documented in Tables 9-8 and 9-9 of the GS3 LTR [Ref. 1]. This  
10 plant-specific approach for Options I-D and II is acceptable for each of the analyzed plants

11 [[ ]]

12 4.4 APPLICABILITY OF THE PLANT-SPECIFIC APPLICABILITY CHECKLIST

13 Section 10 of the LTR describes the procedure to implement the GS3 scram-setpoint  
14 methodology in plant-specific applications. Table 10-1 of the LTR defines the applicability  
15 checklist that is used to determine if the generic GS3 setpoints may be used for this application.



1 This checklist is used to ensure that the plant and operating conditions lie inside the GS3  
2 applicability envelope (see Section 09).

3 [[

4

5 ]]

6 The staff has reviewed both the applicability checklist and the extension procedure and  
7 concludes that they constitute an acceptable methodology for GS3 implementation.

#### 8 4.5 APPLICABILITY OF [[ ]]

9 During the July 24, 2014 audit [Ref. 78], the staff reviewed a number of electronic design record  
10 files (eDRFs), as well as plots and tables derived from them. For all the calculations reviewed  
11 by the staff, [[ ]]

12 [[

13

14

15 ]] On a typical 2RPT, the CPR increases when the flow is  
16 reduced. Later in the transient, CPR is degraded if oscillations are established. The CPR  
17 increase due to the initial flow/power reduction tends to dominate the final results of the  
18 analysis.

19 [[

20

21 ]] An example is shown in Figure 4. For  
22 all the cases that the staff reviewed, a similar trend was observed. [[ ]]

23 Figure 5 shows a calculation for [[

24

25

26

27

28 ]]

1 [[

2

]]

3

**Figure 4.** [[

]]

1 [[

2 ]]

3 **Figure 5.** [[  
4 ]]

5 4.6 LEGACY FUEL

6 During the July 24, 2014 audit [Ref. 78], the staff reviewed an eDRF of the current Nine Mile |  
7 Point, Unit 1 cycle, which contains a mixture of legacy GE11 and GNF2 fuel in order to  
8 determine the effect legacy fuel has on [[ ]]. All GE11 fuel is twice  
9 burned (i.e. loaded three times in the core). A complete listing of [[

10  
11 |  
12 ]] This makes it highly unlikely that twice burned GE11 fuel  
13 could control the response of the core to an OPRM scram. In this particular example, [[

14  
15 ]]

1 For a given core loading, the “dominant” fuel type is the one with bundles that are closer to  
2 safety limits than the rest of the core. Typically fuel types become “dominant” towards the end  
3 of their first cycle and beginning of the second, when the gadolinium (Gd) burnable poison is  
4 essentially removed, but significant Uranium-235 (U-235) loading remains and these fuel  
5 bundles carry a larger fraction of the power load than the rest of the core. By the time a fuel  
6 bundle has been in the core for two or more cycles (twice- burned), the Gd has essentially been  
7 depleted and the U-235 content is relatively low, so that these bundles are not likely to have  
8 ~~neither~~ high powers ~~nor~~ or be close to safety limits. Once this occurs, these fuel bundles are no  
9 longer “dominant”.

10 “Legacy” fuel types are a consequence of the fuel management chosen by a particular core  
11 designer. As the U-235 content is depleted, the core designer will move these bundles towards  
12 the periphery, where the power is lower and not as much U-235 is needed. Typically, most fuel  
13 bundles stay in the core for three cycles and are removed to the spent fuel pool. However,  
14 under some loading strategies, a few of the thrice-burned bundles will be used in the core  
15 periphery and you can have four- or even five-times burned fuels in a particular core design.  
16 These bundles are always loaded in the periphery, where the power is low. If the plant switched  
17 to a more modern fuel design, the old bundles become known as “legacy” fuels, which are never  
18 located in a core position where they could become close to safety limits. As stated in Section  
19 10.1 of the LTR, [[

20  
21 ]]

22 This situation is also likely to occur with LTAs. By its very nature, test assemblies are never  
23 located at peak power positions, so that they burn slower than regular fuel. [[

24  
25  
26 ]]

27 [[

28  
29  
30 ]]

31 4.7 [[

]]

32 During the July 24, 2014 audit [Ref. [78](#)], GEH presented results of a sensitivity study for [[

33  
34  
35  
36  
37 ]] Figure 6 shows a summary

38 of these results. Nevertheless, because of [[

1  
2 ]] as it is customary. The staff has reviewed the  
3 sensitivity [[  
4 ]]  
5 [[

6 ]]

7 **Figure 6. Sensitivity** [[ ]]

8 4.8 [[ ]]

9 During the July 24, 2014 audit [Ref. 78], GEH presented a number of calculations to attempt to  
10 quantify the impact of [[

11  
12  
13  
14  
15 ]

16 ] It is noteworthy, that for most cases, the final MCPR ~~is larger~~ at the moment of scram is larger  
17 than the IMCPR because of the margin increase provided by the pump trip and associated flow  
18 and power decrease. The NRC staff concluded that [[

19 ]] The staff has reviewed the [[  
20 ]]

1 [[

2 ]]

3 **Figure 7. [[ ]] sensitivity results**

4 4.9 [[ ]]

5 During the July 24, 2014 audit [Ref. [78](#)], a study was presented [[

6 |

7

8 |

9

10 |

11

12 |

13

14 |

15

16

1  
2  
3  
4  
5  
6

has reviewed the sensitivity to [[  
]]

]] The staff

[[

7  
8

**Figure 8. Sensitivity** [[

]]

]]

1 [[

2 ]]

3 **Figure 9. Sensitivity to** [[ ]]

4 4.10 [[ ]]

5 During the July 24, 2014 audit [Ref. [78](#)], analyses were presented for [[ ] |

6 ]]

7 ]] The results of the analyses are

8 presented in Figure 10. [[

9

10

11

12 ]] The staff has reviewed the sensitivity [[

13 ]]



1 [[

2 ]]

3 **Figure 10. [[ ]]** sensitivity

4 4.11 MIXED CORES CONSIDERATIONS

5 GEH has performed a study of the impact of mixed core on [[  
6 ]]. The LTR defines a mixed core as, [[

7  
8  
9

10 ]] Figure 11 and Figure 12 show the assumed core  
11 loadings.

1 [[

2  
3 **Figure 11. Mixed core loading** [[ ]]

4 [[

5  
6 **Figure 12. Mixed core loading** [[ ]]

7 Figures [12-13](#) and [13-14](#) show the [[

8  
9  
10  
11  
12

13 ]]

14 [[

15  
16 **Figure 13.** [[ ]]

1 [[

2 ]]

3 **Figure 14.** [[ ]]

4 4.12 IMPACT OF LPRM FAILURES

5 During the July 24, 2014 audit [Ref. 78], the staff reviewed calculations that show the impact of  
6 LPRM failures on GS3 performance is small and well within the allowed margins. Two types of  
7 failures were analyzed:

- 8 1. [[  
9 2. ]]

10 Figure 15 shows a typical LPRM to OPRM cell assignment, and Figure 16 shows  
11 [[ ]] As seen in the RAI response from September 19, 2014 [Ref.  
12 89], all analyzed [[ ]] of scrambling the reactor earlier than  
13 the nominal condition, resulting on a slightly smaller FMCP (i.e., conservative). Overall, the  
14 [[ ]]

15 Figure 17 shows the results of introducing [[  
16 ]]  
17 ]]

18 The staff concludes that LPRM failures [[  
19 ]]

1 [[

2 ]]  
3 **Figure 15. Typical LPRM to OPRM cell assignment**

4 [[

5 ]]  
6 **Figure 16. LPRM failure cases studied**

1 [[

2 ]]

3 **Figure 17. Results of random LPRM failures**

4 4.13 APPLICABILITY OF GS3 TO FUTURE OPERATING CONDITIONS

5 [[

6 ]]

7 In order to capture these changes and ensure ample margin to SAFDLs while continuing to use  
8 the GS3 methodology, the GS3 methodology provides the licensee of the nuclear power plant  
9 using Option III with two options:

10 1. [[

11 ]]

12 ]]

13 ]]

14 These two options are described further below.

15 [[

16 ]]

17 ]]

18 ]]

19 ]]

20 ]]

21 The staff reviewed the [ ] during the July 24, 2014, audit and made the following  
assessment as documented in the audit report [Ref. 78]:

1 [[  
2  
3  
4 ]]

5 Considering the following sensitivity analyses:

6 1. [[  
7  
8  
9  
10 ]]

11 [[  
12  
13  
14 ]]

15  
16 For plants currently using Options I-D or II, [[  
17 ]]. The acceptable limits are documented in  
18 Tables 9-8 and 9-9 of the LTR. The staff has reviewed these limits and they are acceptable.

19  
20 **5.0 CONCLUSIONS**

21 The NRC staff review of GS3 has reached the following conclusions. No restrictions or  
22 limitations are applied to the GS3 LTR approval.

23 1. The proposed GS3 approach for Option III plants provide ample margin for the  
24 conditions inside the envelope of applicability and is an acceptable approach.

25 2. The proposed plant-specific GS3 approach for Option I-D and II plants provides  
26 demonstrated margin and is an acceptable approach.

27 3. The plant-specific applicability checklist defined in Table 10-1 of the LTR is  
28 acceptable to determine whether a plant-specific application lies within the  
29 applicability envelope.

30 4. [[  
31  
32 ]]



1 **6.0 REFERENCES**

- 2 1. GE Hitachi Nuclear Energy. NEDE-33766P, Revision 0, "GEH Simplified Stability  
3 Solution (GS3)," September 2013. (ADAMS Accession number ML13254A137)
- 4 2. GE Nuclear Energy, "Reactor Stability Detect and Suppress Solutions Licensing Basis  
5 Methodology for Reload Applications," NEDO-32465-A, August 1996. (ADAMS  
6 Accession number ML14093A210)
- 7 3. GE Hitachi Nuclear Energy, "Migration to TRACG04/PANAC11 from  
8 TRACG02/PANAC10 for Reactor Stability Detect and Suppress Solutions Licensing  
9 Basis Methodology for Reload Applications," ~~NEDE-32465 Supplement 1 P-A,~~  
10 ~~Revision 01, September 2011~~[October 2014](#). (ADAMS Accession number  
11 ~~ML112550358~~[ML14304A306](#))
- 12 4. GE Nuclear Energy. NEDC-33075P-A, Revision 8, "Detect and Suppress Solution-  
13 Confirmation Density Licensing Topical Report," November 2013. (ADAMS Accession  
14 number ML13324A098)
- 15 5. GE Hitachi Nuclear Energy, "DSS-CD TRACG Application," NEDE-33147P-A, Revision  
16 4, August 2013. (ADAMS Accession number ML13224A307)
- 17 6. GE Hitachi Nuclear Energy, "TRACG Model Description," NEDE-32176P, Revision 4,  
18 January 2008. (ADAMS Accession number ML080370259)
- 19 7. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for  
20 Nuclear Power Plants." US Nuclear Regulatory Commission.
- 21 8. US NRC, "Audit Report- GEH Simplified Stability Solution (GS3) Reactor Systems  
22 Branch Audit Including the Developed Bounding Envelope," August 18, 2014. (ADAMS  
23 Accession number ML14217A046)
- 24 9. GE Hitachi Nuclear Energy, "Response to Request for Additional Information Re: GEH  
25 Licensing Topical Report NEDE-33766P, [GEH Simplified Stability Solution \(GS3\)](#),"  
26 September 19, 2014. (ADAMS Accession number ML14262A445)
- 27 ~~10. GE Nuclear Energy, "TRACG Qualification," NEDE-32177P, Revision 3, August 2007.~~
- 28 ~~11. GE Nuclear Energy, "TRACG Application for Anticipated Operational Occurrences~~  
29 ~~Transient Analyses," NEDE-32906P-A, Revision 3, September 2006.~~
- 30 ~~12. GE Hitachi Nuclear Energy, "Migration to TRACG04/PANAC11 from~~  
31 ~~TRACG02/PANAC10 for TRACG AOO and ATWS Overpressure Transients,"~~  
32 ~~NEDE-32906P, Supplement 3-A, Revision 1, April 2010.~~



- 1 ~~13. GE Nuclear Energy, "Application of Stability Long Term Solution Option II to Nine Mile~~  
2 ~~Point Nuclear Station Unit 1," GENE A13-00360-02, Revision 1, November 1998.~~
- 3 ~~14. GE Nuclear Energy, "Application of Stability Long Term Solution Option II to Oyster~~  
4 ~~Creek," NEDC 33065P, Revision 0, April 2002.~~
- 5 ~~15. GE Nuclear Energy, "BWR Owners' Group Long Term Stability Solutions Licensing~~  
6 ~~Methodology," NEDO 31960-A, November 1995.~~
- 7 ~~16. GE Nuclear Energy, "BWR Owners' Group Long Term Stability Solutions Licensing~~  
8 ~~Methodology," NEDO 31960-A, Supplement 1, November 1995.~~
- 9 ~~17. GE Hitachi Nuclear Energy, "ODYSY Application for Stability Licensing Calculations~~  
10 ~~Including Option I-D and II Long Term Solutions," NEDE 33213P-A, April 2009.~~
- 11 ~~18. 14. OE23808, "Conservative Oscillating Power Range Monitor Setpoint Causes Half~~  
12 ~~Scram," Hope Creek Unit 1, August 7, 2006.~~
- 13 ~~19. GE Nuclear Energy, "LaSalle 1 and 2 OPRM System Performance Evaluation,"~~  
14 ~~GE-NE-0000-0044-5910-R0, March 2006.~~
- 15 ~~20. OE20368, "Oscillation Power Range Monitor Trip Indication in Single Recirculation Loop~~  
16 ~~Operation—Peach Bottom," Peach Bottom Unit 3, February 11, 2005.~~
- 17 ~~21. AR-00976243 Report, "Unexpected Alarm 903-5-E-6, OPRM Alarm (Dresden Unit 3),"~~  
18 ~~October 7, 2009.~~
- 19 ~~22. OE24212, "Unexpected OPRM Related Half Scram During Plant Start Up (OE24212),"~~  
20 ~~Perry Unit 1, December 20, 2006.~~
- 21 ~~23. OE189536, "Failure of RPS Average Power Range Neutron Monitor Channels," Dresden~~  
22 ~~Unit 3, November 13, 2000.~~
- 23 ~~24. NRC, "Quantifying Reactor Safety Margins: Application of Code Scaling, Applicability,~~  
24 ~~and Uncertainty Evaluation Methodology to a Large Break, Loss-of-Coolant Accident,"~~  
25 ~~NUREG/CR-5249, December 1989.~~
- 26 ~~25. Global Nuclear Fuel, "The PRIME Model for Analysis of Fuel Rod Thermal—Mechanical~~  
27 ~~Performance," Technical Bases—NEDC 33256P-A, Revision 1, Qualification—NEDC~~  
28 ~~33257P-A, Revision 1, and Application Methodology—NEDC 33258P-A, Revision 1,~~  
29 ~~September 2010.~~

- 1 ~~26. Letter from Sher Bahadur (NRC) to Jerald G. Head (GEH), "NRC Audit of GE Hitachi~~  
2 ~~Nuclear Energy Americas Topical Report NEDO 33173, Supplement~~  
3 ~~4 A, "Implementation of PRIME Models and Data in Downstream Methods, (TAC No.~~  
4 ~~ME9033)," October 22, 2012.~~
- 5 ~~27. GE Nuclear Energy, "Steady State Nuclear Methods," NEDE 30130P A, April 1985.~~
- 6 ~~28. Letter from S. A. Richards (NRC) to G. A. Watford (GE), "Amendment 26 to GE~~  
7 ~~Licensing Topical Report NEDE 24011 P A, "GESTAR II" — Implementing Improved GE~~  
8 ~~Steady State Methods (TAC No. MA6481)," November 10, 1999.~~
- 9 ~~29. NRC, "Best Estimate Calculations of Emergency Core Cooling System Performance,"~~  
10 ~~Regulatory Guide 1.157, May 1989.~~
- 11 ~~30. GE Hitachi Nuclear Energy "TRACG Application for ESBWR Stability Analysis,"~~  
12 ~~NEDE 33083P A, Supplement 1, Revision 2, September 2010.~~
- 13 ~~31. GE Nuclear Energy, "Qualification of the One Dimensional Core Transient Model for~~  
14 ~~Boiling Water Reactors," NEDE 24154 P A, August 1986.~~
- 15 ~~32. Global Nuclear Fuel, "General Electric Standard Application for Reactor Fuel,"~~  
16 ~~NEDE 24011 P A and NEDE 24011 P A US, (latest approved revision).~~
- 17 ~~33. S.S. Wilks, "Determination of Sample Sizes for Setting Tolerance Limits," The Annals of~~  
18 ~~Mathematical Statistics, 12, 91-96, 1941.~~
- 19 ~~34. W.T. Nutt and G.B. Wallis, "Evaluation of Nuclear Safety from the Outputs of Computer~~  
20 ~~Codes, Reliability Engineering and System Safety," 83, 57-77, 2004.~~
- 21 ~~35. GE Nuclear Energy, "Methodology and Uncertainties for Safety Limit MCPR~~  
22 ~~Evaluations," NEDC 32601P A, August 1999.~~
- 23 ~~36. GE Nuclear Energy, "Power Distribution Uncertainties for Safety Limit MCPR~~  
24 ~~Evaluations," NEDC 32694P A, August 1999.~~
- 25 ~~37. General Electric, "General Electric BWR Thermal Analysis Basis (GETAB): Data,~~  
26 ~~Correlation and Design Application," NEDE 10958 PA, January 1977.~~
- 27 Principal Contributors: Ashley S. Guzzetta, NRR/DSS/SSIB  
28 Jose March-Leuba, ORNL

1 **APPENDIX A: REQUEST FOR ADDITIONAL INFORMATION EVALUATION**

2 RAI-1 REVISED LTR

3 *Provide any changes to the submitted LTR by topic. Include the revised envelope in*  
4 *Table 9-1, mixed core procedures, a definition of legacy fuel, removal of “BWR/3” in*  
5 *Table 9-5, and inclusion of [[ ]] in Section 9.4 of the cycle-*  
6 *specific application.*

7 The information requested was discussed during the July 2014 audit [Ref. 8], and was  
8 documented in the RAI response [Ref. 89].

9 Attachment 1 to RAI-1 MFN 14-058 Enclosure 1 provides the modified sections of  
10 NEDE-33766P, “GEH Simplified Stability Solution (GS3).” GEH has committed to incorporate  
11 this modified pages in the approved “-A” version of the ~~code~~LTR. The response to this RAI is  
12 acceptable.

13 RAI-2 REALISTIC CPR LIMITS FOR GS3 APPLICATION

14 *Provide a chart of example calculations for cycle-specific GS3 application of GE/GNF*  
15 *fuel in the US BWR fleet. Include BWR type, cycle, fuel, initial minimum critical power*  
16 *ratio (MCPR), final MCPR, and margin to safety limit MCPR. For each plant provide the*  
17 *worst case scenarios when the hot channel is assumed to operate at the anticipated*  
18 *operational occurrence operating limit MCPR limit and at the GS3 OLMCPR limit.*

19 The information requested was discussed during the July 2014 audit [Ref. 8], and was  
20 documented in the RAI response [Ref. 89]. The response to this RAI is acceptable.

21 RAI-3 GS3 SENSITIVITY ANALYSES

22 *Provide results of a GS3 sensitivity study for [[*  
23  *]] for a representative plant. Provide the best*  
24 *estimate and worst case initial condition scenarios*

25 The information requested was discussed during the July 2014 audit [Ref. 8], and was  
26 documented in the RAI response [Ref. 89]. The response to this RAI is acceptable.

27 RAI-4 MIXED CORE CONSIDERATIONS

28 *Provide an analysis of a sample transition from GE 14 to GNF2 over three cycles for a*  
29 *representative plant. Provide radial peaking factors for the two transition cycles*  
30 *identifying the fuel type.*

1 The information requested was discussed during the July 2014 audit [Ref. 8], and was  
2 documented in the RAI response [Ref. 89]. The response to this RAI is acceptable.

3 RAI-5 IMPACT OF LPRM FAILURES ON GS3 RESULTS

4 *Provide a sensitivity analysis for the impact of LPRM failures on GS3 results.*

5 The information requested was discussed during the July 2014 audit [Ref. 8], and was  
6 documented in the RAI response [Ref. 89]. The response to this RAI is acceptable.