



**Pacific Gas and  
Electric Company®**

**James M. Welsch**  
Site Vice President

Diablo Canyon Power Plant  
Mail Code 104/6  
P. O. Box 56  
Avila Beach, CA 93424

805.545.3242  
Internal: 691.3242  
Fax: 805.545.4884

February 25, 2015

PG&E Letter DIL-15-006

ATTN: Document Control Desk, 10 CFR 72.44(d)(3), 10 CFR 72.4  
Director, Division of Spent Fuel Storage and Transportation  
Office of Nuclear Material Safety and Safeguards,  
U.S. Nuclear Regulatory Commission,  
Washington, DC 20555-0001

Materials License No. SNM-2511, Docket No. 72-26  
Diablo Canyon Independent Spent Fuel Storage Installation  
Annual Radioactive Effluent Release Report for 2014

Dear Commissioners and Staff:

Pursuant to 10 CFR 72.4 and 10 CFR 72.44(d)(3), this letter provides the report of the quantity of radionuclides released to the environment in liquid and gaseous effluents due to the operation of the Diablo Canyon (DC) Independent Spent Fuel Storage Installation (ISFSI).

For the year 2014, there were no releases of liquid or gaseous radionuclides to the environment from the operation of the DC ISFSI. The basis for this statement, as documented in the DC ISFSI Updated Final Safety Analysis Report, is that the HI-STORM 100 System does not produce any solid, liquid, or gaseous effluents while in storage. In addition, the all-welded construction of the DC ISFSI Multi-Purpose Canisters precludes the release of radioactive effluents from the HI-STORM 100 System.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this letter.

If you have any questions regarding this submittal, please contact Mr. John Knemeyer at (805) 545-4472.

Sincerely,

James M. Welsch

BNSM/64120620

cc: Diablo Distribution  
John M. Goshen, NMSS Project Manager  
Thomas R. Hipschman, NRC Senior Resident Inspector