



**Luminant**

**Rafael Flores**  
Senior Vice President  
& Chief Nuclear Officer  
Rafael.Flores@Luminant.com

**Luminant Power**  
P O Box 1002  
6322 North FM 56  
Glen Rose, TX 76043

**T** 254 897 5590  
**C** 817 559 0403  
**F** 254 897 6652

CP-201500157  
TXX-15022

Ref. # 10CFR50.55a(g)(6)

February 24 , 2015

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**SUBJECT:** COMANCHE PEAK NUCLEAR POWER PLANT  
DOCKET NO. 50-446  
RELIEF REQUEST NO. 2C3-1 FOR THE UNIT 2 REACTOR PRESSURE VESSEL  
LEAK-OFF FLANGE (THIRD ISI INTERVAL START DATE: AUGUST 3, 2014; THIRD  
ISI INTERVAL END DATE: AUGUST 2, 2023)

- REFERENCES: 1. Letter logged TXX-13145 dated October 13, 2013, from Rafael Flores to the NRC submitting Relief Request No. C-3 for the Unit 2 Second 10 Year ISI Interval From 10CFR50.55a Inspection Requirements Due to Hardship (Second Interval Start Date: August 13, 2004) (ML13312A121) as supplemented by letters dated January 23, and February 11, 2014 (ADAMS Accession Nos. ML 14038A256 and ML 14055A318, respectively).
2. NRC Letter dated April 4, 2014, from Michael T. Markley to Rafael Flores concerning Comanche Peak Nuclear Power Plant, Unit 2 - Approval of Relief Request No. C-3 for the Third 10-Year Inservice Inspection Interval (TAC No. MF2997) (ML14084A291)
3. Letter logged TXX-12129 dated August 23, 2012, from Rafael Flores to the NRC submitting Relief Request No. C-2 for the Unit 1 Third 10 Year ISI Interval From 10CFR50.55a Inspection Requirements Due to Hardship (Third Interval Start Date: August 13, 2012)(ML12250A670) as supplemented by letter dated January 9, 2013 (ML130250339)
4. NRC Letter dated March 19, 2013, from Michael T. Markley to Rafael Flores concerning Comanche Peak Nuclear Power Plant, Unit 1 - Approval of Relief Request No. C-2 for the Third 10-Year Inservice Inspection Interval (TAC No. ME9409) (ML13046A385)

Dear Sir or Madam:

Pursuant to 10 CFR 50.55a (h)(3)(z)(1) Luminant Generation Company LLC (Luminant Power) is submitting Relief Request 2C3-1 for Comanche Peak Nuclear Power Plant (CPNPP) Unit 2 for the third ten year inservice inspection interval. Luminant Power has determined that compliance with certain inspection requirements of ASME Section XI would result in an unnecessary hardship or unusual difficulty without a compensating increase in the level of quality and safety.

The reactor pressure vessel flange leak-off piping configuration precludes system pressure testing when the reactor vessel head is removed. The configuration also precludes pressurizing the line externally

A047  
NRR



COMANCHE PEAK NUCLEAR POWER PLANT UNIT 2  
RELIEF REQUEST NUMBER – 2C3-1 FOR THE REACTOR PRESSURE VESSEL LEAK-OFF FLANGE  
(THIRD 10-YEAR ISI INTERVAL START DATE: AUGUST 3, 2014)

1. **ASME Code Component Affected:**

ASME Code Class:	Code Class 2
References:	ASME Section XI, Table IWC-2500-1 and IWC-5220
Examination Category:	C-H (All Pressure Retaining Components)
Item Number:	C7.10
Description:	Alternative Pressure Testing Requirements for the RPV Flange Leak-Off Piping
Component:	NPS ¾" RPV Flange Seal Leak-Off Piping
Material:	SA376 type 304 or 316 Stainless Steel
Line Numbers:	RC-2-080, RC-2-081, RC-2-082
Plant Drawings:	BRP-RC-2-RB-005, BRP-RC-2-RB-006, BRP-RC-2-RB-007, BRP-RC-2-RB-013, BRP-RC-2-RB-014, BRP-RC-1-RB-042, BRP-RC-1-RB-043, M2-0250

2. **Applicable Code Edition and Addenda:**

The applicable ASME Boiler and Pressure Vessel Code edition and addenda is ASME Section XI, "Rules for Inservice of Nuclear Power Plant Components," 2007 Edition through 2008 Addenda. Hereafter referred to as the "Code."

3. **Applicable Code Requirement:**

ASME Section XI, Subarticle IWC-2500, Table IWC-2500-1, Code Category C-H, Item Number C7.10 requires that all Class 2 pressure retaining components be subject to a system leakage test with a Visual, VT-2 examination each inspection period. The system leakage test is performed at the pressure obtained while the subject portion of the system is performing its normal operating function or during a comparable test.

4. **Reason for Request: Hardship without a compensating increase in quality and safety (10 CFR 50.55a (h)(3)(z)(1)) .**

As discussed in Section 3, "Applicable Code Requirement," ASME Section XI, 2007 Edition through 2008 Addenda requires that Class 2 pressure boundary piping shall be pressure tested once each inspection period. The Reactor Pressure Vessel (RPV) head flange seal leak detection piping is separated from the reactor coolant pressure boundary by one passive membrane, which is an O-ring located on the inner vessel flange as shown in Attachment 2. A second O-ring is located on the outside of the tap in the vessel flange. Failure of the inner O-ring is the only condition under which this line is pressurized. Therefore, the line is not expected to be pressurized during the system pressure test following a refueling outage.

The configuration of this piping precludes system pressure testing while the vessel head is removed because the time required by personnel for the installation and removal of a threaded plug in the flange face to act as a pressure boundary for the test would incur significant dose (estimated 20 – 40 mRem/minute), which would be an ALARA concern. This activity would also present a Foreign Material Exclusion issue for the 1/8" plug that would be required to be installed to complete a leakage test at pressure.

COMANCHE PEAK NUCLEAR POWER PLANT UNIT 2  
RELIEF REQUEST NUMBER – 2C3-1 FOR THE REACTOR PRESSURE VESSEL LEAK-OFF FLANGE  
(THIRD 10-YEAR ISI INTERVAL START DATE: AUGUST 3, 2014)

The configuration also precludes pressurizing the line externally with the head installed at the start of an outage. The top head of the vessel contains two grooves that hold the O-rings. The O-rings are held in place by a series of retainer clips that are housed in recessed cavities in the flange face. If a pressure test were to be performed with the head on, the inner O-ring would be pressurized in a direction opposite to its design function. This test pressure would result in a net inward force on the inner O-ring that would tend to push it into the recessed cavity that houses the retainer clips. The thin O-ring material would likely be damaged by the inward force. The inner O-ring failure would prevent pressure build-up by allowing water to pass by and enter the reactor vessel. To ensure that it was in fact an O-ring failure and not a leak in the leak-off piping, the portion of piping in the reactor vessel nozzle inspection areas ("sandboxes") would have to be inspected. The conditions inside the "sandboxes" at the beginning of the outage prior to removing the head would be considered unsafe with extremely high temperatures and dose ratings ranging from 150 to 250 mRem/hr. The leak-off piping travels through three of the eight "sandboxes". It is felt that performing the examination in this manner would result in an unnecessary hardship without a sufficient compensating increase in the level of quality and safety. Therefore, the only time, other than O-ring failure, that the leak-off lines are fluid filled under any type of pressure is when the head is removed and the cavity flooded.

Attachment 3 contains the piping and instrumentation diagram (P&ID) and the piping isometric drawings showing the subject flange leak-off line.

5. **Burden Caused by Compliance:**

Purposely failing or not installing the inner O-ring in order to perform a pressure test would require purchasing a new O-ring set and the time and radiation exposure associated with removing and reinstalling the RPV head to replace the O-rings would be an undue hardship. Therefore, compliance with the IWC-5221 system leakage test requirements results in an unnecessary hardship without a sufficient compensating increase in the level of quality and safety.

6. **Proposed Alternative and Basis for Use:**

In lieu of the requirements of IWC-5221, a VT-2 visual examination of the accessible areas will be performed each period on the piping subjected to the static pressure head when the reactor cavity is filled. This test will be part of the reactor coolant Class 2 leakage test.

During normal operation, the inner O-ring isolation valve is open. Should the inner O-ring leak, a high temperature alarm actuates at 140 degrees F in the control room, informing the operator of the leak. The operator monitors reactor vessel flange leak-off temperature in accordance the CPNPP alarm procedures (ALM-053A for Unit 1 and ALM-053B for Unit 2) and closes the valve, isolating the leak. The procedure directs shutting the manual isolation valve and opening another valve, transferring RCS pressure boundary maintenance to the outer O-ring. Opening the valve then transfers leak detection to the outer O-ring. All drainage/leakage is piped to the reactor coolant drain tank. The procedure also addresses notifying chemistry department to increase monitoring of the containment atmosphere to detect possible outer O-ring failure; perform an operations test to determine leakage rate as applicable; and initiating corrective action documents to identify the condition and correct the condition as applicable.

COMANCHE PEAK NUCLEAR POWER PLANT UNIT 2  
RELIEF REQUEST NUMBER – 2C3-1 FOR THE REACTOR PRESSURE VESSEL LEAK-OFF FLANGE  
(THIRD 10-YEAR ISI INTERVAL START DATE: AUGUST 3, 2014)

Additionally, the flange seal leak-off line is essentially a leakage collection/detection system and the line would only function as a Class 2 pressure boundary if the inner O-ring fails, thereby pressurizing the line. If any significant leakage does occur in the leak-off line piping itself during this time of pressurization then it would clearly exhibit boric acid accumulation and be discernable during the proposed VT-2 visual examination that will be performed unpressurized as proposed in this request. The elevation of the Reactor Vessel flange is 834' ½". The elevation for the water level when the cavity is flooded is 858" 6". Therefore, the minimum pressure at the opening of the flange leak-off line when the exam is performed is 24' 5 ½ " of static pressure head or 10.6 psi.

The system leakage test will be performed in accordance with ASME Section XI Subarticle IWA-5213(a). A 10-minute hold time will be maintained after test pressure has been reached for Class 2 components that are not in use during normal operating conditions. The subject lines are also not insulated.

There has been no known evidence of corrosion, stress corrosion cracking, or fatigue in the subject flange leak-off piping at Comanche Peak. Database searches for the subject lines in the Comanche Peak Corrective Action Program identified no historical instances of degradation.

**7. Duration of Proposed Alternative:**

This alternative is requested for the Third Inservice Inspection Interval, which began on August 3, 2014 and ends on August 2, 2024.

**8. Precedents:**

- (1) Comanche Peak Nuclear Power Plant, Unit 2 Second Inspection Interval Relief Request C-3 "Alternative Pressure Testing Requirements for the RPV Flange Leak-Off Piping", as approved by the NRC on April 4, 2014 (ML14084A291).
- (2) Comanche Peak Nuclear Power Plant, Unit 1 Third Inspection Interval Relief Request C-2 "Alternative Pressure Testing Requirements for the RPV Flange Leak-Off Piping", as approved by the NRC on March 19, 2013 (ML13046A385).
- (3) LaSalle County Station Third Inspection Interval Relief Request I3R-08. "Pressure Testing of the Reactor Vessel Head Flange Leak Detection System", as approved by the NRC in a letter dated January 30, 2008 (ADAMS Accession No. ML073610587)
- (4) Susquehanna Steam Electric Station Third 10-Year Inservice Inspection (ISI) Interval Program Plan Request for Relief 3RR-07 "Exemption for Pressure Testing Reactor Pressure Vessel Head Flange Seal Leak Detection System", approved by the NRC in a letter dated September 24, 2004 (ADAMS Accession No. ML 042680078)

COMANCHE PEAK NUCLEAR POWER PLANT UNIT 2  
RELIEF REQUEST NUMBER – 2C3-1 FOR THE REACTOR PRESSURE VESSEL LEAK-OFF FLANGE  
(THIRD 10-YEAR ISI INTERVAL START DATE: AUGUST 3, 2014)

9. **Reference:**

Code Case N-805, "Alternative to Class 1 Extended Boundary End of Interval or Class 2 System Leakage Testing of Reactor Vessel Head Flange O-ring Leak Detection System," was issued to the 2010 Edition of the ASME Section XI Code and is listed in Supplement 6 for Code Cases. However, Code Case N-805 has not been approved by the NRC and is not identified in Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1."




Figure A3-23: Phase 2 480VAC FLEX Generator Connection to Plant Support Power

**Reactor Pressure Vessel Seal Leak-Off Details**

**Luminant Power  
Comanche Peak Nuclear Power Plant**






Figure 1:  
REACTOR PRESSURE VESSEL HEAD FLANGE  
LEAK-OFF LINE CONFIGURATION





Figure 2:

Reactor Pressure Vessel Head Flange  
Leak-Off Line Details

**Attachment 3 to TXX-15022**  
**Piping and Instrumentation Diagram**  
**and**  
**Piping Isometric Drawings**



- NOTES:
- 2" ID INSIDE DIAMETER (BY WESTINGHOUSE)
  - 3" ID INSIDE DIAMETER (BY WESTINGHOUSE)
  - 2.75" ID INSIDE DIAMETER (BY WESTINGHOUSE)
  - 4" SPRAY LINE SCOOP
  - ELBOW FLOW METERS INSTALLATION-SEE REF. D ON DRAWING M-1000.
  - VENT PIPE FURNISHED WITH REACTOR VESSEL HEAD.
  - HEAD GASKET MONITORING CONNECTIONS FURNISHED WITH REACTOR VESSEL.
  - RTD INSTALLED IN WELL.
  - CONNECTION LOCATED IN BOTTOM HALF OF REACTOR COOLANT PIPING ON 45° ANGLE TO VERTICAL.
  - LOOP IDENTIFICATION AS SHOWN.
  - 3/4" ID FLOOR RESTRICTOR PROVIDED. (SEE MECHANICAL SYMBOLS AND NOTES DRAWING M-1000, NOTE 10).
  - STRAP-ON SURFACE MOUNTED RTD LOCATED AT BOTTOM OF PIPE.
  - 3" ID OPENING REDUCING ELBOW BY WESTINGHOUSE.
  - 4" FLOOR RESTRICTING SOOOP WITH A RISE OF 0.25" WILL BE SUPPLIED BY VENDOR WITH THE LOOP 1 AND LOOP 4 HOT LEGS.
  - FOR MECHANICAL SYMBOLS AND NOTES SEE DRAWING M-1000.
  - TYGON HOSE TO BE INSTALLED AT THIS CONNECTION FOR DRAINING BOTTOM OF CHANNEL HEAD TO CONTAMINATION SUMP AFTER REACTOR COOLANT SYSTEM HAS BEEN DRAINED BELOW STEAM GENERATOR NOZZLES.
  - DELETED
  - LOCATE CONNECTION OF UPPER 90° OF PIPE CIRCUMFERENCE.
  - DELETED
  - LOCATE N-H MONITOR AS CLOSE AS POSSIBLE TO BIOLOGICAL SHIELD.
  - DELETED
  - USE OF THE NORMAL CHARGING LINE AND ALTERNATE CHARGING LINE SHOULD BE ALTERNATED OVER THE PLANT LIFE SUCH THAT NEITHER PATH WILL BE EXPOSED TO MORE THAN 60% OF THE DESIGN TRANSIENTS INVOLVING COMPLETE STORAGE OF LETHAL AND/OR CHARGING FLOW TRANSFER FROM ONE PATH TO THE OTHER SHOULD BE PERFORMED ONLY AT COLD SHUTDOWN CONDITIONS TO AVOID SUBJECTING THE CHARGING LINES TO UNNECESSARY THERMAL TRANSIENTS.
  - DELETED
  - THESE CONNECTIONS MADE AT 1" IN BOTTOM MOUNTED INSTRUMENTATION THIMBLE NUMBER 46 AND 53 WHICH CORRESPOND TO CORE LOCATIONS J-1 AND H-18 RESPECTIVELY.
  - THE STRAP-ON RTD'S IDENTIFIED ON THE FOLLOWING TABLE ARE USED TO MONITOR THERMAL CYCLING AND STRATIFICATION IN THEIR RESPECTIVE PIPING LEGS. AS NOTED ON THE TABLE THE RTD'S ARE MOUNTED ON EITHER THE TOP OR BOTTOM OF THE PIPE.
- | TOP          | BOTTOM       |
|--------------|--------------|
| 2-TL-3500A-1 | 2-TL-3500B-2 |
| 2-TL-3500B-1 | 2-TL-3500C-2 |
| 2-TL-3500C-1 | 2-TL-3500D-2 |
| 2-TL-3500D-1 | 2-TL-3500E-2 |
- USE 3/8" SS TUBING FOR CONNECTION TO CONTROL ROD DRIVE MECHANISM CONTROL ROD DRIVE MECHANISM HEIGHT INCLUDES FLOW RESTRICTOR TO SERVE AS TRANSITION FROM SAFETY CLASS 1 TO 2.
  - DELETED
  - 2-TL-3618A-LA-2D-1B-2C-1 AND C-2 ARE INSTALLED FOR PERIODIC RCS LEVEL MONITORING. ROOT VALVES ARE NORMALLY CLOSED. FOR ONE INSERVING LINE USE APPLICABLE IPS VALVE. ZRC-803 IS TO BE CAPPED OFF WHEN THE RCS LEVEL MONITORING SYSTEM IS NOT IN SERVICE.


REFERENCE NOTES:  
THIS P&ID DIAGRAM HAS BEEN DERIVED FROM WESTINGHOUSE DRAWING NUMBER (EXCEPT SH 1 OF 2 REV 6 WITH EXCEPTIONS AS FOLLOWS)  
a. VALVE AND LINE NUMBERS HAVE BEEN ADDED.  
b. CONTROL LOOPS HAVE BEEN DELETED EXCEPT FOR THE PRIMARY AND THE FINAL ELEMENTS.  
THE DETAILS OF THE CONTROL LOOPS WILL BE SHOWN ON INSTRUMENTATION AND CONTROL DIAGRAM.

CLASS I  
NUCLEAR SAFETY-RELATED  
SAFETY CLASS 1  
SAFETY CLASS 2  
SAFETY CLASS 3  
SAFETY CLASS 4  
SAFETY CLASS 5  
SAFETY CLASS 6  
SAFETY CLASS 7  
SAFETY CLASS 8  
SAFETY CLASS 9  
SAFETY CLASS 10  
SAFETY CLASS 11  
SAFETY CLASS 12  
SAFETY CLASS 13  
SAFETY CLASS 14  
SAFETY CLASS 15  
SAFETY CLASS 16  
SAFETY CLASS 17  
SAFETY CLASS 18  
SAFETY CLASS 19  
SAFETY CLASS 20  
SAFETY CLASS 21  
SAFETY CLASS 22  
SAFETY CLASS 23  
SAFETY CLASS 24  
SAFETY CLASS 25  
SAFETY CLASS 26  
SAFETY CLASS 27  
SAFETY CLASS 28  
SAFETY CLASS 29  
SAFETY CLASS 30  
SAFETY CLASS 31  
SAFETY CLASS 32  
SAFETY CLASS 33  
SAFETY CLASS 34  
SAFETY CLASS 35  
SAFETY CLASS 36  
SAFETY CLASS 37  
SAFETY CLASS 38  
SAFETY CLASS 39  
SAFETY CLASS 40  
SAFETY CLASS 41  
SAFETY CLASS 42  
SAFETY CLASS 43  
SAFETY CLASS 44  
SAFETY CLASS 45  
SAFETY CLASS 46  
SAFETY CLASS 47  
SAFETY CLASS 48  
SAFETY CLASS 49  
SAFETY CLASS 50  
SAFETY CLASS 51  
SAFETY CLASS 52  
SAFETY CLASS 53  
SAFETY CLASS 54  
SAFETY CLASS 55  
SAFETY CLASS 56  
SAFETY CLASS 57  
SAFETY CLASS 58  
SAFETY CLASS 59  
SAFETY CLASS 60  
SAFETY CLASS 61  
SAFETY CLASS 62  
SAFETY CLASS 63  
SAFETY CLASS 64  
SAFETY CLASS 65  
SAFETY CLASS 66  
SAFETY CLASS 67  
SAFETY CLASS 68  
SAFETY CLASS 69  
SAFETY CLASS 70  
SAFETY CLASS 71  
SAFETY CLASS 72  
SAFETY CLASS 73  
SAFETY CLASS 74  
SAFETY CLASS 75  
SAFETY CLASS 76  
SAFETY CLASS 77  
SAFETY CLASS 78  
SAFETY CLASS 79  
SAFETY CLASS 80  
SAFETY CLASS 81  
SAFETY CLASS 82  
SAFETY CLASS 83  
SAFETY CLASS 84  
SAFETY CLASS 85  
SAFETY CLASS 86  
SAFETY CLASS 87  
SAFETY CLASS 88  
SAFETY CLASS 89  
SAFETY CLASS 90  
SAFETY CLASS 91  
SAFETY CLASS 92  
SAFETY CLASS 93  
SAFETY CLASS 94  
SAFETY CLASS 95  
SAFETY CLASS 96  
SAFETY CLASS 97  
SAFETY CLASS 98  
SAFETY CLASS 99  
SAFETY CLASS 100

LUMINANT  
CPSES  
GLEN ROSE, TEXAS

FLOW DIAGRAM  
REACTOR COOLANT SYSTEM

FSAR FIGURE 5.1-1  
THIS DRAWING CREATED ELECTRONICALLY



BILL OF MATERIAL				
PC NO.	QTY	DESCRIPTION	ASME CODE	COLOR CODE
1	1	1/2" S/160 PIPE 3'-9 1/2" EST LG	SA378	BR/
2	1	1/2" S/160 PIPE 3'-7 1/2" EST LG	SA378	BR/
3	1	1/2" S/160 PIPE 2'-9 1/2" EST LG	SA378	BR/
4	1	1/2" S/160 PIPE 2'-0 1/2" EST LG	SA378	BR/
5	5	1/2" 6000 LB SW 90° ELL	SA182	BR/
6	3	1/2" TB1609 SOMA MS-20A.1	SA182	F316
7	1	1/2" S/160 PIPE	SA378	BR/
8	1	1/2" S/160 PIPE	SA378	BR/
9	1	1/2" S/160 PIPE	SA378	BR/
10	1	1/2" S/160 PIPE	SA378	BR/
11	1	1/2" S/160 PIPE	SA378	BR/
12	1	1/2" S/160 PIPE	SA378	BR/
13	1	1/2" OD TUBE	SA213 TP316	-
14	2	1/2" 6000 LB SW TEE	SA182	BR/
15	1	1/2" 6000 LB SW CPLG	SA182	BR/
16	1	1/2" S/160 SWAGelok PIPE TO TUBE	SA403 WP316	-
17	1	ADAPTOR SS-12-MPW-A-6TSW	SA182	F316
17	2	1/2" TA76DL CP-001S/G Z20	SA182	F316

REV	DATE	BY	CHKD	APPV	REMARKS
CP-6	10/15/02	CP	CP	CP	THIS DRAWING REVISED TO INCORPORATE H-S PUNCHLIST COMMENT AND NOTED.

COMPLETE	M2-0511, M2-0512	DATE	
FLOW DIAG	M2-0250, M2-0264	DATE	1-2002, M-2003
DESIGN CALCD	2501R-2, 2505R-2		

NOTES

- REFER TO MRS (MANUFACTURING RECORD SHEET) FOR TYPE OF MATERIAL USED.
- GRADIENT RC-53 PER FOOT IN PIECE 13 WITH VALVE 2RC-8032 (803) IS ACCEPTABLE.
- GRADIENT OF 1.79 PER FOOT IN TUBING AT DISCHARGE OF 2RC-8032 WITH VALVE AT HIGH END IS ACCEPTABLE.
- 1/2" VALVE BORED TO 3/4" REFERENCE TUE 92-5121 REV Q.

TU ELECTRIC  
CPSES  
GLEN ROSE, TEXAS

IMAGE REFLECTS REACTOR COOLANT DOCUMENT QUALITY

GROUP / ORGANIZATION	CPSES	REVIEWER'S INITIALS AND DATE	
CLASS	CLASS 1	TURNOVER NO.	RFT-M2-5501
REV	1 OF 2	REV	CP-5

02-SEP-1992 13:27









BRP-RC-2-RB-014 SH 1 OF 2




IMAGE REFLECTS DOCUMENT QUALITY

THIS DRAWING CREATED ELECTRONICALLY

GROUP/ORGANIZATION	REV. 2	REORAWN FROM: DWG. BRP-2-RB-014
REVIEWER'S INITIALS AND DATE	CLASS I	ORIG. ORG. TU ELECTRIC

BILL OF MATERIAL

PC NO.	QTY	DESCRIPTION	ASME SPEC	GRADE	COLOR CODE
1	2	1/2" S/160 PIPE 0'-5 3/4" EST LG	SA376	304	BR7
2	1	1/2" S/160 PIPE 7'-3 1/2" EST LG	SA376	304	BR7
3	2	1/2" 6000 LB SW 90° ELL	SA182	304	BR7

REV	DATE	BY	CHKD	APPR	REMARKS
CP-1	10/20/98	...	...	...	THIS DRAWING REVEALS TO INCLUDE THE CONTENTS OF TU ELECTRIC DRG BRP-RC-2-RB-014 REV 2.

NOTICE  
DESIGN CHANGE STATUS OF THIS DRAWING SHALL BE CHECKED AT A PRINTED TERMINAL PRIOR TO USE

SPDOL 1 BY B&R.	DATE	250R-2
COMPONENT	M2-0508, M2-0513	
PLANT	M-2003	

NOTES  
1. REFER TO MRS MANUFACTURING RECORD SHEET FOR TYPE OF MATERIAL USED.



*Kevin D. Hill*  
10-20-98


TU ELECTRIC  
CPSES  
GLEN ROSE, TEXAS

REACTOR COOLANT

TURNOVER NO. RFT-42-3501	DWG. NO. BRP-RC-2-RB-014	SAC NO. 1 OF 2	REV. CP-1
--------------------------	--------------------------	----------------	-----------

FINAL PRINT

BRP-RC-2-RB-042 SH 1 OF 2




BILL OF MATERIAL						
PC NO.	REV.	QUANTITY	DESCRIPTION	ASME ASTM	GRADE	COLOR CODE
1	1	2	1/2" S/160 PIPE 2'-0" EST LG	SA378	TP316	BR/
2	1	2	1/2" S/160 PIPE 2'-4" EST LG	SA378	TP316	BR/
3	1	2	1/2" S/160 PIPE 1'-3" EST LG	SA378	TP316	BR/
4	1	2	1/2" S/160 PIPE 1'-2" EST LG	SA378	TP316	BR/
5	1	2	1/2" S/160 PIPE 4'-0" EST LG	SA378	TP316	BR/
6	3	2	1/2" 6000 LB SW 90° ELL	SA182	TP316	BR/
7	1	2	1" 6000 LB SW 45° ELL	SA182	TP316	BR/
8	1	2	1" 6000 LB SW 45° ELL	SA182	TP316	BR/
9	1	2	1" x 1/2" 6000 LB SW RED INSERT	SA182	TP316	BR/

REV	DATE	BY	CHKD	APPV	REMARKS
CP-4	10/23/92	JW	TR	JW	THIS DRAWING REVISED FOR EDITORIAL CHANGES AS NOTED.

COMPANY	M2-0308, M2-0507	PROJECT	
FLOW NO.	M2-0250	SPICE	M-2003
		DESIGN CAT./NO.	250WR-2

NOTES  
 1. REFER TO MRS (MANUFACTURING RECORD SHEET) FOR TYPE OF MATERIAL USED.  
 2. 1" 45° SW ELL IS WELDED DIRECTLY TO INNER MONITOR NOZZLE. CLASS 1 TO CLASS 2 BREAK OCCURS UPSTREAM OF THIS NOZZLE.



TU ELECTRIC  
 CPSES  
 GLEN ROSE, TEXAS

REACTOR COOLANT

GROUP/ ORGANIZATION									
REVIEWER'S INITIALS AND DATE									

CLASS I  
 QUALITY CONTROLLED  
 BY: [Signature]


TURNOVER NO.	REV. NO.	SH. NO.	REV.
RFT-M2-5501	BRP-RC-2-RB-042	1 OF 2	CP-4

THIS DRAWING CREATED ELECTRONICALLY

FINAL PRINT

21-OCT-1992 13:20

BRP-RC-2-RB-043 SH 1 OF 2



BILL OF MATERIAL						
PC NO.	REQ.	CLASS	DESCRIPTION	ASME	GRADE	COLOR CODE
1	1	2	3/4" 5/160 PIPE 2'-2 1/4" EST LG	SA376	WPS	BR/
2	1	2	3/4" 5/160 PIPE 2'-2 1/4" EST LG	SA376	WPS	BR/
3	1	2	3/4" 5/160 PIPE 1'-9 1/4" EST LG	SA376	WPS	BR/
4	1	2	3/4" 5/160 PIPE 16'-7 1/4" EST LG	SA376	WPS	BR/
5	1	2	3/4" 5/160 PIPE 3'-6 1/4" EST LG	SA376	WPS	BR/
6	3	2	3/4" 6000 LB SW 90° ELL	SA182	WPS	BR/
7	1	2	1" 6000 LB SW 45° ELL	SA182	WPS	BR/
8	1	2	3/4" 6000 LB SW 45° ELL	SA182	WPS	BR/
9	1	2	1 1/2" 6000 LB SW RED INSERT	SA182	WPS	BR/

REV	DATE	BY	CHKD	APPV	REMARKS
2	10/22/92	WPS	WPS	WPS	THIS DRAWING REVISED TO INCORPORATE W-9 PURCHASER COMMENTS.

COMPONENT	ITEM NO.	QUANTITY	UNIT	REMARKS
M2-0507				
M2-0250				
M-2003				
2501R-2				

NOTES

- REFER TO WPS MANUFACTURING RECORD SHEET FOR TYPE OF MATERIAL USED.
- 1" 45° SW ELL IS WELDED DIRECTLY TO OUTER MONITOR NOZZLE. CLASS 1 TO CLASS 2 BREAK OCCURS UPSTREAM OF THE NOZZLE.

TU ELECTRIC  
CPSES  
GLEN ROSE, TEXAS

REACTOR COOLANT

GROUP/ ORGANIZATION										
REVIEWER'S INITIALS AND DATE	N/A									

THIS DRAWING CREATED ELECTRONICALLY

CLASS 1  
WPS  
WPS  
WPS

FORMER NO.	DATE	REV.
RP T-M2-9501		

BRP-RC-2-RB-043 SH 1 OF 2 CP-3

21-OCT-1992 EN-33

HRCR00433.1GN

FINAL PRINT