



NUCLEAR ENERGY INSTITUTE

DE?
D Attachment?
D Status?
+ Next steps?
— BEA

CHRIS EARLS
Senior Director

1201 F Street, NW, Suite 1100
Washington, DC 20004
P: 202.739.8130
jhr@nei.org
nei.org

February 18, 2015

Mr. Brian Holian
Deputy Director, Engineering and Corporate Support
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Subject: NRC Review of Technical Updates to the EPRI Motor Operated Valve Performance Prediction Methodology Software Versions 3.4 and 3.5 (Updates)

Project Number: 689

Dear Mr. Holian:

On March 10 and June 17, 2014, the Nuclear Energy Institute (NEI) submitted to the U.S. Nuclear Regulatory Commission (NRC) a report by the Electric Power Research Institute (EPRI) entitled, "Summary of Technical Updates to EPRI MOV PPM Software Versions 3.4 and 3.5". NEI requested that the NRC review and prepare a supplemental safety evaluation for EPRI's updated motor-operated valve (MOV) performance prediction methodology, pursuant to 10 CFR § 170.11(a)(1)(iii). A fee waiver was also requested which was subsequently denied (ML14099A2020 & ML14176B177)

The purpose of this letter is to request that NRC review and then prepare a Supplement 5 to the NRC Safety-Evaluation on EPRI Topical Report 103237 "EPRI Motor-Operated Valve Performance Prediction Program" addressing Technical Updates to EPRI MOV PPM Software Versions 3.4 and 3.5. EPRI understands the NRC's response to the Fee Waiver Request and agrees to pay the required fee.

All NRC fees will be paid directly by EPRI and all bills should be sent to the following address:

EPRI
Attention: Accounts Payable Dept.
3420 Hillview Avenue
PO Box 10412
Palo Alto, CA 94304

If there are any questions on these matters, please contact me (202-739-8078), cee@nei.org or John Hosler (704-252-0780), JHOSLER@epri.com.

NUCLEAR. CLEAN AIR ENERGY

D046
HRR

Add: J. Holonich to ERLOS

Mr. Brian Holian
February 18, 2015
Page 2

Sincerely,

A handwritten signature in black ink that reads "Chris Earls". The signature is written in a cursive style with a long horizontal stroke extending to the right.

Mr. Chris Earls, NEI

Attachment

c: Mr. John Hosler, EPRI