

April 17, 2015

MEMORANDUM TO: Timothy J. McGinty, Director
Division of Safety Systems
Office of Nuclear Reactor Regulation

FROM: Christopher P. Jackson, Chief */RA/*
Reactor Systems Branch
Division of Safety Systems
Office of Nuclear Reactor Regulation

SUBJECT: GAS MANAGEMENT ACTION PLAN UPDATE

The enclosure to this memorandum contains a version of the gas management action plan that can be publically released, prepared in accordance with the requirements of LIC-502, which describes, schedules, and tracks the ongoing activities related to gas management.

These activities include continued collection of information, assessment of the industry's responses, participation in codes and standards activities and development of regulatory products. This action plan focuses on gas management in systems that are important to safety and the potential nuclear safety, public health and environmental effects of gas accumulation.

Enclosure:
NRR Action Plan

CONTACT: Jennifer M. Whitman, DSS/SRXB
(301) 415-3253

Warren C. Lyon, DSS/SRXB
(301) 415-2897

April 17, 2015

MEMORANDUM TO: Timothy J. McGinty, Director
Division of Safety Systems
Office of Nuclear Reactor Regulation

FROM: Christopher P. Jackson, Chief */RA/*
Reactor Systems Branch
Division of Safety Systems
Office of Nuclear Reactor Regulation

SUBJECT: GAS MANAGEMENT ACTION PLAN UPDATE

The enclosure to this memorandum contains a version of the gas management action plan that can be publically released, prepared in accordance with the requirements of LIC-502, which describes, schedules, and tracks the ongoing activities related to gas management.

These activities include continued collection of information, assessment of the industry's responses, participation in codes and standards activities and development of regulatory products. This action plan focuses on gas management in systems that are important to safety and the potential nuclear safety, public health and environmental effects of gas accumulation.

Enclosure:
NRR Action Plan

CONTACT: Jennifer M. Whitman, DSS/SRXB
(301) 415-3253

Warren C. Lyon, DSS/SRXB
(301) 415-2897

DISTRIBUTION:

JWhitman WLyon CJackson AMendiola SSanders
DSS R/F MHam RElliott JDonoghue SStuchell MHoncharik

ADAMS Accession No.: ML15070A154

***via email**

NRR-106

OFFICE	NRR/DSS/SRXB	NRR/DSS/SRXB	NRR/DSS/STSB*	NRR/DSS/SRXB:BC
NAME	JWhitman	WLyon	RElliott	CJackson
DATE	3/16/2015	3 / 24 /2015	3 / 13 /2015	4 / 17 /2015

OFFICIAL RECORD COPY

NRR ACTION PLAN

March 2015

GAS MANAGEMENT

TAC NO. ME4565
Yellow Ticket No. Y020100159

Last Update: February, 2014
Lead Division: DSS
Supporting Divisions: DPR, PGCB, PRPB, ITSB

The Gas Management NRR Action Plan consists of actions to (1) close Generic Letter (GL) 2008-01, (2) create a comprehensive gas management document, (3) address technical specification (TS) issues, and (4) address vortexing, gas transport, operability, and design basis (DB) issues that were not covered in Item 2. Items 1 and 2 have been completed. Selected schedule information is provided in the following table:

Item No.	Milestone ¹	Date (T=target) (C=Complete)	Lead	Support
1	Close GL 2008-01	07/07/11 (C)	SRXB J. (Gall) Whitman	PGCB E. Bowman
	NEI gas management workshop with over 200 attendees	01/08 (C)	SRXB W. Lyon	
	Issue GL 2008-01 (GL, January 11, 2008)	01/11/08 (C)	W. Lyon	
	Receive Licensee 3-Month Responses	04/11/08 (C)	DORL PM	
	Review 3-Month Responses	08/11/08 (C)	W. Lyon	
	Receive Licensee 9-Month Responses	11/11/08 (C)	DORL PM	
	Industry meeting at Westinghouse offices	12/05/08 (C)	SRXB D. Woodyatt W. Lyon	
	Industry meeting at Westinghouse offices	01/30/09 (C)	D. Woodyatt W. Lyon	
	NEI workshop at Dana Point, CA	02/10-12/09 (C)	D. Woodyatt W. Lyon	
	Industry meeting at NEI	03/19/09 (C)	D. Woodyatt W. Lyon	
	Issue Assessment Guidance to Industry (Ruland, May 28, 2009)	05/28/09 (C)	W. Lyon	
	Issue Temporary Instruction (TI) 2515/177 (NRC, June 9, 2009)	06/09/09 (C)	W. Lyon	DIRS/IRIB S. Vaughn
	NEI / Industry / NRC meeting	01/06/10 (C)	W. Lyon	
	Workshop	01/21/10 (C)	W. Lyon	
	Industry meeting at NEI	06/02/10 (C)	W. Lyon	
	Complete Initial GL 2008-01 Response Reviews, Provide Requests for Additional Information (RAIs)	12/30/10 (C)	J. (Gall) Whitman	
	Receive RAI Responses	05/17/11 (C)	DORL PM	
	TI 2515/177 Inspection Guidance to Regions (NRC, May 23, 2011)	05/25/11 (C)	W. Lyon	

¹ The list of meeting is incomplete and is provided to illustrate continued Nuclear Energy Institute (NEI) / industry / NRC interactions in support of gas-related issues.

ENCLOSURE

Item No.	Milestone ¹	Date (T=target) (C=Complete)	Lead	Support
	Complete GL Response Reviews	06/09/11 (C)	J. (Gall) Whitman	
	Send Individual Closure Memos to Licensees	06/30/11 (C)	DORL PM	
	Complete GL Closure Memo (Ulses, July 5, 2011)	07/05/11 (C)	J. (Gall) Whitman	
2	Create Comprehensive Gas Management Document (See also Item 4.)	05/27/14 (C)	W. Lyon	J. (Gall) Whitman
	Define Acceptable Pump Suction Void Fractions	06/30/10 (C)	W. Lyon	
	Regulatory Information Conference (RIC) session	03/11/13 (C)	J. (Gall) Whitman C. Jackson W. Lyon	
	Issue Safety Evaluation Report (SER) that endorses NEI-09-10 (NRC, April, 2013)	03/19/13 (C)	J.(Gall) Whitman W. Lyon	PLPB S.Stuchell
	Issue Regulatory Issue Summary (RIS) that announces endorsement of NEI 09-10 (NRC, August 23, 2013)	03/23/13 (C)	W. Lyon	S.Stuchell
	Issue Comprehensive Gas Assessment update report (Proprietary)	05/27/14 (C)	W. Lyon J. (Gall) Whitman C. Jackson	
3	Engage Licensees to Modify TSs to Ensure Adequate Protection	Ongoing	ITSB M.Hamm	
	Receive Technical Specification Task Force (TSTF) 523 Rev 0 (Schrader, June 29, 2010)	06/29/10		
	TSTF 523 Meetings with Industry	09/30/10 (C) 01/12/11 (C)	J. (Gall) Whitman	PRPB M. Honcharik
	Accept Industry TSTF for Review (Honcharik, March 2, 2011)	03/02/11 (C)	J. (Gall) Whitman	M. Honcharik
	SRXB RAIs	05/10/12 (C)	W. Lyon A. Ulses	
	Reject Proposed TSTF (Jolicoeur, May 25, 2011)	05/25/11 (C)	J. (Gall) Whitman	M. Honcharik
	SE on TSTF-523 Rev 1 (NRC, December, 2012)	12/12 (C)	J. (Gall) Whitman W. Lyon	M. Hamm
	TSTF-523 Rev 2 (TSTF, February 21, 2013)	02/21/13 (C)		M. Hamm
	Publish Federal Register Notice for public comment	09/02/13 (C)		M. Hamm
	Resolve any comments and issue Notice of Availability in Federal Register	12/23/13 (C)	M. Honcharik	M. Hamm
	Licensees Adopt TSTF	Ongoing		
4	Gas Transport and Vortexing Issues	07/31/15 (T)	W. Lyon J. Whitman	J. Holonich
	SRXB inspection support for Millstone ²	10/08 (C)	W. Lyon	
	Meeting with industry to review Purdue Tests	07/07/09 (C)	G. Cranston D. Woodyatt W. Lyon	
	NRC Information Notice 2010-11	06/16/10 (C)	D. Garmon W. Lyon	
	Byron inspection support regarding GOTHIC	01/04/11 (C)	W. Lyon	
	Tele-conference covering planning to discuss computational methodologies	05/17/11 (C)	D. Woodyatt, W. Lyon	
	Input for Prairie Island inspection	06/05/11 (C)	W. Lyon	
	NRC Information Notice 2011-17	07/26/11 (C)	J. (Gall) Whitman W. Lyon	

² Identification of inspection support activities is provided to illustrate continuing involvement. The list is not complete.

Item No.	Milestone ¹	Date (T=target) (C=Complete)	Lead	Support
	Initial Farley Vortex assessment	05/02/12 (C)	W. Lyon	
	SRXB support for DC Cook inspection	06/03/12 (C)	W. Lyon	
	Observe aux feedwater pump test	11/12 (C)	J. Miller	W. Lyon
	Completion of Kewaunee Inspection Support	01/13 (C)	J. Miller W. Lyon	
	Byron inspection support report	02/15/13 (C)	W. Lyon	
	NEI / industry / NRC meeting to discuss vortexing	04/18/13 (C)	W. Lyon	S. Stuchell
	Prairie Island TI-177 SRXB support (further assessment continuing)	07/23/14 (C)	W. Lyon	
	Robinson inspection support report (Lyon, September 24, 2013)	09/27/13 (C)	W. Lyon	
	Ft. Calhoun Inspection Report	03/06/14 (C)	W. Lyon	
	Complete Farley vortex assessment	05/25/14 (C)	R. Nease	W. Lyon
	McGuire inspection support report	07/22/14 (C)	W. Lyon C. Jackson	
	Complete SRXB N. Anna Vortex Inspection support	08/02/14	W. Lyon	
	NEI / industry /NRC meeting to discuss gas issues	08/19/14 (C)	W. Lyon	J. Holonich
	Draft NUREG that addresses gas issues	10/05/14 (C)	W. Lyon J. Whitman	
	SRXB support for Summer inspection	12/20/14 (C)	W. Lyon	
	NEI / industry / NRC meeting to discuss gas issues	01/15/15 (C))		
	SRXB support for Farley inspection	continuing	W. Lyon	
	Send NUREG to other offices for concurrence	04/30/15 (T)	W. Lyon	
	Transmit draft NUREG to NEI for proprietary review	05/16/15 (T)	C. Jackson	
	Receive NEI proprietary review response	06/ 13/15(T)	-	
	Submit NUREG to FRN for publishing	07/13/15 (T)	W. Lyon J. Whitman	J. Holonich
	Publish in FRN	N		
	Receive comments on NUREG	N+60		J. Holonich
	Decision regarding future publications such as RG or other regulatory products	N+90	C. Jackson	W. Lyon J. Whitman
	Address comments and modify NUREG as necessary	N+100	W. Lyon	
	Submit NUREG for final publishing	N+125	ADMIN	J. Holonich
5	Complete Gas Management Action Plan	07/31/16 (T)	W. Lyon J. Whitman	J. Holonich

Description:

A review of operating experience and U.S. Nuclear Regulatory Commission (NRC) inspection results showed that gas accumulation events involving systems that are important to safety have rendered or potentially rendered these risk-significant systems inoperable. The number of identified gas accumulation events and their significance at some facilities raised concerns about whether similar unrecognized design, configuration, and operability problems existed at additional facilities.

System designs vary widely regarding potential gas sources and capability to control gas. It is important that the subject systems are sufficiently filled with water to ensure that they can reliably perform their intended functions under all loss-of-coolant accident (LOCA) and non-

LOCA conditions that require makeup to the reactor coolant system (RCS). The final safety analysis reports (FSARs) at many facilities state that some systems are full of water and technical specifications (TSs) often require periodic surveillances to confirm this condition. Some plant TSs have incomplete surveillance requirements (SRs) that cover only portions of a system. The current staff position is that standard SRs are needed to ensure compliance and adequate protection to the health and safety of the public. The staff is pursuing TS changes with industry through the TSTF process.

Regulatory Requirements:

The regulation at Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.36(c) requires, in part, that TS include SRs. The regulation at 10 CFR 50.36(c)(3) states that SRs are “requirements relating to test, calibration, or inspection to assure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions for operation will be met.”

The regulations in Appendix A to 10 CFR Part 50 or similar plant-specific principal design criteria³ provide design requirements, and Appendix B to 10 CFR Part 50, TSs, and licensee quality assurance programs provide operating requirements. Appendix A requirements applicable to gas management include the following:

- General Design Criterion (GDC) 1 requires that the systems be designed, fabricated, erected, and tested to quality standards.
- GDC 34 requires a residual heat removal (RHR)⁴ system designed to maintain specified acceptable fuel design limits and to meet design conditions that are not exceeded if a single failure occurs and specified electrical power systems fail.
- GDCs 35, 36, and 37 require an emergency core cooling system (ECCS) design that meets performance, inspection, and testing requirements.
- GDCs 38, 39, and 40 require a containment heat removal system design that meets performance, inspection, and testing requirements

Quality assurance criteria provided in Appendix B that apply to gas management include the following:

- Criteria III and V require measures to ensure that applicable regulatory requirements and the design basis, as defined in 10 CFR 50.2, “Definitions,” and as specified in the license application, are correctly translated into controlled specifications, drawings, procedures, and instructions.
- Criterion XI requires a test program to ensure that the subject systems will perform satisfactorily in service. Test results shall be documented and evaluated to ensure that test requirements have been satisfied.
- Criterion XVI requires measures to ensure that conditions adverse to quality, such as failures, malfunctions, deficiencies, deviations, defective material and equipment, and

³ These apply to facilities with a construction permit issued before May 21, 1972, which were not licensed under Appendix A.

⁴ RHR and decay heat removal (DHR) are different names for the same system.

nonconformances, are promptly identified and corrected, and that significant conditions adverse to quality are documented and reported to management.

- Criterion XVII requires maintenance of records of activities affecting quality.

Background:

Instances of gas accumulation in plant systems have occurred since the beginning of commercial nuclear power plant operation. The NRC has published 21 information notices (INs), three Generic Letters (GLs), and NUREG and NUREG/CRs related to this issue and has interacted with the nuclear industry many times in relation to these publications and in response to gas accumulation events. Despite this history, and in many instances inconsistent with the above regulatory requirements, licensees continued to inadequately address gas accumulation issues. This situation changed as a result of plant shutdowns due to gas issues, workshops to address the issues, and following publication of GL 2008-01 and the Institute of Nuclear Power Operations Significant Operating Event Report (SOER) 2-05 (INPO, January 9, 2008).

GL 2008-01 requested that each addressee evaluate its ECCS, DHR system, and containment spray system licensing basis, design, testing, and corrective actions to ensure that gas accumulation is maintained less than the amount that challenges system operability. The INPO SOER 2-05 Rev. 1 also recommended that licensees take appropriate action when conditions adverse to quality are identified. The combination of inspections, plant shutdowns, workshops, meetings, GL 2008-01 and INPO SOER 2-05 Rev. 1 resulted in an in-depth industry effort to address many of the issues. This resulted in a significant and continuing improvement in addressing gas management issues, although further NRC guidance and improvement is needed for some issues, such as gas transport, vortexing, and addressing the DB.

NEI 09-10 Revision 1a-A (NEI, April, 2013), hereafter referred to as NEI 09-10, addressed issues that were identified in GL 2008-01 and INPO SOER 2-05 Rev. 1, during evaluations of industry operations, and in meetings and workshops. It provided recommendations and guidance to nuclear power plant licensees for development and implementation of programs and processes to prevent and manage gas intrusion and gas accumulation in plant systems. The focus was on aspects necessary to maintain operability. This was endorsed in an NRC Safety Evaluation (SE) and announced in a Regulatory Issue Summary (RIS).

The NRC is aware of many potentially significant gas intrusion events that have occurred since GL 2008-01 was issued for comment.⁵ To assess the licensee's evaluations and actions, the NRC requested the licensees "submit information to demonstrate that the subject systems are in compliance with the current licensing and design bases and applicable regulatory requirements, and that suitable design, operational, and testing control measures are in place for maintaining this compliance." The NRC further stated that it would "collect the requested information to determine if additional regulatory action is required." The licensees were requested to submit a written response consistent with the requested actions and information within 9 months of the issuance of the GL. A preliminary assessment of each 9-month licensee response was

⁵ 39 instances of discovery of gas at one site were identified in one licensee document during an inspection at a two unit site. The document also identified multiple cases of unexpected accumulator level changes. A significant increase in the discovery and response to gas voids occurred after the NRC started pursuing this issue, an indication of increased licensee recognition of the potential impact.

completed by the NRC staff to determine whether sufficient information was provided to complete the review and close out the GL.

The reviews determined that the FSARs at many facilities stated that the subject systems were full of water and plant TS often required periodic surveillances to confirm this condition. Most plant DBs require a water-solid condition.⁶ Some plant TSs have incomplete surveillance requirements that cover only portions of the systems. Since the subject systems could be rendered inoperable or degraded by gas accumulation in any section of piping or by ingestion of gas while draining tanks or from sumps, the regulations require assessment of gas issues to establish operability. In recognition of practical operation considerations, some level of gas accumulation may not affect operability as determined by licensee void acceptance criteria that are acceptable to the NRC. However, the NRC staff position is that such gas accumulation should be corrected at the earliest practical times.

Criterion III of Appendix B to 10 CFR Part 50 and the plant's operating license identify regulatory requirements for the design of systems that are important for safety. The failure to translate the design basis (such as the system being maintained full of water) into drawings, specifications, procedures, and instructions would be contrary to Criterion III. System designs vary widely regarding potential gas sources and capability to control gas. Potential gas sources and symptoms of gas leakage from those sources should be identified and potential gas accumulation locations should be known and provisions made to address gas accumulation at those locations. Additionally, Criteria V and XI and the plant operating license require licensees to perform testing using written test procedures that incorporate the requirements and acceptance limits contained in applicable design and licensing documents. Criterion XVII requires keeping appropriate records. Testing of portions of piping and components in systems where unacceptable gas accumulation may occur is necessary to confirm acceptance limits and operability unless it has been acceptability established that some portions may be excluded. Surveillance and testing that do not ensure operability prior to the next surveillance are not consistent with this testing requirement.

Lastly, the reviews identified that some licensees have treated the accumulation of substantial gas quantities as an expected condition rather than a nonconforming condition and have not documented the condition when discovered even when it involved a substantial volume of gas that clearly constituted a significant condition adverse to quality and safety.

Meetings were conducted with the NEI, owners groups, several industry organizations, and licensees to identify additional information needed to be submitted to the NRC. On May 28, 2009, the NRC issued an assessment guidance document to clarify to the licensees what information was needed to be submitted to the NRC to facilitate close out of the GL (Ruland, May 28, 2009). Licensees used this assessment guidance to determine if they wanted to supplement their original submittals.

The staff has completed the detailed review of the licensee responses to GL 2008-01. The reviews assessed the information provided by the licensees to support a conclusion that there is a reasonable assurance that the subject systems are operable. The staff issued individual plant

⁶ "Water-solid", "gas-free", and "free-of gas" mean there is no gas with the exception of isolated gas bubbles that cannot be removed by practical means. Other terms, such as "filled with water," mean there is sufficient water to reasonably ensure system operability. (TIA, October 21, 2008)

closure letters after plant responses were received, reviewed, and accepted. After all individual plant closure letters were issued, the staff issued a GL 2008-01 closure memorandum (Rosenberg, July 7, 2011).

The staff provided Temporary Instruction 2515/177 (NRC, May 23, 2011) to provide background information and guidance for inspectors to verify that the onsite documentation, system hardware, and licensee actions were consistent with the information provided in the licensee's response to GL 2008-01. The staff also provided the regions with generic⁷ and plant-specific inspection guidance for TI 2515/177.

The closure of GL 2008-01 closed the immediate operability issue as defined in the GL. However, it did not close out the gas accumulation and management issue since a number of issues were identified during the GL evaluation that remained to be fully addressed.

Regulatory Outcome:

As stated above, closure of GL 2008-01 closed the immediate operability issue as defined in GL 2008-01. It did not, however, close out all of the gas accumulation and management issues. The staff continued to work with industry through NEI to develop a revised NEI 09-10 that was found acceptable via an SER (NRC, April, 2013). This was followed by RIS 2013-09 to announce endorsement of the revision (NRC, August 23, 2013). These documents:

- conformed to and reinforced previously established NRC regulations,
- reinforced previously issued guidance such as contained in GL 2008-01, various inspection guidance documents [(NRC, May 23, 2011), (NRC, April 16, 2008), (NRC, February, 1978), and (NRC, April 16, 2008)], and discussed in meetings such as those identified in the table at the beginning of this document,
- documented practices that are in widespread use,
- provided insights and attributes to implement aspects of an acceptable approach to effectively prevent and manage gas intrusion and accumulation in plant systems,
- provided an aid in the identification of susceptible systems,
- outlined principles and practices designed to effectively prevent, identify, manage and monitor accumulation of gas that would challenge the capability of a system to perform its functions as designed,
- identified training to ensure plant personnel can readily recognize and effectively respond to gas intrusion and accumulation in susceptible systems,
- provided guidance for addressing gas management issues,

⁷ (NRC, May 23, 2011) is the latest version of the generic guidance.

- added value to NRC and industry activities by detailing methods of resolving gas accumulation issues, and
- will improve the efficiency of licensing processes such as associated with license amendment requests since licensees can reference NEI 09-10, the accompanying SE, and RIS 2013-09 in the same manner as they can reference previously approved NRC documents such as safety evaluations.

With respect to application of computer codes, NEI 09-10 stated “that any computer code used to develop a system specific model should be verified to be applicable to solve problems involving gas transport in piping systems via comparisons with laboratory test data or other appropriate methods. Further, a suitable safety factor should be added to predicted results to reasonably ensure the predictions encompass actual behavior.” Details associated with entrance of gas into systems due to vortexing (gas ingestion from hot leg pipes, storage tanks, and recirculation sumps), were outside of the NEI 09-10 scope.

Application of computer codes to assess gas movement, associated gas movement methodologies, and vortexing have been addressed by preparing additional guidance documents, providing inspection support, and preparation of a draft NUREGs that is under review. Completion of this Action Plan includes addressing these by publication of the NUREG and other documentation. For example, the NUREG describes use of computer codes, vortexing issues, and meeting DB requirements. It further covers insights that have been developed since NEI 09-10 was written and reviewed and, consistent with NEI 09-10, the NUREG covers many of the gas concerns for systems that are necessary to reasonably ensure continued core cooling and prevention of a significant release of radioactive material.

With respect to TSs, 10 CFR 50.36(c)(3) states that SRs are “...requirements relating to test, calibration, or inspection to assure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions for operation will be met.” The Standard Technical Specifications (STS), NUREGs 1430 – 1434, currently include a SR for ensuring the ECCS is full of water consistent with the NRC staff concluding that this is a necessary requirement to reasonably ensure ECCS operability⁸. Operating experience, industry investigations, and NRC activities such as inspections have demonstrated that the TSs and STS are incomplete since they do not address all systems that are important to safety where gas accumulation could cause inoperability. Consequently, STS and TSs must be improved consistent with NRC Administrative Letter 98-10 that addresses response to TSs that may not assure safety (Roe, December 29, 1998).

The goal of gas management TSs is to address system SRs and acceptance criteria for gas voiding in an enforceable manner. Industry submitted TSTF-523 Revision 0 on June 29, 2010. In a July 15, 2010 meeting, ITSB staff stated that entirely removing the gas volume SR from the TSs, as included in TSTF-523, will not be acceptable. In September 30, 2010 and January 12, 2011 meetings, the Staff raised questions about the TSTF but no changes were made in TSTF-523. The staff accepted TSTF-523 for review on March 2, 2011, and determined that it would remove the SRs from the TSs and only insert gas management operability information into the

⁸ Some licensees have less TS coverage than provided in the STS.

Limiting Condition for Operation (LCO) Bases. TSTF-523 would also add a gas management program to the updated FSAR.

Following a determination that the proposed TSTF was unacceptable, the NRC staff continued to work with industry through the TSTF to develop acceptable gas management TSs to further ensure adequate protection of the public. The model safety evaluation for plant-specific adoption of TSTF 523, Revision 2, is available in the Agencywide Documents and Access Management System (ADAMS) under Accession No. ML13255A169. Minor editorial comments were received from the Notice of Opportunity for Public Comment announced in the *Federal Register* on August 2, 2013 (78 FR 47010). Disposition of comments received is available in ADAMS under Accession No. ML13255A403. On December 23, 2014 the staff issued a Notice of Availability in the *Federal Register* for TSTF-523, Revision 2.

Project Management Structure:

This project is being performed as a matrix organizational structure. Team members will support project activities directly but will report administratively through their normal management chain. Approvals will be achieved through the standard concurrence process.

Responsible Division Director: T. McGinty, DSS
Responsible Branch Chief: C. Jackson, SRXB
Responsible Individuals: W. Lyon and J. Whitman, SRXB

Other stakeholders and roles:

DPR/PGCB: support issuance of Generic Communications

DIRS/ITSB: M. Hamm - TS support

DPR/PRPB: M. Honcharik - TSTF support

DPR/PLPB: S. Stuchell and J. Holonich - NEI 09-10 and NUREG support; Jonathan Rowley - Pressurized Water Reactors Owners Group (PWROG) support

DORL: PMs, Support TS amendment changes

NRO/DSRA/SRSB

NRO/DCIP/CTSB

NRC regions and inspectors

Industry: TSTF, NEI, PWROG, Boiling Water Reactors Owners Groups, industry participants

Project Attributes:

As illustrated in the above schedule, this gas management action plan consists of four phases. The first phase involved continued collection of information and evaluation of the licensee's responses to Generic Letter 2008-01. Objectives of this phase included determining reasonable assurance of operability of each licensee and determining the need for additional regulatory requirements. Internal inspection guidance was sent to the regions and public individual closure letters were sent to the plants. This phase of the gas management action plan was completed by closeout of the GL.

The second phase involved completion of comprehensive gas management documentation including preparation of an SE and implementation of an RIS. This established an NRC position

on gas management and served to endorse NEI 09-10 that outlined a method of gas management.

The third phase was to establish enforceable adequate protection in the area of gas intrusion by completion of a TSTF followed by its implementation. The objectives were to establish a TSTF that provided a gas management program in TS administrative controls sections with a surveillance requirement in the limiting condition for operation sections. TSTF-523 is available for adoption by licensees and many licensees have proposed adoption of TSTF-523. The third phase will be completed with implementation of the TSTF by all licensees. Voluntary acceptance of the TSTF by all licensees is the preferred approach; however, it may be necessary to establish a GL or other appropriate communication to implement the TSTF.

The fourth phase is to address all issues including those associated with vortexing, calculation of gas movement, operability, and the DB. This will be accomplished by providing inspection support, issuing a NUREG, and issuing other documentation such as a regulatory guide.

Project success criteria include:

- (1) Publication of a NUREG that describes NRC practices regarding vortexing, gas transport, the DB, and other issues.
- (2) Licensees implement the TSTF to ensure improved adequate protection of public health and safety.

Current Status:

GL 2008-01 responses have been reviewed; individual plant closure memos have been transmitted to licensees. The GL review was closed by (Rosenberg, July 7, 2011).

2515/177 inspections are essentially complete. The Reactor Systems Branch (SRXB) staff continues to provide inspection support when requested.

The SRXB staff has completed a draft NUREG that provides comprehensive coverage of gas issues. The NRC staff is continuing to meet with NEI/Industry to address follow-up items such as vortexing, void transport methodologies, and DB issues.

Potential Problems:

Potential Problem	Response
Regional inspections inconsistent with SRXB conclusions.	Continue to provide SRXB support for plant-specific inspection guidance. Provide a NUREG to document resolution of vortex, gas transport, operability, DB, and other issues. Provide a reference that regional inspectors may use during inspections that describes acceptable practices.
Industry failure to implement TSTF	Consider issuing GL similar to GL-2006 or other appropriate generic communication.

Closeout Criteria:

This action plan will be complete when:

- (1) NRC has issued a NUREG as described above.
- (2) NRC has issued other documents that are found necessary such as a regulatory guide.
- (3) Responses to TSTF-523 have been completed.
- (4) All licensees have implemented TSs that establish acceptable adequate protection in the area of gas intrusion in plant piping.

Proposed Resources and Re-prioritization:

SRXB: 1.5 FTE

Contacts: Warren C. Lyon (301) 415-2897, (SRXB)
Jennifer M. Whitman (301) 415-3253, (SRXB)
Christopher P. Jackson (301) 415-3456, (BC, SRXB)

References:

GL, N. (January 11, 2008). *"Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems," NRC Generic Letter 2008-01, ML072910759, January 11, 2008.*

Honcharik, M. C. (March 2, 2011). *ACCEPTANCE FOR REVIEW OF TRAVELER TSTF-523, REVISION 0, "GENERIC LETTER 2008-01, MANAGING GAS ACCUMULATION" (TAC NO. ME4177).*

INPO. (January 9, 2008). *"Gas Intrusion in Safety Systems," SOER 2-05, Revision 1.*

Jolicoeur, J. R. (May 25, 2011). *"Review of Traveler TSTF-523, Revision 0, 'Generic Letter 2008-01, Managing Gas Accumulation' (TAC No. ME4177)," NRC Letter to Technical Specifications Task Force (TSTF), ML111430832.*

Lyon, W. (September 24, 2013). *"Office of Nuclear Reactor Regulation (NRR) Reactor Systems Branch (SRXB) Support of Region II Inspection of H. B. Robnson Treatment of Voids in Systems that are Important," ML13270A176.*

NEI. (April, 2013). *"Guidelines for Effective Prevention and Management of System Gas Accumulation," Rev 1a-A, ML13136A129.*

NRC. (April 16, 2008). *"... Revision to Guidance Formerly Contained in NRC Generic Letter 91-18, 'Information to Licensees Regarding Two NRC Inspection Manual Sections on Resolution of Degraded and Nonconforming Conditions and on Operability,'" RIS-2005-20-Rev-1, ML07344010.*

NRC. (April 16, 2008). *Part-9900, "Operability Determinations & Functionality Assessments for Resolution of Degraded or Nonconforming conditions Adverse to Quality or Safety," NRC Inspection Manual, Part 9900: Technical Guidance, Attachment to RIS 2005-20 Rev 1.*

NRC. (April, 2013). *"Guidelines for Effective Prevention and Management of System Gas Accumulation," Rev 1a-A, ML13136A129.*

NRC. (August 23, 2013). *"NRC REGULATORY ISSUE SUMMARY 2013-09 NRC ENDORSEMENT OF NEI 09-10, REVISION 1a-A, 'GUIDELINES FOR EFFECTIVE PREVENTION AND MANAGEMENT OF SYSTEM GAS ACCUMULATION,'" ML13178A152.*

NRC. (December, 2012). *"EVALUATION OF TECHNICAL SPECIFICATIONS TASK FORCE (TSTF) – 523, REVISION 1, 'GENERIC LETTER 2008-01, MANAGING GAS ACCUMULATION,' TAC No. ME8308".*

NRC. (February, 1978). *RG-1.33. "Quality Assurance Requirements (Operation)," Regulatory Guide (RG) 1.33, Rev 2.*

NRC. (June 9, 2009). *"Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Contain Spray Systems (NRC Generic Letter 2008-01)," Temporary Instruction 2515/177, ML082950666.*

NRC. (May 23, 2011). *"Guidance to NRC/NRR/DSS/SRXB Reviewers for Writing Temporary Instruction (TI) 2515/177 Suggestions for the Region Inspections," Revision 11, ML111660749.*

Roe, J. W. (December 29, 1998). *"Dispositioning of Technical 'Specifications that are Insufficient to Assure Plant Safety,'" NRC Letter to all holders of operating licenses for nuclear power reactors, ML031110108.*

Rosenberg, S. L. (July 7, 2011). *"Closeout of Multi-Plant Action L803, Generic Letter (GL) 2008-01," NRC Memorandum to Sean C. Meighan, ML111860005.*

Ruland, W. H. (May 28, 2009). *"Preliminary Assessment of Responses to Generic Letter 2008-01, 'Managing Gas Accumulation in emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems,' and Future NRC Staff Review Plans," NRC letter to NEI, ML091390637.*

Schrader, K. J. (June 29, 2010). *"Transmittal of TSTF-523, Revision 0, 'Generic Letter 2008-01, Managing Gas Accumulation,'" Letter to NRC, ML101800175.*

TIA, N. (October 21, 2008). *"Task Interface Agreement - Emergency Core Cooling Systems (ECCS) Voiding Relative to Compliance with Surveillance Requirements (SR) 3.0.1.1, 3.5.2.3, and 3.5.3.1 (TIA 2008-03)," ML082560209.*

TSTF. (February 21, 2013). *"Technical Specifications Task Force, Improved Standard Technical Specifications Change Traveler," ML13053A075.*

Ulses, A. P. (July 5, 2011). *"Completion of Review of Licensee Responses to Generic Letter 2008-01, 'Managing Gas Accumulation in emergency Core Cooling, Decay heat Removal, and Containment Spray Systems,'" NRC Memorandum to Sher Bahadur, ML11165A1650.*