

→(EC-22790, Am. 119)

## 2.2 LIMITING SAFETY SYSTEM SETTINGS

---

### REACTOR TRIP SETPOINTS

2.2.1 The reactor protective instrumentation setpoints shall be set consistent with the Trip Setpoint values shown in Table 2.2-1.

APPLICABILITY: As shown for each channel in Table 3.3-1.

ACTION:

With a reactor protective instrumentation setpoint less conservative than the value shown in the Allowable Values column of Table 2.2-1, declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3-1 until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.

←(EC-22790, Am. 119)

→(EC-22790, Am. 119)

Table 2.2-1  
REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. Steam Generator Level – High	≤ 87.7% (1)	≤ 88.62% (1)

TABLE NOTATIONS

(1) % of the distance between steam generator upper and low level instrument nozzles.

←(EC-22790, Am. 119)