

→(EC-15515, Am. 118)

## 6.0 ADMINISTRATIVE CONTROLS

---

### 6.5 Programs

The following programs shall be established, implemented and maintained.

#### 6.5.1 Snubber Inspection Program

This program provides controls to assure adequate shock suppression protection for primary coolant system piping and any other safety related system or component under dynamic loads as might occur during an earthquake or severe transient, while allowing normal thermal motion during startup and shutdown. This is done by assuring the operability of those shock suppressors installed for that purpose. Snubber program activities shall be performed in accordance with the requirements of the 2001 Edition of ASME OM Code, Subsections ISTA (General Requirements) and ISTD (Preservice and Inservice Examination and Testing of Dynamic Restraints (Snubbers) in Light-Water Reactor Nuclear Power Plants), including the 2002 and 2003 Addenda. Code Case OMN-13 may be used to extend the visual examination interval allowed by Table ISTD-4252-1 provided additional service life monitoring requirements are met.

←(EC-15515, Am. 118)

→(EC-15515, Am. 118)

←(EC-15515, Am. 118)