

REACTIVITY CONTROL SYSTEMS

3/4.1.2 BORATION SYSTEMS

CHARGING PUMPS - APPENDIX R

LIMITING CONDITION FOR OPERATION

3.1.2.4 Charging pumps A and B shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION:

With charging pump A and/or B inoperable, restore the inoperable charging pump(s) to OPERABLE status within 7 days or within the next hour establish an hourly fire watch patrol in accordance with Table 3.1-1.

SURVEILLANCE REQUIREMENTS

4.1.2.4 No additional surveillance requirements other than those required by Technical Specifications 4.1.2.4.

Table 3.1-1
 Impacted Fire Areas with Charging Pump(s) Inoperable

→(LBDCR 14-005)

Out Of Service Component	Fire Areas Impacted (Fire Watch Required)
Charging Pump A	RAB1A RAB1E RAB3 RAB5 RAB7A RAB7B RAB7C RAB7D RAB8B RAB8C RAB15 RAB23 RAB27 RAB30 RAB31 RAB33 RAB37 RAB39
Charging Pump B	RAB1A RAB1E RAB7A RAB7C RAB8A RAB23 RAB27 RAB30 RAB31 RAB34 RAB36 RAB37 RAB39

←(LBDCR 14-005)