

Wolf Creek	EQ MASTER LIST CHANGE NOTICE	INITIATING DOC. TYPE: N/A NO/REV: DCP/CCP NO: REV:
-------------------	------------------------------	--

AFFECTED DOCUMENT: EQ SUMMARY DOCUMENT SECTION II	Page 1 of <u>7</u> REV. NO 27	SEQUENCE 01
---	-------------------------------------	----------------

MASTER LIST REVISION TYPE: CREATE UPDATE DELETE
 Table 1 Table 2
 SYSTEM DESIGNATOR:
 COMPONENT NUMBER: See Attached List

 SPECIFICATION:

 *MODEL NUMBER:

 *MANUFACTURER:

 DESCRIPTION:

 LOCATION:

 HOT SHUTDOWN COLD SHUTDOWN

 LOCA: MSLB: HELB:

 *MAINTENANCE/REPLACEMENT REQUIREMENTS:

NOTES: During the revision of EQSD-III it was noticed that the EQ maintenance contingency for replacement of the top cover gasket on NAMCO EA-180 limit switches were not previously listed in EQSD-III as a result of the qualified life being more than 40 years. However, since anytime the covers are removed it is a EQ requirement to replace them a maintenance activity does need to be put in the EQSD-III and it has. Because these maintenance activities were added to those components, the components listed in the attached table need the maintenance requirements column to be updated accordingly per EQWP HE-3-6 to show a "Y".

* These fields are only required for the Equipment listed in EQSD-II, Table 1.

PREPARED BY:	<u>Brian Masters</u> Qualification Required: ES9280907	DATE:	9/30/14 <hr/>
VERIFIED BY:	<u>Emiguel A. Clark</u> Qualification Required: ES9280907	DATE:	10/1/2014 <hr/>
DOCUMENT SERVICES RELEASE:	<u>Sandy J. Smither</u>	DATE:	10/02/2014 <hr/>

<u>Component</u>	<u>MC</u>	<u>Equipment Qualification Description</u>	<u>Installed Elevation</u>	<u>EQ Room</u>
BBZS8026	N	CONTMN ISOL VLV NIT SUPPLY TO PRT LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
BBZS8702AA	N	RHR PUMP SUCTION ISOLATION VALVE LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
BBZS8702AB	N	RHR PUMP SUCTION ISOLATION VALVE LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
BGZS8160	N	LETDOWN CONTAINMENT ISOL VLV LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
EJZS8701BA	N	RHR SHUTDOWN SUCT LINE ISOL VLV LOOP B LMT SW	231 RX BLDG/ ELEV 1998-6	2000
EJZS8701BB	N	RHR SHUTDOWN SUCT LINE ISOL VLV LOOP B LMT SW	231 RX BLDG/ ELEV 1998-6	2000
EJZS8825	N	TEST LINE ISO VLV HOT LEG INJ LINE LIMIT SW	231 RX BLDG/ ELEV 1998-6	2000
EJZS8890B	N	TEST LINE ISOL VLV COLD LEG INJ LINE LIMIT SW	231 RX BLDG/ ELEV 1998-6	2000
EMZS8823	N	TEST/LINE/CONTAINMENT ISOL VLV SI COLD LEGS LMT SW	231 RX BLDG/ ELEV 1998-6	2000
EMZS8824	N	TESTLINE/CONT ISOL VLV RCS HOT LEGS 1&4 LIMIT SW	231 RX BLDG/ ELEV 1998-6	2000
EMZS8843	N	BIT TESTLINE AND CONTAINMENT ISOL VLV LIMIT SW	231 RX BLDG/ ELEV 1998-6	2000
EMZS8881	N	TESTLINE/CONT ISOL VLV RCS HOT LEGS 2&3 LIMIT SW	232 RX BLDG/ ELEV 1998-6	2000
EPZS8808AB	N	ACCUMULATOR TANK A ISOLATION VALVE LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
EPZS8808DB	N	ACCUMULATOR TANK D ISOLATION VALVE LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
GTZS0005	N	GTHZ0005 LIMIT SWITCH	252 RX BLDG/ ELEV 2047-6	2000
GTZS0007	N	GTHZ0007 LIMIT SWITCH	252 RX BLDG/ ELEV 2047-6	2000
GTZS0008	N	GTHZ0008 LIMIT SWITCH	252 RX BLDG/ ELEV 2047-6	2000
GTZS0011	N	GTHZ0011 LIMIT SWITCH	252 RX BLDG/ ELEV 2047-6	2000
HBZS7126	N	CONTAINMENT ISOLATION VALVE LIMIT SWITCH	231 RX BLDG/ ELEV 1998-6	2000
HBZS7176	N	CONTAINMENT ISOLATION VALVE LIMIT SWITCH	231 RX BLDG	2000

**Wolf
Creek**

EQ MASTER LIST CHANGE NOTICE

MASTER LIST REVISION TYPE: CREATE UPDATE DELETETable 1 Table 2

SYSTEM DESIGNATOR: AB

COMPONENT NUMBER: ABZS0048

SPECIFICATION: J-601A

*MODEL NUMBER: EA180

*MANUFACTURER: NAMCO

DESCRIPTION: LIMIT SWITCH

LOCATION: 1412

HOT SHUTDOWN COLD SHUTDOWN LOCA: MSLB: HELB: *MAINTENANCE/REPLACEMENT REQUIREMENTS:

*These fields are only required for the Equipment listed in EQSD-II, Table 1.

NOTES:

This equipment is required to operate during a MSLB. Therefore. This equipment will be added to Table 1 of EQSD-II and removed from Table 2 of EQSD-II

Wolf Creek	EQ MASTER LIST CHANGE NOTICE	PAGE 4 OF 7 EQSD-II-27- 01
MASTER LIST REVISION TYPE: <input checked="" type="checkbox"/> CREATE <input type="checkbox"/> UPDATE <input type="checkbox"/> DELETE		
Table 1 <input checked="" type="checkbox"/> Table 2 <input type="checkbox"/>		
SYSTEM DESIGNATOR: AB		
COMPONENT NUMBER: ABZS0049		
SPECIFICATION: J-601A		
*MODEL NUMBER: EA180		
*MANUFACTURER: NAMCO		
DESCRIPTION: LIMIT SWITCH		
LOCATION: 1412		
HOT SHUTDOWN <input checked="" type="checkbox"/> COLD SHUTDOWN <input checked="" type="checkbox"/>		
LOCA: <input type="checkbox"/> MSLB: <input checked="" type="checkbox"/> HELB: <input type="checkbox"/>		
*MAINTENANCE/REPLACEMENT REQUIREMENTS: <input checked="" type="checkbox"/>		
*These fields are only required for the Equipment listed in EQSD-II, Table 1.		
NOTES:		
This equipment is required to operate during a MSLB. Therefore. This equipment will be added to Table 1 of EQSD-II and removed from Table 2 of EQSD-II		

**Wolf
Creek**

EQ MASTER LIST CHANGE NOTICE

EQSD-II-27- 01

MASTER LIST REVISION TYPE: CREATE UPDATE DELETETable 1 Table 2

SYSTEM DESIGNATOR: AB

COMPONENT NUMBER: ABHV0048-E01

SPECIFICATION: E-028

*MODEL NUMBER: N/A

*MANUFACTURER: Comsip Customline

DESCRIPTION: VALVE TERMINAL BOX

LOCATION: 1412

HOT SHUTDOWN COLD SHUTDOWN LOCA: MSLB: HELB: *MAINTENANCE/REPLACEMENT REQUIREMENTS:

*These fields are only required for the Equipment listed in EQSD-II, Table 1.

NOTES:

This equipment is required to operate during a MSLB. Therefore. This equipment will be added to Table 1 of EQSD-II and removed from Table 2 of EQSD-II

Wolf Creek	EQ MASTER LIST CHANGE NOTICE	PAGE 6 OF 7 EQSD-II-27- 01
MASTER LIST REVISION TYPE: <input checked="" type="checkbox"/> CREATE <input type="checkbox"/> UPDATE <input type="checkbox"/> DELETE		
Table 1 <input checked="" type="checkbox"/> Table 2 <input type="checkbox"/>		
SYSTEM DESIGNATOR: AB		
COMPONENT NUMBER: ABHV0049-E01		
SPECIFICATION: E-028		
*MODEL NUMBER: N/A		
*MANUFACTURER: Comsip Customline		
DESCRIPTION: VALVE TERMINAL BOX		
LOCATION: 1412		
HOT SHUTDOWN <input checked="" type="checkbox"/> COLD SHUTDOWN <input checked="" type="checkbox"/>		
LOCA: <input type="checkbox"/> MSLB: <input checked="" type="checkbox"/> HELB: <input type="checkbox"/>		
*MAINTENANCE/REPLACEMENT REQUIREMENTS: <input checked="" type="checkbox"/>		
*These fields are only required for the Equipment listed in EQSD-II, Table 1.		
NOTES:		
This equipment is required to operate during a MSLB. Therefore. This equipment will be added to Table 1 of EQSD-II and removed from Table 2 of EQSD-II		

Wolf Creek	EQ MASTER LIST CHANGE NOTICE	PAGE 7 OF 7 EQSD-II-27- 01
-----------------------	------------------------------	-------------------------------

MASTER LIST REVISION TYPE: CREATE UPDATE DELETE

Table 1 Table 2

SYSTEM DESIGNATOR:

COMPONENT NUMBER:

SPECIFICATION:

*MODEL NUMBER:

*MANUFACTURER:

DESCRIPTION:

LOCATION:

HOT SHUTDOWN

COLD SHUTDOWN

LOCA: MSLB: HELB:

*MAINTENANCE/REPLACEMENT REQUIREMENTS:

*These fields are only required for the Equipment listed in EQSD-II, Table 1.

NOTES:

ABZS0048, ABZS0049, ABHV0048-E01 & ABHV0049-E01 is equipment that is required to function during MSLB. Therefore, this equipment will be added to Table 1 of EQSD-II and deleted form Table 2 of EQSD-II.