

NRR-PMDAPEm Resource

From: Oesterle, Eric
Sent: Wednesday, March 25, 2015 12:55 PM
To: Richardson, Michael
Cc: Lingam, Siva; Som, Swagata; Martinez-Navedo, Tania; Mathew, Roy
Subject: Diablo Units 1 and 2 - [Round 2] Requests for Additional Information (RAIs) for License Amendment Request 14-01 Associated with Revision to TS 3.8.1, "AC Sources - Operating" (TAC Nos. MF3826 and MF3827)

Importance: High

The proposed subject amendment dated March 27, 2014 (Agencywide Documents Access and Management System Accession No. ML14086A426) and supplemented by letter dated February 19, 2015 (ADAMS Accession No. ML15050A389), would revise technical specification (TS) surveillance requirements (SRs) associated with emergency diesel generators (DGs) for Diablo Canyon Power Station, Units 1 and 2. The proposed changes reflect the results of a revised load study analysis, as well as a revision to the DG 30-minute load rating. These changes were submitted to address multiple issues identified by U.S. Nuclear Regulatory Commission (NRC) and Pacific Gas and Electric Company (PG&E or the licensee) investigations, and are intended to correct various non-conservative TS SRs/values associated with DG testing.

Please note the following additional **official** RAIs for the subject amendment, and provide your responses no later than 30 days from the date of this e-mail. Providing responses early than 30 days may help to facilitate completion of NRC staff review.

1. Diablo Canyon Power Plant is revising the proposed voltage limit in SR 3.8.1.10 from 5075V to 5096V, please explain why this new voltage limit is acceptable such that none of the components, including the generator, will be adversely affected, damaged or tripped.
2. Please confirm that the stored diesel fuel oil volume requirements specified in Technical Specification 3.8.3. A and B remain valid for the proposed Emergency Diesel Generator (EDG) loading requirements as a result of variations in EDG frequency and voltage.

Eric R. Oesterle

Acting NRC Project Manager
Diablo Canyon
NRR/DORL/LPL4-1
301-415-1014

Hearing Identifier: NRR_PMDA
Email Number: 1955

Mail Envelope Properties (6566BAEC3DB1314381965386524904EC02BA541E7BDD)

Subject: Diablo Units 1 and 2 - [Round 2] Requests for Additional Information (RAIs) for License Amendment Request 14-01 Associated with Revision to TS 3.8.1, "AC Sources - Operating" (TAC Nos. MF3826 and MF3827)

Sent Date: 3/25/2015 12:55:02 PM

Received Date: 3/25/2015 12:55:03 PM

From: Oesterle, Eric

Created By: Eric.Oesterle@nrc.gov

Recipients:

"Lingam, Siva" <Siva.Lingam@nrc.gov>

Tracking Status: None

"Som, Swagata" <Swagata.Som@nrc.gov>

Tracking Status: None

"Martinez-Navedo, Tania" <Tania.Martinez-Navedo@nrc.gov>

Tracking Status: None

"Mathew, Roy" <Roy.Mathew@nrc.gov>

Tracking Status: None

"Richardson, Michael" <MJRm@pge.com>

Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1694	3/25/2015 12:55:03 PM

Options

Priority: High

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: