

Prairie Island ISFSI Amendment 9 Technical Specification Page Changes

Remove Page

3.1.2-2
3.1.2-3

Insert Revised Page

3.1.2-2
3.1.2-3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action A.1 and associated Completion Time not met.	B.1 Return cask to pool and reflood.	7 days

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.1.2.1 -----NOTE----- Not required to be met prior to the specified Frequency. ----- Verify that a helium environment has been established in the cask cavity.	Once within 34 hours after commencing cask draining
SR 3.1.2.2 -----NOTE----- Not required to be met prior to the specified Frequency. ----- Verify that the cask cavity pressure is ≤ 14 mbar absolute.	Once prior to pressurization (SR 3.1.2.3)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.1.2.3 -----NOTE----- Not required to be met prior to the specified Frequency. ----- Verify that the cask cavity helium pressure is ≥ 1345 mbar absolute and ≤ 1445 mbar absolute.</p>	<p>Once prior leak testing (SR 3.1.3.1)</p>