

**Attachment 2, Enclosure 2 contains Westinghouse Proprietary Class 2 Information requested to be withheld from public disclosure under 10 CFR 2.390(a)(4)**



L-2015-085  
10 CFR 52.3

April 2, 2015

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555-001

Re: Florida Power & Light Company  
Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
Voluntary Revised Response to NRC Request for Additional Information Letter No. 061 (eRAI 6432) Related to SRP Section 03.07.01 - Seismic Design Parameters

References:

1. NRC Letter to FPL dated May 17, 2012, Request for Additional Information Letter No. 61 Related to SRP Section 03.07.01 Seismic Design Parameters for the Turkey Point Units 6 and 7 Combined License Application
2. FPL Letter L-2014-285 to NRC dated October 3, 2014, Voluntary Revised Response to NRC Request for Additional Information Letter No. 040 (eRAI 6006) – Standard Review Plan Section 02.05.04 Stability of Subsurface Materials and Foundations
3. FPL Letter L-2014-314 to NRC dated October 29, 2014, Submittal of the Annual Update of the COL Application – Revision 6 and the Semi-Annual Update of the Departures Report

Florida Power & Light Company (FPL) provides, as an attachment to this letter, its revised responses to the Nuclear Regulatory Commission's (NRC) requests for additional information (RAI) 03.07.01-14, 03.07.01-15, 03.07.01-16, and 03.07.01-18 provided in References 1 and 2. The response to RAI 03.07.01-15 has been updated to include the supplemental SSI sensitivity analyses performed based on the 2013 supplemental site investigation and a site response sensitivity analysis, and comparison of the results of the sensitivity analysis to the existing design-basis analysis to assess the significance of the updated seismic input on the previous (Revision 5) site specific Nuclear Island and Safety Class II adjacent structures in-structure response spectra.

The previous responses to the RAIs 03.07.01-14, 03.07.01-16, and 03.07.01-18 provided in the attachments have not changed as a result of the site response sensitivity analysis that was performed. The revised responses do not provide any associated COLA changes as any COLA revisions resulting from the revised responses were incorporated in Revision 6 of the Turkey Point 6 & 7 COL Application submitted in Reference 3.

Florida Power & Light Company

700 Universe Boulevard, Juno Beach, FL 33408

DO97  
NRC

**Attachment 2 Enclosure 2 contains Westinghouse Proprietary Class 2 Information requested to be withheld from public disclosure under 10 CFR 2.390(a)(4)**

Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
L-2015-085 Page 2

Attachment 2 Enclosure 2, AP1000 Turkey Point Site Specific Seismic Evaluation Report, TPG-1000-S2R-802, Revision 6 dated March 2015, contains Westinghouse Proprietary Class 2 information. The Westinghouse proprietary information for which withholding is being requested is further identified in the affidavit signed by Westinghouse Electric Company, LLC. The Westinghouse affidavit accompanying this letter (Attachment 2 Enclosure 1), sets forth the basis on which the information may be withheld from public disclosure by the Commission and address with specificity the considerations listed in 10 CFR 2.390(b)(4). Correspondence with respect to the proprietary aspects of this application for withholding or the accompanying affidavit should reference CAW-15-4127 and should be addressed to J. A. Gresham, Manager, Regulatory Compliance, Westinghouse Electric Company LLC, Suite 428, 1000 Westinghouse Drive, Cranberry Township, Pennsylvania 16066. Based on Attachment 2 Enclosure 1 to this letter, FPL requests that Attachment 2 Enclosure 2 be withheld from public disclosure under 10 CFR 2.390(a)(4).

If you have any questions, or need additional information, please contact me at 561-691-7490.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on April 2, 2015.

Sincerely,



William Maher  
Senior Licensing Director – New Nuclear Projects

WDM/RFB

Attachment 1: FPL Revised Response to NRC RAI No. 03.07.01-14 (eRAI 6432)  
Attachment 2: FPL Revised Response to NRC RAI No. 03.07.01-15 (eRAI 6432)  
Attachment 3: FPL Revised Response to NRC RAI No. 03.07.01-16 (eRAI 6432)  
Attachment 4: FPL Revised Response to NRC RAI No. 03.07.01-18 (eRAI 6432)

cc: w/o Attachments

PTN 6 & 7 Project Manager, AP1000 Projects Branch 1, USNRC DNRLINRO  
Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant 3 & 4