

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Open Session Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, April 9, 2015

Work Order No.: NRC-1506

Pages 1-166

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 623RD MEETING

5 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

6 (ACRS)

7 + + + + +

8 OPEN SESSION

9 + + + + +

10 THURSDAY

11 APRIL 9, 2015

12 + + + + +

13 ROCKVILLE, MARYLAND

14 + + + + +

15 The Advisory Committee met at the
16 Nuclear Regulatory Commission, Two White Flint
17 North, Room T2B1, 11545 Rockville Pike, at 8:30
18 a.m., John W. Stetkar, Chairman, presiding.

19 COMMITTEE MEMBERS:

20 JOHN W. STETKAR, Chairman

21 DENNIS C. BLEY, Member-at-Large

22 RON BALLINGER, Member

23 SANJOY BANERJEE, Member

24 CHARLES H. BROWN, JR., Member

25 MICHAEL L. CORRADINI, Member

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DANA A. POWERS, Member
2 JOY REMPE, Member
3 PETER RICCARDELLA, Member
4 MICHAEL T. RYAN, Member
5 STEPHEN P. SCHULTZ, Member
6 GORDON R. SKILLMAN, Member

7
8 DESIGNATED FEDERAL OFFICIAL:

9 PETER WEN

10 ALSO PRESENT:

11 CLINTON ASHLEY, NRC
12 SCOTT BAUER, NEI
13 ASHLEY GUZZETTA, NRC
14 JIM HARRISON, GE-Hitachi
15 CHARLIE HECK, GE-Hitachi
16 ROY LINTHICUM, Exelon
17 JOSE MARCH-LEUBA, Oak Ridge National
18 Laboratory
19 TIM McGINTY, NRC
20 JOHN McKIRGAN, NRC
21 ABY MOHSENI, NRC
22 JIM SHEA, NRC
23 JUSWALD VEDOVI, GE-Hitachi
24 BILL WILLIAMSON, TVA
25 DAVID YOUNG, NEI

T-A-B-L-E O-F C-O-N-T-E-N-T-S

PAGE

1. Opening Remarks by the ACRS Chairman

1.1) Opening Statement 4

1.2) Items of Current Interest 5

2. Topical Report NEDE-33766P, GEH Simplified

Stability Solution (GS3)

2.1) Remarks by the Subcommittee Chairman 5

2.2) Briefings by and discussions with 45

representatives of the staff and

GE-Hitachi regarding the review of

the GS3 topical report

Draft Proposed Rulemaking for Mitigation

of Beyond-Design-Basis Events

Briefings and Discussion 5

Public Comment 153

Adjourn 153

NEAL R. GROSSCOURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

P-R-O-C-E-E-D-I-N-G-S

(8:31 a.m.)

CHAIRMAN STETKAR: The meeting will now come to order. This is the first day of the 623rd meeting of the Advisory Committee on Reactor Safeguards. During today's meeting the Committee will consider the following, Topical Report NEDE-33766P, GEH Simplified Stability Solution GS3; Draft Proposed Rulemaking for Mitigation of Beyond-Design-Basis Events, and preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Peter Wen is the Designated Federal Official for the initial portion of the meeting.

We've received no written comments or requests to make oral statements from members of the public regarding today's sessions. There will be a phone bridge line. To preclude interruption of the meeting, the phone will be placed in a listen-in mode during the presentations and Committee discussion.

A transcript of portions of the meeting is being kept, and it is requested that speakers

1 use one of the microphones, identify themselves,
2 and speak with sufficient clarity and volume so
3 that they can be readily heard. And I want to
4 remind everyone in the room to please check and
5 silence all of your little devices.

6 As an item of interest, the Commission
7 has reappointed Dr. Dennis Bley for his third
8 term on the ACRS, and has reappointed Mr. Gordan
9 Skillman for his second term on the ACRS. And
10 they reappointed me for my third term. And
11 hearty congratulations to Dennis and Dick.

12 MEMBER POWERS: Rookies, all.

13 CHAIRMAN STETKAR: And if there are no
14 other members who have any other comments or
15 items of interest, I will turn over the
16 proceedings to Dr. Banerjee to lead the first
17 topic on our agenda, and that's the Topical
18 Report NEDE-337 whatever it is, 66P. Sanjoy?

19 MEMBER BANERJEE: Thank you, Mr.
20 Chairman. Let's call it just GEH Simplified
21 Stability Solution GS3.

22 CHAIRMAN STETKAR: Oh, that's a lot
23 simpler.

24 MEMBER BANERJEE: Yes. It's a pleasure
25 to introduce the staff and the GEH. They will

1 tell us a little bit about this simplified
2 stability solution which we held a subcommittee
3 meeting a couple of weeks ago in which they made
4 a very nice presentation.

5 Just to introduce the subject, currently
6 all the BWRs which are not operating in MELLA+
7 but up to the MELLA+ domain use a methodology to
8 set their OPRM and APRM setpoints which is based
9 on a totally unpronounceable set of words, but
10 it's called DIVOM HCOM.

11 And this is a rather conservative
12 methodology which sets the setpoints which really
13 correlates the critical heat flux, or CPR
14 critical power issue with amplitude of an
15 oscillation once you enter into this instability
16 mode.

17 What happens is that because these
18 setpoints have to be set fairly close to the
19 noise levels, and it also gives you some issues
20 with maneuvering, you can have spurious trips
21 which sort of stress the system because they
22 strain the safety systems, they can impact plant
23 aging and all sorts of things.

24 So in order to try to get a more
25 realistic picture of what would happen once a BWR

1 goes into an instability, the Applicant has
2 proposed methodology based on best estimate plus
3 uncertainties using the TRACG code.

4 So this would not apply this methodology
5 to MELLA+ region, operating region which is used
6 in EPU's. For that, also a best estimate plus
7 uncertainty calculation is done, but there are
8 slightly different methodology there which is
9 called detect and suppress confirmation density
10 method.

11 So that is specifically for MELLA+.
12 This methodology will apply to the MELLA
13 operating region but excluding MELLA+ and will
14 really be used to set the setpoints for what is
15 called Option I-D, Option II, and Option III. I
16 won't bore you with the details of what these
17 precisely are. Okay?

18 In any case, with that introduction, it
19 should really make things less conservative, and
20 the real crux of the matter is whether we like
21 the way they did these calculations in order to
22 set the envelope and the conditions of the
23 setpoint.

24 So with that, I'm going to turn it over
25 to the staff. I don't know who is going to lead

1 off there. Okay, Tim, go ahead.

2 MR. MCGINTY: Good morning, I'm Tim
3 McGinty. I'm the Director of the Division of
4 Safety Systems in NRR. And it's my pleasure for
5 the Staff to present the Staff's review of the GE
6 Hitachi Simplified Stability Solution or GS3.

7 Today's presenters are going to be
8 Ashley Guzzetta from the Reactor Systems Branch
9 and Dr. Jose March-Leuba from Oak Ridge National
10 Lab. GS3 is an additional methodology for BWR
11 stability and long term solutions, I-D, II, and
12 III. And I also will not bore you with that
13 demarcation.

14 It is newly developed TRACG best
15 estimate methodology alternative to DIVOM, which
16 stands for Delta over Initial MCPR Versus
17 Oscillation Magnitude methodology. And I suppose
18 GS3 is simplified in the fact that the acronym is
19 simplified.

20 The discontinuation of the DIVOM
21 methodology is one of the reasons for calling
22 this methodology simplified. As such, the GS3
23 methodology takes advantage of modern
24 computational capabilities to replace the DIVOM
25 methodology which is conservative but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unnecessarily complex.

2 GS3 does not require any hardware or
3 software changes to plants. The Staff has
4 reviewed the information provided in the topical
5 report and accepted it without limitations.

6 The main conclusion of the staff
7 evaluation is that the proposed GS3 approach for
8 option I-D, II, and III plants provide ample
9 margin for the conditions inside the envelope of
10 applicability and is an acceptable approach to
11 define scram setpoints.

12 So with that said, I believe that agrees
13 with Dr. Banerjee, so I appreciate the lead-in.
14 At this point, I believe I turn it over to Dr.
15 Vedovi?

16 MEMBER BANERJEE: It's all open session
17 we're in?

18 DR. VEDOVI: This is open, yes.

19 MEMBER BANERJEE: Yes, you have nothing
20 to say that would require a closed session.

21 DR. VEDOVI: Later on.

22 MEMBER BANERJEE: Later on, yes.

23 DR. VEDOVI: Yes.

24 MEMBER BANERJEE: Not right now though,
25 right?

1 DR. VEDOVI: Yes.

2 MEMBER BANERJEE: Okay.

3 DR. VEDOVI: Good morning, everybody.
4 Thank you for allowing us to discuss GS3
5 solution. I am Dr. Juswald Vedovi. I'm the
6 engineering manager for stability and
7 radiological analysis GE-Hitachi.

8 Along with me we have Charlie Heck who
9 is our Consulting Engineer, Jim Harrison who is
10 the Vice President for Regulatory Affair, and
11 Justin Lammey who is a Stability Engineer for our
12 team.

13 We'll have two sessions, one open
14 session which is this one and then we'll discuss
15 the background information and a little bit of an
16 overview of the GS3 methodology. Dr. Banerjee
17 did a very nice introduction which actually
18 simplified, if you allow me the same information
19 that you're going to share in this session.

20 Later on in the closed session to where
21 we have to discuss some preparatory information,
22 we'll dig more in details about the specific
23 aspect of the methodology and show you some
24 results and example of the application.

25 If you go on Slide 4, this is just a

1 summary table of instabilities that have occurred
2 on commercial boiling water reactors throughout
3 history. The main point is that, you know,
4 instabilities are possible, they did occur, they
5 don't care where your plant is built. You know,
6 it happen in every country that had boiling water
7 reactor technology more or less, and for
8 different BWR types as well.

9 However, so that's the driver why
10 instability needs to be addressed. And I would
11 like to also mention that in none of these
12 events, the safety limits were violated as a
13 result of it.

14 MEMBER CORRADINI: So just to clarify,
15 when you say instability, this is for growing
16 power oscillation that leads to trip?

17 DR. VEDOVI: Correct.

18 MEMBER CORRADINI: Or it's just a
19 growing power oscillation that could be taken
20 under control. And all of these led to trip and
21 exceedance of the setpoints?

22 DR. VEDOVI: I believe, I cannot recall
23 if all of them end up to trip. But essentially
24 most of them, they did.

25 MEMBER CORRADINI: But it's a growing

1 power oscillation either local or global?

2 DR. VEDOVI: Correct.

3 MEMBER CORRADINI: Okay.

4 MEMBER BANERJEE: Just to clarify for
5 the committee, a growing power oscillation does
6 not have to lead to a trip. The operator can
7 move out of the region. And in fact, one of the
8 reasons, I think, that GS3 is there setting the
9 setpoints somewhat higher is precisely that, that
10 you could be able to maneuver out if needed,
11 right? You've got time.

12 DR. VEDOVI: Correct. The system has
13 alarms that can be used to give you time to take
14 actions, reduce power and avoid a trip which is a
15 win situation for everybody. And if the
16 setpoints are too low or too close, there is not
17 enough time to take actions. So what kind of --

18 MEMBER CORRADINI: Dr. Vedovi, would you
19 back up one slide? Is the occurrence date, your
20 slide shows 1982 in Italy and 2015 at Fermi. Has
21 there been a reduction in the rate of these
22 instability events?

23 In other words, as we look at those
24 dates, it appears as though it's been six years
25 since the last event. Does that communicate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actions have been taken, at least six years ago,
2 that have really put the brakes on this?

3 DR. VEDOVI: Well, I would say that if
4 you look at the early stage, a lot of emphasis on
5 operator actions and how to deal with instability
6 events really occur at the end of the '80s,
7 beginning of the '90s with the LaSalle
8 instability event that is in these slides.

9 So I think that address in some respect
10 the number of occurrences because plants were
11 more aware of we started to look into this
12 phenomena, analyzing, determine the regions more
13 precisely where this instability may occur.

14 But so to that extent, I think we could
15 tell that from the early stage, '80s, '90s to
16 today's, there is a reduction. But I couldn't
17 draw a conclusion just based on 2009, 2015.

18 It's just a matter that it's possible
19 during maneuvering that you end up having to trip
20 a pump, getting to low flow conditions and it's
21 possible that you develop an instability.

22 But the plants have a way, and we've
23 seen this, to ensure that even if you do trip,
24 your safety limit are protected and you don't
25 exceed any limits throughout the event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Thank you, thank you.

2 MEMBER BANERJEE: Perhaps you could give
3 a little historical perspective to the Committee
4 as to when after LaSalle, the Owners' Group
5 started to install these different options. So
6 if you would give us when the Options I-D and II,
7 III started to, it was post '88, right?

8 DR. VEDOVI: Correct. So the 1988 event
9 at LaSalle is what initiated the emphasis on
10 developing long term stability solution and that
11 were put in place fully in 1996.

12 So during those eight years, there were
13 some interim corrective actions put in place to
14 restrict operation in certain area of the power
15 flow map as a preventive measure to give the time
16 to develop long term solution that will address
17 permanently the issue.

18 And this solution were put in place
19 starting from 1996, and they were based on the
20 DIVOM methodology. And at that point, that was
21 fine. It was a very conservative methodology.
22 It was understood even back then.

23 But there were no tools that could do a
24 better job than using conservative approach back
25 then. And also there were no, the limits set out

1 by other transient event were much higher than
2 stability. And so nobody really was concerned
3 about these excessive conservatism.

4 As we will see in the next few slides,
5 the situation changed in the last ten years where
6 better techniques, advanced methods improved the
7 capability for transient prediction so the limits
8 of transient decreased. And all of a sudden,
9 stability limits were the one setting up the
10 limits.

11 And that's when all this emphasis on why
12 we are using such excessive conservatism into the
13 methodology came to affect plant operation.

14 MEMBER BANERJEE: So how many plants
15 today are stability limited for the oil and CPR
16 rather than, say, turbine trip or whatever?

17 DR. VEDOVI: I cannot give you an exact
18 number from --

19 MEMBER BANERJEE: Is it a significant
20 number?

21 DR. VEDOVI: -- the top of my head, but
22 I would say it's probably is more than five and
23 maybe even ten units.

24 MEMBER REMPE: So if we have all these
25 conservatisms, why are they still occurring, like

1 in 2015?

2 DR. VEDOVI: Well the conservatives,
3 it's in where the setpoint is, it's not in
4 whether or not the event will level off.

5 MEMBER CORRADINI: Conservatism is, as
6 I understand the way you describe it unless I
7 misunderstand is that conservatisms are driving
8 what I'll call the bandwidth between operation
9 and where you demand a trip to be narrow compared
10 to --

11 DR. VEDOVI: Correct.

12 MEMBER REMPE: That's what I'm trying to
13 say that because you narrowed that bandwidth, is
14 that why we're seeing a transient like in 2013
15 with the trip?

16 MEMBER BANERJEE: So you would expect
17 more and more instability events actually as you
18 raise the power density and get into more
19 demanding operating regimes. So there's no
20 reason why you would not be unstable. It's
21 whether you can control the instability either by
22 operator action or by tripping.

23 You don't want to trip, ideally. So you
24 want a reasonable trip setting which will protect
25 the SLMCPR but will not lead to, you know, you

1 tripping without being able to take other
2 actions.

3 MEMBER BROWN: What generates the
4 spurious trips? Is it part of the instability
5 itself that's unpredictable, or is it some other
6 --

7 MEMBER BANERJEE: It can even noise.

8 MEMBER BROWN: Yes, it's just that the
9 low level of the signals that you're dealing
10 with?

11 DR. VEDOVI: Yes, I have a couple of
12 slides that show --

13 MEMBER BANERJEE: I'm sure they'll speak
14 to it. Yes, go ahead.

15 DR. VEDOVI: So to illustrate what kind
16 of instability we are talking about for operation
17 as there are many different type, and forgive me
18 for a little bit proud of my country.

19 MEMBER CORRADINI: You don't have the
20 stability ropes on it though. It's got the
21 stability ropes on it, yes?

22 DR. VEDOVI: Not anymore.

23 MEMBER CORRADINI: Yes, okay.

24 DR. VEDOVI: But it shows that I think
25 it's inside fully in a sense that it's a

1 beautiful masterpiece that dealt with an address,
2 ensure stability for a very long term.

3 So this instability that you are talking
4 about here is a couple thermohydraulic and
5 electrokinetics and stability. What I'm going to
6 show you here is a video of an animation for
7 reference transient scenario that leads to
8 instability which is a two recirculation pump
9 trip.

10 What you are seeing here is the radial
11 power distribution into the core. Each of the
12 squares represent the fuel bundle power, relative
13 power. Red indicates where the hottest bundles
14 are located, and the blue colors indicate where
15 less power is concentrated.

16 MEMBER CORRADINI: Is this axially
17 averaged, or is this peak axial?

18 DR. VEDOVI: It's radial peaking.

19 MEMBER CORRADINI: No, I understand
20 you're showing me a radial map. I'm asking
21 axially are you averaging the power, or this is
22 just an integrated power in the bundle?

23 DR. VEDOVI: These would be the
24 integrated power in the bundle. And you can see
25 also where the control rods are inserted because

1 there is a depression into the power in those
2 areas. You can follow the events through time
3 and power.

4 So I initiated a time T-20 seconds. If
5 you follow on the top part of the screen, there
6 will be the trip of wet pumps. Currently the
7 plant is operating at 2,300 megawatts and steady
8 state of --

9 (Simultaneous speaking.)

10 MEMBER CORRADINI: One pump, two pump
11 trip?

12 DR. VEDOVI: Two pump trips.

13 MEMBER CORRADINI: Two pump trip.

14 DR. VEDOVI: So right now, both pumps
15 trip. There is a reduction in flow. You can see
16 that the reduction in power follows the reduction
17 in flow. And there is a redistribution of flow
18 into the vessel, into the core.

19 As a result of that, you can see that
20 now this side of this fuel bundles in this part
21 and this part of the core becomes hotter and
22 starts to excite one of the highest harmonic
23 along this line of symmetry. And you will see
24 development of the regional oscillations where
25 this part of the core start to oscillate out of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 phase with respect to this part of the core as
2 you can see now.

3 Now this oscillations start to be
4 detected by the detection system that is in the
5 plant. And when they reach certain setpoints,
6 the scram is initiated and the event is
7 terminated.

8 The safety limit were not violated at
9 any point during this event, and this is exactly
10 how an instability event will occur and will be
11 detected and suppressed in actual operation.

12 MEMBER SKILLMAN: So the time dynamic
13 that we just saw --

14 DR. VEDOVI: Is realistic.

15 MEMBER SKILLMAN: It's very fast.

16 DR. VEDOVI: It can be fast, yes.

17 MEMBER SKILLMAN: I mean, that was one
18 or two seconds communicating across that large
19 core to cause those changes. So this is a very
20 rapid oscillation.

21 DR. VEDOVI: The oscillation developed,
22 it can develop in a matter of, you know, 50, 60
23 seconds to a few minutes or many minutes. It
24 depends on how fast is the variation, if you had
25 one pump trip, if you had two pump trip, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know, from where you initiated. So it's, how
2 much feed water reduction you have during the
3 event. So there are a number of variables that
4 determine the timing of the onset of
5 oscillations.

6 MEMBER BANERJEE: But if you took the
7 two pump trip as a limiting event, typically from
8 the onset of oscillations to when SLMCPR is
9 challenged is maybe 50, 60 seconds, right?

10 DR. VEDOVI: It depends within the
11 plant.

12 MEMBER BANERJEE: Okay.

13 DR. VEDOVI: So it can be 60, it can be
14 a couple of minutes.

15 MEMBER BANERJEE: Yes, so it's not,
16 like, real --

17 MEMBER SKILLMAN: It's not
18 instantaneous?

19 MEMBER BANERJEE: That's what I'm, yes.

20 MEMBER CORRADINI: Was that video
21 realtime?

22 DR. VEDOVI: Realtime.

23 MEMBER BANERJEE: Do you want to show it
24 again just for the timing?

25 MR. HARRISON: This is Jim Harrison,

1 GEH. Wouldn't you say that it was probably
2 developing before we could see it visually?

3 DR. VEDOVI: I'm sorry?

4 MR. HARRISON: Wouldn't you say it was
5 probably developing before we saw it visually?

6 DR. VEDOVI: Yes.

7 MEMBER CORRADINI: If you look at the
8 power meter at the bottom, you'll see it
9 developing before you start seeing wiggles, local
10 wiggles.

11 DR. VEDOVI: Okay, so this is the time
12 where the pump trips. And from this moment on,
13 you essentially are waiting for the inlet
14 subcooling to increase as part of the feedwater
15 reduction.

16 And at this time, you cannot see here,
17 but the axial power peak will, axial power shift
18 will become more and more bottom peaked as a
19 result of the inlet subcooling.

20 So this point, you know, is just, it
21 starts to little wiggle, yes, and it start to
22 develop some oscillation. And I do not remember
23 at this particular simulation what setpoint we
24 plugged in for the simulation.

25 So let's see here. Okay, so in this

1 case trip of, I'm sorry, at 70 seconds. So
2 that's the order of magnitude for this specific
3 case. But you understand that if the setpoint is
4 increased, you know, it will be delayed, if it is
5 reduced, it will be faster.

6 MEMBER BANERJEE: So the safety limit,
7 which is of course the critical power ratio plus
8 some uncertainties and things that we add on
9 typically to that mustn't be violated. And
10 that's what the trip tries to do, that safety
11 limit which is the critical power ratio plus
12 uncertainties will be protected so that the fuel
13 is not damaged.

14 DR. VEDOVI: Correct. So what we have
15 to demonstrate is that with the methodology, we
16 are determining setpoints that are still
17 protecting the safety limit. But you are trying
18 to give more room to the plants to avoid, to buy
19 them time and to avoid spurious signal.

20 And just in these slides, you know,
21 that's the general design criteria that were
22 really driving the licensing basis for stability
23 in the US. And GDC 12 requires, if you read the
24 last line, that during power oscillations
25 essentially must be reliably and readily detected

1 and suppressed if they do develop. So that's the
2 whole basis that you're trying to address with
3 the long term stability solution.

4 And at the very essence, what you just
5 saw there can be summarized in the sense that the
6 measurements that are put in place that create
7 signals that are processed through algorithms
8 that track for a specific frequency of interest
9 and start to count oscillations.

10 And then when they reach certain
11 setpoints, then when they initiated the scram.
12 That's what you saw in the previous signal.

13 MEMBER BANERJEE: Perhaps you should
14 sort of lead us through this, the PBDA just so
15 that people understand precisely what it is.

16 DR. VEDOVI: For Option III plants, the
17 algorithm that is used to detect oscillations is
18 called Period Based Detection Algorithm, or PBDA.
19 This algorithm that is processing the number of
20 signals coming from the plant at all times
21 continuously during operation is looking for
22 period of oscillations within the frequency of
23 interest.

24 We know what is the target frequency of
25 interest for thermohydraulic instability because

1 that is determined essentially by the speed of
2 which the liquid goes from the bottom of the core
3 to the top of the core which is linked to the
4 height of the fuel bundle which is fixed, so it's
5 very nice to know --

6 MEMBER BANERJEE: I have a point to ask
7 you about that. That depends on the subcooling
8 because as you know, there are different models
9 for this. If it's a pure density wave, then it's
10 twice. But if it is a velocity wave at high
11 subcoolings, it can be up to four times.

12 DR. VEDOVI: Correct.

13 MEMBER BANERJEE: As you know, of
14 course.

15 DR. VEDOVI: Correct. But that allow
16 us, because the actual determinate valid
17 conditions for where the instability occur in the
18 plants are not dramatically different from plant
19 to plant.

20 We can find out a range of frequency
21 where this events may happen. So the algorithm
22 will account for the frequency and a range in
23 between to count for these oscillations. So if a
24 signal develop --

25 MEMBER BANERJEE: And maybe, Charlie,

1 you can --

2 MR. HECK: Well, this is Charlie Heck,
3 GEH. I just wanted to acknowledge what you said,
4 Dr. Banerjee is that it's actually a density wave
5 that we're concerned with.

6 MEMBER BANERJEE: Relatively low
7 subcooling.

8 MR. HECK: The density, of course, is
9 what controls the neutronic feedback. So it's
10 the density wave that we're concerned with.

11 MEMBER CORRADINI: So although things
12 are whipping through the system at higher rates,
13 your worry is the density feedback to the power?

14 MR. HECK: Yes, that's what causes it to
15 continue to --

16 MEMBER CORRADINI: So just to ask
17 Sanjoy's question differently, so you're looking
18 at essentially a period based one. But you have
19 an amplitude based trip in others. And for the
20 G3 solution, you're only focused on that and you
21 look at a range of periods?

22 MEMBER BANERJEE: You still keep the
23 defense in depth, right?

24 MEMBER CORRADINI: Right, but I thought,
25 I'm sorry.

1 DR. VEDOVI: The algorithm is the same,
2 right? So this is what --

3 MEMBER CORRADINI: They're always
4 looking.

5 DR. VEDOVI: They're always looking and
6 we are not making any change. The only thing
7 that is changing is so the DIVOM methodology will
8 determine where this line which is the amplitude
9 setpoint is going to be.

10 So the methodology is used to set this
11 line higher or lower. And GS3 is doing the same
12 thing. So it would determine what this line --

13 MEMBER BANERJEE: So they're not --
14 (Simultaneous speaking.)

15 DR. VEDOVI: It is. But --

16 MEMBER BANERJEE: You should tell them
17 what DIVOM is. It's basically minimum CPR as a
18 function of amplitude, that's what it tries to
19 give you, right?

20 DR. VEDOVI: Correct.

21 MEMBER BANERJEE: That's the output.

22 DR. VEDOVI: So, but at the very base is
23 the methodologies that is used to determine where
24 this setpoint can be in order to protect the
25 safety limit at event, at the termination of the

1 event.

2 So let's take this picture as an
3 example. If in this case, let's say this is a
4 setpoint amplitude of let's say ten percent. So
5 if this was the signal during the event, this is
6 where a trip would be initiated.

7 So the minimum, we can determine what's
8 the minimum critical power ratio reached before
9 the trip occur. So if the amplitude setpoint is
10 higher, the trip will occur later, that's this
11 point. And so the final MCPR will be lower
12 closer to the safety limit.

13 So if you raise your setpoint, you delay
14 the scram and you get a lower final minimum
15 critical power ratio when the oscillations are
16 terminated. If you decrease the setpoint, you
17 trip earlier and your final MCPR would be higher
18 and you will have more margin to the safety
19 limit.

20 But of course, as we'll see in the next
21 slide, plants are not operating in a steady state
22 conditions. There is inherent noise in the way
23 that they operate. This is an example of actual
24 data from a plant that shows what kind of signal
25 the detectors are capturing during normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operation.

2 And in this case, in terms of relative
3 amplitude, you can see some peaks that are in
4 excess of five percent. And this changes from
5 plant to plant.

6 MEMBER BANERJEE: The OPRM is typically
7 averaging four signals?

8 DR. VEDOVI: Correct.

9 MEMBER BANERJEE: Right.

10 DR. VEDOVI: An OPRM is called
11 oscillation power range monitor and is a relative
12 average of four local power range monitor that
13 are located into the core and provide normalized
14 signal on a specific region of the core.

15 So provides a very localized signal that
16 doesn't average the power across the entire core.
17 So it's a very realistic representation of
18 oscillations in a local region of the core.

19 And so the setpoint, if you come close
20 to this level of noise, you can imagine that if
21 you're in lock in and you have already the
22 confirmation counts and you are pulling the rods,
23 and suddenly you have an increase in an
24 amplitude, you will get a spurious trip.

25 You don't have any stability, you didn't

1 need to have a trip. So that's one of the
2 instances where making sure that you have enough
3 bounding of the noise into the plant, it's
4 important.

5 So too low setpoints interfere with the
6 natural noise of the plant with maneuvering and
7 operation of the plants and can increase the
8 likelihood of spurious scram.

9 MEMBER BROWN: I want to make sure I
10 understand. This is the background noise on the
11 output of the power range, oscillation power
12 range monitor system?

13 DR. VEDOVI: Correct.

14 MEMBER BROWN: Okay, and that's just the
15 variation you're showing over some time period?

16 DR. VEDOVI: Correct.

17 MEMBER BROWN: And that's
18 representative, I take it, of longer term. We've
19 got 800 seconds there, so I assume that's
20 consistent. Is this, I just don't know the
21 plants that this stuff is, I know what BWR is but
22 what type of instrumentation is used for this?
23 Is this analog stuff or is this computer based? I
24 know algorithms, when you say algorithm, I think
25 software. That's not a negative comment, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just --

2 DR. VEDOVI: Yes. These are run through
3 the power range neutron monitor system. So there
4 are some that our system is digital. So the
5 system that we are including in the plant's
6 process is a digital system.

7 MEMBER BANERJEE: But it's digitized.
8 It's an analog system?

9 MEMBER BROWN: Well no, it starts out
10 with the power range detectors --

11 MEMBER BANERJEE: Neutron detector, yes.

12 MEMBER BROWN: -- and that's obviously
13 an analog signal. So you convert those and then
14 you monitor that, and then your algorithm is
15 based on what you've --

16 DR. VEDOVI: Correct.

17 MEMBER BROWN: -- what you've analyzed
18 to determine what the noise level is?

19 DR. VEDOVI: Correct. So it takes all
20 the local power range monitor signal that comes
21 from the plants, those remain the same signals.
22 Those signals are then combined into the back
23 panel of the plant in different channels, and
24 they're sent to process through software that is
25 implementing EPRMs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And those determine then the logic that
2 may send the signal to the reactor detection
3 system for scram.

4 MEMBER BANERJEE: So they count?

5 MEMBER BROWN: No, I understand. I
6 mean, we had tremendous problems with
7 intermediate range noise shutting down our plant,
8 may be plants. And when we went to
9 microprocessor based stuff, we developed
10 algorithms similar to this that literally take
11 the Noise systems out. It took a lot of time to
12 get that refined with the different types of
13 plants we had. So I was just curious as to --

14 MEMBER BANERJEE: So you do filter and
15 do all sorts of things, right?

16 MEMBER BROWN: Well most of the
17 filtering is probably done on the software, isn't
18 it? I mean, you do some basic filtering --

19 (Simultaneous speaking.)

20 DR. VEDOVI: You're correct, because, as
21 we said, we know the range of frequency so we can
22 cut the frequencies that are outside of this
23 range but still within the range of frequency
24 that may be related to thermohydraulic
25 instability, we cannot eliminate that noise.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 As we discussed before, the trend in
2 stability based on MCPR for based on DIVOM
3 methodology have been increased, this OLMCPR and
4 made stability the limiting events. When
5 stability based OLMCPR increase, it becomes more
6 complicated to do a core design. You need to
7 change the amount of fuel bundles that are needed
8 for every load batch fractions and so forth.

9 MEMBER BANERJEE: So normally the
10 operating limit is set based on transients like
11 turbine trips or whatever. So that limit is
12 usually higher than the stability limit. So the
13 plant is allowed to operate up to the OLMCPR.

14 But because the stability limit in some
15 cases is actually challenging this, which is very
16 strange, but nonetheless it is, then your plant
17 limitation is limited now, the OLMCPR.

18 DR. VEDOVI: Correct. So some plants
19 have been essentially forced to try to mitigate
20 this increase in OLMCPR. And the only way that
21 you can do that is to lower your setpoints. But
22 by lowering the setpoints as we saw, now you're
23 increasing the chance of having the spurious
24 scram.

25 So the unpleasant situation where

1 utilities have phased, that they have to make the
2 decisions in terms of, you know, what OLMCPR they
3 can afford to have and what setpoints they're
4 going to implement.

5 And to Dr. Banerjee's point, the actual,
6 you know, resulting operating limit for the plant
7 is really the results of stability, a transient,
8 and core design. So it's really these three
9 function have to come together to determine
10 ultimately what is going to be your operating
11 limit that you design your core fore and that
12 allows you to add margin to the safety limit to
13 accommodate transient and stability event.

14 So you can have a fantastic steady state
15 operating limit. But if your transient is really
16 bad, it doesn't matter because you have to
17 increase your operating limit to account for the
18 margin for a transient or instability event. And
19 that's what really determines the cycle specific
20 operating limits MCPR.

21 So that was the premises that really
22 prompted us to advance the methodology they
23 created for some of the tools that now are
24 available such as best estimate codes, fast
25 computing capability, and provide much more up to

1 date methodology based on realistic analysis to
2 simulated this event and to calculate what
3 operating limit and set points can be
4 implemented.

5 I will not get into the details on how
6 the current methodology is performed. I think
7 the staff might have touched a little bit on
8 this. But it's very counterintuitive way of
9 simulating what is seemingly a very
10 straightforward transient such as a two
11 recirculation pump trip.

12 The analysis itself is divided in pieces
13 and is done with different codes, and the results
14 are put together at the end. Each one of these
15 pieces has its own conservatism, and is on unique
16 peculiarities. So it's a very complex process
17 and very conservative.

18 With GS3, we simulate the actual event
19 from beginning to end with the same code. That's
20 why it's simplified. And we get a little bit
21 more in details in the closed section.

22 As we say, the aim was to reduce the
23 likelihood of spurious scram or alarms, give more
24 plant flexibility by providing more realistic
25 limits for the plant.

1 MEMBER SKILLMAN: Let me ask this
2 question, please. Is there a population of
3 transients that describe or describes the
4 boundary condition? Is there one transient that
5 is the limiting transient or are there two or
6 three that when those transients have been
7 factored into the stability solution, you have
8 99.9 percent confidence level that you have
9 protected the safety margin and the critical
10 power ratios?

11 DR. VEDOVI: Yes, we have very
12 significant literature and history about that.
13 And certainly, a two recirculation pump trip is
14 the referenced limiting transient for stability.
15 And the reason is that because it results into
16 the largest variation of flow and end up to be at
17 the highest power to flow ratio conditions after
18 the pump are tripped because you go all the way
19 back to another recirculation line.

20 So those are the high power to flow
21 ratio is one of the key drivers for developing
22 oscillations and also for assessing how is the
23 grow rate of your simulation. So how fast they
24 develop, how big they are, power to flow ratio is
25 one of the key issues, key driver.

1 That's why the two recirculation pump
2 trip has been in the industry, accepted as the
3 limiting event for stability analysis.

4 MEMBER SKILLMAN: Thank you. Thank you.

5 DR. VEDOVI: So in the next couple of
6 slides, just a quick summary of the GS3
7 methodology. So it's meant to be an alternative
8 to the DIVOM and is using TRACG which is a best
9 estimate system called thermohydraulic and three
10 dimensional electrokinetic models which is used
11 to calculate the minimum critical power ratio at
12 the time of oscillations suppressions and show
13 that the safety limit is protected.

14 As it was mentioned, because we are
15 using the current detecting suppress system
16 implemented at the plants which is the period
17 based detection algorithm that we show before for
18 Option III plants, or the average power range
19 monitor flow bias scram trip for Option 1-D and
20 Option II plants, therefore there is no need to
21 change, we're not asking to change any software
22 or any hardware in the plants.

23 We're simply improving the methodology
24 that allow us to calculate what setpoints are
25 going to protect the safety limits.

1 And as it was mentioned, we have similar
2 methodology that has already been approved and
3 implemented which is DSS-CD but that is used for
4 EPU, MELLA+ operation.

5 GS3 is leveraging the same methodology
6 and is bringing the same technology to plants
7 that do not operate in MELLA+ and is meant to
8 essentially provide, I like the way that Dr.
9 March-Leuba described it, to bring it essentially
10 in the 21st Century Option I-D, Option II, and
11 Option III methodology.

12 So it's a kind of bringing the state of
13 the art technology of analysis for those solution
14 and bring it aligned with what we do currently
15 for the DSS-CD.

16 MEMBER BANERJEE: I guess the real issue
17 here is that we are doing this based on
18 calculations. And you're going to defend this in
19 the future, of course, which is all calculations
20 of stability subject to numerical damping, the
21 numerical diffusion.

22 And you are going to show us, hopefully,
23 why you believe, we visited this for the DSS-CD
24 that you don't have this problem when you do the
25 calculations here.

1 I mean yes, you use explicit codes and
2 so on, but that's the crux of the issue, right,
3 ultimately?

4 MR. HECK: Do you want me to? This is
5 Charles Heck, GEH.

6 MEMBER BANERJEE: You don't have to in
7 open session because we might ask you really more
8 detail questions --

9 MR. HECK: Okay. If you ask the
10 question again, I can answer it in the closed
11 session.

12 MEMBER BANERJEE: And the nodalization,
13 all these things, your validation database, I
14 mean, you have to give us assurance that we feel
15 happy about these calculations.

16 You've made us happy once before, you
17 actually made Dr. Wallace happy enough that he
18 signed off on it. So it's okay.

19 DR. VEDOVI: And what we can, what I can
20 say in this session is that the same nodalization
21 and the same model that we used for DSS-CD we
22 used for GH3. So we leveraged all that database
23 and all the demonstration that we did and were
24 approved for GS3.

25 That's why, I mean, we are saying we are

1 bringing the same methodology, the same
2 technology to Option I-D, II, and III.

3 MEMBER BANERJEE: And nothing has
4 happened in those five years of when we looked at
5 this last that has shaken your faith in TRAC's
6 ability, TRACG's ability to predict these things?

7 DR. VEDOVI: It is not, actually
8 increased it because we keep performing benchmark
9 when we have available data. And that give us
10 more confidence that we are capable of capturing
11 the real phenomena which ultimately is the most
12 important qualification. In fact, in a couple of
13 slides, I'll have the qualification list of TRACG
14 for stability related events.

15 MEMBER BANERJEE: Yes. It's just that
16 any computer code which is finite difference and
17 not based on a non-diffused method is going to
18 give you damping. There's no way out. So how do
19 you know that you've got a converged answer?

20 DR. VEDOVI: Well, as you know we have
21 done extensive sensitivities on the nodalization
22 and on the model. And we have proven that it's
23 an acceptable level and we are capable of
24 simulating the instabilities.

25 Nothing has changed with respect to DSS-

1 CD because the phenomena is the same. It's just
2 different bloodline. But is the same phenomena,
3 the same transient, and so the same model that is
4 capable of capturing actually more limiting event
5 for MELLA+, of course it's capable of capturing
6 the same phenomena for MELLA conditions.

7 MEMBER BANERJEE: Well you can argue
8 that, I don't want to get into this esoteric
9 discussion here. But because things grow more
10 rapidly in the MELLA+ region, actually numerical
11 diffusion makes less of an effect than it would
12 in a more slowly going transient. So just a
13 thought. Okay.

14 DR. VEDOVI: We can come back to later.
15 But we did --

16 MEMBER BANERJEE: I don't want to go
17 over my time limits.

18 CHAIRMAN STETKAR: You're already over.
19 Way over.

20 MEMBER BANERJEE: Really?

21 CHAIRMAN STETKAR: Yes.

22 MEMBER BANERJEE: Okay. Please go
23 ahead. They will castigate me otherwise.

24 DR. VEDOVI: Then as I mentioned, the
25 methodology is based on the same approved methods

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for TRACG AOO and DSS-CD and in essence ESBWR
2 stability LPRs.

3 For the assessment of uncertainty, we
4 used the CSAU, the code scaling applicability and
5 uncertainty methodology that is described in the
6 NUREG 5249. And lastly, to also come to your
7 points, TRACG code has been extensively qualified
8 with respect to stability events and other
9 transient events.

10 In this slide, it summarize the key
11 qualification case with respect to different test
12 facilities and with actual plant data. We saw
13 with the first slide all events that occur, all
14 the instability events that occurred, and we have
15 a very large samples of benchmark that we perform
16 and are used for the qualification of the code.

17 MEMBER BANERJEE: So why is Oskarshamn
18 in red?

19 DR. VEDOVI: Oskarshamn is in red
20 because it's the latest benchmark that we have
21 performed.

22 MEMBER BANERJEE: And where did TRACG
23 not work well? I don't want to know where it
24 worked well. Where did it not work?

25 DR. VEDOVI: Well, it depends on what it

1 means not work well I guess. We were successful
2 --

3 MEMBER BANERJEE: Suppose you did not
4 tune the code to anything. Were you able to do
5 all this without any form of tuning? Did you get
6 the amplitudes and the onset for those events
7 which could be measured?

8 DR. VEDOVI: Well, I was not around in
9 '77 so I cannot claim for the --

10 MEMBER BANERJEE: That's a good answer.

11 DR. VEDOVI: -- Peach Bottom cases or
12 the LaSalle. But I mean, in the early stage when
13 these best estimate codes were developed, of
14 course there was a lot of work done on developing
15 and finding what models, nodalizations, and
16 numerics, and modeling capability were necessary
17 to reproduce these events.

18 What I can tell you is that the one that
19 we have been simulating, you know, from the last
20 four or five, we didn't have to cue in the model.
21 We simply tried to model the event as it is.

22 And the key part is really to get the
23 right initial conditions, the boundary conditions
24 for the event. Sometimes the key part is to be
25 able to get what we call it, the wrap-up or the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 core state from when the event initiated.

2 And that's important to represent,
3 capture the initial state point. But the code,
4 it's really then we let the code simulate and
5 calculate, you know, as realistically as it can.

6 But we have done so much leg work on the
7 nodalization to validate what you describe
8 before, the medical damping, convergence and so
9 forth that we don't have to do that, tune it on a
10 case specific basis because that would invalidate
11 our basis.

12 MEMBER CORRADINI: Can I ask Sanjoy's
13 question differently? So you must have a series
14 of figures of merit that when you run an untuned
15 simulation, you look at timing to trip, amplitude
16 predicted versus amplitude data.

17 What are the figures of merit that you
18 use to decide success or failure? Do you have
19 that list? Or we can talk about it in closed
20 session? We can talk about it in closed session
21 since we're already behind.

22 (Simultaneous speaking.)

23 MEMBER CORRADINI: But I guess I'd be
24 curious about these are the five things I look
25 at. So when I do a simulation I look at these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 five things that are within my engineering
2 judgement tolerance and then I move on, or I
3 don't.

4 MR. HECK: This is Charlie Heck, GEH.
5 I think I can address that. What are the figures
6 of merit when you're qualifying your code against
7 --

8 MEMBER CORRADINI: Right.

9 MR. HECK: -- these kind of events?
10 You've already mentioned one, amplitude, the
11 magnitude of the, or if it ends up being a limit
12 cycle oscillation, the ultimate magnitude that's
13 reached. If it's a growing oscillation, the
14 growth rate.

15 If it's a decaying oscillation, for
16 example these low decay ratio Peach Bottom tests,
17 it's how fast does it decay which also addresses
18 the issue about numerical damping. And the
19 fourth one is frequency. Do you predict the
20 right --

21 MEMBER CORRADINI: Sure.

22 MR. HECK: -- frequency according to the
23 measured base. So those are the main, main ones.
24 For some of these regional oscillations where you
25 see an out of phase thing, if you have

1 information, we also had recorded information
2 from Peach Bottom even though that wasn't
3 regional, you would see an axial power shaped
4 shift that's available and can be determined from
5 each of the LPRM levels.

6 So you should see that timing shift as
7 axial power shape changes up and down. So that's
8 another figure of merit that's evaluated. So I
9 think I covered them all --

10 MEMBER BANERJEE: I'll tell you what
11 puzzles me about this, and maybe this should be
12 in the closed session. But, you know, this is a
13 very complicated feedback loop in which the fuel
14 participates. And there's of course the gap
15 conductance changes which is always what I worry
16 about.

17 And so the time constant for these to go
18 back and forth is probably between six and ten
19 seconds depending on the -- or lower is it?

20 MR. HECK: Four or five.

21 MEMBER BANERJEE: Four or five, okay.
22 But you know, even when you go to a different
23 fuel or you have something like a fuel at a
24 different burn up. So that's why I'm so
25 surprised that if you get the answers right.

1 Novak Zuber used to always tell me that
2 if you get the answers right all the time,
3 something is being cooked. You know? When you
4 look at --

5 MR. HECK: They didn't say they get them
6 right. That's why I asked about what's the
7 tolerance because I'm assuming that the tolerance
8 is --

9 MEMBER BANERJEE: Because with all these
10 different fuels, all these different burnups, you
11 know, with all these different gap conductances
12 things, how is it that you get it right?

13 DR. VEDOVI: What we show is that we are
14 capable of reproducing the events and in most
15 case when we are interested in a particular
16 parameters, say power, we are not matching
17 exactly what was in the event, but we are
18 bounding.

19 So if we can ensure that our predicted
20 power is higher than it's conservative. And so
21 it's okay. We are capturing the evolution of
22 events, we are bounding the data. And so for
23 purpose of applicability, that is acceptable. We
24 don't claim that we can match the exact power
25 peak of each event that occur.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And with respect of timing, timing is
2 one of the most difficult things to capture. But
3 as far as the setpoint calculation goes, it's
4 irrelevant of when the oscillation starts. And
5 we are not have any specific target or
6 calculations that enforces us to calculate well,
7 the oscillation had to develop in 60 seconds or
8 two minutes or five minutes.

9 It doesn't matter. If they do develop
10 and they do grow, what's the setpoint that is
11 going to the safety limit?

12 MEMBER BANERJEE: I agree. So the
13 fidelity of this has to be sufficient to ensure
14 that your set points will protect your safety
15 limits?

16 DR. VEDOVI: Correct.

17 MEMBER BANERJEE: That's really --

18 DR. VEDOVI: That's the purpose of the
19 methodology.

20 MEMBER BANERJEE: We're just giving you
21 a hard time.

22 DR. VEDOVI: Thank you. And that's
23 everything we have for the open session.

24 MEMBER BANERJEE: All right, thanks very
25 much. Now I guess we need to hear from the staff

1 in open session briefly, and then you'll be back,
2 right?

3 DR. VEDOVI: Correct.

4 MEMBER BANERJEE: Don't mind us.

5 MS. GUZZETTA: I'm Ashley Guzzetta with
6 NRR staff and this is Dr. Jose March-Leuba from
7 Oak Ridge National Laboratory. We're going to
8 give a brief overview. I'll turn it over to
9 Jose.

10 DR. MARCH-LEUBA: Yes, so we're way
11 behind time so I'm immanently qualified to finish
12 this really fast. We are going to skip a little
13 bit through the slides that we have prepared and
14 just give you the points of what the ideas that
15 we wanted to transfer to your minds after this
16 presentation.

17 Number one is it's a little surreal and
18 the Staff take instabilities very, very
19 seriously. And I as a consultant take
20 instabilities very seriously. Instabilities are
21 real and they can become a real problem if we
22 don't discuss.

23 We must discuss. Okay? The other
24 problem we have, I'm showing you here real data
25 from plant in which the LPRN, the local power was

1 oscillating this high. And when you average the
2 left side and the right side of the core and you
3 do the APRN, this is the response you get so that
4 you're having very large power oscillations,
5 there's flow oscillations, there are CPR
6 oscillations and you're not seeing it on your
7 reactor protection system.

8 So that's why we needed to have this
9 long term solutions which will address this type
10 of instability and scram on time.

11 Let's go back, I was very quiet during
12 the previous presentation. I want to address a
13 few of the points that have been raised that
14 weren't on my slides at all.

15 MEMBER BANERJEE: In open session?

16 DR. MARCH-LEUBA: In the open session.
17 You ask about what has the event, the event
18 frequency been reduced recently. And I'm going
19 to give you some anecdotal evidence.

20 Back in the early '80s when I was 35
21 years younger than I look now, and I went to make
22 some stability tests in Dresden reactor. And we
23 were there because I knew fuel what we need to
24 use and we were running some stability tests.

25 We were there for five days, and at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 end of the day the operator came to me and said
2 what is this stability thing about? The operator
3 was not even aware that the reactors could become
4 unstable.

5 You go now to the control room of any
6 control room in the United States and the first
7 thing you see is the operating map which in big
8 red area that says instability reaching. Avoid
9 it.

10 There awareness of operators about the
11 stability has increased tenfold. And that is one
12 of the reasons why the event frequency has been
13 reduced.

14 Number two reason that it's been reduced
15 is because the fuel elements are really good.
16 The fuel designs that we've had recently are
17 extremely -- if we were running the reactors the
18 way we're running them now with 1980s technology,
19 1980s fuel, they'll all be unstable.

20 These new fuels are designed with a
21 stability in mind, and we can go into the terms
22 of why they are more stable, but they are a lot
23 more stable than --

24 MEMBER BANERJEE: Does it got to do with
25 the time constants because of more subdivision or

1 what?

2 DR. MARCH-LEUBA: Mostly with the
3 pressure drop and their optimized spaces.

4 MEMBER BANERJEE: But now just to ask
5 you this question, would the new fuel which is
6 optimized for higher CPR, again I don't know if I
7 should talk about this in the open session, so if
8 you reduce the flow of course, your CPR
9 performance actually deteriorates, right?

10 DR. MARCH-LEUBA: That happens with one
11 type of fuel.

12 MEMBER BANERJEE: Yes, so without naming
13 it, so what you're saying is sort of out of whack
14 with that, right?

15 DR. MARCH-LEUBA: No.

16 MEMBER BANERJEE: Because if you do a --

17 DR. MARCH-LEUBA: If you remember,
18 without naming the fuel by name I think we can
19 talk about this. This fuel is just as good as
20 the old one, as low flow. It's much better at
21 high flow. So when we say that there's a
22 reduction in the flow --

23 MEMBER BANERJEE: Okay, that's a nice
24 way to put it. Go ahead.

25 DR. MARCH-LEUBA: Yes, so it's just as

1 good as the old one was on low flow.

2 MEMBER REMPE: But Jose, if we know
3 about it and we've tried to address it so much,
4 why are we still having it in 2015 which is what
5 I was trying to ask earlier. I mean, is it, it
6 seems like we should be accommodating, or ending
7 them from occurring, right?

8 DR. MARCH-LEUBA: Considering how we are
9 running this reactor, we're doing pretty well.

10 MEMBER REMPE: But it's because we're
11 reducing the margin is why we're still seeing it?

12 DR. MARCH-LEUBA: The reactors are
13 unstable at low flow high power. And in this
14 particular event we're still evaluating it. We
15 have some information from the plant and it was a
16 reactional flow because it was the pump.

17 MEMBER REMPE: Okay. It happens.

18 DR. MARCH-LEUBA: And it happens the
19 same way that turbine trips happen. It's just
20 another AOO, it's nothing to worry about. We
21 have to make sure that the protection works and
22 it protects the reactor.

23 Another thing I wanted to say is that
24 we've had, again, just we have 15 events there,
25 they're having a lot more than that because the

1 German reactors are required to unstable once a
2 cycle.

3 They actually test their limit line
4 experimentally. So there's a lot more events
5 than that. And not a single one of these events
6 have resulted in fuel damage. Okay, fuel damage
7 is of course the way to measure the real impact.

8 And the calculations show that not a
9 single event has violated CPR. Definitely no
10 fuel damage for sure. So we are doing a good job
11 preventing it. There are turbine trips, there are
12 fuel water heater running and there are lots of
13 pumps, there are instabilities. It's one more
14 AOO.

15 This slide was trying to address another
16 question that was addressed by Dr. Skillman
17 again. You said which is the limiting event that
18 we have to analyze.

19 So this is the power to flow map. And
20 we know the stable region is somewhere to the
21 left of this red line. And we've said that
22 before, this red line is a function of 25
23 different parameters. We cannot do a two
24 dimensional map and draw a line. It's a function
25 of 25 parameters.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But in our mind we can draw it in a two
2 dimensional line, and you can close this line two
3 ways. During the start up going up this way, or
4 you can go forward action to that way.

5 There are a million other ways to get
6 in, but they're not likely. So when you go
7 during a startup, you're pulling control rods
8 slowly, and they're control, and therefore you
9 penetrate the line just a little bit. So you
10 have an instability, it's going to be a small one
11 and it's going to be no consequence.

12 The operator is looking at it because he
13 just pulled that rod. He's going to put the same
14 rod back in immediately. So this instabilities,
15 we analyze them but they're of no consequence.

16 The important one is when you're
17 operating up here and you lose your pumps and you
18 move all the way into unstable region. Then
19 you're very unstable and that is going to be your
20 limiting case. And that's why the two pump RPT
21 is the one that we consider to be the limiting
22 scenario.

23 I won't bore you, we don't have the time
24 unless you really want to ask the question about
25 what the DIVOM methodology is. Basically it's

1 correlating the oscillation power versus the loss
2 of CPR, and certainly not HCOM.

3 You are welcome to ask questions, but we
4 are running out of time. I love to talk about
5 this for three days. So this is our typical
6 limiting transient. It's a two reactor pump, two
7 recirculation pump trip.

8 So your reactor power is oscillate is
9 here at 100 percent power or whatever. You trip
10 your pump so you're going to have a significant
11 reduction in power immediately. And then slowly,
12 you're going to have a subcooling transient.

13 And that has to do with the behavior of
14 the feed water heaters and the turbine. And it
15 is that subcooling that typically gets the
16 instability going. So we don't have the
17 stabilities right here during the flow and back.
18 We typically have them 20, 30, 60 seconds later
19 as the subcooling comes.

20 But if we look in the CPR domain, this
21 is the CPR as a function of time for the same
22 event, you have an initial CPR. And because of
23 the reduction in power, you gain CPR. And now
24 you start oscillating with an increased margin
25 because you have gained some CPR before the

1 oscillation occur.

2 If your LTS, long term solution is
3 sensitive enough, you're going to scram even
4 before you get back to where you were, and that
5 is the case in most plants. I mean, what we do,
6 the multi-panel analysis and we have run and we
7 see it in the closed session, every single plant
8 unit that stays is going to apply years three,
9 half of them end up scrambling here with more
10 margin than they started with.

11 And the other half end up scrambling here
12 with a slightly less margin than they started
13 with, but with a lot of margin to do safety
14 limit. We will also be showing this slide a lot,
15 you see on the left. And the people from
16 Subcommittee have seen it, have had it burned in
17 their retina. But the other guys have not seen
18 it.

19 And this is how the operating limit is
20 set in front. You are trying to protect your
21 MCPR of 1.0 which is your safety limit, right,
22 your real safety limit. But you have
23 uncertainties. You don't know what your flow
24 really is, you don't know what your CPR
25 correlation really is. You have a two, three

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent accuracy.

2 So you have to add all this
3 uncertainties and you try to protect what we call
4 the safety limit so that whenever you hit the
5 CPR, you're very sure that you're not here. So
6 you're having a probabilistic approach.

7 On top of the safety limit, then you run
8 all your transients and your AOOs. And for
9 example, for AOO number three you have this
10 amount of CPR, for AOO number two you have this
11 much delta CPR. For stability you have this much
12 delta CPR and one of them is going to be the
13 limiting one. That's the one that says your
14 operating limit.

15 When you add them all up, you get your
16 operating limit. Typical numbers for the
17 operating fleet, I'm about to say what happens is
18 Monte Carlo simulation for every plant in United
19 States, the delta CPR, this number is 0.26,
20 that's the average for all 15 plants that were
21 analyzed.

22 The delta CPR for stability in GS3 is
23 0.13. Okay, so you are going to be operating here
24 at 0.26 when you only need 0.13 for stability
25 wise. However, because of the conservatism in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the methodology, some plants, which is five,
2 maybe more, were actually set in their own CPR
3 higher because they thought they needed margin.

4 And GS3 really brings that into
5 perspective and through analysis demonstrated
6 that they were over doing it. So I won't bore
7 you with the summary. You can read it and we can
8 speed up through the presentation and talk more
9 details in the closed session.

10 So I will propose that we move into the
11 closed session if there are no questions.

12 CHAIRMAN STETKAR: GE's up?

13 MS. GUZZETTA: GE's up, yes.

14 CHAIRMAN STETKAR: Okay, what we have to
15 do is make sure that everyone present confirms
16 there's no one here that shouldn't be here. We
17 need to also insure that we get the bridge line
18 closed. And we will wait until we have
19 confirmation that that's taken care of.

20 MEMBER BANERJEE: We have a confirmation
21 density.

22 CHAIRMAN STETKAR: You're a sick person.

23 MEMBER REMPE: Just a sick sense of
24 humor I would say.

25 CHAIRMAN STETKAR: No, he has no sense

1 of humor, he's a sick person. And we're still on
2 the public record.

3 (Whereupon, the above-entitled matter
4 went off the record at 9:38 a.m. and resumed at
5 10:46 a.m.)

6 CHAIRMAN STETKAR: We are back in
7 session, and the next topic, Draft Proposed
8 Rulemaking on Mitigation of Beyond-Design-Basis
9 Events, and Dr. Steve Schultz will lead us
10 through this.

11 Steve?

12 MEMBER SCHULTZ: Thank you, John.

13 This is a draft proposed rulemaking.
14 This is the state that we're in with this
15 project, and it is the purpose of the committee's
16 deliberation today to determine whether the
17 package that's been developed by the staff is
18 ready to be presented to the Commission and go
19 out for then public comment. And so we're in
20 that phase of the rulemaking.

21 We've met with the staff many times on
22 this project in various forms because originally
23 there were many pieces coming from the NTF
24 recommendations following the Fukushima accident
25 that proposed rulemaking in different areas.

1 This then eventually turned into a
2 consolidated rulemaking package which coupled
3 together a number of different parts of program
4 that made sense to address in concert because of
5 administrative issues as well as technical
6 issues.

7 So what we're going to hear today is
8 that the consolidated rulemaking package
9 discussion all focused on these beyond-design-
10 basis events. So with that this morning I'd like
11 to turn the discussion over to the staff to Aby
12 Mohseni to introduce the topic from the staff and
13 introduce the participants today.

14 MR. MOHSENI: Thank you very much, Dr.
15 Schultz. Good morning. My name is Aby Mohseni
16 and I'm the deputy director for the Division of
17 Policy and Rulemaking in the Office of Nuclear
18 Reactor Regulation.

19 Today we will discuss the proposed
20 mitigation of beyond-design-basis events
21 rulemaking. We presented the proposal to the
22 ACRS Fukushima Subcommittee on March 19th, 2015.
23 Today we plan to go through a similar
24 presentation using essentially the same slides
25 but at a higher level of discussion, recognizing

1 the much more limited time available for this
2 full committee meeting.

3 We are seeking ACRS endorsement for
4 issuance of the proposed rule package for public
5 comment. With regard to ACRS endorsement for
6 issuance of the proposed MBDBE rulemaking, it is
7 our view that the proposed rule needs to be
8 sufficient to support informed external feedback
9 such that the NRC using that feedback can produce
10 a good final rule.

11 Accordingly, you will find that this
12 proposed rule package seeks external feedback on
13 a number of issues for which the NRC expects
14 stakeholder feedback to be helpful in reaching a
15 final regulatory position.

16 To support this presentation I have
17 several members of NRR and NRO. Tim Reed from my
18 staff will be leading the discussion of the
19 proposed rulemaking. Tim will go through a
20 fairly quick presentation on the proposed rule
21 and supporting guidance.

22 From NRO we have John McKirgan who will
23 support Tim with regard to the portions of the
24 proposed rule that impact new reactors. Also
25 from NRO we have Clint Ashley who will support

1 the discussion on draft regulatory guidance that
2 is applicable to new reactors. There are other
3 members from Mitigation of Beyond-Design-Basis
4 Events Rulemaking working group in attendance to
5 support questions from the committee. We
6 look forward to an informative interaction with
7 the ACRS today. I want to thank the ACRS for its
8 flexibility and patience in supporting the staff
9 with our efforts to provide the materials for the
10 committee.

11 As the ACRS knows, this proposed
12 rulemaking is a high priority action on an
13 expedited schedule. In fact as we speak we are
14 in the last portion of office concurrence. We
15 expect to get the proposed rule to the EDO
16 towards the end of next week.

17 And now I would like to turn it over to
18 Tim Reed to begin the presentation.

19 MR. REED: Okay, thanks Aby. Thanks Dr.
20 Schultz. Like is mentioned I'll try to go
21 through this a little bit faster than we went
22 through it on March 19th.

23 So to start with the background, and Dr.
24 Schultz somewhat summarized this already, as this
25 committee's well aware this is rulemaking that

1 pulled together, consolidated two other ongoing
2 rulemakings and weaved those into an integrated
3 package that I think works pretty well.

4 For many reasons, administrative and
5 technical seem to work together of course, as
6 with the Station Blackout Mitigation Strategies
7 rulemaking and the Onsite Emergency Response
8 capabilities rulemaking efforts. And those as a
9 result of that address a fairly large number of
10 recommendations that were in the NTTF report.
11 Those are enumerated on the slide.

12 Again this should be very familiar to the ACRS.
13 And more importantly, they actually address the
14 actual regulatory actions that stem from those.
15 And those are two orders. EA-12-049, by far the
16 most significant portion of this rulemaking,
17 that's the mitigation strategies order; and Order
18 EA-12-051, that's the spent fuel pool level
19 instrumentation order. Those are both addressed
20 in this and made generically applicable through
21 this proposed rulemaking.

22 It also addresses the request for
23 additional information from March 12th of 2012,
24 and insofar as it was addressing staffing and
25 communications capability, so that's built into

1 this also.

2 And of course I think the committee's
3 very well aware that we're also considering the
4 feedback from the reevaluated hazards that are
5 being currently addressed under NTF 2.1 and that
6 factors into reasonable protection in 155(c)(2).
7 So all that's being done. That's the scope of
8 this rulemaking. I think most folks here are
9 very well aware of that.

10 So I'll just walk through this thing
11 very quickly then. It's structured like all
12 rules starting off with the applicability section
13 and then followed by the more substantive
14 requirements. This of course applies to power
15 reactors whether they're current licensees or
16 applicants. And we've developed in such a way as
17 to fold in decommissioning.

18 So what basically applies to you as
19 throughout your lifetime as a licensee, and we've
20 removed those requirements as we'll talk about at
21 the bottom of the slide, as you proceed through
22 decommissioning process. So that's good
23 rulemaking. We understand the folks on
24 decommissioning. We're trying to build that into
25 our regulation as we go along.

1 In addition to that it also has new
2 design requirements, new future design features
3 for future power reactors, and that of course is
4 the 155(d), and I have several folks from NRR
5 here that can talk about that in more detail when
6 we get to that later on Slide 7.

7 Decommissioning provisions I just
8 mentioned. Those are basically to reflect the
9 recent decisions that the NRC's made in recent
10 decommissioning actions. And so we're not
11 carving out any new territory here, but we are in
12 fact trying to reflect that and hopefully by
13 building those requirements into our rule
14 facilitate that process.

15 So as you remove fuel from the reactor,
16 obviously the reactor itself no longer becomes
17 the concern nor the primary containment. It goes
18 to the spent fuel pool and if you have a
19 secondary containment you're concerned about
20 that. And then once it gets to a low enough
21 level of decay heat, then you can remove
22 everything except what we always call (e) (5) (B)
23 provisions or what's now in 50.54(hh) (2).

24 So that's the way -- and then once you
25 pull everything out of the spent fuel pool and

1 just to see you were out completely, so it's that
2 basic structure again. This reflects exactly how
3 we've been proceeding through decommissioning
4 right now. We're trying to reflect that in our
5 rule and facilitate that process. So again no
6 new territory there. That's just trying to do
7 rulemaking correctly.

8 Now we get to actual, what I think of as
9 the central centerpiece, if you will, of this
10 rulemaking and why it made so much sense to pull
11 it together into one rule and that is the
12 integrated response capability requirements.

13 And those are requirements that would
14 require licensees to develop, implement and
15 maintain an integrated response capability that
16 includes three different guideline sets, if you
17 will, that were developed for different
18 circumstances under different times, and
19 integrate those with the currently existing
20 symptom based EOPs that many folks here are well
21 aware and in fact probably worked on that went
22 into place after TMI.

23 So the intent is not to touch EOPs,
24 leave that intact, but then weave these three
25 different guideline sets in there and do that in

1 a way that develops an integrated response
2 capability and allows the licensee to more
3 seamlessly transition and use those guidelines
4 sets as you proceed through an event. So that's
5 the intent of these regulations.

6 And the first one, the beyond-design-
7 basis external event mitigation requirements,
8 those are in fact the mitigation strategies order
9 requirements or what's more commonly known as
10 FLEX in the industry or FLEX support guidelines.
11 And so that's about making those mitigation
12 strategies generically applicable, and that is
13 155(b) (1) .

14 And then the second portion, 155(b) (2)
15 is basically simply transporting into this rule
16 what currently exists at 50.54(hh) (2) . And
17 that's the intent. There's no intent here to
18 substantively change any of that work.

19 So the idea is we're moving in here, it
20 makes a lot of sense to have it here. As folks
21 out in the industry know very well, these
22 strategies are virtually identical in some cases
23 to what's going in place with FLEX, of course
24 FLEX is a much more capable and engineered
25 solution, in my opinion, than what was in

1 existence before. But they are very similar and
2 it makes a lot of sense for them to be there.

3 But those are for loss of large areas
4 due to due explosions and fires. That was the
5 circumstance for which they were developed, and
6 now of course what we're putting in place with
7 mitigation strategies beyond-design-basis events
8 is for a site-wide event. It's an indefinite
9 engineered capability, all those functions
10 simultaneously and no sharing of equipment.

11 So you can see how it's a much more
12 substantial requirement that FLEX is putting in
13 place, but they do work very well by integrating
14 them, in my view, into this paragraph (b). So
15 those are both requirements, either by order or
16 currently in the regulation.

17 And then finally we come to what I'm
18 sure will be the focus, has been the focus today
19 for many folks looking at this rule and I'm sure
20 it will be for the Commission is the Severe
21 Accident Management Guidelines. And these are
22 currently a voluntary initiative developed in the
23 late '80s and through the '90s and that were
24 implemented as a voluntary initiative in the end
25 of 1998 at all facilities. And as I think the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 committee's well aware, following the Fukushima
2 event the NRC staff went out in a TI and looked
3 at that to see where those stood in terms of the
4 voluntary initiative, and found at least in some
5 cases a lack of configuration management or
6 maintaining those over time, okay.

7 So that's kind of the lesson learned, if
8 you will. That was why these things got brought
9 into integration, in fact, under the
10 Recommendation 8 rulemaking effort.

11 So the way that's structured is, and
12 I've talked about this extensively before. We've
13 structured that in light of what I think are the
14 risk insights that make sense here is to
15 certainly solve the problem, and that would be
16 putting in place requirements for the guidelines,
17 maintain the configuration of those guidelines
18 both for the plant configuration and for generic
19 changes from the Owners' Group, okay, to reflect
20 these new capabilities which are pretty
21 substantial in terms of FLEX.

22 But obviously they were designed pre-
23 core damage but you would of course would try to
24 use those post-core damage. So they reflect all
25 that in these SAMGs and of course integrate them

1 with the EOPs and that as you hopefully are aware
2 that also involves drills, training, and change
3 control folds into SAMGs, what you integrate them
4 into (b) (1). So that's the nature of the three
5 guideline sets that we're trying to integrate
6 into EOPs.

7 CHAIRMAN STETKAR: Okay, and I'm going
8 to stop you. You're being Tim, so I'm going to
9 stop you right here. You used the word, I didn't
10 count it, the number of times, but you used the
11 word "integrated" quite often.

12 After Three Mile Island we went through
13 a realization that event-based operating
14 procedures where the operators had to look at
15 specific conditions and decide that they were in
16 a small LOCA inside the containment versus a tube
17 rupture versus some other transient that might
18 look like a LOCA weren't very well suited. So we
19 developed what I'll use the term "integrated",
20 function based, symptom based emergency operating
21 procedures that have served the industry very
22 well, and I agree with that.

23 We have now devolved into a situation
24 where we are progressively reinforcing that old
25 notion of event based procedures now outside of

1 the EOPs. We have event based FLEX procedures
2 that specifically apply to, I've forgotten what
3 the quote is but it's something like -- I'll have
4 to read it here. No, I can't find it quickly,
5 but it applies specifically to beyond-design-
6 basis external events caused by natural phenomena
7 that result in an extended loss of all AC power
8 and loss of access to the normal, to the ultimate
9 heat sink. So that's a condition that I have to
10 think of as an operator.

11 We have fire response procedures which
12 according to the Statements of Consideration are
13 specifically not included in this integration
14 that apply to fires that cause damage and require
15 operators to take a lot of the same types of
16 mitigation actions but for some reason those
17 aren't not to be considered. But I need to
18 understand if I have a fire in a particular
19 location.

20 We have EDMGs that are stylistically
21 tailored toward losses of particular areas in the
22 plant of a big enough fire and explosion, but not
23 a fire and explosion that might be for a fire
24 that require other actions that sound a lot like
25 some of the FLEX things.

1 We have SAMGs which you've already
2 admitted include several of the same guidance
3 that are in the EDMGs and now the fire response
4 procedures and the FLEX procedures.

5 Why don't we think about a real
6 integration that looks at maintaining functions
7 outside the EOPs, rather than having EOPs that
8 just have a pointers to all of these event based
9 responses now that require the team in the
10 control room to say which of these events do I
11 have? Maybe I had a seismic event that caused
12 two fires in the plant. Well, that's not one of
13 my EDMG conditions. Maybe I got one bus
14 available but it's not a safety bus so I don't
15 have an extended loss of all AC power. What am I
16 going to do?

17 So why didn't we think about that? Why
18 are we devolving into a bunch of event based
19 guidance?

20 MR. REED: I hope we're not devolving. I
21 don't think we are. Let me see if I can answer
22 it. I've had this kind of, you know, concern or
23 comment come up several times, and I think you've
24 got to view the regulatory framework one way,
25 okay, and then you've got to review what really

1 goes on the facility and response with another
2 way.

3 CHAIRMAN STETKAR: Okay, Tim, I'm going
4 to view as if I'm an operator in the control
5 room. So you explain it to me how this has made
6 my life easier.

7 MR. REED: Yes, I think the response is
8 totally symptom based as the operator. In other
9 words even though I'm talking about, for example,
10 loss of large areas due to explosions or fires
11 where a beyond-design-basis external event, for
12 example, that goes to a beyond-design-basis
13 external event, how do they actually respond to
14 it?

15 Well, they're going to be in the control
16 room looking for conditions, okay, and if I have
17 no power on my emergency AC buses, for example,
18 4160 buses, and I can't recover any power
19 offsite, I'm looking at the symptoms right now,
20 I'm basically trying to figure out what to do
21 from the symptoms and guess what they do? Once
22 they figure out that they're in an ELAP they
23 declare an ELAP. So it's simply based --

24 MEMBER BLEY: They don't care it's an
25 ELAP. They care they don't have any instruments.

1 That's really John's point.

2 CHAIRMAN STETKAR: My point is that in
3 Control 7 he doesn't know what's going on. I'm
4 not an attorney. I'm not an attorney. I'm
5 simply responding to what I know. I have X, I
6 don't have Y, please tell me what I should think
7 about doing in these conditions.

8 MR. REED: Absolutely.

9 CHAIRMAN STETKAR: Should I think about
10 depressurizing and getting that 500 gpm low
11 pressure pump feeding the vessel? Should I think
12 about maybe getting power back to something
13 because that's the best strategy? What should I,
14 I don't care if I had a fire. I don't care
15 whether I had a legislated type accident because
16 the plant doesn't care either.

17 MR. REED: That's exactly same
18 responses -

19 CHAIRMAN STETKAR: And my question is
20 why are we pigeonholing all of this and calling
21 it integration?

22 MR. REED: Okay, yes, at the regulation
23 standpoint it does look disconnected.

24 CHAIRMAN STETKAR: No, it looks
25 disconnected at the regulation standpoint which

1 is a problem, I think, for the agency, and in the
2 implementing guidance. The Reg Guides just say
3 use, they endorse all of the NEI reports. And
4 the NEI reports just say basically, write
5 procedures for these specific conditions and put
6 pointers from the EOPs. So it's beyond
7 the regulations, it's --

8 MEMBER BLEY: I'll tell you what bothers
9 me about it Tim is where John started. I mean
10 these are for things we don't really expect to
11 see but we might. And I'd sure hate in two
12 years, five years, fifteen years, to have nature
13 teach us once again like at TMI that the way we
14 patch this stuff together isn't serving the
15 operators and therefore isn't serving safety as
16 well as it could.

17 I mean we've got an opportunity now,
18 it's a shame to miss it.

19 MR. REED: I think the actual, in
20 other words what I think would be good for you to
21 see, the committee to see is the actual
22 implementation at the plant level. In other
23 words to understand EOPs and the connections, and
24 then I think you'd see it's symptom based in the
25 response. Even though the regulation doesn't

1 look that way, implementation works that way. So
2 that's the only way you can respond --

3 MEMBER BLEY: It doesn't look that way
4 in the NEI document.

5 CHAIRMAN STETKAR: It doesn't look that
6 way in the NEI documents and people tend to write
7 things according to NEI guidance, because if I'm
8 a utility, oh my god, I don't want to be
9 countervailing NEI guidance so I'll write it
10 according to that guidance. And I already have
11 the EDMGs so I don't need to touch those.

12 All I've got to do is write these FLEX
13 procedures and put some pointers from my EOPs. I
14 have the fire procedures hanging out here in
15 limbo-land. I have flooding procedures which
16 aren't even mentioned in here. Those are also
17 things that are beyond that I need to do. And
18 the operator now has to learn and think about all
19 of these different decision criteria.

20 MEMBER SCHULTZ: So Tim, to turn around
21 what you said, the more the regulatory framework
22 can look like it's integrated, can really move
23 forward in that direction rather than have words
24 that suggest --

25 MR. REED: That's definitely something

1 we would try to get to, yes.

2 MEMBER SCHULTZ: But rather indicate
3 that this is what should be done, shall be done,
4 then we're headed in the right direction. Right
5 now, if we say well it doesn't matter what we say
6 up here when we get down here, that's not really
7 as we know the way it works.

8 MR. REED: Yes. I hear the comment. I
9 think hopefully by the final rule we do get
10 closer to that mark.

11 MEMBER SCHULTZ: See, the problem is the
12 rule language. I can read the rule language, the
13 literal rule language with sort of a broad
14 perspective and say it does not preclude me from
15 doing sort of my concept. If I read the
16 Statements of Consideration which people do read
17 it says that I'm precluded from doing that
18 because I can't consider integrating the fire
19 response procedures. It specifically says those
20 are off the table.

21 And it speaks about each of those three
22 bullets on this slide as distinct sets of
23 procedures, and furthermore it elaborates on the
24 specific conditions for which each of those
25 bullets apply.

1 So it's very, very clear to me anyway
2 when I read the Statements of Consideration that
3 these are not considered as an integrated
4 function based response. They're discrete sets
5 of procedures.

6 MEMBER BLEY: I'd just make one last
7 comment on this if I could. We hear arguments
8 about why the fire procedures shouldn't be
9 involved in this, but if you look back
10 historically, two for sure and depending on how
11 you think about up to four, I think, fires in our
12 history have shown that the lack of integration
13 of fire and EOPs has led to very difficult
14 situations during those events and caused
15 confusion and got people out of the loop who were
16 needed in other places. So we've got some
17 history saying this would be a good idea, in
18 addition to going all the way back to TMI.

19 CHAIRMAN STETKAR: Well, there's one
20 event where the operators thought they had a
21 fire. They didn't really have a fire but they
22 got meshed in the fire procedures which
23 distracted them so —

24 MEMBER BLEY: That's right. That's why
25 I say and you know how you think about it, yes.

1 CHAIRMAN STETKAR: Now one other item so
2 I won't belabor this any further is you did
3 mention drills, and I wasn't going to bring that
4 up. If I look at the guidance, the NEI guidance
5 for drills, the NEI guidance for drills
6 completely reinforces this notion of discrete
7 procedures because the drill guidance as set up
8 is I drill for the EOP transitions to FLEX the
9 FSGs.

10 I separately drill for the EOP
11 transitions to the EDMGs. I separately drill for
12 the EOP transitions to the SAMGs. I never drill
13 for the integrated set of all of these things.
14 If you could show me wherever the NEI guidance
15 says that I drill for the integrated set of these
16 things I'd like to see it.

17 MR. REED: Yes, I guess it's
18 interesting, yes.

19 CHAIRMAN STETKAR: So that reinforces
20 this bilateral transfer to make a decision about
21 which particular procedure am I going to be in,
22 and that's the only way the operators are going
23 to be trained also.

24 MR. REED: I mean when I write rule
25 language in the section by section, I'm trying to

1 establish the minimum requirements and clearly
2 what they are, and sometimes that forces me into
3 this box that you're saying. And it's not the
4 intended to mean that for example you have to do
5 them discretely but you want them to choose one
6 of each, you know, for example.

7 CHAIRMAN STETKAR: That's the path of
8 least resistance that people will take.

9 MR. REED: Yes, I understand. A
10 licensee would try to get all the, you know,
11 birds with one stone I'm sure if they could, you
12 know, for example.

13 MEMBER REMPE: So I have a question for
14 what I believe is Slide 2. During our
15 subcommittee meeting there was a lot of
16 discussion about how the Severe Accident
17 Management Guidelines would be checked by the
18 NRC, was it just a check the box, I believe as
19 one member questioned.

20 And when industry got up they mentioned
21 this letter about auditing and that was after
22 your time. And I just was wondering, is your
23 vision that you'd be doing what was suggested by
24 the BWR/PWR Owners' Group for auditing the Severe
25 Accident Management Guidelines where there would

1 be a period where the staff would review new ones
2 that are issued and provide comments? Because
3 that never was elaborated in your presentation
4 last time.

5 MR. REED: Yes, we're certainly, and I
6 think we do talk about it in here. We're
7 certainly very familiar with the work that's
8 going on today and I think, we have an ePortal.
9 I think you're familiar with the offer that was
10 made to the two Owners' Groups to us.

11 MEMBER REMPE: Right.

12 MR. REED: And so we have a lot
13 familiarity today and we would certainly be
14 following that. While I don't want to overplay
15 that because that's not an official review, you
16 know --

17 MEMBER REMPE: Right, it isn't.

18 MR. REED: -- and I can't say that. You
19 know, we do have substantial understanding what's
20 going on, but that's, I don't --

21 MEMBER REMPE: If that were the process
22 that were followed it would take an amount of
23 rigor from the staff to make sure that they did
24 review them and provide comments in a timely
25 fashion.

1 MR. REED: Yes, it would.

2 MEMBER REMPE: And everybody's stressed
3 on budget and time and stuff like that too.

4 MR. REED: Yes, absolutely. If we were
5 going that way you're absolutely correct. We
6 would have to put something in place of a
7 somewhat disciplined process, I agree. That's
8 not there yet. And I think that the, and
9 I think you're going to hear it today the
10 suggestion from industry on the commitment for
11 SAMGs. I think they think a commitment aligns
12 very well with what we have as our proposed
13 regulation, and what we are proposing that we
14 probably would inspect at that level, by the way.

15 So you mentioned inspection, it would be
16 a very high level. Make sure you have them,
17 you're maintaining them, you're affecting
18 configuration management, you write the Owners'
19 Group changes and you're integrating them with
20 the --

21 MEMBER REMPE: At least the auditing
22 letter lets you review the content. Right here
23 we're just checking the box.

24 MR. REED: If we reviewed the content
25 and basically there was something that didn't

1 resemble a strategy obviously then that would not
2 even meet a SAMG. But we know right now it's not
3 there.

4 MEMBER SCHULTZ: We have time on that
5 and a presentation coming to this later so let's
6 hold it until then on this one.

7 MR. REED: Sure. Okay. We're at 11:25.

8 MEMBER SCHULTZ: Go ahead.

9 MR. REED: Okay, so let me just -- I
10 think I'm done with this slide. So I mentioned
11 integrate probably too many times with the EOPs.
12 Obviously that was just simply to keep all the
13 substantial and good work that was done with the
14 simply based EOPs intact, and that, you know, go
15 revisit that. So that's the idea.

16 And if you're going to have a site-wide
17 type of response what conceivably can be a site-
18 wide beyond-design-basis external event, for
19 example, leading into this integrated response,
20 then you need sufficient staffing and command and
21 control. And so that's also built into our
22 paragraph (b).

23 So now I've come to Slide 7 and I'll
24 hand it over to John.

25 MR. MCKIRGAN: Great. Thanks, Tim. So

1 I just want to speak to this provision here in
2 the rule. This is a paragraph that's really
3 focused on new reactor applicants, and the
4 requirement here is for new reactor applicants to
5 incorporate into the design features that would
6 enhance the coping durations and reduce or
7 minimize reliance on human actions to achieve the
8 key safety functions that we've talked about in
9 the rule.

10 So as drafted, this paragraph would
11 apply to new construction permits, operating
12 licenses if a construction permit was issued
13 after the effective date of the rule, design
14 certifications, combined licenses that don't
15 reference the certified design and manufacturing
16 licenses. From a practical perspective we're
17 really targeting the design vendors is the intent
18 here of the rule.

19 And so what the staff is trying to
20 achieve is to get the designers thinking about
21 this condition very early in the design process
22 so that they can incorporate some of this
23 thinking before the designs become finalized.

24 So we think this is consistent with the
25 Commission policy statements and we've quoted

1 some, you know, the policy statements have set
2 the expectation from the Commission that new
3 designs would have enhanced margins, use
4 simplified means to accomplish safety functions
5 including longer times for operators to diagnose
6 and manage challenges, and then simplified safety
7 systems to reduce the complexity of those
8 actions.

9 So it's the staff's view that new
10 reactors would benefit from longer time and a
11 longer time before they need to rely on portable
12 or offsite resources. So that's the balance that
13 we're trying to strike here.

14 So the staff has looked at similar
15 rulemakings that the committee might be familiar
16 with. Some similar language and thinking was
17 applied in the development of the aircraft impact
18 rule 51.50. There again the designers were
19 required to address features in their design that
20 would reduce reliance on operator action.

21 So in essence here the designers have an
22 opportunity to assess the balance between
23 hardened, installed safety systems and portable
24 backup systems and think about the means of
25 simplifying the operator actions that would be

1 required to implement the strategies that are in
2 essence in this rule.

3 CHAIRMAN STETKAR: John, you said the
4 word "hardened" but it's my reading of the rule
5 that it only has to be designed to the design-
6 basis of the plant.

7 MR. MCKIRGAN: That is correct.

8 CHAIRMAN STETKAR: So it's not anymore
9 hardened than any of the other safety related
10 equipment in the plant.

11 MR. MCKIRGAN: That is correct.

12 CHAIRMAN STETKAR: Okay, thank you.

13 MR. MCKIRGAN: So the rule language is
14 high level. It's a performance based rule. The
15 staff's developed guidance on what our intent is
16 to implement this particular portion. Clint will
17 speak about that in a few minutes.

18 The rulemaking is as Aby mentioned in
19 his opening remarks going through concurrence.
20 There have been a few tweaks, one in particular
21 in this area where we've added some clarification
22 on what we mean with respect to passive designs
23 for access to the ultimate heat sink. In the
24 case of passive designs we're talking about
25 normal access to the normal heat sink. It's an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 important caveat for us in new reactors and so
2 there are a few tweaks going on to the rule.

3 With that I will pause for a moment and
4 perhaps turn it back over to Dr. Schultz unless
5 there are any questions on this.

6 MEMBER SCHULTZ: Well, before we go to
7 questions I'd like to take the opportunity for
8 the committee to hear an individual from the
9 staff. In the agency of course we have a process
10 under which an employee can raise an issue and
11 concerns associated with the way a formal process
12 is moving forward. And given that this is a
13 rulemaking process it is a formal one.

14 And Jim Shea from the staff has moved
15 forward to participate in the non-concurrence
16 process and has filed his opinions to management,
17 and the committee wanted to provide an
18 opportunity to Jim to come here and present to
19 us. And he has taken advantage of the offer and
20 would like to say a few words about what his
21 concerns are and it's related to this particular
22 portion of the proposed rule that is focused on
23 new reactor.

24 Jim?

25 MR. SHEA: Yes, thank you. Thanks for

1 the opportunity. Again, Jim Shea. I am in NRO
2 right now in licensing, but before that I was
3 working on the working group and before that I
4 was actually on JLD when we implemented the
5 orders and before that I was in the ops center
6 when the event was actually occurring. And the
7 reason for that was ten years' experience on
8 shift at a BWR as an STA and a supervisor.

9 So with that background I think the best
10 way to highlight my issues, I know I wrote them
11 down. I won't go over hand over fist, but just
12 to highlight it is to maybe feed on Dr.
13 Stetkar's, you know, issue about operators and go
14 through a quick fictitious scenario. Take a
15 minute -- I can't talk as fast as my friend here
16 but I will try.

17 So okay, imagine we're all SOLs, we're
18 at this fictitious future plant, 2,000 megawatts
19 and it's time-zero and a beyond-design-basis
20 external event occurs at time-zero. Takes out my
21 generator and of course 86G, will take out my
22 turbine and also trip the reactor.

23 So time-zero we're in the control room
24 and all the lights go out, and at the same time
25 we know we lost offsite power, because you know

1 that instantly because all the control room
2 lights go on, off, the battery lights come on,
3 okay. That's the typical scenario.

4 So now I know I'm in, really, right away
5 to answer the question, I know I'm in loss of
6 offsite power. So then in approximately maybe
7 five to ten minutes depending on severity of what
8 the external event was I'd have an EO could tell
9 me that our station blackout diesel's not going
10 to operate. So given that, now I know I'm in an
11 extended station blackout.

12 So ten minutes later one of the things
13 we'll be doing in the control room we would
14 confirm all rods are in. That would be the first
15 thing. So within ten minutes I would know that
16 I'm less than two percent power because on the
17 decay heat curve, rule of thumb, at ten minutes
18 two percent power, LPRMs all down scale -- that's
19 a BWR thing, but -- so in the scenario loss of
20 all AC, loss of DC. We figure out we're not
21 going to get AC back, so if I'm the SRO I direct
22 the lead operator to --

23 CHAIRMAN STETKAR: Jim, you have DC or
24 not?

25 MR. SHEA: No. Well, we had the

1 important -

2 CHAIRMAN STETKAR: The FLEX says --

3 MR. SHEA: This is a wholly fictitious
4 thing but we will have DC in phase one --

5 CHAIRMAN STETKAR: I'm just walking you
6 through the scenarios so --

7 MR. SHEA: No, I understand. But we may
8 or may not have it, but we'll say we do for this
9 particular scenario. All right, so my lead SRO I
10 ask him to confirm that the ECD is operating.
11 You might ask what is the ECD? It's the new
12 enhanced coping duration system.

13 And he reports back to me for some
14 reason the enhanced coping duration systems are
15 not operable. And I go -- and his name happened
16 to be Goodnight, and I'm like, Operator
17 Goodnight, it's not going to be a good night.

18 So I ask the SCA where does this put us?
19 Well, I look at my decay heat curve and I also
20 notice that because of the rule we were able to
21 design our FLEX system that's in the shed out to
22 72 hours. So I look at the 72, well, can we do
23 anything with that 72-hour shed FLEX pump? Well,
24 unless we get the ECD back we're in trouble
25 because that pump's not going to be big enough to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deal with the decay heat.

2 So I also know that through a rule of
3 thumb, six hours I have until my inventory in the
4 reactor is depleted and I will have core damage
5 but fuel melting will then start and you'll end
6 up with the core in the bottom of the vessel.

7 So now we're at a, so that really
8 highlights my concern with this rulemaking.
9 Because I'll go back to what I thought when I was
10 part of the orders, what the Commission found was
11 that additional capability was what we really
12 required. You can't really design for these
13 unknown events that I just, you know, put through
14 a fictitious scenario.

15 So the issue that you had I thought was,
16 in terms of adequate protection was the fact that
17 you need additional capability, so to leave the
18 operator with something that he can handle that
19 decay heat at six hours or eight hours going
20 forward.

21 To rely on something that we think we
22 can design, and I think it's really problematic
23 when the NRC thinks we can design something,
24 that's problematic on my end, but I think that
25 becomes problematic and I think we may

1 potentially leave those future operators without
2 capability.

3 And so therefore I think that in general
4 this rule is almost contradictory to the rule
5 language in the previous sections about
6 mitigating strategies and doesn't meet the intent
7 of the original Commission requirement of
8 additional capability.

9 And when we look at that additional
10 capability it's really technology neutral. It's
11 best to look at each plant individually,
12 technology neutral, figure out what they have for
13 coping in phase one, six, eight, ten, whatever
14 hours they have, and then you would add, then
15 apply that flexible equipment.

16 And what I think this rule language is
17 doing is actually telling certain active plants
18 that might be looking for a license that they
19 shouldn't apply to the NRC or United States even
20 though their containment may be double-walled,
21 they may have robust containment so they may
22 assume the core melts and you'd less release than
23 a reactor that has more passive design.

24 So anyway that I thought was the best
25 way to highlight my issues on this, and with that

1 if there's any questions --

2 MEMBER SCHULTZ: Any questions for Jim
3 for clarification?

4 MEMBER CORRADINI: Well, just for
5 clarification. So this is particularly for new
6 reactors?

7 MR. SHEA: Yes.

8 MEMBER CORRADINI: And your concern is
9 that the language is fuzzy and it needs more
10 specificity or, I'm trying to understand your
11 scenario and how I map it into your concern.

12 MR. SHEA: My concern is --

13 CHAIRMAN STETKAR: He missed the ECD.

14 MR. SHEA: Right, the ECD. The ECD
15 system which is the enhanced coping duration
16 which is the --

17 CHAIRMAN STETKAR: The new plant
18 installed system that's required.

19 MR. SHEA: Right. Which I do find very
20 nebulous in a sense that I'm not sure what that
21 is, and along with enhanced, the other for
22 operators is minimize reliance on human actions.
23 I think there's issues there because it's hard to
24 define a success there. How do you define?

25 So I see this as very problematic for

1 the licensees in general because how do they
2 design this enhanced coping duration? How do
3 they know it's going to withstand that
4 unspecified future event, you know, that could
5 occur?

6 And then are we leaving the operator
7 potentially under a scenario where they don't
8 have a pump in the shed that they could pull out
9 to deal with the six-hour and beyond decay heat
10 level. If you look at the decay heat curve at
11 six hours it's approximately, it's about one
12 percent. At 72 hours you've got, it goes down to
13 like three percent, 0.3 percent, and 24 hours is
14 0.6 percent. So you're not, you potentially are
15 leaving the operator without additional
16 capability as provided in the FLEX.

17 MEMBER CORRADINI: I want to say it back
18 to you so I get it. So your point is there's a
19 gap.

20 MR. SHEA: There's a gap.

21 MEMBER CORRADINI: And your point is the
22 requirement to fill the gap is nebulous at best.

23 MR. SHEA: Yes.

24 MEMBER CORRADINI: Okay, that's what I
25 thought you were getting at.

1 MR. REED: And his non-concurrence is on
2 155(d) only, okay.

3 MEMBER CORRADINI: Yes, I'm with you
4 there.

5 MR. REED: Okay. And I think he's
6 suggesting -- I'm putting words in his mouth, but
7 I think he's suggesting by designing, trying to
8 design capability you may lessen the mitigation
9 capability.

10 CHAIRMAN STETKAR: That's a little bit
11 of what I got is the notion that the operators
12 are going to rely that I have, I'll call it the
13 super good ECD out there that's only designed to
14 the same criteria as my other safety related
15 stuff that by definition was damaged. And
16 because I in regulatory space can rely on the
17 super good ECD thing to get me out to -- pick a
18 number -- six hours, eight, I don't care what it
19 is, I can then say, well, I only need like a 27-
20 1/2 gpm pump out in the shed with a little
21 gasoline engine on it because by definition I'll
22 be able to get out that far, according to the
23 rule. Whereas, it would better suit me to have
24 that 500 gpm, pick a discharge pressure -

25 MR. SHEA: As the operator I want the

1 500 gpm.

2 CHAIRMAN STETKAR: You want the 500 gpm
3 pumps in there. You can always throttle it out.

4 MR. SHEA: That's my primary concern.
5 And when you think about it, if you go full
6 circle, I was at the RIC, recent RIC. I noticed
7 when the Chinese presented their flexible
8 approach they were going with, their design was
9 very simple. At six hours we're going to be able
10 to cope with the decay heat on any plant that
11 they have in China regardless if it's passive.

12 And I also talk about the passive issue.
13 You know, it's interesting because actually this
14 non-concurrence has been in my head since back in
15 2012 actually. I would have suggested that no
16 new reactors needed to deal with Fukushima
17 because it's just an enhanced design. Because if
18 you think about it, the Owners, the designers,
19 already took the Commission policy statement and
20 built these new reactors with that in mind and
21 built all these.

22 It's really not, I'd look at the
23 enhanced, the policy statement for advanced
24 reactors not for the staff, it was really for the
25 industry to go out and do good and build these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safer plants. So I think it's a little
2 mischaracterization.

3 CHAIRMAN STETKAR: I think you're right.
4 This is my own personal opinion. You're right
5 for the passive plants, not so much necessarily
6 when we talk new reactors we're still looking at,
7 you know, active new reactor designs that instead
8 of having two trains they've got four trains of
9 safety systems, but it's just more of the same.
10 It's not clear necessarily how much the active
11 plants gain from that.

12 MEMBER SCHULTZ: Jim --
13 Go ahead, Dick.

14 MEMBER SKILLMAN: Jim, I appreciate the
15 connection between your background and your non-
16 concurrence, and I really appreciate the scenario
17 with Mr. Goodnight who's not going to have a good
18 night. I understand that.

19 MR. SHEA: I had to throw a little
20 operator humor in.

21 MEMBER SKILLMAN: That's all right.
22 What you've done is you've described what you
23 don't want and you don't like. So if you're king
24 for a day, in three sentences what exactly would
25 you change?

1 MR. SHEA: Well, like I said if I was
2 doing my job well I would have non-concurred on
3 NRO having to do anything for Fukushima. Because
4 I was there, wrote the orders and when we first
5 gave them to Summer and Vogtle I was pretty much
6 opposed, but, you know, if you're one guy
7 swimming up the stream it's tough too, and like I
8 go back to this whole passive issue.

9 And then when I saw the NEI guidance
10 come out and they basically gave all the credit
11 for passive systems on AP 1000, I was concerned
12 about that at the time. But I looked in the
13 context of the fact these are new reactors. This
14 really doesn't matter in my mind. None of this
15 Fukushima thing really applies to new reactors.
16 So I didn't really make a big issue of that.

17 So it kind of pops up back in my non-
18 concurrence now but, so that's kind of the
19 history of that because I always felt that new
20 reactors never needed this and so maybe that was
21 -

22 MEMBER SKILLMAN: Okay, so for active
23 plants going forward what would you do?

24 MR. SHEA: Well, in fact active plants,
25 what I'm saying in short is that active plants

1 may have more robust capability for mitigating
2 strategies than any passive plant. Because I
3 don't want to name any plants, but let's say you
4 had a plant that needed to employ FLEX within
5 four or five hours because of whatever design
6 they may have, they don't have a steam generator,
7 AFW pump or whatever. Well, that pump's going to
8 have to be a lot bigger than, right, and it's
9 going to be -- and so they will have a much more
10 robust capacity to deal with mitigating
11 strategies. So it's kind of
12 counterintuitive in the direction that we've been
13 going with this now for the last four years in
14 allowing passive plants all this credit.

15 But I'd just like to highlight the fact
16 that this same scenario, the same scenario I just
17 went through, you could have been the operator in
18 Fukushima 1 and I would have sent the operator,
19 maybe skip the coffee break when he was going to
20 look at the ECD which happened to be in that
21 particular case the iso-condenser which is a
22 passive system. The valve failed. We still
23 don't quite understand why the valve failed.

24 I have my own theories because I was an
25 iso-condenser system engineer, and I put forth

1 those theories but we never confirmed exactly why
2 the isolation condenser, first of all they closed
3 it. They shouldn't have, but then why it
4 couldn't be reopened, I have my own theories.
5 Anyway but that's one of the issues you have if
6 you're relying on these as-built design features
7 you don't know what you don't know. I mean the
8 iso-condenser just to be clear is that it has a
9 HELB isolation for a very good reason.

10 Back in the '80s in a high energy line break
11 isolation on that system that is actually by
12 battery. If you lose your battery you get the
13 isolation on the HELB. It's like a fail-safe.
14 So those valves could have been closed just on
15 the loss of that particular battery bus that's
16 feeding that isolation condenser valve. And then
17 the operators would never be able to open it.

18 CHAIRMAN STETKAR: Thank you, Jim.

19 MEMBER SCHULTZ: Jim, thank you very
20 much. Appreciate the briefing. And with that
21 we'll return Tim to the presentation. We're with
22 John still --

23 MR. MCKIRGAN: I believe I had completed
24 and I was about to turn it back to Tim for the
25 rest of the group.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. REED: And so we went to (d), we'll
2 go back to © here for a second and then skip to
3 (e) just to go out of order a little bit and keep
4 everybody confused.

5 As you're aware, paragraph © of the
6 proposed rule contains the equipment requirements
7 that support the mitigation strategies, the
8 integrated capabilities of (b), and those
9 equipment requirements are entirely limited to
10 two sets of requirements. The requirements that
11 go into place as a result of the EA-12-049,
12 mitigation strategies orders rulemaking, those
13 are at (c)(1), (c)(2) and (c)(3). And then
14 there's a (c)(4), if you will, that is the spent
15 fuel pool level equipment order or
16 instrumentation order, okay, requirements.

17 So we have those sets of requirements,
18 (c)(1) is a basic capacity and capability
19 requirement. It's to ensure that you have the
20 capacity and capability of the equipment to
21 mitigate basically, you know, something that
22 could be site-wide so you have to build a,
23 simultaneously maintain and restore core
24 coolings, spent fuel pool cooling and containment
25 capabilities across the site, and that places

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 demands on both the capability of your individual
2 equipment, it has to be able to function under
3 the conditions it's being asked to function as
4 well as the capacity and the amount of the
5 equipment you have to have.

6 And if you drove down into the guidance,
7 I assume you folks have, you'll see the need for
8 n+1 sets of equipment. That's down in (gg) 1301,
9 it's actually all the way down into 12-06, NEI
10 12-06, excuse me. So that sets the capacity kind
11 of requirements, and also the amount of time you
12 can take things out of service or have an
13 unavailability of equipment. (c)(2) has been a
14 big focus of everybody so far, and this goes to
15 the reasonable protection of the equipment.

16 And we in fact have the exact language
17 up there on the slide. The mitigation strategies
18 equipment, this is the EA-12-049 mitigation
19 strategies equipment for beyond-design-basis
20 external events must be reasonably protected from
21 the effects of natural phenomena that are more
22 severe of either your current external design-
23 basis requirements, or if in fact the reevaluated
24 hazard work going on in NTTF 2.1 right now that
25 comes out to be a larger hazard and as verified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 by the NRC's assessment of that.

2 In other words we have to reach
3 agreement of what that hazard is, what the
4 licensees that'll establish that hazard and then
5 that becomes what you need to reasonably protect.
6 So that as you folks well know, you know, was
7 quite about a large amount of interaction with
8 this committee on COMSECY-14-0037. We got the
9 SRM on March 30th. I believe that language is
10 still in line with that SRM, so that issue's
11 being worked very hard right now.

12 And we do have some challenges. We'll
13 talk about that here in a second about some of
14 the guidance that would support that especially
15 in the seismic area. I think we're going to be
16 probably okay with the consideration of
17 reevaluating flooding hazards but seismic's going
18 to be a challenge. We'll have to figure that out
19 and what to do. So that's (c) (2).

20 Then (c) (3) is a basic maintenance
21 requirement. It's a set of requirements that
22 would ensure that your equipment remains capable
23 of performance and intended function. So while
24 it says maintenance, it would be maintenance,
25 testing, whatever you need to do to your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment to ensure that it remains capable of
2 performing its intended function. So that's a
3 basis requirement on maintenance.

4 And then finally (4), as I just
5 mentioned, is a performance level requirement
6 that would make generically applicable EA-12-051.
7 And that basically comes out of the order EA-12-
8 051 up in the main body. We didn't incorporate
9 any of the detail. The attachment requirement's
10 in there. So we're leaving it at a high level
11 performance based requirement for future reactor
12 licensees and applicants to see if they can do
13 something better than what's been done to date in
14 that regard. So that's the equipment
15 requirements of ©.

16 We talked about (d) already. We can
17 skip then to (e) at the bottom of this. Training
18 requirements. These are structured to be a very
19 high level performance based using a systems
20 approach to training. You need to have your,
21 obviously when you think about what we're talking
22 about here today, three guideline sets
23 integrating with the EOPs, those guidelines are
24 not always, although they do have a resemblance
25 to step by step or two-column format if you look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at some of the FSGs, I don't know if you folks
2 have seen that but they are in fact not step by
3 step.

4 So I think it places more demand, if you
5 will, on the training and the qualification of
6 your personnel to be able to implement those
7 guidelines. So that's the nature of this.
8 However, recognizing that we also recognize that
9 an awful lot of this is really in place. You
10 either have this training, in fact, in place to
11 support your EOPs right now or you're putting it
12 in a place right now to support implementation of
13 the order EA-12-049, and in fact you may even
14 have applicable training in other areas.

15 As you folks probably know that some of
16 this equipment is basically fire protection
17 equipment that's being used, and so some of the
18 training for that program as one example might be
19 really very directly applicable as well as the
20 training in the EP area.

21 So what we're trying to do here is
22 establish a minimum training requirement because
23 what we think is really the delta, if you will,
24 is the training really for SAMGs.

25 And so again with that context of SAMGs

1 I'm trying to keep a minimal regulatory footprint
2 on SAMGs. I'm trying to allow licensees to use
3 basically everything they have available to make
4 maximum use where there is a differential,
5 whether the delta uses a systems approach to
6 training and then implement training first, and I
7 think it'll be towards SAMGs using that type of
8 approach. And that's the way as you read in the
9 SOC, that's the way it's written throughout the
10 Statement of Considerations.

11 I mentioned drills already a little bit
12 here. Unfortunately drills requirements become a
13 fairly complex set of regulations because of the
14 unfortunately complex regulatory state that we
15 have between Part 50 and Part 52 and the
16 different kinds of situations you can be in as an
17 applicant and a licensee. But basically it can
18 be simplified to if you're about to get a license
19 then you need to show us you can transition to
20 and use these strategies and guidelines and be
21 uncued. So basically a person who's about to get
22 their license would have to be able to do
23 basically any kind of a strategy or transition
24 to. In other words they don't know which I'm
25 going to ask them to do, so that's the idea

1 there. It's the initial transition and use drill
2 is to demonstrate that.

3 And then to follow on from that there's
4 an eight-year calendar period where I think John
5 was mentioning it a little earlier. We talked
6 about the drills, where we want you to perform
7 one of each type of drill during that calendar
8 period. It's written that way as John mentioned
9 as discrete drills but certainly a licensee could
10 do more than one of those at one time and it
11 would be more efficient obviously on their part.

12 And of course we say drills or exercises
13 because you can then roll these into EP
14 exercises. We recognize that the timing's a
15 little different than EP exercises, so if you go
16 into the stakeholder questions you'll see we're
17 asking about the timing on this versus the timing
18 of EP exercises. We want to give licensees the
19 flexibility to use, make maximal or most
20 efficient use of their resources and so we're
21 asking that question, how does that work, is this
22 going to help you make most efficient use of your
23 resources in trying to do these drills and
24 exercises. So we have a question there. So
25 hopefully that simplifies I hope that's pretty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 complex drill frequencies that we have in there.

2 Finally then we go to change control.
3 As folks are aware the change control provisions
4 that are in place right now are like many things
5 in our regulations, they're geared to look at
6 their exact regulatory area. The most famous and
7 most important, frankly, change control is very
8 extensive over 50.59, and as well, but we have
9 change control provisions in 50.54, and whether
10 it's in security or Appendix, you know, EP and
11 other areas.

12 And in fact people have fire protection
13 change control procedures out there too. So we
14 have a lot of different change control mechanisms
15 in place right now, and when you go and do these
16 facility modifications as the licensees are all
17 too aware I'm sure, you impact on all these areas
18 in your facility and gets to be a very complex
19 situation about making sure that what you're
20 putting in places mean the objectives of the
21 beyond-design-basis functional requirements you
22 want to achieve, but not degrading anything in
23 terms of like a safety related system structure
24 component or adversely impacting security or
25 adversely impacting fire protection.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so what we're suggesting is we want
2 a change control for the beyond-design-basis
3 because none of these other change controls do
4 that, and we want to ensure that you also use all
5 those other change control procedures also so
6 that you're basically assuring yourself, one,
7 it's even if it's the exact same system structure
8 component that its function for beyond-design-
9 basis you've addressed, its functions for within
10 design-basis you're addressing. You got them
11 both and you're okay.

12 And I do recognize there's an enormous
13 amount of complexity. It's been a long time
14 since I've personally been involved with 50.59,
15 but I was a long time ago so I'm aware of that.
16 And hopefully we can get that kind of feedback to
17 see whether there's some disconnects or one
18 stopping the other.

19 And I think this came up at the
20 subcommittee where, you know, if you think about
21 it in a beyond-design-basis framework you're
22 going to do things, you're going to push
23 equipment or maybe do things like even open
24 security doors that you would not normally do
25 under any, under a design-basis regulation or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 format, and we don't want those to stop each
2 other so they've got to work back and forth.

3 So the idea here is hopefully get a lot
4 of good stakeholder feedback and if there are any
5 disconnects we can remove those disconnects and
6 make them work together. So that's the change
7 control provision.

8 The other most substantial part of these
9 new requirements are what I like to refer to as
10 the enhanced onsite emergency response capability
11 requirements. So we have what I think of as most
12 of the central piece in 50.155, but then we have
13 what are the onsite emergency response
14 capabilities are in Appendix E, either directly
15 in a current part of Appendix E or an additional
16 Section VII to Appendix E. So that's what this
17 is talking about.

18 And those basically address several
19 items. First of all, I mentioned earlier about
20 the staffing and communications requirements that
21 went out as a 50.54(f) letter on March 12th of
22 2012. Those are captured in Section VII and so
23 that's making that requirement generically
24 applicable there.

25 We also have multi-source term

1 requirements built right into Appendix E. Right
2 now it would be a single source term. but of
3 course Fukushima Lesson Learned, you can have
4 multiple obviously source terms. And so this
5 would be at one point some people sometimes call
6 this multi-unit but it shouldn't be seen that
7 way.

8 A single unit can have a source term
9 issue with its reactor and spent fuel pool so
10 it's multi-source term, and of course this can
11 get very complex with multiple units and multiple
12 spent fuel pools. So this is being put in place
13 right now too and that's in Appendix E, built
14 right into Appendix E.

15 And then we have basically I think of it
16 as an administrative clean up on ERDS and to
17 reflect the removal of a reference to a modem
18 technology which is no longer used so we're
19 removing that technology reference and making it
20 not reference technology and hopefully you won't
21 get into that disconnect in the future. So we're
22 cleaning that up as we go along as part of this
23 rule.

24 Finally, well, two more things.
25 Application requirements, we have contents of

1 application requirements of both Part 50 and Part
2 52. They're made to be parallel although this
3 process is obviously very different. We tried to
4 structure that whether you go under Part 50 or
5 Part 52 you're going to be submitting the same
6 types of information from both, and this of
7 course is if you're going to come in for a new
8 reactor what kind of information we want you to
9 provide with regard to this new regulation so
10 that we can review that and to judge whether your
11 application is acceptable or not. And there's
12 quite a bit of regulation in there.

13 And then, finally, the implementation
14 requirements. I think it was at this committee I
15 think provided feedback on the implementation
16 requirements that was at one point, in fact I've
17 heard it through the concurrence process and also
18 from industry, I believe, too at the last
19 subcommittee, so implementation requirements
20 right now as the rulemaking sits right now and it
21 can of course change, it's not through
22 concurrence yet.

23 I've revised that to a four-year
24 implementation period as opposed to two refueling
25 outages, so that's to reflect some of the

1 feedback we hear. I think that makes more sense.
2 Now I'm going to put a big caveat on that because
3 it depends on how things actually shake out on
4 implementation of reasonable protection on some
5 of those.

6 On the reevaluated hazards I don't
7 foresee that to be an issue, but if that becomes
8 an issue downstream that could be something you'd
9 want to tie to a refueling outage because this
10 could be a re-working modifications.

11 But what we foresee right now in terms
12 of implementation would be focused really on
13 SAMGs because as a vast majority of this
14 regulation that we're proposing is actually in
15 place or going into place right now. And so
16 really the overhang, if you will, the delta is
17 largely in SAMGs, and they don't need to be in a
18 refueling outage to do those kinds of changes.

19 So that's the idea, we think four years
20 is sufficient. So of course we'll pursue that
21 using our process, as you folks are aware, the
22 cumulative effects regulation process to
23 determine whether in fact we've hit the mark
24 there, what else we're going to put on that, and
25 if we have to make adjustments to implementation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the final rule certainly we'll consider that
2 input at that time.

3 So that gets me through the proposed
4 rules language and now I'll move on to something
5 on the backfit and some of the supporting
6 analysis.

7 MEMBER SCHULTZ: Tim, would it make
8 sense to pause here and have industry come up and
9 make their presentation? Let's do that and make
10 a quick transition.

11 MR. REED: Sure. I'm flexible.

12 MEMBER SCHULTZ: Because we had
13 scheduled them from noon to 12:15.

14 MR. REED: Okay. Sure.

15 MEMBER SCHULTZ: So let's make that
16 transition now and we can do that quickly and
17 move forward.

18 Thanks, Tim. We're still moving
19 forward. We did start 15 minutes late but we
20 want to stay on the window schedule that we have
21 to the best of our ability. So we'll go ahead
22 and start.

23 David, I'll turn it over to you.

24 MR. YOUNG: Great. Thank you. So good
25 afternoon. My name's David Young and I'm a

1 senior project manager in the Emergency
2 Preparedness Department at NEI, and with me are
3 Roy Linthicum from the Pressurized Water Reactor
4 Owner's Group and Scott Bauer from NEI. We
5 appreciate this opportunity to provide industry
6 comments on the proposed draft Mitigation of
7 Beyond-Design-Basis Events rule.

8 So my friend here, Roy, is on kind of a
9 tight schedule right now, so what I'd like to do
10 if we can, go right to Slide 7, and we'll let Roy
11 do his thing and then we'll come back and start
12 off then with Scott and go through the rest of
13 the presentation.

14 MR. LINTHICUM: And I do apologize. I
15 actually have a webcast I have to host which is
16 why I have to leave, and we've got about 100
17 industry people calling in so I can't miss that.

18 So what I'm going to talk about is
19 actually plant indications and instrumentation
20 for use during severe accidents primarily as used
21 by the SAMGs. Both Owners' Groups actually in
22 their SAMG guidance provide guidance to determine
23 and actually validate the instrumentation
24 readings that they have. We know that you
25 can't necessarily rely on the instrumentation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 readings directly. There can be a lot of
2 uncertainties as far as what you're reading.
3 Also potential power issues, you may not have
4 power to provide instrumentation. So we do use
5 and look at all possible instrumentations that
6 could provide us a help in determining what the
7 functions are that need to be addressed.

8 We look at alternate instrumentation.
9 We looked at linked parameters such as both
10 pressure and temperature to make sure we're in
11 the right place. And really what we're looking
12 for when we talk about SAMG instrumentation is
13 we're not really focused on absolute readings,
14 we're really looking at trends and changes in
15 trends. So we don't necessarily need to know the
16 exact value, but we're trying to understand the
17 progression of the accident, are things getting
18 worse, is containment pressure going up or going
19 down, are the actions we've taken in the SAMG
20 actually been effective?

21 And then for those instrumentations
22 where we know we don't have available
23 instrumentation, we actually are providing
24 calculational aids so we can actually calculate
25 where we expect to be based upon the conditions

1 we've seen rather than relying on
2 instrumentation.

3 And then lastly, we are develop --

4 MEMBER BROWN: What do you mean by
5 conditions you've seen?

6 MR. LINTHICUM: Conditions are times, so
7 one of the ones --

8 MEMBER BROWN: I mean how do you
9 evaluate the conditions if you don't have any
10 instrumentation?

11 MR. LINTHICUM: Well, we expect to have
12 some instrumentation. Most of the
13 instrumentation we rely on to implement the SAMGs
14 is actually also instrumentation that we're going
15 to be powering up for use as part of the FLEX
16 guidance. So we do expect to have some
17 instrumentation available. If we don't we have
18 calculational aids that look at, you know, how
19 much time we've had since the accident has
20 occurred and when we lost instrumentation and we
21 can calculate where we expect to be and then make
22 decisions based upon those types of calculations.

23 MR. YOUNG: So it looks like a simple
24 example might be a Heat-up rate, just a very
25 simple example.

1 MR. LINTHICUM: A Heat-up rate. One for
2 us in the PWR side, hydrogen concentration is a
3 major item where we know we're not really going
4 to have instrumentation so we have a calc aid to
5 determine how much hydrogen we expect to see in
6 containment.

7 MEMBER BROWN: That assumes that the
8 plant's intact though I guess.

9 MR. LINTHICUM: It assumes, if you're go into
10 SAMG space it assumes that you've actually
11 started melting the core. We don't get into the
12 SAMGs until you've had the onset of core damage.
13 But we know when we transitioned, we record that
14 information and, you know, we base everything on
15 the core exit thermocouples when we transition,
16 then we can estimate hydrogen concentrations
17 based upon that information. Like I say it
18 is an estimate, it won't know exactly, but we
19 don't need to know exact information.

20 MEMBER BROWN: Okay, thank you.

21 MR. LINTHICUM: Lastly, we are
22 developing training material for the operators
23 and the technical supports at our staff and part
24 of that focus will be on the importance of
25 validating any instrumentation response and not

1 relying directly on one instrumentation that you
2 see.

3 We know you can't, like I say there's
4 going to be a lot of questions as far as the
5 complete accuracy of the instrumentation and we
6 need people to focus on trends, not necessarily
7 those absolute parameters.

8 MEMBER CORRADINI: I'm sure you're going
9 to ask a question so I was going to wait for it,
10 to look to you.

11 MEMBER REMPE: Thank you. Okay, my
12 understanding is both the BWR and PWR Owners'
13 Group based on presentations that were given at
14 MPRC meeting, that recent meeting as well as
15 other places, they're updating the guidance for
16 Severe Accident Management and consideration of
17 the instrumentation. I've heard from the
18 PWR Owners' Group that they're looking at a lot
19 of different scenarios. Are the BWR Owners'
20 Group looking at more than one scenario? Because
21 I know that they're focusing a lot, and maybe
22 it's just what I've seen presented on what
23 happened at Daiichi, and are they going to look
24 at different types of scenarios and update the
25 guidance on a lot of different scenarios or just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one?

2 MR. LINTHICUM: I believe, and Bill
3 Williamson are you on the phone?

4 MR. YOUNG: Is there a way to open the
5 line?

6 MR. LINTHICUM: I believe the answer's
7 yes but I'm not tied in directly with the BWRs.
8 But I believe we have a BWR representative on the
9 phone.

10 MEMBER REMPE: Haven't seen them
11 presented but I just would like to --

12 CHAIRMAN STETKAR: On the phone, he
13 could comment during the public comment period.

14 MEMBER REMPE: I tried to ask questions
15 with the public comments during the subcommittee
16 when he came on and I was told I couldn't, so
17 let's make sure we get that answer please.

18 MR. YOUNG: He's alerted.

19 MEMBER SCHULTZ: David? Go ahead and
20 ask.

21 MR. YOUNG: Bill Williamson, are you on?

22 MR. WILLIAMSON: I'm on.

23 MR. YOUNG: There you go. So did you
24 hear the question, Bill, or do you need it
25 rephrased?

1 MR. WILLIAMSON: I believe I heard the
2 question.

3 MR. YOUNG: Can you give us an insight
4 on that?

5 MR. WILLIAMSON: Yes. This is Bill
6 Williamson, TVA and Browns Ferry and the BWR OG.
7 Right now we are primarily looking at the
8 instrumentation needs from the Fukushima Daiichi,
9 the three different sites, but before we finish
10 we will look at other scenarios also in order to
11 keep the symptomatic nature of our plant.

12 That'll usually say we're going to look
13 at something like an ATWA, something like the
14 designed station blackout, small break LOCAs,
15 large break LOCAs, and just make sure everything
16 is still working the way we believe it should.
17 So a short answer following my long answer is
18 that yes we're going to look at other scenarios
19 than just the extended station blackout.

20 MEMBER REMPE: Thank you.

21 MEMBER SCHULTZ: Go right ahead David.

22 MR. YOUNG: So any other questions for
23 Roy before he needs to leave?

24 MEMBER CORRADINI: Yes, before you go
25 off and become the host, so in terms of both the

1 Owners' Groups, are you trying to develop a
2 minimum set of the instrumentation with the
3 current VQ and say with that in trending that
4 will give you enough to essentially lead you
5 through the SAMGs? That's what I hear you say
6 but --

7 MR. LINTHICUM: It's the basic concept
8 with backup instrumentation as well.

9 MEMBER CORRADINI: Okay, has that
10 minimum set been determined or are you in the
11 process of determining it? The way Bill said it
12 on the phone is I interpreted that you're in the
13 middle of determining it.

14 MR. LINTHICUM: Where we're at on the
15 PWR side is we have drafted where we want to be
16 with our enhanced SAMGs which covers and brings
17 all the PWRs under one set and we're in the
18 process of validating that effort. So there's
19 still some work to be done. We're not complete
20 yet.

21 MEMBER CORRADINI: Okay. And validating
22 it means you run through a series of what-ifs and
23 then see --

24 MR. LINTHICUM: Yes.

25 MEMBER REMPE: Actually Bob Lutz's

1 presentation at MPRC identified a set of
2 instrumentations and when questioned he said
3 we're in the process of validating by going to
4 different plants -- group of operators?

5 MR. LINTHICUM: Well, yes, it's going to
6 be validated at different plants because we need
7 to address the three different NSSS sites and
8 make sure that given the set of instrumentation
9 we have that we can actually implement all the
10 SAMGs. So we do have a set that's been
11 developed. but I'm not going to say it's complete
12 until we've been through the validation effort.

13 MR. YOUNG: And initially I just was
14 thinking, so hey, Bob Lutz, are you also on the
15 line?

16 CHAIRMAN STETKAR: He is.

17 MR. YOUNG: Okay, so Bob will be able to
18 speak to that too if he's unmuted.

19 MEMBER SCHULTZ: We've closed the line.

20 MR. YOUNG: Oh, have you, okay.

21 MEMBER SKILLMAN: Roy, I would offer
22 this comment. We went through this 36 years ago.
23 And on the P side there's probably some pretty
24 good information that would identify a minimum
25 set of instruments that you need.

1 MR. LINTHICUM: There is, yes.

2 MEMBER SKILLMAN: Pressurizer level,
3 containment level, gas concentrations, radiation
4 levels, before you lose your pumps' pressurizer
5 level after you've lost your pumps' vibration.
6 But we lived this in March of 1979, so there's
7 probably a good place to start.

8 MR. LINTHICUM: Right, yes, we are not
9 starting from scratch, but like I said we are
10 making a significant change to our SAMG process.
11 It's really the first significant change since we
12 first developed them in the '90s. Like I say,
13 part of that is to put all of the PWRs on the
14 same footing all using the same set of guidance
15 at this point.

16 MEMBER SKILLMAN: I would make one other
17 comment. Once you've lost the core it becomes a
18 containment issue.

19 MR. LINTHICUM: It absolutely does.

20 MEMBER SKILLMAN: And really buckling
21 down containment and knowing its physical
22 condition carries the day because that is where
23 the radiological questions begin to arrive.

24 MR. LINTHICUM: Right. And part of our
25 process is part of what we're looking at, and in

1 the SAMG space we are all function based and we
2 are primarily focusing on containment, protecting
3 containment, actually protecting the steam
4 generator tubes to make sure you don't have a
5 containment bypass event at that point as well.
6 So it's something a little bit lacking from the
7 original SAMGs and we want to provide that
8 guidance on and make sure people are prioritized
9 on protecting containment once you get into the
10 SAMGs.

11 MEMBER SKILLMAN: Thank you.

12 MEMBER SCHULTZ: Hearing no other
13 questions for Roy, thank you very much.

14 MR. LINTHICUM: Thank you.

15 MEMBER SCHULTZ: And David, you can
16 continue with your presentation.

17 MR. YOUNG: Will do. Well, with that
18 then if we can kind of go back to, I guess it
19 would be the second slide, and I'll go ahead and
20 turn it over to Scott to talk about mitigating
21 systems.

22 MR. BAUER: So let me answer the
23 question at hand, I think, from an industry
24 perspective. The industry does support sending
25 the proposed rule to the Commission for their

1 consideration for issuance as a proposed rule for
2 public comment.

3 One of the reasons for that is we really
4 need to get the rule back out into a public arena
5 to where we can continue to comment on it. We do
6 have two reservations on that though but we don't
7 believe those reservations stop us, should
8 prevent moving the rule through to proposed rule
9 status. And those two reservations are with
10 regard to how the reevaluated hazards are being
11 incorporated in the rule.

12 Obviously with the recent SRM on the
13 SECY 14-0037 there's uncertainty as to what the
14 future holds for how the reevaluated hazards are
15 going to be addressed and how they should be
16 factored into the regulation. And then, you
17 know, I think as Tim was about to get to,
18 comments on how to incorporate the SAMGs if they
19 don't meet the backfit analysis requirement.

20 So with that said, I'll talk about the
21 reevaluated hazard issue a little bit about some
22 of our concerns. And I think these were
23 mentioned at the March 19th meeting when Brian
24 Ford was here, but the number one concern is we
25 believe the reevaluated hazard is in the wrong

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 position in the rules, in paragraph (c) (2) under
2 equipment and just says you should protect that
3 equipment reasonably from the reevaluated hazard.

4 Well, what we have proposed is that you
5 may need to develop additional mitigating
6 strategies for the reevaluated hazard so there
7 really should be two options on the rule which
8 are on this side. Number one is I can maintain
9 my FLEX capability for the reevaluated hazard and
10 I'm done, or I can make modifications to my FLEX
11 strategy and still, and make it work and I'm
12 done. That's the first bullet.

13 The second bullet though is if I can't
14 do that and modifying the FLEX strategy is not
15 reasonable then we're going to develop an
16 alternate mitigating strategy to basically deal
17 with the reevaluated flood hazard. And I say
18 flood right now because the guidance we're
19 developing only addresses the flood hazard.

20 So (c) (2) basically says the reevaluated
21 hazards with an s, and blind seismic and flood
22 both from the 50.54(f) letter. Right now the
23 only guidance being developed is for the
24 reevaluated flood hazard. There is work being
25 done on seismic, but we're not anywhere near

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 having guidance. So we wouldn't be able to
2 follow the cumulative effects of regulation
3 provision that we have guidance that goes out
4 simultaneously with the rule on that issue.

5 MEMBER BLEY: I'm sorry. I could see
6 how one could interpret the top bullet as
7 allowing you to do this. This is just trying to
8 be precise and say that we might have to, maybe
9 modifying the strategy isn't enough, we might
10 have to do a completely new one.

11 MR. BAUER: Yes.

12 MEMBER BLEY: Okay, which seems a really
13 fine point to me, but okay.

14 MEMBER CORRADINI: So you're going to
15 give an example of that? I was trying to
16 understand it too.

17 MR. BAUER: Okay, I can give an example.
18 When we were here previously with, we had
19 Dominion up here and we gave an example. But,
20 you know, if the reevaluated flood hazard is such
21 that it would be, well, first of all, FLEX starts
22 off with the initial conditions of I have an
23 extended loss of AC power and loss of normal
24 access to the ultimate heat sink. S o
25 basically we said we don't know what event caused

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this but here's the result of the event. So it's
2 a, you know, we start with a consequences then we
3 say develop strategies to mitigate those
4 consequences.

5 So in the reevaluated flood hazard, if
6 those strategies would still work for the
7 reevaluated hazard or I can modify those
8 strategies reasonably to make them work, I can
9 stay with that same set of initial conditions and
10 initial assumptions. If I decide that I cannot
11 do that reasonably under the alternate mitigating
12 strategy or the targeted hazard mitigating
13 strategy provisions which discuss on this slide,
14 I would start the event with okay, here's my
15 flood, now let me figure out what the initial
16 conditions are that are caused by that and I
17 would not necessarily assume an extended loss of
18 AC power nor would I assume loss of normal access
19 to the ultimate heat sink unless the reevaluated
20 flood hazard caused that.

21 MEMBER BLEY: To me this gets us back to
22 where we were discussing these things being, all
23 of these procedures, all of them together being
24 so event-driven that we lose the flexibility to
25 respond to functionality. And man, if we're

1 looking at it this way, this reinforces my worry
2 about that.

3 MR. BAUER: Well, you know, I was
4 talking to some, or trying to whisper to some
5 colleagues about our reaction to the statements
6 of what you were asking Tim up here with regard
7 to that. We believe the procedures are still
8 symptom based.

9 Now they are, you know, when we revised
10 the emergency operating procedures to sequence
11 through to recognize the conditions that would
12 exist when I have an extended loss of AC power or
13 what would I see that would make me declare or
14 determine I had an extended loss of AC power, and
15 then those symptoms would drive me to go to the
16 FLEX support guidelines. And then those
17 are indication driven and that you go out and you
18 determine the status of all of your equipment and
19 say what components do I have available now to
20 deal with the conditions I'm seeing and the
21 symptoms I have? So we believe it is still
22 strongly symptom based.

23 Understand the word integration,
24 understand we're dealing with a particular hazard
25 condition. This ultimate --

1 MEMBER BLEY: I'll just throw the last
2 word in, it's just smelling to me like we're
3 telling the operators, man, if you can't meet the
4 definition of using this, just sit there, you
5 know, you don't have a way out. And that's
6 what's worrying me. And you were picking on this
7 makes me worry about it even more.

8 MR. YOUNG: Let it melt and the SAMGs
9 will take care of the public.

10 MEMBER BLEY: I'm sorry David.

11 MR. YOUNG: No, no, don't be sorry, but
12 I think in this case I might suggest that, you
13 know, particularly for these categories -- and I
14 think Scott's right. I think for the FLEX stuff
15 that is much more symptom based, I think, then
16 maybe is what was portrayed here this morning.

17 But, you know, something like this, you
18 know, these are a little bit more event based
19 because these are things where you would have in
20 many instances advanced warning of the flooding
21 event, you know, the dam broke. Or you had the
22 long, prolonged precipitation events in the upper
23 Midwest that you know the river downstream's
24 going to flood in six days.

25 So these things, I think, you know, lend

1 themselves a little bit more to an event based
2 kind of response because the event is what is
3 going to --

4 MEMBER BLEY: I understand what you're
5 saying.

6 MR. YOUNG: Okay.

7 MEMBER BLEY: But I still have this
8 sense that we're painting the poor guys into a
9 spot that if I can't meet all the rigorous
10 definition of using this I can't use it, and that
11 just takes me away from --

12 MR. YOUNG: Yes, I mean I think there's
13 been videos that we have done. I don't know if
14 you've had an opportunity to see some of them,
15 but I mean we've done some of these simulator
16 videos where we've sort of filmed this stuff.
17 And I think it looks and smells really like a
18 symptom based approach where you're getting into
19 FLEX.

20 MEMBER BLEY: I'd like to see that. I
21 haven't seen those, but, you know, what you just
22 talked about if that's what happens this is going
23 to work great. But if it's something different
24 and it doesn't meet that definition, we're almost
25 saying well, then you don't use this. And it

1 might be just the right thing to use for the
2 thing we haven't thought about yet.

3 MR. YOUNG: Well, yes, but at the end of
4 the day the operator still always has the
5 opportunity, if he's in some nebulous space,
6 there's always X, right? I mean he's like I can
7 always declare X, and go get the pump and do what
8 I got to do, or go get the battery charger and do
9 what I got to do. So I don't know that it's
10 precluded.

11 CHAIRMAN STETKAR: It's not precluded,
12 but operators tend, if they're trained to use
13 specific procedures under specific conditions
14 they want to do that. That's the problem that we
15 have with the fire procedures.

16 People have gotten into problems where
17 they've said, my god, we have a fire so we have
18 to do this but the EOPs tell me to do -- what do
19 I do? Because there's not that coordination. If
20 they're trained to follow a particular procedure
21 for a particular set of conditions that's what
22 they do. Follow the procedures. My god, if I
23 don't follow the procedures somebody going to
24 throw me into Leavenworth if not kill me.

25 MR. BAUER: The same groups that

1 developed the current EOPs, the PWR and BWR OG
2 procedure subcommittees are the ones who have
3 developed in a large part these FSGs. So they
4 basically went back to the EOP and said well,
5 where, you know, symptom based, when would I
6 declare an extended loss of AC power, and then it
7 directs you to these FLEX support guidelines. So
8 the same thought processes were used.

9 And I think you have to start with,
10 what's the event I'm dealing with and then what
11 are the symptoms of that event going to be to
12 build my procedure.

13 CHAIRMAN STETKAR: Our whole point is
14 that you can't think of all of the events. So if
15 you tailor those procedures to those events
16 you're putting the operators in a pigeonhole
17 which will not work for the events that you
18 haven't thought about.

19 MEMBER BLEY: Which might make them turn
20 a double blind and create confusion in places
21 where it's not necessary.

22 MR. BAUER: Understand. Okay.

23 Okay, so, and in this next slide we
24 thought more since the March 19th meeting about
25 potential ways to word the rulemaking to deal

1 with the issue I've mentioned on the previous
2 about how to move the requirement to have a
3 mitigating strategy up into (b)(1) where we
4 believe it belongs as opposed to having
5 reevaluated hazards just in (c)(2). That's what
6 that slide was for.

7 MEMBER SCHULTZ: And that Scott is
8 you've moved the language to a different place or
9 is it created language that --

10 MR. BAUER: No, we capture the idea that
11 we want to talk about the requirement to have a
12 mitigating strategy for these events not just
13 protect equipment for the event.

14 MR. YOUNG: Yes, so let me elaborate on
15 that for just a moment. I mean that is what this
16 proposed wording is trying to get to is that we
17 think this wording accommodates the use of
18 alternate or targeted mitigating strategies,
19 strategies beyond the FLEX strategies, and allows
20 you to do so looking at a hazard-specific, site
21 and hazard-specific analysis. And if that by the
22 way tells you have different initial conditions
23 then the FLEX assumptions of total loss of AC
24 power, loss of access to the ultimate heat sink
25 then that's okay, then those are your initial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conditions because you have the analysis that
2 tells you what those are. So that suggests the
3 wording does two things. It addresses both of
4 these items here.

5 MR. BAUER: The targeted hazard
6 mitigation strategy wording is our terminology
7 for Recommendation 2 that was in the SECY-14-0037
8 which the Commission approved.

9 Okay, moving on. So we are developing
10 an Appendix G to NEI 12-06. It's been drafted by
11 the industry and we're basically holding it at
12 this point. But it does address how to do the
13 mitigating strategies for this, you know, if you
14 can't, well it talks about can you make FLEX
15 more, can you modify FLEX or do you have to go to
16 the alternate or targeted hazard and how to do
17 that.

18 And as soon as we get back into the
19 discussion mode on this and understand what the
20 full impact of the SRM is we'll start engaging
21 the staff on what we're proposing on how to do
22 that mitigation strategy development.

23 MEMBER CORRADINI: Can I ask you a
24 question? Because your example, because it's
25 flooding, implies that there's a time element

1 that allows you to prepare that doesn't exist
2 with the assumptions in FLEX for the ELAP which
3 is just instantaneous, here's your damage state.
4 But if you were to think of seismic, wouldn't
5 that take you directly into you'd have to survive
6 that with the FLEX equipment because there's no
7 warning? There's no time window that allows you
8 to deal something, deal with it differently. So
9 you can't be, I don't want to say sequence based,
10 but you can't be event based in that regard.

11 MR. BAUER: Yes, so for both flooding
12 and seismic there may be an instantaneous event,
13 there may be a delayed event. So the development
14 of the strategy would allow you to take into
15 account, I mean obviously for seismic it's going
16 to be probably an immediate.

17 MEMBER CORRADINI: And that's a segue to
18 the second bullet, right? Is that we're still
19 working on the --

20 MR. BAUER: Right. I mean we're still
21 working with the staff on how to figure out to
22 develop mitigating strategy for seismic, whether
23 the SPRA is for plants, you know, how plants are
24 going to get screened in and out of whatever
25 condition they, you know, whatever bin they fall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in in seismic, whether the SPRAs answer the
2 question we're trying to figure out the guidance
3 for how to do the seismic in the strategy.

4 For flooding we're a little bit more,
5 well, obviously we could develop this Appendix G
6 so we believe we understand how to move forward
7 with a flooding mitigating strategy.

8 MEMBER BALLINGER: But it's possible to
9 have a simultaneous seismic event failure of a
10 dam and then get flooding, so they're not
11 disconnected from all that.

12 MR. BAUER: Right. So the flooding
13 event may be caused by a seismic event, and then
14 depending on where the dam is you may have
15 warning time or you may not. So warning time is
16 built into the development of the strategies to
17 determine with my new flood hazard do I have
18 warning time, yes or no, because then that helps
19 you to figure out the time it takes to respond,
20 what I can do? Can I shut down the plant prior
21 to the event? You know, can I make a lot, you
22 know, understand the flood is coming I have time
23 to take some actions as opposed --

24 MEMBER BALLINGER: But the seismic event
25 may have put the plant in a damaged state which

1 hurts you with respect to responding to the
2 flood.

3 MR. BAUER: Yes, understand. I mean 12-
4 06 currently says don't take multiple events
5 simultaneously, so I mean we would have to take
6 that in, you know.

7 MR. YOUNG: But all that engagement in
8 the analysis space and how to apply that in the
9 reevaluated hazard space is work that needs to be
10 done. I mean there's a conversation still to be
11 having.

12 MEMBER RICCARDELLA: So will there be
13 another appendix like Appendix G to address the
14 seismic --

15 MR. BAUER: That would be the thought
16 would be Appendix H would be the next one and
17 we'd develop potentially a way to develop a
18 mitigating strategy for seismic events. But
19 we're still in the stages with the staff of
20 trying to figure out what the path forward looks
21 like there, so we're not nearly as far along as
22 we are on the first one.

23 MEMBER RICCARDELLA: Then the words in
24 the rule are adequate protection for this, I mean
25 are you opposed to those rules? I mean these

1 appendices presumably will eventually give us
2 adequate protection against both seismic and
3 flooding of the strategies.

4 MR. BAUER: I guess I would answer that
5 right now that we are in favor of going down this
6 path of developing a mitigating strategy for
7 these events and subsuming them under the
8 adequate protection umbrella of FLEX or the
9 order. That's kind of the premise going forward
10 with the rulemaking, rather than, you know, let
11 the 50.54(f) letter takes its course and then do
12 a backfit analysis to figure out whether it meets
13 adequate protection.

14 So, but again the SRM to me has put all
15 that into question. It's not clear to us what
16 the path forward is on the SRM. So we are moving
17 forward. We believe Appendix G is going to be
18 the way to deal with the flood but we don't know
19 for sure.

20 MEMBER RICCARDELLA: It seems the big
21 issue with the SECY paper was this integrated
22 assessment, and it sounds like you are proposing
23 guidance in how to perform the integrated
24 assessment, right, of the new flooding hazard.

25 MR. BAUER: Yes. This Appendix G title

1 is Mitigating Strategies, Flood Hazard
2 Information, Integrated Assessment.

3 MEMBER SCHULTZ: Next slide.

4 MR. BAUER: Okay, last slide is on this
5 qualitative factors issues for the SAMGs, and
6 again I think Tim was just getting ready to talk
7 to this about the backfit analysis not
8 necessarily supporting, or the analysis not
9 supporting a backfit of the SAMGs into the
10 regulations.

11 And it was originally proposed based on
12 qualitative factors that you reach an acceptable
13 backfit consideration, which we believe is not
14 consistent with what the Commission has directed
15 and we're not in favor of using qualitative
16 factors to put SAMGs into the rule.

17 If the backfit analysis can't support it
18 the way backfit analyses should be done, the
19 industry is willing to make a commitment to
20 continue to develop or use SAMGs with these four
21 elements. We would maintain the strategies.
22 We'd integrate them -- here we go with that word
23 again -- EOPs, and we would have timely
24 incorporation of any Owners' Group revisions to
25 them, and we would establish configuration

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 controls for them to maintain them.

2 MR. YOUNG: And recall these are the key
3 attributes from the Statement of Consideration
4 elements of the rule.

5 MEMBER CORRADINI: So if I can rephrase,
6 you'll do what's in the proposed rule but you
7 don't want to be forced to do it. I retract
8 that. You don't want to be forced to, and you
9 don't want to have it checked. Because if I
10 remember correctly, in the subcommittee meeting I
11 asked this precisely of Tim, which is it wasn't a
12 content issue, it was is it being done, is it
13 being done in some structured manner? And the
14 answer was, at least I remember the answer was
15 yes. So given the fact that you're going to do
16 it anyway, why not have NRC audit it? What am I
17 missing?

18 MEMBER SCHULTZ: Inspect it.

19 MEMBER CORRADINI: Inspect it. Excuse
20 me, inspect.

21 MR. BAUER: All we're saying is that we
22 think we should properly respect the backfit
23 process. We are willing to have it in the rule.
24 But if the backfit process doesn't warrant being
25 in a rule or doesn't pass the test to be in a

1 rule then we shouldn't manipulate the backfit
2 process to put it in the rule.

3 MR. YOUNG: It's the basis. It is the
4 basis of the imposition. It's not the
5 imposition, it's not having inspections, it's not
6 doing all these things.

7 MR. BAUER: Totally in agreement with
8 doing -- what has been aligned out for SAMGs.

9 CHAIRMAN STETKAR: I asked this at the
10 subcommittee and we're running along on time so I
11 just want to get it on the record. Does the
12 industry have full scope, full scope level 2 PRA
13 capability for all internal and external
14 initiating events where you could quantify the
15 difference in safety benefit with and without
16 SAMGs? And I'm just asking for a yes or a no.
17 If you don't --

18 MR. YOUNG: You didn't give me "I don't
19 know."

20 CHAIRMAN STETKAR: If you don't know
21 that's a fair answer. Because I know the staff
22 doesn't, that's why they can't quantify the
23 answer.

24 MR. WEBSTER: Again we don't have, all
25 plants don't have full scope.

1 CHAIRMAN STETKAR: Let us know who you
2 are.

3 MR. WEBSTER: I'm Bill Webster with
4 Dominion. I'm sorry.

5 MR. YOUNG: And Bill is the --

6 MR. WEBSTER: I'm the PRA supervisor for
7 Dominion. So we don't have full scope level 2
8 PRAs that we could formally do that calculation.

9 CHAIRMAN STETKAR: That's in my mind a
10 bit of the bind on the inability of anyone to
11 quantify the benefits of SAMGs because nobody has
12 the calculator to do that. Regardless of whether
13 you say the onus is on the staff or the onus is
14 on the industry to show that they don't provide,
15 nobody has that calculator. So there isn't that
16 ability to do that kind of real quantitative
17 comparison. The analysis that the staff made
18 reference to is inadequate to draw any
19 conclusion.

20 MEMBER SCHULTZ: Any other questions for
21 industry? We'll make a quick shot back to the
22 staff.

23 MR. YOUNG: Let me just thank you for
24 allowing us to come up and --

25 MEMBER SCHULTZ: Well, thank you.

1 Tim, speaking of backfit considerations,
2 you're up.

3 MR. REED: This is a segue of sorts.
4 This is backfit. As you've heard, industry has
5 some serious concerns about the backfit
6 justification. I certainly understand those
7 concerns. It was as I mentioned here in the
8 slide it's got two aspects to it. We'll talk
9 about it here in a slide.

10 But first of all, before you get into
11 the nuts and bolts of that I think you can look
12 at all the requirements in this regulation kind
13 of in two bins. The first bin is what's already
14 going into place, and it's either going into
15 place because of an order or it's going into
16 place for a broad implementation of an order or
17 it's going into place because voluntarily the
18 industry's doing it.

19 And so you see those items listed there.
20 So everything for EA-12-049 and obviously EA-12-
21 051 are already in place, therefore they're not
22 backfits so have already been imposed by order.
23 Multi-source dose assessments being done
24 voluntarily, okay. So we expect that they'll be
25 no impact, but technically that is in your

1 requirements a backfit so we have to address
2 that.

3 Technology-neutral ERDS is really a
4 cleanup. In my view that's simply
5 administrative. The staffing and communications
6 has been, I don't mention it there, but I think
7 it goes hand in hand with a mitigation response
8 for a site.

9 So I view that as integral to a
10 successful mitigation of a site-wide event, so I
11 view that as part, really, of the order even
12 though they came out in two separate actions. So
13 I personally view it that way. I think that's
14 the right way to see it in backfit space.

15 So that leaves us simplifying this down
16 to the SAMGs and everything that supports the
17 SAMGs and a forward fitted, as the slang amusing
18 here, it's a backfit. Forward fitting means it's
19 not being opposed by any current licensee for the
20 design features requirements that you heard
21 earlier in which Jim Shea has a non-concurrence
22 on.

23 So that's down the road new design type
24 of thing, and everything else I'm looking at from
25 a current licensee's imposition thing and that's

1 the SAMGs. So this is basically trying to
2 simplify what can be fairly complex given all
3 these regulations in there how the backfit sorts
4 out.

5 So, and I've got two parts of it and
6 I've qualitative arguments for it that I've tried
7 to put together I think are very strong
8 qualitative arguments. I do recognize that
9 unfortunately I wasn't able to reflect the
10 qualitative factors SRM. It came out too late in
11 the process, but that just came out here in March
12 and certainly I wasn't aware when a lot of this
13 was drafted. But I do understand the concerns
14 from external stakeholders in that regard.

15 But it's very clear that -- I don't
16 think anybody would argue about this at all --
17 that SAMGs are a very direct link in terms of
18 defense in depth. You can argue about whether
19 those are warranted even though if they are
20 defense in depth, but clearly they are. They
21 obviously go directly to the use of containment
22 when containment matters when you have fission
23 products and in trying to make maximal, best use
24 of that containment using your equipment, your
25 people, ensure that that maintains under human

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control.

2 You don't want to lose the integrity of
3 that containment if at all possible, and you want
4 to basically use that containment to hold up and
5 minimize releases to the maximum extent you can.
6 That's the whole point there with the
7 containment.

8 And SAMGs also, it was talked about a
9 little bit earlier about the instrumentation and
10 everything. As those folks are going on they're
11 trying to get the best understanding of this,
12 prevention of this event, and that can provide
13 valuable information to the emergency response
14 organization in terms of the fission product
15 barrier integrity or the loss of it or the
16 impending loss of it, and so there's at least an
17 opportunity there that there could be great
18 information coming out of this that could inform
19 those decisions both for onsite and offsite
20 protective actions.

21 And that goes to another big piece of
22 the infrastructure of the NRC's regulations and
23 EP. So the arguments that I think you folks are
24 probably well aware of, I've made two pretty
25 strong qualitative arguments in terms of defense

1 in depth. One related directly to containment,
2 one related to EP. I think the committee liked
3 those arguments. However, I think it's very
4 important for the Commission and not only in this
5 regulatory action, in all regulatory actions, to
6 provide them as much as possible risk insights
7 that I checked.

8 And so in that regard I tried to look at
9 everything I could, and I do fully understand the
10 limitations of the available information out
11 there, but I nonetheless tried to, I think I was
12 fairly careful when I went back and looked, I
13 think I'm pretty careful about how I've caveated
14 the limitations of that information. I looked at
15 what's available in terms of risk insights.

16 There is no PRA out there available
17 today unfortunately that looks at SAMGs. You
18 know, as John said and probably was asking
19 before, we unfortunately don't have it, but we do
20 have information that in my view is very, very
21 important. Because it shows, as the committee's
22 aware, risk levels that are not just below the
23 QHOs, they're way below the QHOs.

24 And in fact I took to heart some of the,
25 and I'm probably going to get some more feedback

1 here in a minute, what we got to the
2 subcommittee, and I went back and looked at the
3 state of the art reactor consequence study and it
4 says the same thing even stronger actually. And
5 it by the way modeled 50.54(hh)(2).

6 And there may be some challenges to that
7 modeling, but I don't think there will be any
8 challenges today given what's happening on the
9 mitigation strategies order, because the
10 mitigation strategy capability going into place
11 today, okay, is site-wide, is indefinite, is
12 engineered with connections in plug and play and
13 it's been engineered the whole way through.

14 And so now I think the mitigation
15 capability is very real and it's truly an
16 additional capability and I think it's a great
17 effort from everybody involved, but I think it
18 does show a pretty substantial benefit in core
19 damage reduction in these analyses.

20 Now I do recognize there's limitations.
21 I do recognize they weren't geared to look at
22 SAMGs, and I fully understand the human
23 reliability aspect wasn't done that well. But
24 those risk insights, I think, are still valuable
25 and I think that I owe it to the Commission to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 informing their decision, and this is their
2 decision. Everybody should understand that it's
3 the Commission's decision on how much weight they
4 want to put on the qualitative argument versus
5 how much they want to look at these risk
6 insights. And that's kind of what that SRM and
7 qualitative factor says.

8 So what I'm trying to do is fully inform
9 them so they can make the best decision possible.
10 And that's the spirit that this was done in, and
11 I think providing this package to them in that
12 way and showing them SAMGs in the rulemaking
13 enables them to see how it would look, and if
14 they need to extract it out it's certainly easier
15 to take out than to put in, you know, in terms of
16 envisioning how it would look.

17 So that's how it's going forward.
18 Understand the feedback from the industry. That
19 voluntary commitment is certainly, at least the
20 ideas put on their slide are much more detailed
21 commitment to SAMGs than what was in place today
22 from the 1990s for folks that don't know that.
23 So it does hit the main elements of our proposed
24 regulation as was just mentioned.

25 So I'll come to a full stop because I

1 imagine some folks want to comment. If not, we
2 can keep going. John, you're still looking down.
3 I don't know if -

4 MEMBER SCHULTZ: We can come back to
5 this if we have questions. Go ahead and do the
6 reg guidance.

7 MR. REED: Okay.

8 So going into draft regulatory guidance
9 we have is two sets, three sets of regulatory
10 guidance. DG-1301, which is the draft guide that
11 would endorse the mitigation strategies guidance
12 and we're hoping to get NEI 12-06 rev 1. The
13 current guidance that's endorsed for the
14 mitigation strategies order was rev 0.

15 So what we're doing is working it up to
16 rev 1 and that way it would fold in all basically
17 the lessons learned and feedback from
18 implementation of the orders. And it's a pretty
19 substantial update to that and we hope to get
20 that fairly soon.

21 And we have I think as you've heard some
22 challenges in at least two areas. Hopefully we
23 have, we'll be able to get an appendix on the
24 reevaluated hazards and how that should be
25 considered within the mitigation strategies and

1 reasonable protection. and it sounds like maybe
2 even to go into alternative targeted strategies
3 as we just presented.

4 And then we have a larger challenge, I
5 think, on how to address seismic at least in the
6 near term. You know, I know there's seismic PRAs
7 down the road and so I think that's as mentioned
8 there that's a whole different animal in my view
9 than flooding. And so we'll have to get creative
10 on how we do that, because right now, as was
11 mentioned actually in the previous presentation,
12 without that guidance we'd be very challenged to
13 meet our CER, Cumulative Effects of Regulation
14 process in putting the guidance out with the
15 rules. So we'll have to look and see what we can
16 do.

17 And second guidelines, DG-1317, there's
18 no substantive changes to the previous
19 endorsement of the guidance for EA-12-051, it's
20 just now at a reg guide format. That's not too
21 interesting, I'm sure, for this committee's
22 results.

23 The third one, I'm sure, probably is.
24 DG-1319, the Integrated Response Capabilities for
25 Beyond-Design-Basis Events. This is looking at

1 three different NEI guidelines. First, 12-01
2 which was already endorsed and there are no
3 substantive changes to that. That's staffing and
4 communications capability. That remains
5 basically intact, okay, so there's no change from
6 what was found acceptable in response to this
7 50.54(f) letter. But the next two are new, 13-06
8 and 14-01, we can talk about those. I believe I
9 have a slide coming up here in a second.

10 So DG-1301, I only do a not very good
11 facsimile of Eric Bowman. Eric's the guy,
12 obviously he wasn't able to be here today. But
13 this is, I mentioned, it's unfortunately not in a
14 final form. We're waiting to get to rev 1, where
15 currently we have a draft © of this version to
16 get to rev 1.

17 And as I mentioned it incorporates
18 lessons learned feedback from EA-12-049. And we
19 have to figure out, it's been noted here, at what
20 to do with this reevaluated hazard in the SRM,
21 how to fold that guidance in as appendices. So
22 that I think is a substantial challenge that we
23 need to address, and I think we'll have to see
24 what we can do with meeting with the committee
25 here in future meetings and see what we can do in

1 that regard.

2 Then we have Appendix A to 1301 which
3 goes to new reactor design, and I'll turn it over
4 to the folks here from NRO.

5 MR. ASHLEY: Thanks. My name's Clint
6 Ashley and I work in the office of New Reactors.
7 I was a member of a team that worked to put
8 together some of this new reactor guidance in the
9 proposed rule, and there's other members in the
10 audience if there's questions that should arise.

11 Current agency endorsed guidance has
12 focused on the operating fleet and reflects the
13 fact that operating reactors are constrained by
14 existing structure systems and components as well
15 as plant layouts.

16 However, without such constraints new
17 reactor applicant have an opportunity to
18 incorporate into the plant design those design
19 features that enhance mitigating strategies to
20 maintain and restore key safety functions. Such
21 design features should reduce and simplify the
22 manual actions necessary to maintain these safety
23 functions and allow more time to assess plant
24 conditions and prolong the use of installed plant
25 equipment.

1 This approach as John mentioned earlier
2 is consistent with the advanced reactor policy
3 statement in which the Commission previously
4 encouraged vendors to include these design
5 features into the design. So on this Draft Guide
6 1301 Appendix A, it contains guidance that
7 provides applicant for new reactor power plants
8 with an acceptable method to meet the proposed
9 rule, and this slide highlights guidance related
10 to coping duration and human actions which are
11 the areas that are not addressed by NEI 12-06 due
12 to the fact that paragraph (d) is a fairly recent
13 addition to the proposed rule and is obviously
14 limited to new reactor applicants.

15 So to enhance coping durations, the
16 design features should increase the amount of
17 time that safety functions can be maintained
18 early in an event before there's a need to
19 augment with plant equipment, excuse me, augment
20 the plant equipment with onsite portable
21 equipment. Enhancing coping duration provides
22 operators time to plan and implement the onsite
23 portable equipment and mitigation strategy for
24 the longer term coping.

25 So for enhanced coping durations the

1 staff looked at two things. Basically there's
2 two time frames that we define, one is the 24
3 hours and the other one is 72 hours. The 24
4 hours is how we define enhanced coping durations
5 for the initial phase. The staff's reasoning
6 behind selecting that period of time was based on
7 information associated by reviewing new designs
8 as well as the existing fleet. For example, the
9 AP 1000 and the ESBWR, that initial coping is for
10 72 hours. For the ABWR design it can cope out
11 to, I believe, 36 hours. And in general for a
12 lot of the operating reactors the coping duration
13 for the initial phase is at about eight hours or
14 less.

15 CHAIRMAN STETKAR: You had to say it, I
16 wasn't going to because of the time, ABWR is 36
17 hours if and only if the operators de-energize
18 the control room to extend the batteries,
19 relocate to a place where they don't normally
20 live and try to do things from that location.
21 That to me is not minimizing operator actions.

22 We need to keep on with the time. I
23 just wanted to get that on the record.

24 MR. MCKIRGAN: Thank you. Yes, and
25 certainly --

1 CHAIRMAN STETKAR: That's the only way
2 the ABWR meets 36 hours.

3 MR. MCKIRGAN: And that is part of the
4 motivation of the staff in offering this
5 provision paragraph (d). We think new reactor
6 vendors have an opportunity to enhance those so
7 that those kinds of actions aren't necessary.

8 CHAIRMAN STETKAR: Thank you.

9 MR. ASHLEY: We also believe that
10 specifying coping durations in guidance would
11 actually contribute to the regulatory stability
12 and predictability for new reactors with respect
13 to the proposed rule.

14 We already talked about, 72 hours is
15 basically when you would expect offsite resources
16 to come in so that transition period would take
17 you from at least 24 hours to out to 72 hours.
18 And the 72 hours again is consistent where we see
19 a lot of the, not just new reactor designs but
20 even the op fleet can easily go out to 72 hours
21 in many instances before they need to have the
22 outside resources applied.

23 The guidance for new reactors also has
24 in the initial response phase we permit use of an
25 installed AC power engineered alternative and we

1 call this a supplemental AC source. This source
2 has to be protected from the external hazards
3 such as flood and seismic. Basis for eight hours
4 is to be consistent with the near-term task force
5 report.

6 And this supplemental AC source is
7 independent and diverse from the emergency AC
8 source. Permanently installed and normally
9 disconnected from the electrical bus and designed
10 such that only minimal operator action is
11 necessary to place this in service.

12 With respect to minimized reliance on human
13 actions, the proposed requirement is really
14 modeled after the aircraft impact assessment, and
15 so we adopt a similar concept here. We view
16 greater reliance on design features that include
17 well thought out human/machine interface would
18 reduce reliance and simplify the manual actions
19 necessary to maintain and restore key safety
20 functions. And further reducing reliance on
21 human actions would also reduce the potential for
22 human failures during stressful, adverse
23 conditions.

24 So for the initial response we look at
25 minimal actions at limited protected locations

1 with monitoring, control and coordination from
2 the main control room or, if needed, at some
3 other location that is designed for that purpose.

4 Following the initial phase, again we
5 look at this as just actions should be reasonable
6 considering the conditions following the event.
7 That's the end of the information I had.
8 Questions?

9 MEMBER SCHULTZ: Thank you, Clint.
10 After you, Tim.

11 MR. REED: Okay. Going to DG-1319, the
12 third draft guidance documents I mentioned, it's
13 carried forward, the guidance from NEI 12-01 that
14 we said going to the staffing analysis and
15 communications capabilities with no substantive
16 changes. It's endorsing NEI 13-06, and that
17 document if you drove down to it contains
18 guidance on multi-source term dose assessment.
19 It's got training and drills and exercises
20 guidance in there as well as PPE facilities and
21 equipment guidance in there.

22 And then finally it also addresses or
23 endorses NEI 14-01 which is addressing basically
24 integration but also SAMGs. It talks about SAMGs
25 but not the actual detailed review of Owners'

1 Group or plant-specific SAMGs. Basically more
2 first principles on how they developed the SAMGs,
3 how to maintain them, contain them and control
4 them, configuration and that kind of thing. In
5 line basically with our regulatory structure
6 though, and it also addresses command and
7 control. So those are the three guidance
8 documents that are the three NEI documents that
9 are endorsed through DG-1319.

10 So I get to the Status and Path Forward
11 and we can see where we go from here. As
12 mentioned at the very beginning of the meeting,
13 we are very far and deep into concurrence. Most
14 of the offices have concurred with the exception
15 of work in the Office of General Counsel, and
16 then finally we'll go through the NRR.

17 So we're near the end here of
18 concurrence hopefully, and our goal is to get it
19 to the EDO's office at the end of next week,
20 which is extremely fast given what we have left,
21 and then get it two weeks later to the
22 Commission. We as part of our CR process want to
23 issue all the draft guidance with the proposed
24 rule. I think we have some challenges there to
25 work on that and that's certainly recognizing

1 that we've got ongoing work on 1301.

2 It's been talked about several times
3 today, and we, at the subcommittee, we've offered
4 to meet with the subcommittee, the ACRS in
5 general as much as you folks want to meet with us
6 as best as we can, and try to, you know, interact
7 and get the committee's feedback as we go
8 forward.

9 Now as the process itself is about
10 getting the guidance out with the proposed rules,
11 so you have to try to guess on how long it's
12 going to take the Commission to do its thing and
13 deliberate on the facts and give us an SRM. And
14 I know there's a Commission briefing set for July
15 9th. I know that because I probably have to be
16 at that at the table. And so that I think
17 realistically we're looking at maybe end of July
18 or even August by the time this would go to the
19 Federal Register.

20 So I think that's the real deadline for
21 guidance, and even then I think that's really
22 ambitious on where we're at on some of the
23 guidance. We're going to have to figure out
24 creatively what we can do there and we can work
25 with ACRS and what you folks want to do and

1 meeting with us best we can.

2 MEMBER SCHULTZ: Our approach with
3 regard to the draft guides would be to move ahead
4 as quickly as we can to have a Fukushima
5 Subcommittee meeting on this soon. We're not
6 putting any conditions out beyond that but it's
7 not only aimed at Draft Guide 1301 but the draft
8 guides as a package.

9 MR. REED: Okay.

10 MEMBER SCHULTZ: So we'll address the
11 priorities there and the content to that meeting
12 later.

13 MR. REED: I think if I was going to try
14 to time that meeting I would try to understand
15 where we might expect to get the flooding
16 appendix in NEI. If that's reasonably in the
17 short term and you think we can respond to that,
18 Eric can respond to that, that might inform, that
19 would be a really good point of then meeting with
20 the ACRS. It would be a lot more information.

21 CHAIRMAN STETKAR: Okay, let me try
22 something here because we have a hard time
23 constraint on the members here. We can work out
24 details of subcommittee meetings off line.

25 MR. REED: Okay. That's really all I

1 had.

2 MEMBER SCHULTZ: Questions for the
3 staff? Comments related to the presentation by
4 the staff? From the committee? Not hearing any,
5 I will ask if there are members of the public in
6 the room that would like to make a statement to
7 the committee.

8 And while we're seeing whether that's
9 the case we're going to open up the phone line.
10 If you'd like to make a statement please come to
11 this microphone. Announce your name and make
12 your comment to the committee.

13 MR. DOLLEY: Thank you. My name is
14 Steven Dolley. I'm a reporter with Platts. I
15 edit "Inside NRC." And it's actually a question
16 rather than a comment. If that's not --

17 MEMBER SCHULTZ: We'll only take
18 comments. You could ask the question --

19 MR. DOLLEY: Okay, my comment is, I sure
20 would like to know if Jim Shea's non-concurrence
21 has been made public and how it's addressed.

22 MR. REED: It has not been made public
23 yet, but Jim has asked for it to be made public
24 and it will be made public.

25 MEMBER SCHULTZ: All right. Is the

1 phone line open? If you're on the phone line
2 please let us know that you're there by saying
3 hello. Is anyone on the phone line? We believe
4 it's open but I don't hear it exactly. Hold on
5 for a moment and we'll see if we can validate our
6 -- all right, I think I hear it.

7 If any member of the public is present
8 could you please say hello? Is there anyone, a
9 member of the public who would like to make
10 comment? If so, please state your name and make
11 a comment.

12 Hearing no response I'll consider the
13 public comment period closed and turn the meeting
14 back over to you, John.

15 CHAIRMAN STETKAR: Thank you very much.
16 And again thanks for the staff and the industry.
17 This is a really important effort. We're running
18 a little bit long as well, well justified.

19 We will recess for lunch.

20 (Whereupon, the above-entitled matter
21 went off the record at 12:57 p.m.)
22
23
24
25



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

GEH Simplified Stability Solution (GS3) Background

ACRS Meeting

April 9, 2015

Ashley S. Guzzetta

George Thomas


Reactor Systems Branch

Division of Safety Systems

Dr. Jose March-Leuba




Oak Ridge National Laboratory

Instabilities are Real!




- Reactor must scram!

Out-of-Phase Oscillations





- APRM High Power Scram may not provide protection for all scenarios
 - Long Term Solutions (LTS) were developed

Instability Scenarios





- Startup
 - Slow rod motion
 - Low amplitude oscillations
- Flow Reduction
 - Fast entry to Instability Region
 - Oscillations may be large
- 2RPT is analyzed to demonstrate acceptability of LTS implementations


DIVOM Methodology



TRACG Calculations





“HCOM” Methodology




- OPRM safety channel is a combination of multiple LPRMs
- If OPRM detects scram at 12% amplitude, peak LPRM may oscillate by 20%, 30%, 40% ...

Typical 2RPT

- CPR at time of scram can be larger than at initial conditions



Safety and Operating Limits



- OLMCPR is defined by the AOO event with largest impact
- With GS3 Methodology, Instability is no longer the limiting AOO for any plant
- Typical ΔCPR numbers are
 - 0.26 for AOO
 - 0.13 for stability

Summary

- Current D&S LTS methodology is conservative, but unnecessarily complex, and costly
- Confirmatory calculations show that “real” transient has plenty of margin
- GS3 attempts to make the methodology more realistic while maintaining conservative margin
- Reduces spurious trips by demonstrating effectiveness of best-estimate margins

Industry Perspective on Draft Proposed Mitigation of Beyond Design Basis (BDB) Events Rule

Scott Bauer
Sr. Project Manager,
NEI

Roy Linthicum
Exelon Nuclear
Chairman,
PWROG RMSC

David Young
Sr. Project Manager,
NEI

April 9, 2015 • ACRS Meeting

Mitigating Strategies

- For BDB external events, the rule should reflect requirements for:
 - Maintaining the capability to implement FLEX strategies, AND, if needed,
 - Developing and maintaining another mitigating strategy if new/updated hazard information indicates that implementation of FLEX strategies may not be successful
 - Increased flood level

Mitigating Strategies

- Hazard-specific strategies could be:
 - **Alternate Mitigating Strategy** that protects all irradiated fuel in the core and spent fuel pool, and the containment function
 - **Targeted Hazard Mitigation Strategy** that protects all irradiated fuel in the core and spent fuel pool, but not the containment function
- **Key Difference** - These strategies should be based on a hazard-specific analysis and not the assumptions used in FLEX strategies (e.g., an installed AC power source or the ultimate heat sink may be available)

Reevaluated Hazards – (b)(1)

(b) *Integrated response capability.* Each applicant or licensee shall develop, implement, and maintain an integrated response capability that includes:

(1) Mitigation Strategies for Beyond-Design-Basis External Events.

(i) Strategies and guidelines to mitigate beyond-design-basis external events from natural phenomena that result in an extended loss of all ac power concurrent with a loss of normal access to the ultimate heat sink. These strategies and guidelines must be capable of being implemented site-wide and must include maintaining or restoring core cooling, containment, and spent fuel pool cooling capabilities.

(ii) Strategies and guidelines to mitigate beyond-design-basis external events from natural phenomena that results in a damage state determined by a site-specific analysis, if the analysis indicates that implementation of the strategies and guidelines in paragraph (b)(1)(i) will not be effective. These strategies and guidelines must be capable of being implemented site-wide and must include maintaining or restoring core cooling and spent fuel pool cooling, and, where feasible, containment capabilities.

(iii) The acquisition and use of offsite assistance and resources to support the functions required by paragraph (b)(1)(i) and (b)(1) (ii) of this section.

Appendix G to NEI 12-06

- Will contain guidance for performing an integrated assessment of the mitigating strategies for new/updated flood hazard information
- At this time, does not contain guidance for addressing new/updated seismic hazard information
 - Need staff engagement to determine process
 - May impact timeline or content of rule package

Qualitative Factors Requiring SAMGs

- Use of qualitative factors to justify imposing SAMG requirements is not in accordance with Commission direction (SRM-SECY-14-0087)
- Industry supports submittal of a docketed commitment by each site to address SAMGs
 - Maintain SAMG strategies
 - Integration with EOPs and other guidelines sets
 - Timely incorporation of Owners Group revisions
 - Establishment of configuration controls

Plant Indications During Severe Accidents

- Owners Groups provide guidance to determine or validate indications using available information
- Use alternate instrumentation for a parameter value
 - Look at related or linked parameters (e.g., P and T)
- Assess parameter trends and changes in trends
- Determine indications/trends not directly provided by instrumentation (e.g. use of calculational aids)
- Training material will review the importance of validating instrument responses

Mitigation of Beyond-Design-Basis Events (MBDBE) Proposed Rulemaking

Advisory Committee on Reactor Safeguards

Full Committee

April 9, 2015

Background

- Efficiency gains through consolidation
- Scope of proposed rulemaking as it relates to originating Near-Term Task Force (NTTF) recommendations:
 - All of recommendations 4, 7, and 8
 - All of 9.1, 9.2. and 9.3 – except long term Emergency Response Data System (ERDS)
 - 10.2 (command and control/decision maker qualifications) and 11.1 (delivery of equipment to site - phase 3 portion of Order EA-12-049)
 - Includes NTTF 9.4 (ERDS modernization)
- In terms of post-Fukushima regulatory actions already underway:
 - Makes generically-applicable Order EA-12-049 and Order EA-12-051
 - Addresses staffing and communications from NTTF 9.3 (10 CFR 50.54(f) request)
 - Addresses re-evaluated hazards from NTTF 2.1 (10 CFR 50.54(f) request)

Proposed Rule Language

Paragraph (a) - Applicability

- **Applicability**
 - Current operating reactors
 - New reactors
 - Decommissioning reactors
- **Requirements apply to both current and new reactor licensees and applicants**
 - Design features requirements in proposed § 50.155(d) are for new reactor plant designs, and are in addition to the remainder of the requirements
- **Decommissioning provisions:**
 - Once fuel is permanently removed from the reactor - no reactor or primary containment requirements
 - Once decay heat is sufficiently low versus SFP heat up/boil off to provide ample time: then only remaining mitigation is § 50.155(b)(2)
 - Once irradiated fuel is removed from the spent fuel pool - all requirements cease

Proposed Rule Language

Paragraph (b) – Integrated Response

- Integrated Response Capability
 - Beyond-design-basis external event mitigation
 - Would make Order EA-12-049 generically applicable
 - Formerly referred to as SBOMS (industry’s “FLEX” program)
 - Extensive Damage Mitigation Guidelines (EDMGs)
 - Would move § 50.54(hh)(2) requirements to this rule
 - No substantive changes to requirements
 - Severe Accident Management Guidelines (SAMGs)
 - Currently voluntary industry initiative
 - Regulation would require SAMGs
 - Inspection under ROP only - no licensing review.
 - No additional equipment requirements

Proposed Rule Language

Paragraph (b) – Integrated Response



- Integrate with Emergency Operating Procedures(EOPs)
 - Structured to not impact previous regulatory efforts on EOPs
- Supporting staffing and command and control
 - Both staffing and command and control should be in place after Order EA-12-049 implementation
 - Recognizes challenge of a site-wide event that could lead to core damage and involve offsite assistance

Proposed Rule Language

Paragraph (d) – New Reactor Requirements

- New reactor design requirements:
 - Only applies to applicants listed in paragraph § 50.155(a)(4)
 - Would require that design features be incorporated into new reactor plant designs that enhance coping durations and minimize reliance on human actions for an extended loss of all ac power concurrent with either a loss of normal access to the ultimate heat sink, or, for passive reactor designs, a loss of normal access to the normal heat sink.
- Intent:
 - Require certain elements of the Commission’s advanced reactor policy statement for new reactor designs during ELAP/LUHS
 - “...longer time constants and sufficient instrumentation to allow for more diagnosis and management before reaching safety systems challenge or exposure of vital equipment to adverse conditions.”
 - “simplified safety systems that, where possible, reduce required operator actions”
 - Applicants would consider the effects of an ELAP/LUHS early in the design process and incorporate design features that provide enhanced capabilities to address these events

Proposed Rule Language

Paragraph (c) – Equipment Requirements

Paragraph (e) – Training Requirements



- Equipment Requirements
 - Would make Order EA-12-049 equipment requirements generically applicable
 - Would make Order EA-12-051 spent fuel pool level instrumentation requirements generically applicable
 - § 50.155 (c)(2) revised to reflect COMSECY-14-0037:
 - Mitigation strategies equipment required by paragraph (b)(1) must be reasonably protected from the effects of natural phenomena that are the more severe of: (1) the design basis of the facility; or (2) the licensee's reevaluated hazards, stemming from the March 12, 2012, NRC letter issued under § 50.54(f), as verified by the NRC's assessment issued by [EFFECTIVE DATE OF THE RULE].
- Training
 - Training of personnel for activities not already addressed
 - Systems approach to training
 - Expect most training already addressed as part of EOPs and Order EA-12-049 implementation
 - New training should be in the SAMG area

Proposed Rule Language

Paragraph (f) Drills and Exercises

Paragraph (g) – Change Control

- Drills provide assurance that guideline sets are integrated and can be used
 - Initial drill(s) to show use and transitions
 - Follow-on drill(s) to provide assurance of continuing capability
 - Complex drill schedule: Initial drill within 2 refueling outages (RFs) and follow-on in 8 calendar years
 - Current operating licensees/holder of combined license (COL) after 52.103(g) finding:
 - 1st drill within 2 RFs – after that 8 year period
 - Applicants for a part 50 operating license (OL) or holder of COL before 52.103(g) finding:
 - Demonstrate use and transitions – initial drill(s)
 - Subsequent drills - 8 year period
- MBDBE Change Control
 - Facility changes can impact multiple regulatory areas; all change controls must be applied
 - No threshold criterion; must comply with requirements

Proposed Rule Language

Appendix E, Application, Implementation



- New Appendix E requirements
 - Multi-source term requirements are incorporated directly into current Appendix E
 - New Section VII requirement for staffing and communications
 - Technology-neutral ERDS
- Application requirements
 - Applications for new reactors
- Implementation: Will use the Cumulative Effects of Regulation (CER) process

Backfit Considerations

- The MBDBE rule has different supporting backfit bases:
 - Proposed rule requirements are severable
 - Order EA-12-049 and Order EA-12-051 requirements are not backfits (i.e., already imposed by orders)
 - All other requirements need justification under Part 50 backfitting provisions (operating reactors) and Part 52 issue finality provisions (new reactors) :
 - Items supporting Order EA-12-049 are technically backfits without impact
 - SAMGs and supporting requirements (drills and training that involve SAMGs)
 - Multi-source dose assessment (voluntarily implemented): Is a backfit but should not cause additional impact
 - New reactors requirements are designed to be “forward fitted”
 - Technology-neutral Emergency Response Data System (ERDS) remove technology reference, aligns with current practice, not a backfit

SAMGs Backfit

- Qualitative basis for imposing SAMG requirements
 - Guideline set used by operators and decision-makers following onset of core damage
 - SAMGs support making optimal decisions concerning containment
 - SAMGs support informing the emergency response organization with regard to protective actions (e.g., fission product barrier integrity)
 - The value of SAMGs, pre-planned guidelines for best use of all available resources to mitigate the accident
- Quantitative basis informed by Containment Protection and Release Reduction effort

Draft Regulatory Guidance

- DG-1301 “Flexible Mitigation Strategies for Beyond-Design-Basis Events”
 - Current draft guidance would endorse NEI 12-06 rev. 1 with clarifications
 - NEI is revising NEI 12-06 rev. 0 (to produce rev. 1):
 - To reflect lessons-learned from implementation of Order EA-12-049
 - To address re-evaluated hazards
 - Includes guidance for new reactor designs to meet proposed § 50.155(d)
- DG-1317 “Wide-Range Spent Fuel Pool Level Instrumentation”
 - Would endorse NEI 12-02 (Previously endorsed for Order EA-12-051)
- DG-1319 “Integrated Response Capabilities for Beyond-Design-Basis Events”
 - Would endorse NEI 12-01 (Previously endorsed for RFI), NEI 13-06, and NEI 14-01

DG-1301

- Preliminary Draft
- NEI 12-06, Diverse and Flexible Coping Strategies (FLEX) Implementation Guide, Revision 1, Draft C, is basis
- Incorporates lessons learned in Order EA-12-049 implementation (alternative approaches, generic items, etc.)
- Work remaining includes:
 - Receipt of SRM-COMSECY-14-0037 to support development of NEI 12-06 Appendices for Seismic and Flooding Re-evaluations

DG-1301 Appendix A

(For New Reactor Designs)

- *Enhance coping durations*
 - Initially cope with installed SSCs at least 24 hours
 - After 8 hours, use of supplemental ac permissible
 - Then, cope at least 72 hours, using on-site equipment, before off-site resources are obtained
- *Minimize reliance on human actions*
 - Initially, minimal actions at limited and protected locations; monitoring, control, and coordination from the MCR or designed in location
 - Following the early phase, actions should be reasonable considering anticipated site conditions following the event

- NEI 12-01, “Guidelines for Assessing Beyond Design Basis Accident Response Staffing and Communications Capabilities”
 - Accident response staffing
 - Communications systems
- NEI 13-06, “Enhancement to Emergency Response Capabilities for Beyond Design Basis Events and Severe Accidents”
 - Multi-unit dose assessment
 - Training
 - Drills and exercises
 - EP facilities and equipment
- NEI 14-01, “Emergency Response Procedures and Guidelines for Beyond Design Basis Events and Severe Accidents”
 - SAMGs - No detailed review of Owners Group or plant-specific SAMGs
 - Command and control
 - Procedure integration

Status and Path Forward

- Proposed rule package is in concurrence:
 - Due to EDO on April 16, 2015 and Commission on April 30, 2015
 - Draft guidance should be issued with proposed rule in summer 2015
 - Recognize the ongoing work on DG-1301 and can meet with the ACRS prior to July or during public comment period if the Committee desires.
- Future ACRS interactions
 - If desired - can meet on DG-1301
 - Final rulemaking meetings – TBD