

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.19.1 Perform a CHANNEL FUNCTIONAL TEST.	18 months
SR 3.3.19.2 Perform a CHANNEL CALIBRATION of the voltage sensing channel with the setpoint allowable value as follows: Degraded voltage ≥ 226 kV and ≤ 229 kV with a time delay of 9 seconds ± 1 second.	18 months

9903240150 990311
PDR ADOCK 05000269
P PDR