

BASES

---

APPLICABLE  
SAFETY ANALYSES  
(continued)

Primary to secondary LEAKAGE is a factor in the dose releases outside containment resulting from a SLB accident. To a lesser extent, other accidents or transients involve secondary steam release to the atmosphere, such as a steam generator tube rupture (SGTR). The leakage contaminates the secondary fluid and can be released to the environment.

The safety analysis assumptions for the SLB accident bounds 300 gallon per day primary to secondary LEAKAGE in one generator as an initial condition. The dose consequences resulting from the SLB accident are within the limits defined in 10 CFR 100.

RCS operational LEAKAGE satisfies Criterion 2 of 10 CFR 50.36 (Ref.3).

---

LCO

RCS LEAKAGE includes leakage from connected systems up to and including the second normally closed valve for systems which do not penetrate containment and the outermost isolation valve for systems which penetrate containment. Loss of reactor coolant through reactor coolant pump seals and system valves to connecting systems which vent to the gas vent header and from which coolant can be returned to the RCS shall not be considered as RCS LEAKAGE.

RCS operational LEAKAGE shall be limited to:

a. Pressure Boundary LEAKAGE

No pressure boundary LEAKAGE is allowed, being indicative of material deterioration. LEAKAGE of this type is unacceptable as the leak itself could cause further deterioration, resulting in higher LEAKAGE. Violation of this LCO could result in continued degradation of the RCPB. LEAKAGE past seals, gaskets, and steam generator tubes is not pressure boundary LEAKAGE.

9905270129 990519  
PDR ADOCK 05000269  
P PDR

(continued)

---

Attachment 2

BASES

---

APPLICABLE  
SAFETY ANALYSES  
(continued)

Primary to secondary LEAKAGE is a factor in the dose releases outside containment resulting from a SLB accident. To a lesser extent, other accidents or transients involve secondary steam release to the atmosphere, such as a steam generator tube rupture (SGTR). The leakage contaminates the secondary fluid and can be released to the environment.

The safety analysis assumptions for the SLB accident bounds 300 gallon per day primary to secondary LEAKAGE in one generator as an initial condition. The dose consequences resulting from the SLB accident are within the limits defined in 10 CFR 100.

RCS operational LEAKAGE satisfies Criterion 2 of 10 CFR 50.36 (Ref.3).

---

LCO

RCS leakage includes leakage from connected systems up to and including the second normally closed valve for systems which do not penetrate containment and the outermost isolation valve for systems which penetrate containment.

RCS operational LEAKAGE shall be limited to:

a. Pressure Boundary LEAKAGE

No pressure boundary LEAKAGE is allowed, being indicative of material deterioration. LEAKAGE of this type is unacceptable as the leak itself could cause further deterioration, resulting in higher LEAKAGE. Violation of this LCO could result in continued degradation of the RCPB. LEAKAGE past seals, gaskets, and steam generator tubes is not pressure boundary LEAKAGE.

*Loss of reactor coolant through reactor coolant pump seals and system valves to connecting systems which vent to the gas vent header and from which coolant can be returned to the RCS shall not be considered as RCS LEAKAGE.*

(continued)

---