





W. R. McCollum, Jr.  
Vice President

**Duke Power**

Oconee Nuclear Site  
7800 Rochester Highway  
Seneca, SC 29672  
(864) 885-3107 OFFICE  
(864) 885-3564 FAX

June 14, 1999

U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Document Control Desk

Subject: Oconee Nuclear Station  
Docket Numbers 50-269, 270, and 287  
Technical Specification Bases Changes

Please find attached revisions to Technical Specification B 3.3.8 which clarifies that an inoperable HPI flow instrument channel causes the affected HPI train's automatic function to be inoperable. The HPI train continues to be manually OPERABLE provided the HPI discharge crossover valves and associated flow instruments are OPERABLE.

Attachment 1 contains the new Technical Specification Bases pages and Attachment 2 contains the markup version of the Bases pages.

If any additional information is needed, please contact Jack E. Burchfield, (864-885-3292)

Very truly yours,

W. R. McCollum, Jr., Vice President  
Oconee Nuclear Site

*ACD*

9906220116 990614  
PDR ADOCK 05000269  
P PDR

990622

U. S. Nuclear Regulatory Commission

June 14, 1999

Page 2

cc: Mr. D. E. LaBarge, Project Manager  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop O-14 H25  
Washington, D. C. 20555

Mr. L. A. Reyes, Regional Administrator  
U. S. Nuclear Regulatory Commission - Region II  
Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303

M. A. Scott  
Senior Resident Inspector  
Oconee Nuclear Station

Virgil R. Autry, Director  
Division of Radioactive Waste Management  
Bureau of Land and Waste Management  
Department of Health & Environmental Control  
2600 Bull Street  
Columbia, SC 29201

Attachment 1